

Lead in School Drinking Water Report

Grainger Elementary School – Post-remediation results



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-04-17

Date(s) analyzed: 2025-07-23

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	403988	Kindergarten Building	Fountain/Tap Combo	Preschool Rm.4	1 of 1	Tap	left	23
2	403986	Kindergarten Building	Fountain/Tap Combo	Preschool Rm.3	1 of 1	Water Fountain	right	6
3	403990	Kindergarten Building	Fountain/Tap Combo	Preschool Rm.4	1 of 1	Water Fountain	right	5
4	403980	Main Building	Fountain/Tap Combo	Rm.322	1 of 1	Tap	left	4
5	403982	Main Building	Fountain/Tap Combo	Resource Rm.110	1 of 1	Water Fountain	right	3
6	403984	Kindergarten Building	Fountain/Tap Combo	Preschool Room 2	1 of 1	Water Fountain	right	2