

December 17, 2025

Mr. Warren Ristine  
Erie 1 BOCES  
355 Harlem Road  
West Seneca, New York 14224

**Re: Lead Testing in School Drinking Water**

Dear Mr. Ristine:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Erie 1 BOCES Buildings, including:

- **Kenton Career and Technical Center – 151 Two Mile Creek Road, Tonawanda, NY**

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: *Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on November 7, 2025. As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 0 sources of potable water in the Kenton Career and Technical Center have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion.

Thank you for the opportunity to be of service to Erie 1 BOCES.

Sincerely,  
Stohl Environmental, LLC.



Michael Scinta  
EPA Lead Risk Assessor

**Lead Testing in School Drinking Water**

**Prepared for:**

**Erie 1 BOCES**

**Prepared by:**



**3860 California Road  
Orchard Park, New York 14127**

**Conditions as of November 7, 2025**

## Summary Tabulation

### Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports and Chain of Custody Documents
- 1.5. Laboratory Certifications

## 1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Erie 1 BOCES to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- **Kenton Career and Technical Center – 151 Two Mile Creek Road, Tonawanda, NY**

### Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within the Kenton Career and Technical Center. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

### Sampling Protocol:

In accordance with NYS regulations, **Subpart 67-4: Lead Testing in School Drinking Water**, and the EPA guidance document, **3Ts for Reducing Lead in Drinking Water in Schools**, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

**1.2 Executive Summary of Sampling and Analysis:**

**Summary of Samples Collected at Kenton Career and Technical Center:**

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Kenton Career and Technical Center	11/7/2025	18	18	0

*\*NYS Action Level is 5 parts per billion*

**1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:**

All the locations sampled were analyzed at less than the NYS Action Level of 5 ppb, therefore no further response action is required.

#### 1.4 Laboratory Analytical Reports and Chain of Custody Documents



December 08, 2025

Service Request No:R2515230

Michael Scinta  
Stohl Environmental  
3860 California Road  
Orchard Park, NY 14219

**Laboratory Results for: Erie 1 BOCES - Kenton Career and Technical Center**

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory November 11, 2025  
For your reference, these analyses have been assigned our service request number **R2515230**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at [Meghan.Pedro@alsglobal.com](mailto:Meghan.Pedro@alsglobal.com).

Respectfully submitted,

**ALS Group USA, Corp. dba ALS Environmental**

Meghan Pedro  
Project Manager

CC: Rebecca  
Franjoine

**ADDRESS**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

**PHONE** +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.  
dba ALS Environmental



# Narrative Documents

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center  
**Sample Matrix:** Drinking Water

**Service Request:** R2515230  
**Date Received:** 11/11/2025

**CASE NARRATIVE**

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

**Sample Receipt:**

Eighteen drinking water samples were received for analysis at ALS Environmental on 11/11/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

**Metals:**

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by \_\_\_\_\_

Date 12/08/2025



### SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

<b>CLIENT ID: 146.4-6</b>	<b>Lab ID: R2515230-007</b>					
---------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.9			1.0	ug/L	200.8

<b>CLIENT ID: 146.4-7</b>	<b>Lab ID: R2515230-008</b>					
---------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.2			1.0	ug/L	200.8

<b>CLIENT ID: 146.4-14</b>	<b>Lab ID: R2515230-015</b>					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.3			1.0	ug/L	200.8



## Sample Receipt Information

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4

**Service Request:**R2515230

**SAMPLE CROSS-REFERENCE**

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2515230-001	146.4-1	11/7/2025	
R2515230-002	146.4-2A	11/7/2025	
R2515230-003	146.4-2B	11/7/2025	
R2515230-004	146.4-3	11/7/2025	
R2515230-005	146.4-4	11/7/2025	
R2515230-006	146.4-5	11/7/2025	
R2515230-007	146.4-6	11/7/2025	
R2515230-008	146.4-7	11/7/2025	
R2515230-009	146.4-8	11/7/2025	
R2515230-010	146.4-9	11/7/2025	
R2515230-011	146.4-10	11/7/2025	
R2515230-012	146.4-11	11/7/2025	
R2515230-013	146.4-12	11/7/2025	
R2515230-014	146.4-13	11/7/2025	
R2515230-015	146.4-14	11/7/2025	
R2515230-016	146.4-15	11/7/2025	
R2515230-017	146.4-16	11/7/2025	
R2515230-018	146.4-17	11/7/2025	



# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-146.4

Client: Erie 1 BOCES Contact: Warren Ristine

Building: BOCES Kenton Career & Technical Center Location: 151 Two Mile Creek Rd, Tonawanda, NY 14150

<b>LEAD</b>		<i>Turnaround</i>
Water by 200.8	<u>X</u>	<u>10 Days</u>

Sample #	Location	Outlet Type	Time
146.4-1	L DF Weight Room	DF	6:14
146.4-2A	R DF Weight Room	DF	6:15
146.4-2B	R DFB Weight Room	DFB	6:17
146.4-3	DFB by 124	DFB	6:18
146.4-4	DFB Next to 109	DFB	6:20
146.4-5	Kitchen Prep Sink FL	Sink	6:21
146.4-6	Kitchen Prep Sink FR	Sink	6:23
146.4-7	Kitchen Prep Sink BL	Sink	6:24
146.4-8	Kitchen Prep Sink BR	Sink	6:26
146.4-9	Kitchen L Prep Sink Closest to Door	Sink	6:27
146.4-10	Kitchen L Prep Sink Farther From Door	Sink	6:29
146.4-11	Kitchen R Single Bay Sink	Sink	6:30
146.4-12	Kitchen R 3 Bay Sink	Sink	6:32
146.4-13	Kitchen Dish Sprayer	Sprayer	6:33
146.4-14	Bakery Sink	Sink	6:35
146.4-15	Bakery Ice Machine	Ice Machine	6:36
146.4-16	Nurses Office Sink	Sink	6:38
146.4-17	101 Sink	Sink	6:40

Notes:  
 Please e-mail lab results to labs@stohlenv.com  If checked, also e-mail results to: Mscinta@stohlenvironmental.com

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 11/7/2025  
 Relinquished By: \_\_\_\_\_ Print Name \_\_\_\_\_ Stohl Env: Connor Crilly Date: 11/10/2025  
 Received (Name / Lab): [Signature] Date: 11/11/25 Time: 08:30  
 Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_

**R2515230 5**  
 Stohl Environmental  
 Erie 1 BOCES - Kenton Career and Technical Cent



R2515230

5

Stohl Environmental  
Erie 1 BOCES - Kenton Career and Technical Cent



### Cooler Receipt and Preservation Check Form

Project/Client Stohl Environmental Folder Number \_\_\_\_\_

Cooler received on 11/11/25 by: KZ COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="radio"/> N <input type="radio"/>	5a	Did VOA vials have sig* bubbles?	Y N <input checked="" type="radio"/> NA <input type="radio"/>
2	Custody papers properly completed (ink, signed)?	Y <input checked="" type="radio"/> N <input type="radio"/>	5b	Sig* bubbles: Alk? Y N <input checked="" type="radio"/> NA <input type="radio"/> Sulfide? Y N <input checked="" type="radio"/> NA <input type="radio"/>	
3	Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="radio"/> N <input type="radio"/>	6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="radio"/> N <input type="radio"/>	7	Soil VOA received as: Bulk Encore 5035set	<input checked="" type="radio"/> NA <input type="radio"/>

8. Temperature Readings Date: 11/11/25 Time: 09:00 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)							
Within 0-6°C?	Y N	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: \_\_\_\_\_ Ice melted Poorly Packed (described below) Same Day Rule  
& Client Approval to Run Samples: \_\_\_\_\_ Standing Approval Client aware at drop-off Client notified by: \_\_\_\_\_

All samples held in storage location: SMO by KZ on 11/11/25 at 09:20  
5035 samples placed in storage location: \_\_\_\_\_ by \_\_\_\_\_ on \_\_\_\_\_ at \_\_\_\_\_ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check\*\*: Date: 11/11 Time: 2:53 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES  NO
- 10. Did all bottle labels and tags agree with custody papers?  YES  NO
- 11. Were correct containers used for the tests indicated?  YES  NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES  NO  N/A
- 13. Were dissolved metals filtered in the field? YES  NO  N/A
- 14. Air Samples: Cassettes / Tubes Intact Y/N with MS Y/N Canisters Pressurized Tedlar® Bags Inflated  N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>202325</u>	HNO <sub>3</sub>		X	<u>NO LOT INTO</u>		<u>All</u>	<u>4mL</u>		<u>4.2</u>
≤2		H <sub>2</sub> SO <sub>4</sub>								
<4		NaHSO <sub>4</sub>								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> (625, 608, CN), ascorbic (phenol).					
		Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>								
		ZnAcetate	-	-						
		HCl	**	**						

\*\*VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: \_\_\_\_\_  
Explain all Discrepancies/ Other Comments:

2) No relinquishing signature, date or time.

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG \*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



## Miscellaneous Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



## REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- \* Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ( $\geq 100\%$  Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)  
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

### Rochester Lab ID # for State Accreditations<sup>1</sup>



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

<sup>1</sup> Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

# ALS Laboratory Group

---

## Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4

**Service Request:** R2515230

**Sample Name:** 146.4-1  
**Lab Code:** R2515230-001  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/7/25  
**Date Received:** 11/11/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 146.4-2A  
**Lab Code:** R2515230-002  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/7/25  
**Date Received:** 11/11/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 146.4-2B  
**Lab Code:** R2515230-003  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/7/25  
**Date Received:** 11/11/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 146.4-3  
**Lab Code:** R2515230-004  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/7/25  
**Date Received:** 11/11/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 146.4-4  
**Lab Code:** R2515230-005  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/7/25  
**Date Received:** 11/11/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4

**Service Request:** R2515230

**Sample Name:** 146.4-5  
**Lab Code:** R2515230-006  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/7/25  
**Date Received:** 11/11/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 146.4-6  
**Lab Code:** R2515230-007  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/7/25  
**Date Received:** 11/11/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 146.4-7  
**Lab Code:** R2515230-008  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/7/25  
**Date Received:** 11/11/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 146.4-8  
**Lab Code:** R2515230-009  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/7/25  
**Date Received:** 11/11/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 146.4-9  
**Lab Code:** R2515230-010  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/7/25  
**Date Received:** 11/11/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4

**Service Request:** R2515230

**Sample Name:** 146.4-10  
**Lab Code:** R2515230-011  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/7/25  
**Date Received:** 11/11/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 146.4-11  
**Lab Code:** R2515230-012  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/7/25  
**Date Received:** 11/11/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 146.4-12  
**Lab Code:** R2515230-013  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/7/25  
**Date Received:** 11/11/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 146.4-13  
**Lab Code:** R2515230-014  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/7/25  
**Date Received:** 11/11/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 146.4-14  
**Lab Code:** R2515230-015  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/7/25  
**Date Received:** 11/11/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4

**Service Request:** R2515230

**Sample Name:** 146.4-15  
**Lab Code:** R2515230-016  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/7/25  
**Date Received:** 11/11/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 146.4-16  
**Lab Code:** R2515230-017  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/7/25  
**Date Received:** 11/11/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 146.4-17  
**Lab Code:** R2515230-018  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/7/25  
**Date Received:** 11/11/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN



## PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

### INORGANIC

#### Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

#### Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

### ORGANIC

**Preparation Methods for Organic methods are listed in the header of the Results pages.**

#### Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



# Sample Results

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 146.4-1  
**Lab Code:** R2515230-001

**Service Request:** R2515230  
**Date Collected:** 11/07/25  
**Date Received:** 11/11/25 08:30  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/05/25 15:33	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 146.4-2A  
**Lab Code:** R2515230-002

**Service Request:** R2515230  
**Date Collected:** 11/07/25  
**Date Received:** 11/11/25 08:30  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/05/25 15:34	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 146.4-2B  
**Lab Code:** R2515230-003

**Service Request:** R2515230  
**Date Collected:** 11/07/25  
**Date Received:** 11/11/25 08:30  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/05/25 15:39	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 146.4-3  
**Lab Code:** R2515230-004

**Service Request:** R2515230  
**Date Collected:** 11/07/25  
**Date Received:** 11/11/25 08:30  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/05/25 15:40	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 146.4-4  
**Lab Code:** R2515230-005

**Service Request:** R2515230  
**Date Collected:** 11/07/25  
**Date Received:** 11/11/25 08:30  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/05/25 15:42	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 146.4-5  
**Lab Code:** R2515230-006

**Service Request:** R2515230  
**Date Collected:** 11/07/25  
**Date Received:** 11/11/25 08:30  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/05/25 15:44	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 146.4-6  
**Lab Code:** R2515230-007

**Service Request:** R2515230  
**Date Collected:** 11/07/25  
**Date Received:** 11/11/25 08:30  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.9	ug/L	1.0	1	12/05/25 15:54	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 146.4-7  
**Lab Code:** R2515230-008

**Service Request:** R2515230  
**Date Collected:** 11/07/25  
**Date Received:** 11/11/25 08:30  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	12/05/25 15:59	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 146.4-8  
**Lab Code:** R2515230-009

**Service Request:** R2515230  
**Date Collected:** 11/07/25  
**Date Received:** 11/11/25 08:30  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/05/25 16:00	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 146.4-9  
**Lab Code:** R2515230-010

**Service Request:** R2515230  
**Date Collected:** 11/07/25  
**Date Received:** 11/11/25 08:30  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/05/25 16:02	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 146.4-10  
**Lab Code:** R2515230-011

**Service Request:** R2515230  
**Date Collected:** 11/07/25  
**Date Received:** 11/11/25 08:30  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/05/25 16:04	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 146.4-11  
**Lab Code:** R2515230-012

**Service Request:** R2515230  
**Date Collected:** 11/07/25  
**Date Received:** 11/11/25 08:30  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/05/25 16:05	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 146.4-12  
**Lab Code:** R2515230-013

**Service Request:** R2515230  
**Date Collected:** 11/07/25  
**Date Received:** 11/11/25 08:30  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/05/25 16:10	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 146.4-13  
**Lab Code:** R2515230-014

**Service Request:** R2515230  
**Date Collected:** 11/07/25  
**Date Received:** 11/11/25 08:30  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/05/25 16:11	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 146.4-14  
**Lab Code:** R2515230-015

**Service Request:** R2515230  
**Date Collected:** 11/07/25  
**Date Received:** 11/11/25 08:30  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.3	ug/L	1.0	1	12/05/25 16:13	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 146.4-15  
**Lab Code:** R2515230-016

**Service Request:** R2515230  
**Date Collected:** 11/07/25  
**Date Received:** 11/11/25 08:30  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/05/25 16:14	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 146.4-16  
**Lab Code:** R2515230-017

**Service Request:** R2515230  
**Date Collected:** 11/07/25  
**Date Received:** 11/11/25 08:30  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/05/25 16:16	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 146.4-17  
**Lab Code:** R2515230-018

**Service Request:** R2515230  
**Date Collected:** 11/07/25  
**Date Received:** 11/11/25 08:30  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/05/25 16:17	



## QC Summary Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2515230-MB1

**Service Request:** R2515230  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/05/25 15:02	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2515230-MB2

**Service Request:** R2515230  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/05/25 15:51	

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515230  
**Date Collected:** 11/07/25  
**Date Received:** 11/11/25  
**Date Analyzed:** 12/5/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 146.4-5  
**Lab Code:** R2515230-006  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2515230-006MS		Duplicate Matrix Spike R2515230-006DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	20.7	20.0	103	20.7	20.0	103	70-130	<1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515230  
**Date Collected:** 11/07/25  
**Date Received:** 11/11/25  
**Date Analyzed:** 12/5/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 146.4-6  
**Lab Code:** R2515230-007  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2515230-007MS		Duplicate Matrix Spike R2515230-007DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	1.9	22.1	20.0	101	22.5	20.0	103	70-130	2	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515230

**Date Analyzed:** 12/05/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L

**Basis:**NA

**Lab Control Sample**  
R2515230-LCS1

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	20.5	20.0	103	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Erie 1 BOCES - Kenton Career and Technical Center/2023L-146.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515230  
**Date Analyzed:** 12/05/25

**Lab Control Sample Summary**  
**Inorganic Parameters**


**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2515230-LCS2

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	21.1	20.0	105	85-115

1.5 Laboratory Certifications

**NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER**



Expires 12:01 AM April 01, 2026  
Issued April 01, 2025

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**  
*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

**MS. CHRISTINE KUTZER**  
ALS ENVIRONMENTAL - ROCHESTER  
1565 JEFFERSON ROAD BUILDING 300, SUITE 360  
ROCHESTER, NY 14623

NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2016) for the category  
ENVIRONMENTAL ANALYSES POTABLE WATER  
All approved analytes are listed below:*

<b>Bacteriology</b>	
Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Colliert)
<b>Dissolved Gases</b>	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
<b>Fuel Additives</b>	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
<b>Metals I</b>	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Zinc, Total	EPA 200.7 Rev. 4.4

Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to [elap@health.ny.gov](mailto:elap@health.ny.gov).

