

Lead in Water Test Results Summary: Central Point Elementary - Main Building

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **1 ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are highlighted in red and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 10 ppb to 14.99 ppb (near the Action Level)** are highlighted in orange and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5.01 ppb to 9.99 ppb** are highlighted in yellow and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than or equal to 5 ppb** are not highlighted and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Support Services Bathroom	20420100001BF25A	5/7/2025	ND	Non-Detect			
RM1 Sink	20420100002CF25A	5/7/2025	ND	Non-Detect			
RM1 Drinking Fountain	20420100003DW25A	5/7/2025	ND	Non-Detect			
Bathroom Between RM1 and RM3	20420100004BF25A	5/7/2025	ND	Non-Detect			
RM3 Sink	20420100005CF25A	5/7/2025	ND	Non-Detect			
RM3 Drinking Fountain	20420100006DW25A	5/7/2025	ND	Non-Detect			
E Wing Right Drinking Fountain	20420100007DW25A	5/7/2025	ND	Non-Detect			
E Wing Left Drinking Fountain	20420100008DW25A	5/7/2025	ND	Non-Detect			
E Wing Bottle Fill	20420100009WB25A	5/7/2025	ND	Non-Detect			
E Wing Girls Bathroom Left Sink	20420100010BF25A	5/7/2025	ND	Non-Detect			
E Wing Girls Bathroom Middle Sink	20420100011BF25A	5/7/2025	ND	Non-Detect			
E Wing Girls Bathroom Right Sink	20420100012BF25A	5/7/2025	ND	Non-Detect			
E Wing Boys Bathroom Right Sink	20420100013BF25A	5/7/2025	ND	Non-Detect			
E Wing Boys Bathroom Middle Sink	20420100014BF25A	5/7/2025	ND	Non-Detect			
E Wing Boys Bathroom Left Sink	20420100015BF25A	5/7/2025	0.579	Low			
RM5 Sink	20420100016CF25A	5/7/2025	0.518	Low			
RM5 Drinking Fountain	20420100017DW25A	5/7/2025	ND	Non-Detect			
Bathroom Sink Between RM5 and RM7	20420100018BF25A	5/7/2025	ND	Non-Detect			
RM7 Sink	20420100019CF25A	5/7/2025	ND	Non-Detect			
RM7 Drinking Fountain	20420100020DW25A	5/7/2025	ND	Non-Detect			
RM8 Drinking Fountain	20420100021DW25A	5/7/2025	ND	Non-Detect			
RM8 Sink	20420100022CF25A	5/7/2025	0.899	Low			
RM6 Drinking Fountain	20420100023DW25A	5/7/2025	ND	Non-Detect			
RM6 Sink	20420100024CF25A	5/7/2025	ND	Non-Detect			
RM27 Sink	20420100025CF25A	5/7/2025	ND	Non-Detect			
RM27 Bathroom Sink	20420100026BF25A	5/7/2025	ND	Non-Detect			
RM4 Drinking Fountain	20420100027DW25A	5/7/2025	ND	Non-Detect			
RM4 Sink	20420100028CF25A	5/7/2025	0.627	Low			
RM2 Drinking Fountain	20420100029DW25A	5/7/2025	ND	Non-Detect			
RM2 Sink	20420100030CF25A	5/7/2025	2.6	Low			
RM222 Sink	20420100031CF25A	5/7/2025	3.09	Low			
Library Storage Area Sink	20420100032CF25A	5/7/2025	1.08	Low			
RM10 Sink	20420100033CF25A	5/7/2025	2.87	Low			
RM10 Drinking Fountain	20420100034DW25A	5/7/2025	ND	Non-Detect			
RM12 Sink	20420100035CF25A	5/7/2025	1.02	Low			
RM12 Drinking Fountain	20420100036DW25A	5/7/2025	ND	Non-Detect			
RM14 Sink	20420100032CF25A	5/7/2025	1.56	Low			
RM14 Drinking Fountain	20420100038DW25A	5/7/2025	ND	Non-Detect			
RM28 Sink	20420100039CF25A	5/7/2025	6.06	Moderate			
RM28 Bathroom Sink	20420100040BF25A	5/7/2025	9.46	Moderate			
RM16 Sink	20420100041CF25A	5/7/2025	1.6	Low			
RM16 Drinking Fountain	20420100042DW25A	5/7/2025	ND	Non-Detect			
RM18 Sink	20420100043CF25A	5/7/2025	1.67	Low			
RM18 Drinking Fountain	20420100044DW25A	5/7/2025	0.792	Low			
RM19 Sink	20420100045CF25A	5/7/2025	0.989	Low			
RM19 Drinking Fountain	20420100046DW25A	5/7/2025	ND	Non-Detect			
RM17 Drinking Fountain	20420100047DW25A	5/7/2025	ND	Non-Detect			
RM17 Sink	20420100048CF25A	5/7/2025	1.04	Low			
West Wing Right Drinking Fountain	20420100049DW25A	5/7/2025	ND	Non-Detect			

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
West Wing Left Drinking Fountain	20420100050DW25A	5/7/2025	ND	Non-Detect			
West Wing Bottle Fill	20420100051WB25A	5/7/2025	ND	Non-Detect			
West Wing Girls Bathroom Left Sink	20420100052BF25A	5/7/2025	6.75	Moderate			
West Wing Girls Bathroom Middle Sink	20420100053BF25A	5/7/2025	4.59	Low			
West Wing Girls Bathroom Right Sink	20420100054BF25A	5/7/2025	1.3	Low			
West Wing Boys Bathroom Right Sink	20420100055BF25A	5/7/2025	2.77	Low			
West Wing Boys Bathroom Middle Sink	20420100056BF25A	5/7/2025	ND	Non-Detect			
West Wing Boys Bathroom Left Sink	20420100057BF25A	5/7/2025	5.58	Moderate			
RM15 Drinking Fountain	20420100058DW25A	5/7/2025	2.61	Low			
RM15 Sink	20420100059CF25A	5/7/2025	ND	Non-Detect			
RM13 Drinking Fountain	20420100060DW25A	5/7/2025	ND	Non-Detect			
RM13 Sink	20420100061CF25A	5/7/2025	1.53	Low			
RM11 Drinking Fountain	20420100062DW25A	5/7/2025	4.96	Low			
RM11 Sink	20420100063CF25A	5/7/2025	ND	Non-Detect			
RM9 Drinking Fountain	20420100064DW25A	5/7/2025	0.751	Low			
RM9 Sink	20420100065CF25A	5/7/2025	6.02	Moderate			
Music Room Left Sink	20420100066CF25A	5/7/2025	3.71	Low			
Music Room Right Sink	20420100067CF25A	5/7/2025	2.33	Low			
Gym Drinking Fountain	20420100068DW25A	5/7/2025	ND	Non-Detect			
Playground Boys Bathroom Right Sink	20420100069BF25A	5/7/2025	0.861	Low			
Playground Boys Bathroom Left Sink	20420100070BF25A	5/7/2025	2.08	Low			
Playground Girls Bathroom Left Sink	20420100071BF25A	5/7/2025	3.72	Low			
Playground Girls Bathroom Right Sink	20420100072BF25A	5/7/2025	1.24	Low			
Hand Sink by Dishroom	20420100073KF25A	5/7/2025	10.4	High			
Dishroom Sprayer	20420100074KF25A	5/7/2025	ND	Non-Detect			
Pot Sink Sprayer	20420100075KF25A	5/7/2025	1.01	Low			
Pot Sink Left Faucet	20420100076KF25A	5/7/2025	1.23	Low			
Hand Sink by Kitchen Office	20420100078KF25A	5/7/2025	22.7	Action Req.	10/29/2025	1.64	Low
Kitchen Bathroom Sink	20420100079BF25A	5/7/2025	1.22	Low			
Pot Fill South Wall	20420100080KF25A	5/7/2025	23.5	Action Req.	10/29/2025	34.3	Action Req.
Steamer Fill South Wall	20420100081KF25A	5/7/2025	123	Action Req.	10/29/2025	3.43	Low
Kettle Fill South Wall	20420100082KF25A	5/7/2025	0.578	Low			
Prep Sink Center Wall	20420100083KF25A	5/7/2025	1.22	Low			
Mixer Fill	20420100084KF25A	5/7/2025	100	Action Req.	10/29/2025	18.7	Action Req.
Prep Sink West Wall	20420100085KF25A	5/7/2025	ND	Non-Detect			
Hand Sink Northwest Corner	20420100086KF25A	5/7/2025	12	High			
Hotwell Fill Serving Area	20420100087KF25A	5/7/2025	2.7	Low			
Staff Womens Bathroom Left Sink	20420100088BF25A	5/7/2025	ND	Non-Detect			
Staff Womens Bathroom Right Sink	20420100089BF25A	5/7/2025	ND	Non-Detect			
Staff Mens Bathroom Right Sink	20420100090BF25A	5/7/2025	0.892	Low			
Staff Mens Bathroom Left Sink	20420100091BF25A	5/7/2025	0.584	Low			
Staff Breakroom Sink	20420100092SF25A	5/7/2025	ND	Non-Detect			
Production RM Sink	20420100093SF25A	5/7/2025	0.862	Low			
Health RM Bathroom Sink	20420100094BF25A	5/7/2025	0.72	Low			
Health RM Nurse Sink	20420100095NS25A	5/7/2025	1.58	Low			
Calming RM Sink	20420100096SF25A	5/7/2025	0.974	Low			
Playground Left Drinking Fountain	20420100097DW25A	5/13/2025	ND	Non-Detect			
Playground Right Drinking Fountain	20420100098DW25A	5/13/2025	ND	Non-Detect			
Music RM Right Drinking Fountain	20420100099DW25A	5/13/2025	ND	Non-Detect			
<u>CPE PORTABLES</u>							
RM621 Sink	20420101001CF25A	5/7/2025	2.12	Low			
RM622 Sink	20420101002CF25A	5/7/2025	ND	Non-Detect			
RM623 Sink	20420102001CF25A	5/7/2025	1.45	Low			
RM623 Bathroom Sink	20420102002BF25A	5/7/2025	ND	Non-Detect			
RM624 Sink	20420102003CF25A	5/7/2025	0.869	Low			
RM624 Bathroom Sink	20420102004DF25A	5/7/2025	0.665	Low			
RM624 Drinking Fountain	20420102005DW25A	5/13/2025	ND	Non-Detect			
RM623 Drinking Fountain	20420102006DW25A	5/13/2025	ND	Non-Detect			