

Lead in Water Test Results Summary: Patrick Elementary School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **1 ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are highlighted in red and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 10 ppb to 14.99 ppb (near the Action Level)** are highlighted in orange and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5.01 ppb to 9.99 ppb** are highlighted in yellow and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than or equal to 5 ppb** are not highlighted and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
<u>GYM</u>							
Kitchen Sink by Door	20420301001KF25A	5/2/2025	6.03	Moderate			
Kitchen Dishroom Sprayer	20420301002KF25A	5/2/2025	ND	Non-Detect			
Kitchen Sink by Gym Door	20420301003KF25A	5/2/2025	0.536	Low			
Kitchen Sink Beneath Window	20420301004KF25A	5/2/2025	0.626	Low			
Gym Girls Bathroom Left Sink	20420301005BF25A	5/2/2025	ND	Non-Detect			
Gym Girls Bathroom Right Sink	20420301006BF25A	5/2/2025	ND	Non-Detect			
Gym Boys Bathroom Left Sink	20420301007BF25A	5/2/2025	ND	Non-Detect			
Gym Boys Bathroom Right Sink	20420301008BF25A	5/2/2025	ND	Non-Detect			
Gym Left Drinking Fountain	20420301009DW25A	5/2/2025	ND	Non-Detect			
Gym Right Drinking Fountain	20420301010DW25A	5/2/2025	ND	Non-Detect			
Gym Bottle Fill	20420301011WB25A	5/2/2025	ND	Non-Detect			
Smart Room Sink	20420301012CF25A	5/2/2025	1.35	Low			
Kitchen Kettle Fill	20420301013KF25A	5/14/2025	0.145	Low			
<u>SECOND WING</u>							
RM5 Classroom Sink	20420302001CF25A	5/2/2025	ND	Non-Detect			
RM5 Drinking Fountain	20420302002DW25A	5/2/2025	ND	Non-Detect			
RM6 Classroom Sink	20420302003CF25A	5/2/2025	ND	Non-Detect			
RM6 Drinking Fountain	20420302004DW25A	5/2/2025	ND	Non-Detect			
RM7 Classroom Sink	20420302005CF25A	5/2/2025	ND	Non-Detect			
RM7 Drinking Fountain	20420302006DW25A	5/2/2025	ND	Non-Detect			
RM8 Classroom Sink	20420302007CF25A	5/2/2025	ND	Non-Detect			
RM8 Drinking Fountain	20420302008DW25A	5/2/2025	ND	Non-Detect			
<u>THIRD WING</u>							
Staffroom Sink by Library	20420303001SF25A	5/2/2025	ND	Non-Detect			
Womens Staff Bathroom Sink	20420303002BF25A	5/2/2025	ND	Non-Detect			
Mens Staff Bathroom Sink	20420303003BF25A	5/2/2025	ND	Non-Detect			
RM9 Drinking Fountain	20420303004DW25A	5/2/2025	ND	Non-Detect			
RM9 Classroom Sink	20420303005CF25A	5/2/2025	ND	Non-Detect			
RM9 Bathroom Sink	20420303006BF25A	5/2/2025	1.42	Low			
RM10 Drinking Fountain	20420303007DW25A	5/2/2025	ND	Non-Detect			
RM10 Classroom Sink	20420303008CF25A	5/2/2025	ND	Non-Detect			
RM10 Bathroom Sink	20420303009BF25A	5/2/2025	3.73	Low			
RM11 Drinking Fountain	20420303010DW25A	5/2/2025	ND	Non-Detect			
RM11 Classroom Sink	20420303011CF25A	5/2/2025	ND	Non-Detect			
RM11 Bathroom Sink	20420303012BF25A	5/2/2025	3.83	Low			
RM13 Classroom Sink	20420303013CF25A	5/2/2025	ND	Non-Detect			
RM13 Drinking Fountain	20420303014DW25A	5/2/2025	ND	Non-Detect			
RM13 Bathroom Sink	20420303015BF25A	5/2/2025	1.31	Low			
RM12 Classroom Sink	20420303016CF25A	5/2/2025	ND	Non-Detect			
RM12 Drinking Fountain	20420303017DW25A	5/2/2025	ND	Non-Detect			
RM12 Bathroom Sink	20420303018BF25A	5/2/2025	0.525	Low			
<u>FOURTH WING</u>							
Boys Bathroom Left Sink	20420304001BF25A	5/2/2025	ND	Non-Detect			
Boys Bathroom Right Sink	20420304002BF25A	5/2/2025	ND	Non-Detect			
Girls Bathroom Left Sink	20420304003BF25A	5/2/2025	ND	Non-Detect			

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Girls Bathroom Right Sink	20420304004BF25A	5/2/2025	ND	Non-Detect			
RM14 Drinking Fountain	20420304005DW25A	5/2/2025	ND	Non-Detect			
RM14 Classroom Sink	20420304006CF25A	5/2/2025	ND	Non-Detect			
RM15 Drinking Fountain	20420304007DW25A	5/2/2025	ND	Non-Detect			
RM15 Classroom Sink	20420304008CF25A	5/2/2025	ND	Non-Detect			
RM16 Drinking Fountain	20420304009DW25A	5/2/2025	ND	Non-Detect			
RM16 Classroom Sink	20420304010CF25A	5/2/2025	ND	Non-Detect			
RM19 Classroom Sink	20420304011CF25A	5/2/2025	ND	Non-Detect			
RM19 Drinking Fountain	20420304012DW25A	5/2/2025	ND	Non-Detect			
RM18 Classroom Sink	20420304013CF25A	5/2/2025	ND	Non-Detect			
RM18 Drinking Fountain	20420304014DW25A	5/2/2025	ND	Non-Detect			
RM17 Classroom Sink	20420304015CF25A	5/2/2025	ND	Non-Detect			
RM17 Drinking Fountain	20420304016DW25A	5/2/2025	ND	Non-Detect			
<u>FRONT WING</u>							
La Clinica Nurse Sink	20420300001NS25A	5/2/2025	5.42	Moderate			
Principal's Office Sink	20420300003SF25A	5/2/2025	ND	Non-Detect			
RM1 Bathroom Sink	20420300004BF25A	5/2/2025	ND	Non-Detect			
RM1 Classroom Sink	20420300005CF25A	5/2/2025	ND	Non-Detect			
RM1 Drinking Fountain	20420300006DW25A	5/2/2025	ND	Non-Detect			
RM2 Bathroom Sink	20420300007BF25A	5/2/2025	ND	Non-Detect			
RM2 Classroom Sink	20420300008CF25A	5/2/2025	ND	Non-Detect			
RM2 Drinking Fountain	20420300009DW25A	5/2/2025	ND	Non-Detect			
RM3 Bathroom Sink	20420300010BF25A	5/2/2025	0.521	Low			
RM3 Classroom Sink	20420300011CF25A	5/2/2025	ND	Non-Detect			
RM3 Drinking Fountain	20420300012DW25A	5/2/2025	ND	Non-Detect			
RM4 Bathroom Sink	20420300013BF25A	5/2/2025	ND	Non-Detect			
RM4 Classroom Sink	20420300014CF25A	5/2/2025	ND	Non-Detect			
RM4 Drinking Fountain	20420300015DW25A	5/2/2025	ND	Non-Detect			