



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Livingston High School (9058), 30 Robert Harp Drive, Livingston, NJ
PAS Project ID : P25-06106

Matrix : Drinking Water
Report Date : 7/9/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-06106-01	LHS-1-WC01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 08:59	7/7/25 09:41
P25-06106-02	LHS-1-WC02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 09:01	7/7/25 09:59
P25-06106-03	LHS-1-BF01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 09:03	7/7/25 10:27
P25-06106-04	LHS-1-S01A	Lead	1.08 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 09:06	7/7/25 10:31
P25-06106-05	LHS-1-S02A	Lead	1.84 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 09:08	7/7/25 10:35
P25-06106-06	LHS-1-H01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 09:11	7/7/25 10:40
P25-06106-07	LHS-1-S04A	Lead	1.46 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 09:14	7/7/25 10:44
P25-06106-08	LHS-1-S05A	Lead	3.92	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 09:17	7/7/25 10:48
P25-06106-09	LHS-1-S06A	Lead	1.27 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 09:18	7/7/25 10:53
P25-06106-10	LHS-1-S07A	Lead	31.9	ug/L	5	10.0	4.50	15.0 *	SM 3113 B	6/15/25 09:20	7/7/25 13:44
P25-06106-11	LHS-1-S08A	Lead	1.27 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 09:22	7/7/25 11:11
P25-06106-12	LHS-1-IM01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 09:26	7/7/25 11:15
P25-06106-13	LHS-1-WC03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 09:29	7/7/25 11:20
P25-06106-14	LHS-1-BF02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 09:30	7/7/25 11:24
P25-06106-15	LHS-1-WC04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 09:33	7/7/25 11:29
P25-06106-16	LHS-1-BF03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 09:35	7/7/25 11:33
P25-06106-17	LHS-1-WC05A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 09:37	7/7/25 11:38
P25-06106-18	LHS-1-WC06A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 09:42	7/7/25 11:43
P25-06106-19	LHS-1-WC07A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 09:46	7/7/25 11:56
P25-06106-20	LHS-1-WC08A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 09:48	7/7/25 12:01
P25-06106-21	LHS-1-BF04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 09:50	7/7/25 12:05
P25-06106-22	LHS-1-WC09A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 09:54	7/7/25 12:23
P25-06106-23	LHS-1-WC10A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 09:57	7/7/25 12:28
P25-06106-24	LHS-1-BF05A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 09:59	7/7/25 12:32
P25-06106-25	LHS-1-S09A	Lead	1.46 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 10:02	7/7/25 12:46
P25-06106-26	LHS-1-S10A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 10:04	7/7/25 12:50
P25-06106-27	LHS-1-S11A	Lead	1.65 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 10:07	7/7/25 12:54
P25-06106-28	LHS-1-S12A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 10:09	7/7/25 12:59
P25-06106-29	LHS-1-S13A	Lead	2.22	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 10:12	7/7/25 13:03
P25-06106-30	LHS-1-WC12A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 10:15	7/7/25 13:08
P25-06106-31	LHS-1-S17A	Lead	1.27 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 10:19	7/7/25 13:12
P25-06106-32	LHS-1-H03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 10:21	7/7/25 13:16
P25-06106-33	LHS-1-IM02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 10:24	7/7/25 13:21
P25-06106-34	LHS-1-WC15A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 10:33	7/7/25 14:39
P25-06106-35	LHS-1-BF06A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 10:35	7/7/25 14:43
P25-06106-36	LHS-1-WC16A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 10:37	7/7/25 14:48
P25-06106-37	LHS-1-S14A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 10:46	7/7/25 14:52
P25-06106-38	LHS-1-B06A	Lead	1.08 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 10:48	7/7/25 13:49
P25-06106-39	LHS-1-S18A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 10:50	7/7/25 13:53
P25-06106-40	LHS-1-WC17A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 11:05	7/7/25 13:58
P25-06106-41	LHS-1-WC18A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 11:06	7/7/25 12:09
P25-06106-42	LHS-1-BF07A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 11:09	7/7/25 12:25
P25-06106-43	LHS-1-S15A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 11:11	7/7/25 12:37
P25-06106-44	LHS-1-B01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 11:14	7/7/25 12:41
P25-06106-45	LHS-1-WC19A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 11:22	7/7/25 12:45
P25-06106-46	LHS-1-WC20A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 11:25	7/7/25 12:49
P25-06106-47	LHS-1-WC21A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 11:27	7/7/25 12:53

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result

* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Livingston High School (9058), 30 Robert Harp Drive, Livingston, NJ
PAS Project ID : P25-06106

Matrix : Drinking Water
Report Date : 7/9/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-06106-48	LHS-2-WC22A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 11:32	7/7/25 12:57
P25-06106-49	LHS-2-WC23A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 11:36	7/7/25 13:01
P25-06106-50	LHS-2-BF08A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 11:38	7/7/25 13:05
P25-06106-51	LHS-2-WC24A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 11:43	7/7/25 13:09
P25-06106-52	LHS-2-WC25A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 11:46	7/7/25 13:21
P25-06106-53	LHS-2-S16A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 11:50	7/7/25 13:25
P25-06106-54	LHS-2-WC26A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 12:05	7/7/25 13:30
P25-06106-55	LHS-2-WC27A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 12:07	7/7/25 13:34
P25-06106-56	LHS-2-BF10A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 12:09	7/7/25 13:38
P25-06106-57	LHS-2-H02A	Lead	2.90	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 12:13	7/7/25 13:42
P25-06106-58	LHS-2-S19A	Lead	1.06 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 12:16	7/7/25 13:46
P25-06106-59	LHS-2-WC28A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 12:20	7/7/25 13:50
P25-06106-60	LHS-2-WC29A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 12:23	7/7/25 13:54
P25-06106-61	LHS-2-BF11A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 12:26	7/7/25 14:06
P25-06106-62	LHS-2-B03A	Lead	4.73	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 12:30	7/7/25 14:22
P25-06106-63	LHS-2-B04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 12:33	7/7/25 14:26
P25-06106-64	LHS-2-B05A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 12:35	7/7/25 14:30
P25-06106-65	LHS-2-WC30A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 12:38	7/7/25 14:34
P25-06106-66	LHS-2-WC31A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 12:42	7/7/25 14:38
P25-06106-67	LHS-2-WC32A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 12:43	7/7/25 14:50
P25-06106-68	LHS-6-15-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/15/25 12:44	7/7/25 14:54

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
- MDL = Minimum Detection Limit
- MCL = Maximum Contaminant Level
- DF = Dilution Factor
- ND = Analyzed for but not detected
- J = Estimated result
- * NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer