

Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

November 13, 2025

Batch #: 111325-1

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1000 Centro Way Bldg.- Christine Grant
Elementary School
North Liberty IA 52317

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

The Results are as follows:

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)	
SML589	SST	BASP 1200A	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	0.8
SMV392	SST	1119 Media Center	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	0.7
SNE899	SST	Kitchen Office	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	0.9
SNK402	SST	1108 Workroom	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	0.9
SNL341	SST	1119A	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	0.8
SNL493	SST	016	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	7.4
SNL546	SST	1109	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	1.1
SNL579	SST	025	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	2.3
SNN861	SST	1105	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	1.1
SNT742	SST	Music 1207	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	2.1
SNU614	SST	1209 Art	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	0.6
SNU695	SST	017	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	0.5
SNU788	SST	Gym 1205	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	<LLD
SNX054	SST	1113	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	1.0
SNX091	SST	1100B	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	<LLD
SNX106	SST	1129	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	1.0
SOA537	SST	1116	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	0.9
SOM102	SST	015	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	0.7
SOP140	SST	1219	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	1.2
SOP309	SST	1107	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	1.4
SOV236	SST	Gym 1205	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	0.7
SOV338	SST	1100C	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	1.4
SOV356	SST	1100 Reception	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	1.0
SOV729	SST	1112	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	<LLD
SOV734	SST	1119 Media Center	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	<LLD
SOV744	SST	1120	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	1.2
SOV803	SST	028	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	1.2
SOV828	SST	1115	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	1.5
SOV838	SST	027	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	1.2
SOV891	SST	018	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	0.7
SOV931	SST	029	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	<LLD
SOV970	SST	1100D	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	0.7
SOW042	SST	1111	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	0.9
SOW056	SST	019	04-Nov-2025	9:55 AM	07-Nov-2025 7:15 AM	<LLD

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

November 13, 2025

Batch #: 111325-1

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1000 Centro Way Bldg.- Christine Grant
Elementary School
North Liberty IA 52317

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SNU420	SST	1101	04-Nov-2025 9:55 AM	07-Nov-2025 7:15 AM	0.7
SNW993	SST	1101	04-Nov-2025 9:55 AM	07-Nov-2025 7:15 AM	0.8
Average Radon Concentration in:			1101		0.7 pCi/L
SNU349	SST	Nurse 1100A	04-Nov-2025 9:55 AM	07-Nov-2025 7:15 AM	<LLD
SNU572	SST	Nurse 1100A	04-Nov-2025 9:55 AM	07-Nov-2025 7:15 AM	1.3
Average Radon Concentration in:			Nurse 1100A		0.7 pCi/L
SNL329	SST	1114	04-Nov-2025 9:55 AM	07-Nov-2025 7:15 AM	1.2
SNX012	SST	1114	04-Nov-2025 9:55 AM	07-Nov-2025 7:15 AM	0.7
Average Radon Concentration in:			1114		0.9 pCi/L
SOV759	SST	1119B	04-Nov-2025 9:55 AM	07-Nov-2025 7:15 AM	1.4
SOV827	SST	1119B	04-Nov-2025 9:55 AM	07-Nov-2025 7:15 AM	0.5
Average Radon Concentration in:			1119B		1.0 pCi/L
SNU502	SST	1210	04-Nov-2025 9:55 AM	07-Nov-2025 7:15 AM	0.6
SOV844	SST	1210	04-Nov-2025 9:55 AM	07-Nov-2025 7:15 AM	2.5
Average Radon Concentration in:			1210		1.5 pCi/L
SNN721	SST	020	04-Nov-2025 9:55 AM	07-Nov-2025 7:15 AM	0.9
SNX267	SST	020	04-Nov-2025 9:55 AM	07-Nov-2025 7:15 AM	<LLD
Average Radon Concentration in:			020		0.6 pCi/L

Deployed By: Sam Becker RNTST10096
Retrieved By: Sam Becker RNTST10096
Analyzed By: Sam Becker RNTST10096
Reader S/N: E0747 **Reader Calibration Due:** 4/14/2026
Conditions: Requirements for Closed-Building Met
Weather: No Abnormal Weather Conditions
Vents: Open / Fan Auto
Mitigation: No System Installed

Note: <LLD = Less than the Lower Limit of Detection (LLD) of the Radon Detector.

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

November 13, 2025

Batch #: 111325-1

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1000 Centro Way Bldg.- Christine Grant
Elementary School
North Liberty IA 52317

www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

November 15, 2025

Batch #: 111325-6

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1725 North Dodge St. Bldg.- ESC
Building
Iowa City IA 52245

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

The Results are as follows:

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SML589	SST	102C	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	1.6
SNE899	SST	105	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.7
SNK402	SST	103	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.7
SNL329	SST	129	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.6
SNL468	SST	125	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	1.0
SNL493	SST	142C	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.7
SNL546	SST	119	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.6
SNL577	SST	155A	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.8
SNN861	SST	141	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	1.1
SNT742	SST	118	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	<LLD
SNU420	SST	117	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.7
SNU572	SST	110	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	<LLD
SNU737	SST	HRB2	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.8
SNW993	SST	124	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.8
SNX012	SST	44/45	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	1.1
SNX054	SST	107	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.9
SNX091	SST	114	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.6
SNX106	SST	111	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.8
SOA537	SST	116	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.8
SOM102	SST	142A	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	1.4
SOP140	SST	120	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	<LLD
SOV235	SST	156	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.8
SOV236	SST	136	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	<LLD
SOV275	SST	153	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.7
SOV381	SST	165	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	<LLD
SOV729	SST	112	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	1.0
SOV734	SST	122	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.7
SOV744	SST	155	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	<LLD
SOV808	SST	151	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.9
SOV827	SST	131	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.7
SOV828	SST	102A	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.7
SOV838	SST	142B	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	1.4
SOV844	SST	130	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	1.1
SOV879	SST	159	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.5
SOV891	SST	128	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	<LLD
SOV931	SST	109	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	1.2

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

November 15, 2025

Batch #: 111325-6

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1725 North Dodge St. Bldg.- ESC
Building
Iowa City IA 52245

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SOV970	SST	101	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.9
SOW042	SST	102B	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.7
SOW066	SST	144	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.8
SOW075	SST	164	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.5
SOW457	SST	161	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	<LLD
SPK858	SST	149	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.5
SPK915	SST	147	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.7
SPL094	SST	163	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.8
SNL341	SST	108	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	1.0
SNU614	SST	108	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.6
Average Radon Concentration in:			108				0.8 pCi/L
SOP309	SST	113	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.5
SOV356	SST	113	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.8
Average Radon Concentration in:			113				0.7 pCi/L
SNU349	SST	121	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	1.6
SOV803	SST	121	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.5
Average Radon Concentration in:			121				1.0 pCi/L
SNL579	SST	135	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	<LLD
SOV338	SST	135	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.7
Average Radon Concentration in:			135				<LLD pCi/L
SNU695	SST	148	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.9
SNU788	SST	148	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.9
Average Radon Concentration in:			148				0.9 pCi/L
SMV392	SST	160	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.5
SNL467	SST	160	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.6
Average Radon Concentration in:			160				0.5 pCi/L
SNN721	SST	166	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	<LLD
SNU502	SST	166	10-Nov-2025	10:10 AM	13-Nov-2025	8:10 AM	0.7
Average Radon Concentration in:			166				0.6 pCi/L

Deployed By: Sam Becker RNTST10096

Retrieved By: Sam Becker RNTST10096

Analyzed By: Sam Becker RNTST10096

Reader S/N: E0747

Reader Calibration Due: 4/14/2026

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

November 15, 2025

Batch #: 111325-6

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1725 North Dodge St. Bldg.- ESC
Building
Iowa City IA 52245

Conditions: Requirements for Closed-Building Met

Weather: No Abnormal Weather Conditions

Vents: Open / Fan Auto

Mitigation: No System Installed

Note: <LLD = Less than the Lower Limit of Detection (LLD) of the Radon Detector.

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: _____ Date: _____

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

November 13, 2025

Batch #: 111325-5

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1255 Barrington Road Bldg.- Hoover
Elementary
Iowa City IA 52240

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

The Results are as follows:

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SNE903	SST	024 BASP	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.5
SNL335	SST	212 (2nd Floor)	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	<LLD
SNL492	SST	027	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	1.2
SNL523	SST	Reception	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.8
SNN017	SST	003	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.4
SNN806	SST	033	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.5
SNU494	SST	036	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.6
SNU504	SST	107	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.5
SNU522	SST	037	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.5
SNU577	SST	008	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	<LLD
SNX080	SST	111	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	<LLD
SNX113	SST	207 (2nd Floor)	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.5
SNX269	SST	029	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	<LLD
SOV250	SST	040	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.5
SOV271	SST	112	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.6
SOV994	SST	113	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	1.0
SOW021	SST	108	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	<LLD
SOW044	SST	014	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.5
SOW063	SST	023	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.5
SOW065	SST	014C Custodial	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	<LLD
SOW288	SST	114	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.8
SOW360	SST	031	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	<LLD
SPK911	SST	014	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.6
SPK969	SST	039	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	<LLD
SPL015	SST	021	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.8
SPL035	SST	012	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	<LLD
SPL037	SST	110	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.5
SPL049	SST	115	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.6
SPL057	SST	041	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.6
SPL060	SST	014	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.5
SPL069	SST	019	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	<LLD
SPL096	SST	025	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.9
SPL090	SST	010	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	<LLD
SPL161	SST	010	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	<LLD

Average Radon Concentration in:

010

<LLD pCi/L

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

November 13, 2025

Batch #: 111325-5

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1255 Barrington Road Bldg.- Hoover
Elementary
Iowa City IA 52240

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SNU547	SST	014A	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	<LLD
SPK861	SST	014A	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.6
Average Radon Concentration in:			014A		0.5 pCi/L
SNX031	SST	042	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.5
SPL044	SST	042	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.6
Average Radon Concentration in:			042		0.6 pCi/L
SPK866	SST	116	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.5
SPL097	SST	116	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.6
Average Radon Concentration in:			116		0.5 pCi/L
SOV910	SST	109	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.6
SPL192	SST	109	10-Nov-2025 7:00 AM	13-Nov-2025 7:30 AM	0.5
Average Radon Concentration in:			109		0.6 pCi/L

Deployed By: Sam Becker RNTST10096
Retrieved By: Sam Becker RNTST10096
Analyzed By: Sam Becker RNTST10096
Reader S/N: E0747 **Reader Calibration Due:** 4/14/2026
Conditions: Requirements for Closed-Building Met
Weather: No Abnormal Weather Conditions
Vents: Open / Fan Auto
Mitigation: No System Installed

Note: <LLD = Less than the Lower Limit of Detection (LLD) of the Radon Detector.

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: _____ **Date:** _____

Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

December 17, 2025

Batch #: 121525-2

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
600 Koser Ave Bldg.- Horn Elementary
Iowa City IA 52246

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

The Results are as follows:

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SML544	SST	50	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	1.4
SNE751	SST	013	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	0.8
SNK478	SST	15	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	0.5
SNL380	SST	009	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	0.5
SNL385	SST	19	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	0.6
SNL441	SST	023 Art	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	1.0
SNL474	SST	43	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	1.9
SNL484	SST	001 Office	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	1.9
SNL491	SST	81 Custodian	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	2.4
SNL497	SST	25	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	0.6
SNL578	SST	70 BASP	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	2.3
SNL607	SST	38	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	1.4
SNU551	SST	40	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	1.3
SNU577	SST	41B	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	0.9
SNU624	SST	56 Media Center	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	0.7
SNU669	SST	49	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	1.2
SNU745	SST	41A	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	0.8
SNX008	SST	56 Media Center	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	0.6
SNX059	SST	47	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	0.8
SNX095	SST	012	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	0.6
SNX099	SST	76	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	0.9
SNX130	SST	67	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	2.1
SNX184	SST	003 Nurse	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	0.6
SNX196	SST	53	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	1.0
SNX267	SST	66	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	0.8
SNX276	SST	011	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	0.6
SOA602	SST	024 Music	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	0.8
SOV265	SST	74	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	0.9
SOV298	SST	52	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	1.4
SOV323	SST	39	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	1.3
SOV339	SST	51	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	1.2
SOV811	SST	73	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	1.2
SOV817	SST	16	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	0.7
SOV853	SST	004 Conference	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	0.5
SOV876	SST	65	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	0.7
SOV884	SST	64	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	0.7
SOV886	SST	46	19-Nov-2025 3:30 PM	24-Nov-2025 9:50 AM	1.2

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

December 17, 2025

Batch #: 121525-2

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
600 Koser Ave Bldg.- Horn Elementary
Iowa City IA 52246

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SOV893	SST	48	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	1.3
SOV902	SST	002 Principal	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	1.0
SOV962	SST	030 Gym	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	0.7
SOW001	SST	42	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	1.2
SOW004	SST	45	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	1.5
SOW062	SST	14	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	0.7
SOW095	SST	57	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	1.1
SOW169	SST	36	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	1.4
SOW183	SST	62	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	1.4
SOW295	SST	18	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	1.3
SOW472	SST	63	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	1.1
SOW489	SST	44	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	1.4
SMV427	SST	005 Lounge	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	1.1
SNX283	SST	005 Lounge	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	0.9
Average Radon Concentration in:			005 Lounge			1.0 pCi/L	
SNL471	SST	17	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	0.6
SNX268	SST	17	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	0.7
Average Radon Concentration in:			17			0.6 pCi/L	
SNX005	SST	032 PE Office	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	0.8
SNX029	SST	032 PE Office	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	0.8
Average Radon Concentration in:			032 PE Office			0.8 pCi/L	
SNL401	SST	75	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	1.2
SNL490	SST	75	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	1.1
Average Radon Concentration in:			75			1.2 pCi/L	
SOA666	SST	68	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	1.9
SOV794	SST	68	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	1.7
Average Radon Concentration in:			68			1.8 pCi/L	
SNX032	SST	58	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	0.7
SOW125	SST	58	19-Nov-2025	3:30 PM	24-Nov-2025	9:50 AM	0.8
Average Radon Concentration in:			58			0.8 pCi/L	

Deployed By: Sam Becker RNTST10096

Retrieved By: Sam Becker RNTST10096

Analyzed By: Sam Becker RNTST10096

Reader S/N: E1549 Reader Calibration Due: 10/24/2026

Conditions: Requirements for Closed-Building Met

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

December 17, 2025

Batch #: 121525-2

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
600 Koser Ave Bldg.- Horn Elementary
Iowa City IA 52246

Weather: No Abnormal Weather Conditions
Vents: Open / Fan Auto
Mitigation: No System Installed

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: _____ Date: _____

Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

November 13, 2025

Batch #: 111325-3

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1401 9th Street Bldg.- Kirkwood
Elementary
Coralville IA 52241

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

The Results are as follows:

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SNK324	SST	117	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.7
SNL380	SST	124	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.1
SNL401	SST	126	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.5
SNL424	SST	116	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.4
SNL459	SST	125	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.8
SNL474	SST	140 Multipurpose	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	2.3
SNL484	SST	135	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.6
SNL515	SST	100A Nurse	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.5
SNL553	SST	118A	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.1
SNL558	SST	118C	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.1
SNU202	SST	118B	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.1
SNU462	SST	137	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.1
SNU490	SST	148	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.3
SNU510	SST	140B	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	9.2
SNX007	SST	156	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	0.6
SNX015	SST	109	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.1
SNX022	SST	153 Gym	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	0.9
SNX136	SST	138	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	2.3
SNX137	SST	114	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.7
SNX240	SST	123	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	0.5
SNX268	SST	102 Art	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.1
SOA024	SST	104	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.1
SOA644	SST	120	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	4.8
SOV301	SST	152	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.7
SOV361	SST	100E Principal	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.2
SOV814	SST	108	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	0.5
SOV818	SST	110 Work Room	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.2
SOV889	SST	110 Lounge	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	2.2
SOV895	SST	111	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.5
SOV902	SST	136 Support	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.9
SOV960	SST	153 Gym	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.7
SOV976	SST	Media Center	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.9
SOV980	SST	100C Conference	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.4
SOV990	SST	100B Office	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.5
SOW008	SST	141	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.9
SOW043	SST	Media Center	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	2.2

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

November 13, 2025

Batch #: 111325-3

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1401 9th Street Bldg.- Kirkwood
Elementary
Coralville IA 52241

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SOW068	SST	121 Collaborative	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.7
SOW078	SST	107 Support	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	2.6
SOW142	SST	119	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.2
SOW170	SST	100D Office	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.0
SOW182	SST	112	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	0.9
SOW234	SST	139	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	2.1
SOW250	SST	143	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.6
SOW286	SST	122	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.0
SOW295	SST	140 Multipurpose	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	2.9
SOW383	SST	154	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.7
SNE751	SST	153A Office	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.2
SOV853	SST	153A Office	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.0

Average Radon Concentration in: 153A Office 1.1 pCi/L

SNU501	SST	150	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	2.2
SOV227	SST	150	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.2

Average Radon Concentration in: 150 1.7 pCi/L

SOV761	SST	145	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	2.0
SOW519	SST	145	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.0

Average Radon Concentration in: 145 1.5 pCi/L

SOV812	SST	Main Office	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.0
SOV872	SST	Main Office	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	0.9

Average Radon Concentration in: Main Office 0.9 pCi/L

SNK478	SST	128	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.3
SNX283	SST	128	04-Nov-2025 10:55 AM	07-Nov-2025 8:00 AM	1.3

Average Radon Concentration in: 128 1.3 pCi/L

Deployed By: Sam Becker RNTST10096
Retrieved By: Sam Becker RNTST10096
Analyzed By: Sam Becker RNTST10096
Reader S/N: E0747 **Reader Calibration Due:** 4/14/2026
Conditions: Requirements for Closed-Building Met
Weather: No Abnormal Weather Conditions
Vents: Open / Fan Auto
Mitigation: No System Installed

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

November 13, 2025

Batch #: 111325-3

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1401 9th Street Bldg.- Kirkwood
Elementary
Coralville IA 52241

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: _____ Date: _____

Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

November 13, 2025

Batch #: 111325-2

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

230 N. Dubuque Street Bldg.- Penn
Elementary
North Liberty IA 52317

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

The Results are as follows:

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)	
SMV427	SST	156	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	2.0
SNE890	SST	185 Band/Orchestra	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	1.7
SNF027	SST	198	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	1.8
SNK501	SST	125	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	2.0
SNL306	SST	160	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	0.9
SNL313	SST	146	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	2.2
SNL318	SST	176 Media Center	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	0.9
SNL322	SST	133 Staff Lounge	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	2.4
SNL334	SST	121	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	2.2
SNL343	SST	166	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	1.5
SNL385	SST	204	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	1.7
SNL393	SST	124	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	2.2
SNL418	SST	127	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	2.4
SNL441	SST	183 PE Office	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	2.0
SNL456	SST	145	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	2.1
SNL460	SST	Principal	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	3.8
SNL490	SST	196	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	2.1
SNL503	SST	147	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	2.7
SNL509	SST	176.1	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	0.8
SNL588	SST	176.2	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	<LLD
SNL592	SST	Nurse	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	2.8
SNL731	SST	Gym	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	1.3
SNL744	SST	169	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	1.7
SNM860	SST	141	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	1.8
SNN813	SST	101 Office	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	2.6
SNN815	SST	Dining Room	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	1.4
SNT909	SST	162	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	1.5
SNU156	SST	104	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	1.4
SNU449	SST	168	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	36.7
SNU469	SST	176.3 Media Resource	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	1.8
SNU540	SST	202	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	1.8
SNU555	SST	203	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	2.4
SNU562	SST	Gym	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	1.3
SNU574	SST	123	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	1.9
SNU590	SST	176 Media Center	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	1.3
SNU615	SST	129	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	2.9
SNU633	SST	122	04-Nov-2025	9:00 AM	07-Nov-2025 6:20 AM	2.7

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

November 13, 2025

Batch #: 111325-2

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

230 N. Dubuque Street Bldg.- Penn
Elementary
North Liberty IA 52317

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SNU661	SST	163	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	1.6
SNU710	SST	171	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	0.7
SNX000	SST	200	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	1.8
SNX005	SST	209	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	2.4
SNX006	SST	157	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	1.1
SNX062	SST	154	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	2.4
SNX063	SST	Gym	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	1.4
SNX095	SST	205	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	1.7
SNX099	SST	Dining Room	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	1.5
SNX115	SST	207	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	2.6
SNX184	SST	189B	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	1.6
SNX241	SST	167	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	<LLD
SNX250	SST	158	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	1.6
SNX276	SST	Gym	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	1.2
SOA602	SST	199	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	2.6
SOV786	SST	197	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	2.2
SOW073	SST	102	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	2.0
SNL562	SST	109	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	2.6
SNM776	SST	109	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	2.4
Average Radon Concentration in:			109	2.5 pCi/L	
SNU470	SST	126	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	2.3
SNU603	SST	126	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	2.4
Average Radon Concentration in:			126	2.4 pCi/L	
SNN731	SST	144	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	<LLD
SOV284	SST	144	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	1.5
Average Radon Concentration in:			144	0.8 pCi/L	
SNF009	SST	165	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	0.7
SNL397	SST	165	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	0.8
Average Radon Concentration in:			165	0.7 pCi/L	
SNU552	SST	173	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	0.9
SOW120	SST	173	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	1.0
Average Radon Concentration in:			173	1.0 pCi/L	
SNL601	SST	187 Custodian	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	1.6
SNX176	SST	187 Custodian	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	1.4
Average Radon Concentration in:			187 Custodian	1.5 pCi/L	

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

November 13, 2025

Batch #: 111325-2

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

230 N. Dubuque Street Bldg.- Penn
Elementary
North Liberty IA 52317

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SNL525	SST	201	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	2.3
SNX029	SST	201	04-Nov-2025 9:00 AM	07-Nov-2025 6:20 AM	2.2

Average Radon Concentration in: 201 2.3 pCi/L

Deployed By: Sam Becker RNTST10096
Retrieved By: Sam Becker RNTST10096
Analyzed By: Sam Becker RNTST10096
Reader S/N: E0747 **Reader Calibration Due:** 4/14/2026
Conditions: Requirements for Closed-Building Met
Weather: No Abnormal Weather Conditions
Vents: Open / Fan Auto
Mitigation: No System Installed

Note: <LLD = Less than the Lower Limit of Detection (LLD) of the Radon Detector.

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: _____ Date: _____

Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

December 15, 2025

Batch #: 121525-1

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
2501 Bradford Drive Bldg.- South East
Iowa City IA 52240

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

The Results are as follows:

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SNK402	SST	1124	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	2.5
SNL329	SST	1036	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	2.5
SNL467	SST	1158 Break Room	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	1.9
SNL493	SST	1188	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	<LLD
SNL546	SST	Wrestling 1101	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	2.0
SNL570	SST	1101A Inside Gym Locker Room	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	2.6
SNL577	SST	1148 Integrated Arts	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	2.6
SNL579	SST	1144A	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	3.0
SNN721	SST	1141 Band	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	0.9
SNN861	SST	1137 Office inside Boy's Locker Rm	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	0.7
SNT742	SST	1034	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	2.3
SNU349	SST	1144	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	2.2
SNU420	SST	1001	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	2.1
SNU490	SST	2104	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	1.2
SNU502	SST	1185	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	0.8
SNU572	SST	Gym 1115	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	2.0
SNU614	SST	1106 Gym	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	0.9
SNU737	SST	Commons	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	2.3
SNU750	SST	2031	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	1.6
SNW993	SST	1143 Choir Room	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	2.2
SNX007	SST	1182	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	0.8
SNX012	SST	1106 Gym	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	0.7
SNX015	SST	2025	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	1.3
SNX022	SST	1177 Office	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	3.2
SNX054	SST	1040A	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	1.2
SNX091	SST	1026	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	1.3
SOM102	SST	Wrestling 1101	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	17.2
SOP309	SST	Gym 1115	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	1.9
SOV227	SST	2114	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	1.1
SOV235	SST	1142 Orchestra	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	1.4
SOV236	SST	1106 Gym	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	1.0
SOV278	SST	1047	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	10.8
SOV301	SST	1180	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	0.6
SOV338	SST	1003	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	2.1
SOV349	SST	1042	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	1.5

Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

December 15, 2025

Batch #: 121525-1

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
2501 Bradford Drive Bldg.- South East
Iowa City IA 52240

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)	
SOV356	SST	Gym 1115	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	2.2
SOV361	SST	2007	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	1.6
SOV381	SST	1149 Industrial Tech	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	3.3
SOV729	SST	Gym 1115	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	2.0
SOV734	SST	1110C Office	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	2.9
SOV737	SST	1044	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	2.6
SOV744	SST	1187	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	0.6
SOV789	SST	1049	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	4.1
SOV799	SST	1050	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	1.8
SOV803	SST	1008 Art	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	1.9
SOV808	SST	1160 Kitchen Office	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	1.9
SOV812	SST	2015	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	1.2
SOV827	SST	1141A	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	0.9
SOV828	SST	1019	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	2.5
SOV838	SST	1184	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	<LLD
SOV844	SST	1141B Office	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	1.6
SOV872	SST	2008	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	1.5
SOV879	SST	1155 Cafeteria	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	1.9
SOV931	SST	1014	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	2.4
SOV960	SST	1178	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	1.1
SOV970	SST	1038	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	3.3
SOV975	SST	1046	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	4.6
SOV980	SST	2011	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	1.2
SOV990	SST	1176	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	1.3
SOW042	SST	1028	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	2.5
SOW043	SST	2018	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	1.2
SOW044	SST	1122	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	2.1
SOW056	SST	1150 Wood Shop	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	3.1
SOW066	SST	1150A Office	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	3.7
SOW078	SST	2023	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	0.8
SOW142	SST	2013	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	0.9
SOW234	SST	2033	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	1.3
SOW250	SST	2029	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	1.4
SOW383	SST	1181	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	0.5
SOW457	SST	1140 Fitness	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	0.8
SOW519	SST	2035	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	2.6
SPK858	SST	1143A	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	1.7
SPK861	SST	1136 Office inside Girl's Locker Rm.	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	2.2
SPK915	SST	1186	19-Nov-2025	8:30 AM	24-Nov-2025 6:15 AM	0.7

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

December 15, 2025

Batch #: 121525-1

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
2501 Bradford Drive Bldg.- South East
Iowa City IA 52240

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SPL094	SST	1142B Office	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	1.2
SNN784	SST	1039	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	13.2
SOW368	SST	1039	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	13.1
Average Radon Concentration in:			1039		13.1 pCi/L
SNL424	SST	2009	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	1.2
SOV976	SST	2009	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	0.9
Average Radon Concentration in:			2009		1.1 pCi/L
SML589	SST	1024	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	2.0
SOV891	SST	1024	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	1.8
Average Radon Concentration in:			1024		1.9 pCi/L
SNL341	SST	1012 Art	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	2.1
SNX106	SST	1012 Art	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	2.0
Average Radon Concentration in:			1012 Art		2.0 pCi/L
SOP140	SST	1000 Science	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	2.4
SOV759	SST	1000 Science	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	2.5
Average Radon Concentration in:			1000 Science		2.4 pCi/L
SMV392	SST	1142C	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	1.3
SOW075	SST	1142C	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	1.2
Average Radon Concentration in:			1142C		1.3 pCi/L
SNU695	SST	1166 Lounge	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	2.6
SNU788	SST	1166 Lounge	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	2.4
Average Radon Concentration in:			1166 Lounge		2.5 pCi/L
SNU501	SST	1183	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	0.7
SNX136	SST	1183	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	0.8
Average Radon Concentration in:			1183		0.7 pCi/L
SOV761	SST	1179 Flex	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	1.8
SOW008	SST	1179 Flex	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	1.3
Average Radon Concentration in:			1179 Flex		1.6 pCi/L
SNL515	SST	2027	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	1.5
SOV895	SST	2027	19-Nov-2025 8:30 AM	24-Nov-2025 6:15 AM	1.3
Average Radon Concentration in:			2027		1.4 pCi/L

Deployed By: Sam Becker RNTST10096

Retrieved By: Sam Becker RNTST10096

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

December 15, 2025

Batch #: 121525-1

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
2501 Bradford Drive Bldg.- South East
Iowa City IA 52240

Analyzed By: Sam Becker RNTST10096
Reader S/N: E0747 **Reader Calibration Due:** 4/14/2026
Conditions: Requirements for Closed-Building Met
Weather: No Abnormal Weather Conditions
Vents: Open / Fan Auto
Mitigation: No System Installed

Note: <LLD = Less than the Lower Limit of Detection (LLD) of the Radon Detector.

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: _____ Date: _____

Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

November 13, 2025

Batch #: 111325-4

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1528 Mall Drive Bldg.- Tate High School
Iowa City IA 52240

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

The Results are as follows:

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SNK609	SST	116A	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	34.0
SNL492	SST	132	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	1.2
SNL523	SST	123	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	0.7
SNL561	SST	134	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	0.8
SNU494	SST	113A Office	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	1.2
SNU522	SST	101A Custodian	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	1.7
SNU547	SST	117	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	<LLD
SNU577	SST	144 Gym	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	1.1
SNX031	SST	126	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	0.8
SNX080	SST	111A	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	1.3
SNX113	SST	116	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	1.1
SNX269	SST	115	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	1.1
SOV250	SST	143 Fitness	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	1.6
SOV271	SST	133	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	1.2
SOV808	SST	125	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	1.6
SOV994	SST	144 Gym	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	1.1
SOW021	SST	128	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	0.9
SOW044	SST	144 Gym	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	1.2
SOW063	SST	144 Gym	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	1.4
SPK858	SST	102	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	0.7
SPK861	SST	102B	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	0.7
SPK911	SST	131	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	<LLD
SPK915	SST	102I	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	0.7
SPK969	SST	108	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	1.9
SPL035	SST	102C	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	1.4
SPL037	SST	110	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	0.9
SPL057	SST	115A	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	0.5
SPL060	SST	102E	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	0.9
SPL069	SST	111	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	0.9
SPL090	SST	102A	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	1.0
SPL096	SST	118	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	<LLD
SPL097	SST	103	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	1.0
SPL161	SST	112	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	0.9
SPL192	SST	114	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	1.6

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

November 13, 2025

Batch #: 111325-4

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1528 Mall Drive Bldg.- Tate High School
Iowa City IA 52240

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SPK866	SST	102G	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	0.5
SPL094	SST	102G	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	0.9
Average Radon Concentration in:			102G		0.7 pCi/L
SPL044	SST	113	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	0.7
SPL049	SST	113	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	0.7
Average Radon Concentration in:			113		0.7 pCi/L
SNN017	SST	124	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	1.5
SOV910	SST	124	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	1.3
Average Radon Concentration in:			124		1.4 pCi/L
SNE903	SST	141 PE Office	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	1.7
SNN806	SST	141 PE Office	04-Nov-2025 12:00 PM	07-Nov-2025 8:20 AM	1.4
Average Radon Concentration in:			141 PE Office		1.5 pCi/L
Deployed By:	Sam Becker	RNTST10096			
Retrieved By:	Sam Becker	RNTST10096			
Analyzed By:	Sam Becker	RNTST10096			
Reader S/N:	E0747		Reader Calibration Due:	4/14/2026	
Conditions:	Requirements for Closed-Building Met				
Weather:	No Abnormal Weather Conditions				
Vents:	Open / Fan Auto				
Mitigation:	No System Installed				

Note: <LLD = Less than the Lower Limit of Detection (LLD) of the Radon Detector.

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: _____ Date: _____

Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

December 17, 2025

Batch #: 121625-1

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
170 Abigail Avenue Bldg.- Van Allen
Elementary
North Liberty IA 52317

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

The Results are as follows:

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SNE890	SST	212	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	3.4
SNF009	SST	618	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.3
SNK501	SST	704	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.0
SNL313	SST	410	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	1.4
SNL318	SST	619	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.5
SNL322	SST	702 Music	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.3
SNL343	SST	211	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.6
SNL378	SST	213	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	3.5
SNL393	SST	411	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.7
SNL397	SST	315	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.7
SNL418	SST	620	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.1
SNL456	SST	412	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	1.6
SNL460	SST	310	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	3.1
SNL503	SST	311	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.4
SNL558	SST	308	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.2
SNL562	SST	408	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.0
SNL592	SST	306	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.2
SNL601	SST	215	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	3.0
SNL731	SST	207	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.5
SNL744	SST	208	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	3.3
SNM776	SST	313	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.6
SNM860	SST	615 Library	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.4
SNN731	SST	307	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	5.7
SNU156	SST	714 Gym	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.1
SNU449	SST	206	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	
SNU470	SST	406	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	1.6
SNU510	SST	512 Health	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.2
SNU540	SST	106	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.1
SNU552	SST	109	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.5
SNU562	SST	110	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.4
SNU574	SST	615A Computer Lab	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.1
SNU603	SST	407	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	1.5
SNU615	SST	703 Art	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.3
SNU633	SST	607	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.4
SNU661	SST	312	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.4
SNU710	SST	714 Gym	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.0

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

December 17, 2025

Batch #: 121625-1

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
170 Abigail Avenue Bldg.- Van Allen
Elementary
North Liberty IA 52317

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SNX006	SST	714 Gym	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	1.8
SNX063	SST	617	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.5
SNX115	SST	210	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.8
SNX241	SST	111	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.3
SNX250	SST	707 PE Office	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	1.9
SOV284	SST	708 Custodian	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	1.6
SOV709	SST	602 Cafeteria	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	1.9
SOV786	SST	714 Gym	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	1.6
SOV818	SST	507 Principal	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.3
SOV889	SST	602 Cafeteria	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.4
SOW073	SST	508 Conference	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.2
SOW120	SST	108	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.6
SOW170	SST	502 Workroom	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	3.2
SNL331	SST	509 Reception	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.5
SOV814	SST	509 Reception	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.2
Average Radon Concentration in:			509 Reception	2.3 pCi/L	
SNN813	SST	309	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	3.9
SNU462	SST	309	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.6
Average Radon Concentration in:			309	3.3 pCi/L	
SNL306	SST	609 Library Office	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.2
SNX062	SST	609 Library Office	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.2
Average Radon Concentration in:			609 Library Office	2.2 pCi/L	
SNL525	SST	409	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	1.7
SNT909	SST	409	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.2
Average Radon Concentration in:			409	1.9 pCi/L	
SNL588	SST	209	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	4.8
SNX176	SST	209	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.5
Average Radon Concentration in:			209	3.7 pCi/L	
SNU469	SST	107	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.4
SNU590	SST	107	19-Nov-2025 2:30 PM	24-Nov-2025 8:50 AM	2.6
Average Radon Concentration in:			107	2.5 pCi/L	

Deployed By: Sam Becker RNTST10096
Retrieved By: Sam Becker RNTST10096
Analyzed By: Sam Becker RNTST10096

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

December 17, 2025

Batch #: 121625-1

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
170 Abigail Avenue Bldg.- Van Allen
Elementary
North Liberty IA 52317

Reader S/N:	E1549	Reader Calibration Due: 10/24/2026
Conditions:	Requirements for Closed-Building Met	
Weather:	No Abnormal Weather Conditions	
Vents:	Open / Fan Auto	
Mitigation:	No System Installed	

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: _____ Date: _____