

Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample Results (in parts per billion)	Remediation Action - Required for any Outlet > 5.0 parts per billion	Resampling Dates - Required After Remediation Action	Passing/Clearance Results; must be ≤ 5.0 parts per billion	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
2025-SO-WS-1	Wm O'Schaefer	1	Kitchen - Triple Sink/Double Faucet - Faucet 1 (left when facing)	11/15/25	8.8	DO NOT DRINK signage displayed; Staff will be advised to use alternate means for cooking and/or drinking until further notice.	12/19/2025	10.7	No	Pending	Not Applicable
2025-SO-WS-2	Wm O'Schaefer	1	Kitchen - Triple Sink/Double Faucet - Faucet 2 (right when facing)	11/15/25	12	DO NOT DRINK signage displayed; Staff will be advised to use alternate means for cooking and/or drinking until further notice.	12/19/2025	17.6	No	Pending	Not Applicable
2025-SO-WS-3	Wm O'Schaefer	1	Small/Single Kitchen Handwashing Sink Faucet	11/15/25	5.1	DO NOT DRINK signage displayed; Staff will be advised to use alternate means for cooking and/or drinking until further notice.	12/19/2025	< 1.0	Yes	12/19/2025	Not Applicable
2025-SO-WS-4	Wm O'Schaefer	1	Hallway Across from Rooms 40/42 - Water Cooler (Combo Unit) - Mouth (left when facing)	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-5	Wm O'Schaefer	1	Hallway Across from Rooms 40/42 - Water Cooler (Combo Unit) - Bottle Filler (left when facing)	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-6	Wm O'Schaefer	1	Hallway Across from Rooms 40/42 - Water Cooler (Combo Unit) - Mouth (right when facing)	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-7	Wm O'Schaefer	1	Hallway Across from Rooms 40/42 - Water Cooler (Combo Unit) - Bottle Filler (right when facing)	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-8	Wm O'Schaefer	1	Classroom 44 Faucet	11/15/25	27.3	DO NOT DRINK signage displayed; Staff will be advised to use alternate means for cooking and/or drinking until further notice.	Not Required	Not Required	N/A	Not Required	Outlet re-designated as non-potable; Do not drink sign will remain permanently
2025-SO-WS-9	Wm O'Schaefer	1	Hallway by Room 57 - Water Cooler (Combo Unit) - Mouth (left when facing)	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-10	Wm O'Schaefer	1	Hallway by Room 57 - Water Cooler (Combo Unit) - Bottle Filler (left when facing)	11/15/25	< 1.0	Not Required	Not Required	< 1.0		11/15/25	Not Applicable
2025-SO-WS-11	Wm O'Schaefer	1	Hallway by Room 57 - Water Cooler (Combo Unit) - Mouth (right when facing)	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-12	Wm O'Schaefer	1	Hallway by Room 57 - Water Cooler (Combo Unit) - Bottle Filler (right when facing)	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable

2025-SO-WS-13	Wm O'Schaefer	1	Classroom 69 Faucet	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-14	Wm O'Schaefer	1	Classroom 71 Faucet	11/15/25	1.6	Not Required	Not Required	1.6	Yes	11/15/25	Not Applicable
2025-SO-WS-15	Wm O'Schaefer	1	Classroom 72 Faucet	11/15/25	2.2	Not Required	Not Required	2.2	Yes	11/15/25	Not Applicable
2025-SO-WS-16	Wm O'Schaefer	1	Outside Room 67 Boy's Bathroom - Water Cooler (Combo Unit) - Mouth	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-17	Wm O'Schaefer	1	Outside Room 67 Boy's Bathroom - Water Cooler (Combo Unit) - Bottle Filler	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-18	Wm O'Schaefer	1	Outside Room 67 Girl's Bathroom - Water Cooler (Combo Unit) - Mouth	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-19	Wm O'Schaefer	1	Outside Room 67 Girl's Bathroom - Water Cooler (Combo Unit) - Bottle Filler	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-20	Wm O'Schaefer	1	Classroom 101 Faucet	11/15/25	1.6	Not Required	Not Required	1.3	Yes	11/15/25	Not Applicable
2025-SO-WS-21	Wm O'Schaefer	1	Classroom 102 Faucet	11/15/25	1.4	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-22	Wm O'Schaefer	1	Classroom 103 Faucet	11/15/25	2.8	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-23	Wm O'Schaefer	1	Across from Library Between Rooms 6 & 16 - Water Cooler (Combo Unit) - Mouth (left when facing)	11/8/23	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-24	Wm O'Schaefer	1	Across from Library Between Rooms 6 & 16 - Water Cooler (Combo Unit) - Bottle Filler (left when facing)	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-25	Wm O'Schaefer	1	Across from Library Between Rooms 6 & 16 - Water Cooler (Combo Unit) - Mouth (right when facing)	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable

2025-SO-WS-26	Wm O'Schaefer	1	Across from Library Between Rooms 6 & 16 - Water Cooler (Combo Unit) - Bottle Filler (right when facing)	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable

Non Potable Outlets - these are outlets that were determined by the District to not be used for cooking or drinking by staff or students.

<i>Not Sampled</i>	Wm O'Schaefer	1	Gender Neutral Staff bathroom across from Room 103 - Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 105 (OT/PT Rm) Bathroom Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Coach Office (in Gym) Bathroom Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Boys Bathroom Outside Rooms 67/69 - Faucet 1 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Boys Bathroom Outside Rooms 67/69 - Faucet 2 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Girls Bathroom Outside Rooms 70/72 - Faucet 1 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Girls Bathroom Outside Rooms 70/72 - Faucet 2 (middle when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Girls Bathroom Outside Rooms 70/72 - Faucet 1 (right when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Student Enrichment (Room 20 B) (across hallway from Main Office) bathroom Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Outside Room 56 - Boy's Bathroom Faucet 1 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

Not Sampled	Wm O'Schaefer	1	Outside Room 56 - Boy's Bathroom Faucet 2 (right when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	1	Outside Rm 54 Girl's Bathroom Faucet 1 (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	1	Outside Rm 54 Girl's Bathroom Faucet 2 (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	1	Custodial Office Bathroom Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	1	Next to Room 40 Gender Neutral Bathroom Faucet 1 (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	1	Next to Room 40 Gender Neutral Bathroom Faucet 2 (right when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	1	Nurse's Office Bathroom Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	1	Custodial Closet by Room 60 Slop Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	1	Boys bathroom between Rooms 6 and 16 - Tempered Faucet to the left when facing	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	1	Boys bathroom between Rooms 6 and 16 - Tempered Faucet to the right when facing	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	1	Girls bathroom between Rooms 6 and 16 - Tempered Faucet to the left when facing	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	1	Girls bathroom between Rooms 6 and 16 - Tempered Faucet to the right when facing	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	1	Boiler Room Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.

Not Sampled	Wm O'Schaefer	1	Custodial Closet Across from Library- Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	Exterior	Exterior Hose Bib- Wall to left of Main Entrance	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	Exterior	Exterior Hose Bib- Wall to right of Main Entrance	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	Exterior	Exterior Hose Bib- by Staff Parking lot/South Playground	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	Exterior	Exterior Hose Bib- wall by South playground	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	Exterior	Exterior Hose Bib- Wall outside Room 68	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	Exterior	Exterior Hose Bib- Wall outside Room 100	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	1	Classroom 1 Tempered Faucet	Not Sampled	Not Sampled	Not Required	Not Required	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	1	Classroom 2 Tempered Faucet	Not Sampled	Not Sampled	Not Required	Not Required	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	1	Classroom 3 (Tech. Office) Tempered Faucet	Not Sampled	Not Sampled	Not Required	Not Required	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	1	Classroom 4 Tempered Faucet	Not Sampled	Not Sampled	Not Required	Not Required	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	1	Classroom 6 Tempered Faucet	Not Sampled	Not Sampled	Not Required	Not Required	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Wm O'Schaefer	1	Teacher's Lounge (Room 5) Tempered Faucet	Not Sampled	Not Sampled	Not Required	Not Required	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

