



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557858

LIMS Reference ID: ED57858

EMSL Customer ID: ROCL63

Attention: Dawn Izenman
Rockland Boces (Health & Safety Dept.) [ROCL63]
65 Parrott Road Bldg. 4
West Nyack, NY 10994
(845) 627-4764
dizenman@rboces.org

Project Name: 2025 South Orangetown, William O. Schaefer
Elementary School

Project ID: _Master Project-ROCL63

Customer PO: 26-00590

Sales Rep: Jeromy Bish

Received: 12/23/2025 10:07

Reported: 12/23/2025 16:18

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 2025-SO-WS-1/Kitchen - Triple Sink/Double Faucet - Faucet 1 (left when facing)									
			Lims Reference ID:		ED57858-01		Matrix: Drinking Water		Sampled: 12/19/25 06:36:00
Metals									
Lead	10.7		1	1.0	µg/L	12/23/25 15:26	12/23/25 15:26	BP	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-WS-2/Kitchen - Triple/Double Faucet - Faucet 2 (right when facing)									
			Lims Reference ID:		ED57858-02		Matrix: Drinking Water		Sampled: 12/19/25 06:37:00
Metals									
Lead	17.6		1	1.0	µg/L	12/23/25 15:30	12/23/25 15:30	BP	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-WS-3/Small/Single Kitchen Handwashing Sink Faucet									
			Lims Reference ID:		ED57858-03		Matrix: Drinking Water		Sampled: 12/19/25 06:38:00
Metals									
Lead	< 1.0		1	1.0	µg/L	12/23/25 15:31	12/23/25 15:31	BP	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557858

LIMS Reference ID: ED57858

EMSL Customer ID: ROCL63

Attention: Dawn Izenman
Rockland Boces (Health & Safety Dept.) [ROCL63]
65 Parrott Road Bldg. 4
West Nyack, NY 10994
(845) 627-4764
dizenman@rboces.org

Project Name: 2025 South Orangetown, William O. Schaefer
Elementary School

Project ID: _Master Project-ROCL63

Customer PO: 26-00590

Sales Rep: Jeromy Bish

Received: 12/23/2025 10:07

Reported: 12/23/2025 16:18

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557858

LIMS Reference ID: ED57858

EMSL Customer ID: ROCL63

Attention: Dawn Izenman
Rockland Boces (Health & Safety Dept.) [ROCL63]
65 Parrott Road Bldg. 4
West Nyack, NY 10994
(845) 627-4764
dizenman@rboces.org

Project Name: 2025 South Orangetown, William O. Schaefer
Elementary School
Project ID: _Master Project-ROCL63
Customer PO: 26-00590
Sales Rep: Jeromy Bish
Received: 12/23/2025 10:07
Reported: 12/23/2025 16:18

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

ED57858

Customer Information	Customer ID: ROCL63	Billing Information	Billing ID: ROCL63
	Company Name: William O. Schaefer Elementary School		Company Name: Rockland BOCES
	Contact Name: Dawn Izenman		Billing Contact: Dawn Izenman
	Street Address: 140 Lester Drive		Street Address: 65 Parrott Road
	City, State, Zip: Tappan, NY 10983 Country: USA		City, State, Zip: W. Nyack, NY 10994 Country: USA
	Phone: 845-627-4764		Phone: 845-627-4764
Email(s) for Report: dizenman@rboces.org	Email(s) for Invoice: dizenman@rboces.org		

Project Name/No: 2025 South Orangetown		Purchase Order: 26-00590
EMSL LIMS Project ID: (If applicable, EMSL will provide)	US State where samples collected: NY	State of Connecticut (CT) must select project location: <input type="checkbox"/> Commercial (Taxable) <input type="checkbox"/> Residential (Non-Taxable)
Sampled By Name: Dawn Izenman	Sampled By Signature:	No. of Samples in Shipment: 3

Turn-Around-Time (TAT)

3 Hour
 6 Hour
 24 Hour
 32 Hour
 48 Hour
 72 Hour
 96 Hour
 1 Week
 2 Week

Please call ahead for large projects and/or turnaround times 6 Hours or Less. *32 Hour TAT available for select tests only; samples must be submitted by 11:30am

MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
CHIPS <input type="checkbox"/> % by wt. <input type="checkbox"/> ppm (mg/kg) <input type="checkbox"/> mg/cm ² *Reporting Limit based on a minimum 0.25g sample weight. **Not appropriate for Ceramic Tiles - XRF is recommended	SW 846-7000B	Flame Atomic Absorption	0.008% (80ppm)	<input type="checkbox"/>
	SW 846-6010D*	ICP-OES	0.0004% (4ppm)	<input type="checkbox"/>
	NIOSH 7082	Flame Atomic Absorption	4µg/filter	<input type="checkbox"/>
AIR	NIOSH 7303M	ICP-OES	1.0µg/filter	<input type="checkbox"/>
	NIOSH 7303M	ICP-MS	0.05µg/filter	<input type="checkbox"/>
WIPE <input type="checkbox"/> ASTM <input type="checkbox"/> NON-ASTM *If no box is checked, non-ASTM Wipe is assumed	SW 846-7000B	Flame Atomic Absorption	10µg/wipe	<input type="checkbox"/>
	SW 846-6010D*	ICP-OES	1.0µg/wipe	<input type="checkbox"/>
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.2 mg/L (ppm)	<input type="checkbox"/>
	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
TTLC	22 CCR App. II, 7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>
	22 CCR App. II, SW 846-6010D*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
Soil	SW 846-7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>
	SW 846-6010D*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>
Wastewater	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
Unpreserved				<input type="checkbox"/>
Preserved with HNO3 <input type="checkbox"/> PH<2	EPA 200.7	ICP-OES	0.020 mg/L (ppm)	<input type="checkbox"/>
Drinking Water	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	<input type="checkbox"/>
Unpreserved <input type="checkbox"/>	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	<input type="checkbox"/>
Preserved with HNO3 <input checked="" type="checkbox"/> PH<2				<input checked="" type="checkbox"/>
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 µg/filter	<input type="checkbox"/>
Other:				<input type="checkbox"/>

AB 200.8 Billing 12/23/25

RECEIVED
EMSL ANALYTICAL, INC.
Cable Place, NY
DEC 25 AM 10:07

(Handwritten initials)

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
2025-SO-WS-1	Kitchen - Triple Sink/Double Faucet - Faucet 1 (left when facing)	250 ml.	12/19/25 6:36 am
2025-SO-WS-2	Kitchen - Triple Sink/Double Faucet - Faucet 2 (right when facing)	250 ml.	12/19/25 6:37 am
2025-SO-WS-3	Small/Single Kitchen Handwashing Sink Faucet	250 ml.	12/19/25 6:38 am

Method of Shipment:	Sample Condition Upon Receipt:
Relinquished by: Dawn Izenman	Received by: <i>(Signature)</i>
Date/Time: 12/19/25	Date/Time: 12/22/25
Relinquished by:	Received by: <i>(Signature)</i>
Date/Time:	Date/Time: 12/22/25