

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample Results in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Resampling Dates - Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (-) 5.0 PPB
2025-SO-CL-1	Cottage Lane ES	1	Classroom 410 Faucet	11/15/2025	1.1	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-2	Cottage Lane ES	1	Classroom 409 Faucet	11/21/2025	1.8	Not Required	Not Required	Not Required	Yes	11/21/2025	Not Applicable
2025-SO-CL-3	Cottage Lane ES	1	Classroom 408 Faucet	11/15/2025	2.3	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-4	Cottage Lane ES	1	Classroom 407 Faucet	11/15/2025	1.4	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-5	Cottage Lane ES	1	Classroom 406 Faucet	11/15/2025	1.2	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-6	Cottage Lane ES	1	Classroom 405 Faucet	11/15/2025	2	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-7	Cottage Lane ES	1	Hallway outside Classroom 400 - New Water Cooler (Combo Unit) - Mouth	11/15/2025	< 1.0	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-8	Cottage Lane ES	1	Hallway outside Classroom 400 - New Water Cooler (Combo Unit) - Bottle Filler	11/15/2025	< 1.0	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-9	Cottage Lane ES	1	Classroom 108 Faucet	11/15/2025	4.6	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-10	Cottage Lane ES	1	Classroom 109 Faucet	11/15/2025	12.3	See Last Column	Not Required	Not Required	No	N/A	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
2025-SO-CL-11	Cottage Lane ES	1	Classroom 110 Faucet	11/15/2025	3.2	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-12	Cottage Lane ES	1	Classroom 111 Faucet	11/15/2025	7.5	DO NOT DRINK signage displayed; Staff will be advised to use alternate means for cooking and/or drinking until further notice.	Not Required	Not Required	No	N/A	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
2025-SO-CL-13	Cottage Lane ES	1	Hallway outside Classroom 107 - Water Cooler (Combo Unit) - Mouth	11/15/2025	< 1.0	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-14	Cottage Lane ES	1	Hallway outside Classroom 107 - Water Cooler (Combo Unit) - Bottle Filler	11/15/2025	< 1.0	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-15	Cottage Lane ES	1	Kitchen - Single Faucet	11/15/2025	7.9	DO NOT DRINK signage displayed; Staff will be advised to use alternate means for cooking and/or drinking until further notice.	Not Required	Not Required	N/A	N/A	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
2025-SO-CL-16	Cottage Lane ES	1	Kitchen - Double Faucet Left (when facing) - Sink 1	11/15/2025	2.4	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample Results in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Resampling Dates - Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
2025-SO-CL-17	Cottage Lane ES	1	Cafeteria West Wall - Water Cooler (Combo Unit) - Mouth	11/15/2025	< 1.0	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-18	Cottage Lane ES	1	Cafeteria West Wall - Water Cooler (Combo Unit) - Bottle Filler	11/15/2025	< 1.0	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-19	Cottage Lane ES	1	Classroom 205 Faucet	11/15/2025	1.3	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-20	Cottage Lane ES	1	Classroom 208 Faucet	11/15/2025	12.7	<i>DO NOT DRINK signage displayed; Staff will be advised to use alternate means for cooking and/or drinking until further notice.</i>	Not Required	Not Required	No	N/A	<i>Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.</i>
2025-SO-CL-21	Cottage Lane ES	1	Hallway outside Classroom 300B - New Water Cooler (Combo Unit) - Mouth	11/15/2025	< 1.0	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-22	Cottage Lane ES	1	Hallway outside Classroom 300B - New Water Cooler (Combo Unit) - Bottle Filler	11/15/2025	< 1.0	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-23	Cottage Lane ES	1	Classroom 301 Faucet	11/15/2025	3.8	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-24	Cottage Lane ES	1	Classroom 303 Faucet	11/15/2025	4.8	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-25	Cottage Lane ES	1	Hallway outside Classroom 303 (by Girls Bathroom - New Water Cooler Combo Unit) - Mouth	11/15/2025	< 1.0	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-26	Cottage Lane ES	1	Hallway outside Classroom 303 (by Girls Bathroom - New Water Cooler Combo Unit) - Bottle Filler	11/15/2025	< 1.0	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-27	Cottage Lane ES	1	Hallway outside Classroom 303 (by Boys Bathroom - Water Cooler Combo Unit) - Mouth	11/15/2025	< 1.0	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-28	Cottage Lane ES	1	Hallway outside Classroom 303 (by Boys Bathroom - New Water Cooler Combo Unit) - Bottle Filler	11/15/2025	< 1.0	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-29	Cottage Lane ES	1	Classroom 305 Faucet	11/15/2025	8.6	<i>DO NOT DRINK signage displayed; Staff will be advised to use alternate means for cooking and/or drinking until further notice.</i>	Not Required	Not Required	No	N/A	<i>Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.</i>
2025-SO-CL-30	Cottage Lane ES	1	Classroom 306 Faucet	11/15/2025	9.8	<i>DO NOT DRINK signage displayed; Staff will be advised to use alternate means for cooking and/or drinking until further notice.</i>	Not Required	Not Required	No	N/A	<i>Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.</i>
2025-SO-CL-31	Cottage Lane ES	1	Classroom 307 Faucet	11/15/2025	79.9	<i>DO NOT DRINK signage displayed; Staff will be advised to use alternate means for cooking and/or drinking until further notice.</i>	Not Required	Not Required	No	N/A	<i>Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.</i>
2025-SO-CL-32	Cottage Lane ES	1	Classroom 308 Faucet	11/15/2025	4.6	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample Results in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Resampling Dates - Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (-) 5.0 PPB
2025-SO-CL-33	Cottage Lane ES	1	Classroom 309 Faucet	11/15/2025	34	DO NOT DRINK signage displayed; Staff will be advised to use alternate means for cooking and/or drinking until further notice.	Not Required	Not Required	No	N/A	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
2025-SO-CL-34	Cottage Lane ES	1	Classroom 310 Faucet	11/15/2025	6.5	DO NOT DRINK signage displayed; Staff will be advised to use alternate means for cooking and/or drinking until further notice.	Not Required	Not Required	No	N/A	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
2025-SO-CL-35	Cottage Lane ES	Modular	Modular Library - Upper Water Cooler Fountain (Left of Bottle Filler Unit)	11/15/2025	< 1.0	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-36	Cottage Lane ES	Modular	Modular Library - Water Cooler Fountain (Combo Unit) - Mouth	11/15/2025	< 1.0	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable
2025-SO-CL-37	Cottage Lane ES	Modular	Modular Library - Water Cooler Fountain - (Combo Unit) - Bottle Filler	11/15/2025	< 1.0	Not Required	Not Required	Not Required	Yes	11/15/2025	Not Applicable

**Non-Potable Outlets Below (these are outlets that were determined by the District to not be used for cooking or drinking by staff or students.)**

Not Sampled	Cottage Lane ES	1	Custodial Closet in 100s Wing - Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Custodial Closet Across from Room 206- Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Boiler Room Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Boys Bathroom across from classroom 400 left sink -Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Boys Bathroom across from classroom 400 middle sink -Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Boys Bathroom across from classroom 400 right sink- Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Gang Sink Boys Bathroom across from classroom 206 left tempered Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Gang Sink in Boys Bathroom across from classroom 206 middle tempered Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Gang Sink in Boys Bathroom across from classroom 206 right tempered Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Gang Sink in Girls Bathroom across from classroom 206 left tempered Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample Results (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Resampling Dates - Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (≥) 5.0 PPB
Not Sampled	Cottage Lane ES	1	Gang Sink in Girls Bathroom across from classroom 206 middle tempered Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Gang Sink in Girls Bathroom across from classroom 206 right tempered Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Girls Bathroom across from classroom 105 left sink tempered Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Girls Bathroom across from classroom 105 left sink tempered Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Girls Bathroom across from classroom 105 left sink tempered Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Boys Bathroom across from classroom 105 left sink tempered Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Boys Bathroom across from classroom 105 left sink tempered Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Boys Bathroom across from classroom 105 left sink tempered Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Room 101 G Bathroom Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Gender Neutral Bathroom Faucet across from classroom 205	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Nurses Office (Rm 201)- Bathroom Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Teachers Bathroom Faucet across from classroom 301	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Girls Bathroom outside of classroom 300B left sink (facing) Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Girls Bathroom outside of classroom 300B right sink (facing) Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Boys Bathroom outside of classroom 300B	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Girls Bathroom across from classroom 303 left (facing) sink Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample Results in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Resampling Dates - Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (≥) 5.0 PPB
Not Sampled	Cottage Lane ES	1	Girls Bathroom across from classroom 303 middle sink Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Girls Bathroom across from classroom 303 right sink Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Boys Bathroom across from classroom 303 left sink (facing) Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Boys Bathroom across from classroom 303 middle sink Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Boys Bathroom across from classroom 303 right sink Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Gender Neutral Bathroom Faucet Across from classroom 105	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Gender Neutral Bathroom Faucet Next to classroom 102C	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Girls Bathroom Across from classroom 400 left sink (facing) Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Girls Bathroom Across from classroom 400 middle sink Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Girls Bathroom Across from classroom 400 right sink Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	Modular	Modular Library- Bathroom Faucet (Left Facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	Modular	Modular Library- Bathroom Faucet (Right Facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	Exterior	Exterior Hose Bib - Outside Classroom 404/406	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	Exterior	Exterior Hose Bib - Outside Classroom 4407/409	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	Exterior	Exterior Hose Bib - Outside Classroom Classroom 202	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	Exterior	Exterior Hose Bib - Outside Classroom 207 Between G/B Bathrooms	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample Results in parts per billion	Remediation Action -- Required for any outlet > 5.0 parts per billion	Resampling Dates - Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (≥) 5.0 PPB
Not Sampled	Cottage Lane ES	Exterior	Exterior Hose Bib - Outside Classroom 309	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Classroom 411 Tempered Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Classroom 102A Bathroom Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Classroom 102B Bathroom Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Classroom 107 Tempered Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Room 101A (Book Room) Bathroom Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Kitchen-Double Faucet right (when facing) - Sink 2 - Chemical Hose Hooked Up	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Teacher's Lounge Tempered Faucet (Room 206)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Classroom 300C Tempered Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Classroom 301A Tempered Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Classroom 311 Tempered Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Classroom 312 Tempered Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Cottage Lane ES	1	Room 210 Hose Bib (in Classroom)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.