

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report South Orangetown Middle School

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample ults (in parts per billion)	Remediation Response -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Response	Passing/Clearance Results -- (in parts per billion; must must ≤ 5.0)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
2025-SO-MS-1	SO	SOMS	3	3rd Floor by Girls Bathroom (across from Library) Water Cooler Fountain (Combo Unit) - Mouth	12/6/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	12/6/2025	Not Applicable
2025-SO-MS-2	SO	SOMS	3	3rd Floor by Girls Bathroom (across from Library) Water Cooler Fountain (Combo Unit) - Bottle Filler	12/6/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	12/6/2025	Not Applicable
2025-SO-MS-3	SO	SOMS	2	2nd Floor Main Entrance Lobby Water Cooler Fountain (Combo Unit) - Mouth	12/6/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	12/6/2025	Not Applicable
2025-SO-MS-4	SO	SOMS	2	2nd Floor Main Entrance Lobby Water Cooler Fountain (Combo Unit) - Bottle Filler	12/6/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	12/6/2025	Not Applicable
2025-SO-MS-5	SO	SOMS	2	Room 226- Staff Lounge Sink Faucet	12/6/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	12/6/2025	Not Applicable
Out of Service	SO	SOMS	2	Hallway Next to Boys Room 234 Water Cooler (Combo Unit) - Mouth	Out of Service	Out of Service	Out of Service	Out of Service	Out of Service	Out of Service	Out of Service	Out of Service
Out of Service	SO	SOMS	2	Hallway Next to Boys Room 234 Water Cooler (Combo Unit) - Bottle Filler	Out of Service	Out of Service	Out of Service	Out of Service	Out of Service	Out of Service	Out of Service	Out of Service
2025-SO-MS-6	SO	SOMS	2	Hallway Next to Girls Room 236 Water Cooler (Combo Unit) - Mouth	12/6/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	12/6/2025	Not Applicable
Out of Service	SO	SOMS	2	Hallway Next to Girls Room 236 Water Cooler (Combo Unit) - Bottle Filler	Out of Service	Out of Service	Out of Service	Out of Service	Out of Service	Out of Service	Out of Service	Out of Service
2025-SO-MS-7	SO	SOMS	1	Outside Girls Locker Room Water Cooler (Combo Unit) - Mouth	12/6/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	12/6/2025	Not Applicable
2025-SO-MS-8	SO	SOMS	1	Outside Girls Locker Room Water Cooler Fountain (Combo Unit) - Bottle Filler	12/6/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	12/6/2025	Not Applicable

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report South Orangetown Middle School

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample ults (in parts per billion)	Remediation Response -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Response	Passing/Clearance Results -- (in parts per billion; must ≤ 5.0)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
2025-SO-MS-9	SO	SOMS	1	Boys Locker Room Water Cooler Fountain (Combo Unit) - Mouth	12/6/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	12/6/2025	Not Applicable
2025-SO-MS-10	SO	SOMS	1	Boys Locker Room Water Cooler Fountain (Combo Unit) -Bottle Filler	12/6/2025	< 1.0	Not Required	6/22/2021	< 1.0	Yes	12/6/2025	Not Applicable
2025-SO-MS-11	SO	SOMS	1	1ST Floor Classroom 179 (Home Ec) Sink (left when facing) Faucet 1	12/6/2025	< 1.0	Not Required	11/7/2023	< 1.0	Yes	12/6/2025	Not Applicable
2025-SO-MS-12	SO	SOMS	1	1st Floor Classroom 179 (Home Ec) Sink (middle when facing) Faucet 2	12/6/2025	< 1.0	Not Required	11/7/2023	< 1.0	Yes	12/6/2025	Not Applicable
2025-SO-MS-13	SO	SOMS	1	1st Floor Classroom 179 (Home Ec) Sink (right when facing) Faucet 3	12/6/2025	< 1.0	Not Required	11/7/2023	< 1.0	Yes	12/6/2025	Not Applicable
2025-SO-MS-14	SO	SOMS	1	Kitchen Ice Machine	12/6/2025	4.3	Not Required	Not Required	4.3	Yes	12/6/2025	Not Applicable
2025-SO-MS-15	SO	SOMS	1	Kitchen Island Single Sink Faucet	12/6/2025	1.1	Not Required	11/7/2023	1.1	Yes	12/6/2025	Not Applicable
2025-SO-MS-16	SO	SOMS	1	Kitchen Double Sink Faucet 2 (right when facing)	12/6/2025	3.4	Not Required	Not Required	3.4	Yes	12/6/2025	Not Applicable
2025-SO-MS-17	SO	SOMS	1	Kitchen Small Handwashing Sink Faucet (Near Server Line)	12/6/2025	5.4	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.	Not Required	Not Required	N/A	N/A	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Mouth Piece out of service and will be permanently removed.	SO	SOMS	1	Cafeteria Water Cooler (Combo Unit) - Mouth	12/6/2025	Out of Service	Out of Service	Out of Service	Out of Service	Out of Service	Out of Service	Out of Service
2025-SO-MS-18	SO	SOMS	1	Cafeteria Water Cooler (Combo Unit) - Bottle Filler	12/6/2025	3.0	Not Required	Not Required	3.0	Yes	12/6/2025	Not Applicable

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report South Orangetown Middle School

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample ults (in parts per billion)	Remediation Response -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Response	Passing/Clearance Results -- (in parts per billion; must ≤ 5.0)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
2025-SO-MS-19	SO	SOMS	1	Pool Locker Hallway Water Cooler Fountain (lower) Combo Unit- Mouth	12/6/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	12/6/2025	Not Applicable
2025-SO-MS-20	SO	SOMS	1	Pool Locker Hallway Water Cooler Fountain (lower) Combo Unit- Bottle	12/6/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	12/6/2025	Not Applicable
2025-SO-MS-21	SO	SOMS	1	Inside Pool Room Single Water Cooler Fountain (upper unit)	12/6/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	12/6/2025	Not Applicable
2025-SO-MS-22	SO	SOMS	1	Inside Pool Room Single Water Cooler Fountain (lower combo unit)- Mouth	12/6/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	12/6/2025	Not Applicable
2025-SO-MS-23	SO	SOMS	1	Inside Pool Room Single Water Cooler Fountain (lower combo unit)- Bottle Filler	12/6/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	12/6/2025	Not Applicable
2025-SO-MS-24	SO	SOMS	1	Band Room Sink Faucet	12/6/2025	5.3	<i>Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.</i>	Not Required	N/A	N/A	N/A	<i>Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.</i>
2025-SO-MS-25	SO	SOMS	1	Four Corners Hallway Water Cooler (Combo Unit) - Mouth	12/6/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	12/6/2025	Not Applicable
2025-SO-MS-26	SO	SOMS	1	Four Corners Hallway Water Cooler (Combo Unit) - Bottle Filler	12/6/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	12/6/2025	Not Applicable
2025-SO-MS-27	SO	SOMS	1	Hallway Next Boys Room/170 Water Cooler (Combo Unit) - Mouth	12/6/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	12/6/2025	Not Applicable
2025-SO-MS-28	SO	SOMS	1	Hallway Next Boys Room/170 Water Cooler (Combo Unit) - Bottle Filler	12/6/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	12/6/2025	Not Applicable
2025-SO-MS-29	SO	SOMS	1	Hallway Next Girls Room/172 Water Cooler (Combo Unit) - Mouth	12/6/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	12/6/2025	Not Applicable

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report South Orangetown Middle School

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample Results (in parts per billion)	Remediation Response -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Response	Passing/Clearance Results -- (in parts per billion; must $\leq$ 5.0)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
2025-SO-MS-30	SO	SOMS	1	Hallway Next Girls Room/172 Water Cooler (Combo Unit) - Bottle Filler	12/6/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	12/6/2025	Not Applicable

**Non-Potable Outlets Below - these are outlets that were determined by the District to not be used for cooking or drinking by staff or students.**

<i>Not Sampled</i>	SO	SOMS	3	3rd Floor Hallway by Staff/Gender Neutral-Bathroom Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
<i>Not Sampled</i>	SO	SOMS	3	3RD Floor Custodial/Roof Access Room - Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
<i>Not Sampled</i>	SO	SOMS	3	3RD Floor Classroom 309, Left to Right, Lab Sink 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
<i>Not Sampled</i>	SO	SOMS	3	3RD Floor Classroom 309, Left to Right, Lab Sink 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
<i>Not Sampled</i>	SO	SOMS	3	3RD Floor Classroom 309, Left to Right, Lab Sink 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
<i>Not Sampled</i>	SO	SOMS	3	3RD Floor Classroom 309, Left to Right, Lab Sink 4	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report South Orangetown Middle School

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample ults (in parts per billion)	Remediation Response -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Response	Passing/Clearance Results -- (in parts per billion; must ≤ 5.0)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
Not Sampled	SO	SOMS	3	3RD Floor Classroom 309, Left to Right, Lab Sink 5	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3RD Floor Classroom 309, Left to Right, Lab Sink 6	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3RD Floor Classroom 309, Left to Right, Lab Sink 7	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3RD Floor Classroom 309, Teachers Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3RD Floor Classroom 320, Left to Right, Lab Sink 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3RD Floor Classroom 320, Left to Right, Lab Sink 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3RD Floor Classroom 320, Left to Right, Lab Sink 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3RD Floor Classroom 320, Left to Right, Lab Sink 4	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report South Orangetown Middle School

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample ults (in parts per billion)	Remediation Response -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Response	Passing/Clearance Results -- (in parts per billion; must ≤ 5.0)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
Not Sampled	SO	SOMS	3	3RD Floor Classroom 320, Left to Right, Lab Sink 5	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3RD Floor Classroom 320, Left to Right, Lab Sink 6	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3RD Floor Classroom 320, Left to Right, Lab Hood Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3RD Floor Classroom 320, Teachers Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3RD Floor Classroom 324, Left to Right, Lab Sink 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3RD Floor Classroom 324, Left to Right, Lab Sink 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3RD Floor Classroom 324, Left to Right, Lab Sink 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3RD Floor Classroom 324, Left to Right, Lab Sink 4	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report South Orangetown Middle School

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample ults (in parts per billion)	Remediation Response -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Response	Passing/Clearance Results -- (in parts per billion; must ≤ 5.0)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
Not Sampled	SO	SOMS	3	3RD Floor Classroom 324, Left to Right, Lab Sink 5	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3RD Floor Classroom 324, Left to Right, Lab Sink 6	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3RD Floor Classroom 324, Left to Right, Lab Hood Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3RD Floor Classroom 324, Teachers Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3rd Floor Girls Bathroom Sink Tempered Faucet 1 (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3rd Floor Girls Bathroom Sink Tempered Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3rd Floor Girls Bathroom Sink Tempered Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3rd Floor Girls Bathroom Sink Tempered Faucet 4	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report South Orangetown Middle School

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample ults (in parts per billion)	Remediation Response -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Response	Passing/Clearance Results -- (in parts per billion; must ≤ 5.0)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
Not Sampled	SO	SOMS	3	3rd Floor Boys Bathroom Sink Tempered Faucet 1 (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3rd Floor Boys Bathroom Sink Tempered Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3rd Floor Boys Bathroom Sink Tempered Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	Library Makers Space Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	3	3rd Floor Boys Bathroom Sink Tempered Faucet 4	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2ND Floor Storage Room, Next to Admins Offices, Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2ND Floor, Classroom 220, Left to Right, Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2ND Floor, Classroom 220, Left to Right, Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report South Orangetown Middle School

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample ults (in parts per billion)	Remediation Response -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Response	Passing/Clearance Results -- (in parts per billion; must ≤ 5.0)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
Not Sampled	SO	SOMS	2	2ND Floor, Classroom 220, Left to Right, Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2ND Floor, Classroom 220, Left to Right, Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2ND Floor, Classroom 220, Lab Hood Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2ND Floor Gender Neutral Staff Bathroom (Across from Main Office) Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2nd Floor (in Adminstration Wing) Gender Neutral Bathroom (Staff) Sink Faucet (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2nd Floor Mens (in Adminstration Wing) Staff Gender Neutral Bathroom Sink Faucet (right when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2ND Floor, Classroom 222, Teachers Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2ND Floor, Classroom 222, Left to Right, Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report South Orangetown Middle School

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample ults (in parts per billion)	Remediation Response -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Response	Passing/Clearance Results -- (in parts per billion; must ≤ 5.0)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
Not Sampled	SO	SOMS	2	2ND Floor, Classroom 222, Left to Right, Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2ND Floor, Classroom 222, Left to Right, Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2ND Floor, Classroom 222, Left to Right, Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2ND Floor, Classroom 222, Left to Right, Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2ND Floor, Classroom 222, Left to Right, Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2ND Floor, Classroom 222, Lab Hood Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2ND Floor, Classroom 224, Teachers Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2ND Floor, Classroom 224, Left to Right, Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report South Orangetown Middle School

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample ults (in parts per billion)	Remediation Response -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Response	Passing/Clearance Results -- (in parts per billion; must ≤ 5.0)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
Not Sampled	SO	SOMS	2	2ND Floor, Classroom 224, Left to Right, Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2ND Floor, Classroom 224, Left to Right, Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2ND Floor, Classroom 224, Left to Right, Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2ND Floor, Classroom 224, Left to Right, Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	SOMS	2	2ND Floor, Classroom 224, Left to Right, Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	SOMS	2	2ND Floor, Classroom 224, Lab Hood Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	SOMS	2	2ND Floor Girls Bathroom (Next to Room 236) Sink Tempered Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	SOMS	2	2ND Floor Girls Bathroom (Next to Room 236) Sink Tempered Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	SOMS	2	2ND Floor Girls Bathroom (Next to Room 236) Sink Tempered Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	SOMS	2	2ND Floor Girls Bathroom (Next to Room 236) Sink Tempered Faucet 4	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report South Orangetown Middle School

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample ults (in parts per billion)	Remediation Response -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Response	Passing/Clearance Results -- (in parts per billion; must ≤ 5.0)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
Not Sampled	SO	SOMS	2	2ND Floor Boys Bathroom (Next to Room 234) Sink Tempered Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2ND Floor Boys Bathroom (Next to Room 234) Sink Tempered Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2ND Floor Boys Bathroom (Next to Room 234) Sink Tempered Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2ND Floor Boys Bathroom (Next to Room 234) Sink Tempered Faucet 4	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2nd Floor by Lobby (Next to Room 220) Boys Bathroom Sink Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2nd Floor by Lobby (Next to Room 220) Boys Bathroom Sink Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2nd Floor by Lobby (Next to Room 220) Boys Bathroom Sink Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2nd Floor by Lobby (Next to Room 220) Boys Bathroom Sink Faucet 4	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report South Orangetown Middle School

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample ults (in parts per billion)	Remediation Response -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Response	Passing/Clearance Results -- (in parts per billion; must ≤ 5.0)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
Not Sampled	SO	SOMS	2	2nd Floor by Lobby (Next to Room 220) Girls Bathroom Sink Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2nd Floor by Lobby (Next to Room 220) Girls Bathroom Sink Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2nd Floor by Lobby (Next to Room 220) Girls Bathroom Sink Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2nd Floor by Lobby (Next to Room 220) Girls Bathroom Sink Faucet 4	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	2	2nd Floor Custodial Room (across from Counseling Center) Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1ST Floor Corridor Boys Bathroom Sink (Between rooms 170-172) (Left when facing) Tempered Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1ST Floor Corridor Boys Bathroom Sink (Between rooms 170-172) Tempered Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1ST Floor Corridor Boys Bathroom Sink (Between rooms 170-172) Tempered Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report South Orangetown Middle School

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample ults (in parts per billion)	Remediation Response -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Response	Passing/Clearance Results -- (in parts per billion; must ≤ 5.0)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
Not Sampled	SO	SOMS	1	1ST Floor Corridor Boys Bathroom Sink (Between rooms 170-172) (right when facing) Tempered Faucet 4	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1ST Floor Corridor Boys Bathroom Sink (Between rooms 170-172) (Left when facing) Tempered Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1ST Floor Corridor Girls Bathroom Sink (Between rooms 170-172) Tempered Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1st Floor Corridor Girls Bathroom Sink (Between rooms 170-172) Tempered Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1st Floor Corridor Girls Bathroom Sink (Between rooms 170-172) Tempered Faucet 4	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1ST Floor Classroom 180 Window Wall Start, Right to Left, Lab Sink 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1ST Floor Classroom 180 Window Wall Start, Right to Left, Lab Sink 4	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1ST Floor Classroom 180 Window Wall Start, Right to Left, Lab Sink 5	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report South Orangetown Middle School

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample ults (in parts per billion)	Remediation Response -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Response	Passing/Clearance Results -- (in parts per billion; must ≤ 5.0)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
Not Sampled	SO	SOMS	1	1ST Floor Classroom 180 Window Wall Start, Right to Left, Lab Sink 6	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1ST Floor Classroom 180 Window Wall Start, Right to Left, Lab Sink 7	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1ST Floor Classroom 180, Lab Hood, Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1ST Floor By Boiler Room, Bathroom Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Boys Locker Room Temperered Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Girls Locker Room Temperered Sink Faucet 1 (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Girls Locker Room Temperered Sink Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1st Floor Nurses Office Small Bathroom Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report South Orangetown Middle School

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample ults (in parts per billion)	Remediation Response -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Response	Passing/Clearance Results -- (in parts per billion; must ≤ 5.0)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
Not Sampled	SO	SOMS	1	Nurse's Room Sink Faucet (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Nurse's Room Sink Faucet (middle when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Nurse's Room Sink Faucet (right when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1ST Floor Classroom 181 (Reading Room) Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1ST Floor (by Nurse Office/4 Corners) Boys Bathroom Sink (Left when facing) Tempered Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1ST Floor (by Nurse Office/4 Corners) Boys Bathroom Sink (Left when facing) Tempered Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1ST Floor (by Nurse Office/4 Corners) Boys Bathroom Sink (Left when facing) Tempered Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1ST Floor (by Nurse Office/4 Corners) Girls Bathroom Sink (Left when facing) Tempered Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report South Orangetown Middle School

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample ults (in parts per billion)	Remediation Response -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Response	Passing/Clearance Results -- (in parts per billion; must ≤ 5.0)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
Not Sampled	SO	SOMS	1	1st Floor (by Nurse Office/4 Corners) Girls Bathroom Sink (Left when facing) Tempered Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1st Floor (by Nurse Office/4 Corners) Girls Bathroom Sink (Left when facing) Tempered Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1st Floor (by Nurse Office/4 Corners) Girls Bathroom Sink (Left when facing) Tempered Faucet 4	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1st Floor Classroom 183 (Art Room) Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1st Floor Classroom 187 (Art Room) Sink (closest to door) Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1st Floor Classroom 187 (Art Room) Sink (closest to door) Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1st Floor Classroom 189 (Art Room) Sink (closest to phone) Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1st Floor Classroom 189 (Art Room) Sink (closest to door) Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report South Orangetown Middle School

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample ults (in parts per billion)	Remediation Response -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Response	Passing/Clearance Results -- (in parts per billion; must ≤ 5.0)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
Not Sampled	SO	SOMS	1	Girls Athletic Office Bathroom Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Boys Pool Locker Rooms Bathroom Single Sink (left when facing) Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Boys Pool Locker Rooms Bathroom Single Sink (middle) Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Boys Pool Locker Rooms Bathroom Single Sink (right when facing) Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Pool Gender Neutral Bathroom Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Pool Area Custodial Room Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Girls Pool Locker Rooms Bathroom Single Sink (left when facing) Tempered Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Girls Pool Locker Rooms Bathroom Single Sink (middle) Tempered Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report South Orangetown Middle School

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample ults (in parts per billion)	Remediation Response -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Response	Passing/Clearance Results -- (in parts per billion; must ≤ 5.0)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
Not Sampled	SO	SOMS	1	Girls Pool Locker Rooms Bathroom Single Sink (right when facing) Tempered Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Boys Gym Locker Room Bathroom Sink (left when facing)Tempered Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Boys Gym Locker Room Bathroom Sink (left when facing) Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Bathroom Sink (left when facing) in Girls Locker Room (by Gym) Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Bathroom Sink (left when facing) in Girls Locker Room (by Gym) Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Bathroom Sink (left when facing) in Girls Locker Room (by Gym) Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1st Floor - Bathroom Sink Faucet by Custodial Break Room	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	All Eyewash Stations in School	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report South Orangetown Middle School

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample ults (in parts per billion)	Remediation Response -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Response	Passing/Clearance Results -- (in parts per billion; must ≤ 5.0)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
Not Sampled	SO	SOMS	1	All Showers in Girls Locker Rooms	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	All Showers in Boys Locker Rooms	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Kitchen Double Sink Faucet 1 (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Kitchen Single Sink- Dishwasher Sprayer	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled **Added to List	SO	SOMS	1	Cafeteria Sink for Recyclable Bottles	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Orchestra Room Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	1ST Floor Classroom 175 Sink (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Room 153 (Shop) Single Sink (east wall ) Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report South Orangetown Middle School

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample ults (in parts per billion)	Remediation Response -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Response	Passing/Clearance Results -- (in parts per billion; must ≤ 5.0)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
Not Sampled	SO	SOMS	1	Room 153 (Shop) Single Sink (west wall) Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Classroom 151 (Shop) Single Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Exterior Hose Bib- Wall by Loading Dock	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Exterior Hose Bib- Wall by Kitchen Door	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Exterior Hose Bib- Wall by Loading Dock	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Exterior Hose Bib- Wall by Loading Dock	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Exterior Hose Bib- Wall by Loading Dock	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.
Not Sampled	SO	SOMS	1	Exterior Hose Bib- Wall by Loading Dock	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report South Orangetown Middle School

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample ults (in parts per billion)	Remediation Response -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Response	Passing/Clearance Results -- (in parts per billion; must ≤ 5.0)	Is Outlet in Compliance?	Passing/Clearance Date	Remediation Steps for any outlet sampled and found to be greater than (>) 5.0 PPB
Not Sampled	SO	SOMS	1	Exterior Hose Bib- Wall by Loading Dock	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Outlet classified as "non potable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet. Faucet will only be used for handwashing.