

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report Tappan Zee High School

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Sampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
2025-SO-HS-1	Tappan Zee High School	1	Library Office Sink Faucet	11/22/2025	4.7	Not Required	Not Required	4.7	Yes	11/22/2025	Not Applicable
2025-SO-HS-2	Tappan Zee High School	1	300's Wing Hallway - Water Cooler Fountain (Combo Unit) - Mouth	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	Not Applicable
2025-SO-HS-3	Tappan Zee High School	1	300's Wing Hallway - Water Cooler Fountain (Combo Unit) - Bottle Filler	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	Not Applicable
2025-SO-HS-4	Tappan Zee High School	1	Teacher's Lounge Room 304	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	Not Applicable
2025-SO-HS-5	Tappan Zee High School	1	400's Wing Hallway - Water Cooler Fountain (Combo Unit) - Mouth	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	Not Applicable
2025-SO-HS-6	Tappan Zee High School	1	400's Wing Hallway - Water Cooler Fountain (Combo Unit) - Bottle Filler	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	Not Applicable
2025-SO-HS-7	Tappan Zee High School	1	500's Wing Hallway - Water Cooler Fountain (Combo Unit) - Mouth	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	Not Applicable
2025-SO-HS-8	Tappan Zee High School	1	500's Wing Hallway - Water Cooler Fountain (Combo Unit) - Bottle Filler	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	Not Applicable
2025-SO-HS-9	Tappan Zee High School	1	500's Wing Hallway Water Cooler Fountain next to Gender Neutral Bathroom & Elevator (Combo Unit) - Mouth	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	Not Applicable
2025-SO-HS-10	Tappan Zee High School	1	500's Wing Hallway Water Cooler Fountain next to Gender Neutral Bathroom & Elevator (Combo Unit) - Bottle Filler	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	Not Applicable
2025-SO-HS-11	Tappan Zee High School	1	Main Office Hallway across from SRO office / 600's Wing - Water Cooler Fountain (Combo Unit) - Mouth	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	Not Applicable
2025-SO-HS-12	Tappan Zee High School	1	Main Office Hallway across from SRO office / 600's Wing - Water Cooler Fountain (Combo Unit) - Bottle Filler	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	Not Applicable
2025-SO-HS-13	Tappan Zee High School	1	1ST Floor C-13 - School Store Kitchen Faucet	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	Not Applicable

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report Tappan Zee High School

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Sampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
2025-SO-HS-14	Tappan Zee High School	1	Classroom 950 (Testing Room) Sink Faucet	11/22/2025	4.4	Not Required	Not Required	4.4	Yes	11/22/2025	Not Applicable
2025-SO-HS-15	Tappan Zee High School	1	Auditorium Hallway - Water Cooler Fountain (Combo Unit) - Mouth	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	Not Applicable
2025-SO-HS-16	Tappan Zee High School	1	Auditorium Hallway - Water Cooler Fountain (Combo Unit) - Bottle Filler	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	Not Applicable
2025-SO-HS-17	Tappan Zee High School	1	Kitchen Prep Double Sink Faucet 1 (by Refrigerator Wall & Eyewash - Left When Facing)	11/22/2025	5.4	DO NOT DRINK signage displayed; Staff will be advised to use alternate means for cooking and/or drinking until further notice.	12/19/2025	2.1	Yes	12/19/2025	Not Applicable
2025-SO-HS-18	Tappan Zee High School	1	Kitchen Prep Double Sink Faucet 2 (by Refrigerator Wall & Eyewash - Right When Facing)	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	Not Applicable
2025-SO-HS-19	Tappan Zee High School	1	Kitchen Single Hand Washing (White) Sink Faucet	11/22/2025	2.5	Not Required	Not Required	2.5	Yes	11/22/2025	Not Applicable
2025-SO-HS-20	Tappan Zee High School	1	Kitchen Single Sink Faucet (by Window Wall)	11/22/2025	2	Not Required	Not Required	2	Yes	11/22/2025	Not Applicable
2025-SO-HS-21	Tappan Zee High School	1	Kitchen Double Sink (by Window Wall & Detergent Dispensers) Faucet 2 (Right When Facing)	11/22/2025	3	Not Required	Not Required	3	Yes	11/22/2025	Not Applicable
2025-SO-HS-22	Tappan Zee High School	1	Kitchen Island Sink by Stove	11/22/2025	7	DO NOT DRINK signage displayed; Staff will be advised to use alternate means for cooking and/or drinking until further notice.	12/19/2025	4.4	Yes	12/19/2025	Not Applicable
2025-SO-HS-23	Tappan Zee High School	1	Kitchen Ice Machine	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	Not Applicable
2025-SO-HS-24	Tappan Zee High School	1	Kitchen Sink Faucet by Pizza Serving Line	11/22/2025	9.0	DO NOT DRINK signage displayed; Staff will be advised to use alternate means for cooking and/or drinking until further notice.	12/19/2025	4.6	Yes	12/19/2025	Not Applicable
2025-SO-HS-25	Tappan Zee High School	1	Kitchen Sink Faucet by Deli Serving Line	11/22/2025	3.7	Not Required	Not Required	3.7	Yes	11/22/2025	Not Applicable
2025-SO-HS-33	Tappan Zee High School	L	Boy's Locker Room Ice Machine	12/19/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	12/19/2025	Not Applicable

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report Tappan Zee High School

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Sampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	Tappan Zee High School	1	200's Wing Hallway Men's Bathroom Sink Faucet (right when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable
Not Sampled	Tappan Zee High School	1	400'S Wing Faculty Men's Bathroom Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable
Not Sampled	Tappan Zee High School	1	400'S Wing Faculty Women's Bathroom Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable
Not Sampled	Tappan Zee High School	1	500's Wing Hallway Sink Faucet in Women's Staff Bathroom	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable
Not Sampled	Tappan Zee High School	1	C-Wing Boys Bathroom Sink Faucet 2 (right when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable
Not Sampled	Tappan Zee High School	1	Main Office South Bathroom Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable
Not Sampled	Tappan Zee High School	1	Main Office North Bathroom Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable
Not Sampled	Tappan Zee High School	1	Guidance Office Bathroom Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable
Not Sampled	Tappan Zee High School	1	Kitchen Ladies Room Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable
Not Sampled	Tappan Zee High School	1	Girl's Locker Room Athletic Office Bathroom Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable
Not Sampled	Tappan Zee High School	1	1ST Floor Room C8- Lab Tables by Window-Front- Back Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room C8- Lab Tables by Window-Middle- Front Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room C8- Lab Tables by Window-Middle- Back Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room C8- Lab Tables- Middle Front - Front Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report Tappan Zee High School

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Sampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	Tappan Zee High School	1	1ST Floor Room C8- Lab Tables- Middle Front - Back Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room C8- Lab Tables- Middle Back - Front Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room C8- Lab Tables- Middle Back - Back Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room C8- Lab Tables- Hallway Front - Front Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room C8- Lab Tables- Hallway Front - Back Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room C8- Lab Tables- Hallway Back - Front Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room C8- Lab Tables- Hallway Back - Back Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room C8- Lab Sink- Back Wall	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room C8- Fume Hood Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 316-Lab Sink (Teachers Desk)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 316- Fume Hood Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 316- Lab Sink RT Window Side	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 316- Lab Sink LT Window Side	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 316- Lab Sink RT Back Wall Side	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report Tappan Zee High School

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Sampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	Tappan Zee High School	1	1ST Floor Room 316- Lab Sink LT Back Wall Side	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 316- Lab Sink RT Hallway Wall Side	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 316- Lab Sink LT Hallway Wall Side	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 320-Lab Sink (Teachers Desk)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 320-Lab Sink, RT Wall - Sink by Door	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 320-Lab Sink, RT Wall - Middle Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 320-Lab Sink, RT Wall - Sink by Window	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 320-Lab Sink, LT Wall - Sink by Window	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 320-Lab Sink, LT Wall - Middle Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 320-Lab Sink, LT Wall - Sink by Door	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 324-Lab Table- Teachers Desk - Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 324-Lab Table-Left Wall Front Desk- LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 324-Lab Table-Left Wall Front Desk- RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 324-Lab Table-Left Wall Back Desk- LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report Tappan Zee High School

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Sampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	Tappan Zee High School	1	1ST Floor Room 324-Lab Table-Left Wall Back Desk- RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 324-Lab Table-Middle Front Desk- LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 324-Lab Table-Middle Front Desk- RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 324-Lab Table-Middle Back Desk- LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 324-Lab Table-Middle Back Desk- RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 324-Lab Table-Right Wall Front Desk- LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 324-Lab Table-Right Wall Front Desk- RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 324-Lab Table-Right Wall Back Desk- LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 324-Lab Table-Right Wall Back Desk- RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 324- Fume Hood Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 325- Middle Island- Lab Sink by Door	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 325- Middle Island- Lab Sink by Window	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 325- Lab Sink by Hallway Wall	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 325- Lab Sink by Window	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report Tappan Zee High School

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Sampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	Tappan Zee High School	1	Classroom 702 (Art Room) Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Classroom 704 (Art Storage) Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 705 (Art Room)- Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Classroom (Science Room) 706 Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Classroom (Science Room) 706 Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 706 (Art Room)- Sink by Door-Faucet by Eye Wash	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 706- (Art Room) Sink away from Door- Faucet by Eye Wash Station	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 706 (Art Room)- Sink away from Door- Middle Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 706 (Art Room)- Sink away from Door-Faucet by Hallway Side	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Classroom 707 (Art Room) Sink Faucet 1 (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Classroom 707 (Art Room) Sink Faucet 2 (right when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 712 (Art Room)- Sink by Door- LT Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 712 (Art Room)- Sink by Door- Middle Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 712 (Art Room)- Sink by Door- RT Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report Tappan Zee High School

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Sampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	Tappan Zee High School	1	1ST Floor Room 712 (Art Room) - Sink away from Door- LT Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 712 Art Room)- Sink away from Door- Middle Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 712 (Art Room)- Sink away from Door- RT Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 707 (Art Room)- Sink Faucet RT Door Side	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 707 (Art Room)- Sink Faucet LT Window Side	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 800-Teachers Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 800-Lab Sink- LT Front Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 800-Lab Sink- LT Front Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 800-Lab Sink- LT Back Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 800-Lab Sink- LT Back Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 800-Lab Sinks- Middle Front Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 800-Lab Sinks- Middle Front Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 800-Lab Sinks- Middle Back Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 800-Lab Sinks- Middle Back Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report Tappan Zee High School

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Sampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	Tappan Zee High School	1	1ST Floor Room 800-Lab Sink- RT Front Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 800-Lab Sink- RT Front Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 800-Lab Sink- RT Back Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 800-Lab Sink- RT Back Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 800- Fume Hood Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 801-Teachers Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 801-Lab Sinks- LT Front Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 801-Lab Sinks- LT Front Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 801-Lab Sinks- LT Back Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 801-Lab Sinks- LT Back Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 801-Lab Sinks- Middle Front Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 801-Lab Sinks- Middle Front Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 801-Lab Sinks- Middle Back Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 801-Lab Sinks- Middle Back Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report Tappan Zee High School

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Sampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	Tappan Zee High School	1	1ST Floor Room 801-Lab Sinks- RT Front Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 801-Lab Sinks- RT Front Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 801-Lab Sinks- RT Back Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 801-Lab Sinks- RT Back Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 801-Fume Hood Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 806-Teachers Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 806-Lab Sinks- LT Front Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 806-Lab Sinks- LT Front Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 806-Lab Sink- LT Back Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 806-Lab Sink- LT Back Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 806-Lab Sinks- Middle Front Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 806-Lab Sinks- Middle Front Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 806-Lab Sinks- Middle Back Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 806-Lab Sink- Middle Back Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report Tappan Zee High School

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Sampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	Tappan Zee High School	1	1ST Floor Room 806-Lab Sinks- RT Front Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 806-Lab Sinks- RT Front Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 806-Lab Sinks- RT Back Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 806-Lab Sinks- RT Back Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 806- Fume Hood Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 808-Teachers Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 808-Lab Sinks- LT Front Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 808-Lab Sinks- LT Front Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 808-Lab Sinks- LT Back Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 808-Lab Sinks- LT Back Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 808-Lab Sinks- Middle Front Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 808-Lab Sinks- Middle Front Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 808-Lab Sinks- Middle Back Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 808-Lab Sinks- Middle Back Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report Tappan Zee High School

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Sampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	Tappan Zee High School	1	1ST Floor Room 808-Lab Sinks- RT Front Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 808-Lab Sinks- RT Front Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 808-Lab Sinks- RT Back Desk-LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 808-Lab Sinks- RT Back Desk-RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 808- Fume Hood Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 807/809- Lab Sink- RT Back Desk - LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 807/809- Lab Sink- RT Back Desk - RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 807/809- Lab Sink- Middle Front Desk - LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 807/809- Lab Sink- Middle Front Desk - RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 807/809- Lab Sink- Middle Back Desk - LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 807/809- Lab Sink- Middle Back Desk - RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 807/809- Lab Sink- LT Front Desk - LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 807/809- Lab Sink- LT Front Desk - RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 807/809- Lab Sink- LT Back Desk - LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report Tappan Zee High School

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Sampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	Tappan Zee High School	1	1ST Floor Room 807/809- Lab Sink- LT Back Desk - RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 807/809-Lab Sink Fume Hood	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 816- Lab Sink- Middle Back Desk - LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 816- Lab Sink- Middle Back Desk - RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 816- Lab Sink- RT Front Desk - LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 816- Lab Sink- RT Front Desk - RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 816- Lab Sink RT Back Desk - LT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 816- Lab Sink- RT Back Desk - RT	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 816- Fume Hood Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 810 Lab Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 813- Teachers Lab Desk Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 813- Lab Tables, Hallway Side Front- Front Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 813- Lab Tables, Hallway Side Front- Back Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 813- Lab Tables, Hallway Side Middle- Front Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report Tappan Zee High School

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Sampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	Tappan Zee High School	1	1ST Floor Room 813- Lab Tables, Hallway Side Middle- Back Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 813- Lab Tables, Hallway Side - Back- Front Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 813- Lab Tables, Hallway Side - Back- Back Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 813- Lab Tables, Window Side - Front- Front Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 813- Lab Tables, Window Side - Front- Back Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 813- Lab Tables, Window Side - Middle- Front Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 813- Lab Tables, Window Side - Middle- Back Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 813- Lab Tables, Window Side - Back- Front Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 813- Lab Tables, Window Side - Back- Back Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	1ST Floor Room 813- Fume Hood Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Maintenance Garage (Next to Plow Garage) - Bathroom Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Maintenance Garage (Next to Plow Garage) - Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	Maintenance/Plow Garage- Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	100's Wing - Records/BOCES Room- Bathroom Sink Tempered Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report Tappan Zee High School

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Sampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	Tappan Zee High School	L	Boiler Room Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	100's Hallway Custodial Closet Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	Gymnasium/Hall of Fame Lobby - Girl's Bathroom Sink Tempered Faucet 1 (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	Gymnasium/Hall of Fame Lobby - Girl's Bathroom Sink Tempered Faucet 2 (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	Gymnasium/Hall of Fame Lobby - Girl's Bathroom Sink Tempered Faucet 3 (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	Gymnasium/Hall of Fame Lobby - Boy's Bathroom Sink Tempered Faucet 1 (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	Gymnasium/Hall of Fame Lobby- Boy's Bathroom Sink Tempered Faucet 2 (middle when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	Gymnasium/Hall of Fame Lobby - Boy's Bathroom Sink Tempered Faucet 3 (right when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	Gymnasium/Hall of Fame Lobby Custodial Closet Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	Boy's Locker Room Bathroom Gang Sink Tempered Faucet 1 (Left When facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	Boy's Locker Room Bathroom Gang Sink Tempered Faucet 2 (Middle When facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	Boy's Locker Room Bathroom Gang Sink Tempered Faucet 1 (Right When facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	Girl's Locker Room Bubbler Water Fountain	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	Girl's Locker Room Bathroom Gang Sink Tempered Faucet 1 (Left When facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report Tappan Zee High School

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Sampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	Tappan Zee High School	L	Girl's Locker Room Bathroom Gang Sink Tempered Faucet 2 (Left When facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	Girl's Locker Room Bathroom Gang Sink Tempered Faucet 3 (Left When facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	Boy's and Girl's Locker Rooms -- All Showers	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Girl's Locker Room Gender Neutral Bathroom Sink Tempered Faucet 1 (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Girl's Locker Room Gender Neutral Bathroom Sink Tempered Faucet 2 (middle when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Girl's Locker Room Gender Neutral Bathroom Sink Tempered Faucet 3 (right when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Kitchen Custodial Room Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Auditorium Hallway Boys Bathroom Tempered Faucet 1 (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Auditorium Hallway Boys Bathroom Tempered Faucet 2 (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Auditorium Hallway Boys Bathroom Tempered Faucet 3 (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Auditorium Hallway Girls Bathroom Tempered Faucet 1 (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Auditorium Hallway Girls Bathroom Tempered Faucet 2 (middle when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Auditorium Hallway Girls Bathroom Tempered Faucet 3 (right when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Main Office 1 Water Cooler Fountain (Permanently Removed From Service)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report Tappan Zee High School

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Sampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	Tappan Zee High School	1	Classroom 712 (Science) Sink 1 Tall Faucets B (right facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Classroom 712 (Science) Sink 2 Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Classroom 712 (Science) Sink 2 Tall Faucet A (left facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Classroom 712 (Science) Sink 2 Tall Faucet A (left facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Classroom 712 Sink 3 Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Classroom 712 Sink 3 Tall Faucet A (left facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Classroom 712 Sink 3 Tall Faucet B (left facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Classroom 712 Sink 4 Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Classroom 712 Sink 4 Tall Faucet A (left facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Classroom 712 Sink 4 Tall Faucet B (left facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Classroom 706 (BOCES/Science) Sink Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Classroom 706 (BOCES/Science) Sink Tall Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	700's Hallway Boys Bathroom Tempered Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	700's Hallway Boys Bathroom Tempered Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report Tappan Zee High School

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Sampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	Tappan Zee High School	1	700's Hallway Boys Bathroom Tempered Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	700's Hallway Boys Bathroom Tempered Faucet 4	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	700's Hallway Boys Bathroom Tempered Faucet 5	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	700's Hallway Boys Bathroom Tempered Faucet 6	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	700's Hallway Girls Bathroom Tempered Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	700's Hallway Girls Bathroom Tempered Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	700's Hallway Girls Bathroom Tempered Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	700's Hallway Girls Bathroom Tempered Faucet 4	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	700's Hallway Girls Bathroom Tempered Faucet 5	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	700's Hallway Girls Bathroom Tempered Faucet 6	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Nurse's Bathroom 1 Bathroom Sink Tempered Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	500's Hallway ADA/Boys Bathroom Sink Tempered Faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	500's Hallway ADA/Boys Bathroom Sink Tempered Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	500's Hallway ADA/Boys Bathroom Sink Tempered Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report Tappan Zee High School

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Sampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	Tappan Zee High School	1	500's Hallway ADA/Boys Bathroom Sink Tempered Faucet 4	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	500's Hallway Custodial Room Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	500's Hallway Gender Neutral Bathroom Sink Tempered Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	600's Hallway Girl's Bathroom Sink Tempered faucet 1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	600's Hallway Girl's Bathroom Sink Tempered faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	600's Hallway Girl's Bathroom Sink Tempered faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	300's Hallway Girls Gang Bathroom Sink Tempered Faucet 1 (left most when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	300's Hallway Girls Gang Bathroom Sink Tempered Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	300's Hallway Girls Gang Bathroom Sink Tempered Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	300's Hallway Girls Gang Bathroom Sink Tempered Faucet 4	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	300's Hallway Girls Gang Bathroom Sink Tempered Faucet 5	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	300's Hallway Girls Gang Bathroom Sink Tempered Faucet 6	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	300's Hallway Boys Gang Bathroom Custodial Closet Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	300's Hallway Boys Gang Bathroom Sink Tempered Faucet 1 (left most when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report Tappan Zee High School

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Sampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	Tappan Zee High School	1	300's Hallway Boys Gang Bathroom Sink Tempered Faucet 2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	300's Hallway Boys Gang Bathroom Sink Tempered Faucet 3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	300's Hallway Boys Gang Bathroom Sink Tempered Faucet 4	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	300's Hallway Boys Gang Bathroom Sink Tempered Faucet 5	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	300's Hallway Boys Gang Bathroom Sink Tempered Faucet 6	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	200's Hallway Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	100's Wing - Records/BOCES Room-Bathroom Sink Tempered Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	All Eyewash Stations in the School	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	Exterior	Fieldhouse/Snackbar (by Football Field) Men's Bathroom Sink Faucet 1 (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	Exterior	Fieldhouse/Snackbar (by Football Field) Men's Bathroom Sink Faucet 2 (right when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	Exterior	Fieldhouse/Snackbar (by Football Field) Women's Bathroom Sink Faucet 1 (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	Exterior	Fieldhouse/Snackbar (by Football Field) Women's Bathroom Sink Faucet 2 (right when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	Exterior	Outside Room 419- Exterior Hose Bib	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	Exterior	Outside Room 411- Exterior Hose Bib	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report Tappan Zee High School

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Sampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	Tappan Zee High School	Exterior	Outside Room 401- Exterior Hose Bib	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	Exterior	Outside Room 607- Exterior Hose Bib	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	Exterior	Outside Room Auditorium Entrance- Exterior Hose Bib	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	Exterior	West Wall Outside by Stage- Exterior Hose Bib	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	Exterior	Outside Loading Dock by Stairs- Exterior Hose Bib	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	Exterior	Directly Outside Kitchen - South Wall - Exterior Hose Bib	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	Exterior	Outside Kitchen West- Exterior Hose Bib	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	Exterior	Outside Kitchen East- Exterior Hose Bib	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	Exterior	In Courtyard by Teacher's Lounge- Exterior Hose Bib	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	Exterior	In Courtyard by Cafeteria East- Exterior Hose Bib	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	Exterior	Outside Room Boys Locker Room- Exterior Hose Bib	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	Exterior	Outside Courtyard by Library- Exterior Hose Bib	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Nurse's Office Main Room Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Nurse's Office Recovery Room (with Curtain) Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.

South Orangetown CSD 2020-21 Lead in Water Testing Results and Compliance Report Tappan Zee High School

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Sampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	Tappan Zee High School	1	Nurse's Office Recovery Room (without Curtain) Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Classroom 951 (Music Room) Sink Faucet 2 (Right When Facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	1	Kitchen Double Sink (by Window Wall & Detergent Dispensers) Faucet 1 (Left When Facing)- Dishwasher Sprayer	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	Boy's Physical Education Office (Next to Main Gym) Bathroom Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	Classroom 118 (Art Room) Triple Sink-Faucet 1 (left when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	Classroom 118 (Art Room) Triple Sink-Faucet 2 (middle when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	Classroom 118 (Art Room) Triple Sink-Faucet 3 (right when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.