



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557425

LIMS Reference ID: ED57425

EMSL Customer ID: ROCL63

Attention: Dawn Izenman
Rockland Boces (Health & Safety Dept.) [ROCL63]
65 Parrott Road Bldg. 4
West Nyack, NY 10994
(845) 627-4764
dizenman@rboces.org

Project Name: 2025 South Orangetown, Tappan Zee High School
Project ID: _Master Project-ROCL63
Customer PO: 26-00590
Sales Rep: Jeromy Bish
Received: 11/26/2025 09:15
Reported: 12/03/2025 16:52

Analytical Results

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: 2025-SO-HS-1/Library Office Sink Faucet Lims Reference ID: ED57425-01 Matrix: Drinking Water Sampled: 11/22/25 00:00:00

Metals

Lead 4.7 1 1.0 µg/L 12/01/25 16:22 12/01/25 16:22 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: 2025-SO-HS-2/300's Wing Hallway - Water Cooler Fountain (Combo Unit) - Mouth Lims Reference ID: ED57425-02 Matrix: Drinking Water Sampled: 11/22/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 12/01/25 16:24 12/01/25 16:24 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: 2025-SO-HS-3/300"s Wing Hallway - Water Cooler Fountain (Combo Unit) - Bottle Filler Lims Reference ID: ED57425-03 Matrix: Drinking Water Sampled: 11/22/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 12/01/25 16:28 12/01/25 16:28 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: 2025-SO-HS-4/Teacher's Lounge Room 304 Lims Reference ID: ED57425-04 Matrix: Drinking Water Sampled: 11/22/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 12/01/25 16:29 12/01/25 16:29 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: 2025-SO-HS-5/400's Wing Hallway - Water Cooler Fountain (Combo Unit) - Mouth Lims Reference ID: ED57425-05 Matrix: Drinking Water Sampled: 11/22/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 12/01/25 16:30 12/01/25 16:30 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: 2025-SO-HS-6/400's Wing Hallway - Water Cooler Fountain (Combo Unit) - Bottle Filler Lims Reference ID: ED57425-06 Matrix: Drinking Water Sampled: 11/22/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 12/01/25 16:32 12/01/25 16:32 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: 2025-SO-HS-7/500's Wing Hallway - Water Cooler Fountain (Combo Unit) - Mouth Lims Reference ID: ED57425-07 Matrix: Drinking Water Sampled: 11/22/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 12/01/25 16:33 12/01/25 16:33 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: 2025-SO-HS-8/500's Wing Hallway - Water Cooler Fountain (Combo Unit) - Bottle Filler Lims Reference ID: ED57425-08 Matrix: Drinking Water Sampled: 11/22/25 00:00:00



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557425

LIMS Reference ID: ED57425

EMSL Customer ID: ROCL63

Attention: Dawn Izenman
Rockland Boces (Health & Safety Dept.) [ROCL63]
65 Parrott Road Bldg. 4
West Nyack, NY 10994
(845) 627-4764
dizenman@rboces.org

Project Name: 2025 South Orangetown, Tappan Zee High School
Project ID: _Master Project-ROCL63
Customer PO: 26-00590
Sales Rep: Jeromy Bish
Received: 11/26/2025 09:15
Reported: 12/03/2025 16:52

Analytical Results
(Continued)

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|
|---------|--------|---|----|----|-------|--------------------|--------------------|------------------|-------------------------|

Sample: 2025-SO-HS-8/500's Wing Hallway - Water Cooler Fountain (Combo Unit) - Bottle Filler (Continued) **Lims Reference ID:** ED57425-08 **Matrix:** Drinking Water **Sampled:** 11/22/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 12/01/25 16:34 12/01/25 16:34 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: 2025-SO-HS-9/500's Wing Hallway Cooler Fountain by Gender Neutral Bthrm/Elevator (Combo Unit) - Mouth **Lims Reference ID:** ED57425-09 **Matrix:** Drinking Water **Sampled:** 11/22/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 12/01/25 16:36 12/01/25 16:36 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: 2025-SO-HS-10/500's Wing Hallway Cooler Fountain by Gender Neutral Bthrm/Elevator (Combo Unit) - Bottle Filler **Lims Reference ID:** ED57425-10 **Matrix:** Drinking Water **Sampled:** 11/22/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 12/01/25 16:40 12/01/25 16:40 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: 2025-SO-HS-11/Main Office Hallway across from SRO Office / 600's Wing - Water Cooler Fountain (Combo Unit) - Mouth **Lims Reference ID:** ED57425-11 **Matrix:** Drinking Water **Sampled:** 11/22/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 12/01/25 16:44 12/01/25 16:44 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: 2025-SO-HS-12/Main Office Hallway across from SRO Office / 600's Wing - Water Cooler Fountain (Combo Unit) - Bottle Filler **Lims Reference ID:** ED57425-12 **Matrix:** Drinking Water **Sampled:** 11/22/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 12/01/25 16:45 12/01/25 16:45 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: 2025-SO-HS-13/1st Floor C-13 - School Store Kitchen Faucet **Lims Reference ID:** ED57425-13 **Matrix:** Drinking Water **Sampled:** 11/22/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 12/01/25 16:46 12/01/25 16:46 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: 2025-SO-HS-14/Classroom 950 (Testing Room) Sink Faucet **Lims Reference ID:** ED57425-14 **Matrix:** Drinking Water **Sampled:** 11/22/25 00:00:00



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557425

LIMS Reference ID: ED57425

EMSL Customer ID: ROCL63

Attention: Dawn Izenman
Rockland Boces (Health & Safety Dept.) [ROCL63]
65 Parrott Road Bldg. 4
West Nyack, NY 10994
(845) 627-4764
dizenman@rboces.org

Project Name: 2025 South Orangetown, Tappan Zee High School
Project ID: _Master Project-ROCL63
Customer PO: 26-00590
Sales Rep: Jeromy Bish
Received: 11/26/2025 09:15
Reported: 12/03/2025 16:52

Analytical Results
(Continued)

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---|--------|---|--------------------------------------|-----|-------------------------------|--------------------|--------------------|-----------------------------------|--------------------------|
| Sample: 2025-SO-HS-14/Classroom 950 (Testing Room) Sink Faucet (Continued) | | | | | | | | | |
| | | | Lims Reference ID: ED57425-14 | | Matrix: Drinking Water | | | Sampled: 11/22/25 00:00:00 | |
| Metals | | | | | | | | | |
| Lead | 4.4 | | 1 | 1.0 | µg/L | 12/01/25 16:48 | 12/01/25 16:48 | KT1 | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 2025-SO-HS-15/Auditorium Hallway - Water Cooler Fountain (Combo Unit) - Mouth | | | | | | | | | |
| | | | Lims Reference ID: ED57425-15 | | Matrix: Drinking Water | | | Sampled: 11/22/25 00:00:00 | |
| Metals | | | | | | | | | |
| Lead | < 1.0 | | 1 | 1.0 | µg/L | 12/01/25 16:49 | 12/01/25 16:49 | KT1 | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 2025-SO-HS-16/Auditorium Hallway - Water Cooler Fountain (Combo Unit) - Bottle Filler | | | | | | | | | |
| | | | Lims Reference ID: ED57425-16 | | Matrix: Drinking Water | | | Sampled: 11/22/25 00:00:00 | |
| Metals | | | | | | | | | |
| Lead | < 1.0 | | 1 | 1.0 | µg/L | 12/01/25 16:50 | 12/01/25 16:50 | KT1 | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 2025-SO-HS-17/Kitchen Prep Double Sink Faucet 1 (by Refrigerator Wall & Eyewash - Left When Facing) | | | | | | | | | |
| | | | Lims Reference ID: ED57425-17 | | Matrix: Drinking Water | | | Sampled: 11/22/25 00:00:00 | |
| Metals | | | | | | | | | |
| Lead | 5.4 | | 1 | 1.0 | µg/L | 12/01/25 16:52 | 12/01/25 16:52 | KT1 | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 2025-SO-HS-18/Kitchen Prep Double Sink Faucet 2 (by Refrigerator Wall & Eyewash - Right When Facing) | | | | | | | | | |
| | | | Lims Reference ID: ED57425-18 | | Matrix: Drinking Water | | | Sampled: 11/22/25 00:00:00 | |
| Metals | | | | | | | | | |
| Lead | < 1.0 | | 1 | 1.0 | µg/L | 12/01/25 16:53 | 12/01/25 16:53 | KT1 | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 2025-SO-HS-19/Kitchen Single Hand Washing (White) Sink Faucet | | | | | | | | | |
| | | | Lims Reference ID: ED57425-19 | | Matrix: Drinking Water | | | Sampled: 11/22/25 00:00:00 | |
| Metals | | | | | | | | | |
| Lead | 2.5 | | 1 | 1.0 | µg/L | 12/02/25 11:15 | 12/02/25 11:15 | JH | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 2025-SO-HS-20/Kitchen Single Sink Faucet (by Window Wall) | | | | | | | | | |
| | | | Lims Reference ID: ED57425-20 | | Matrix: Drinking Water | | | Sampled: 11/22/25 00:00:00 | |
| Metals | | | | | | | | | |
| Lead | 2.0 | | 1 | 1.0 | µg/L | 12/02/25 11:16 | 12/02/25 11:16 | JH | EPA 200.8 (DA)/EPA 200.8 |



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557425

LIMS Reference ID: ED57425

EMSL Customer ID: ROCL63

Attention: Dawn Izenman
Rockland Boces (Health & Safety Dept.) [ROCL63]
65 Parrott Road Bldg. 4
West Nyack, NY 10994
(845) 627-4764
dizenman@rboces.org

Project Name: 2025 South Orangetown, Tappan Zee High School
Project ID: _Master Project-ROCL63
Customer PO: 26-00590
Sales Rep: Jeromy Bish
Received: 11/26/2025 09:15
Reported: 12/03/2025 16:52

Analytical Results
(Continued)

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|--|--------|---|----|---------------------------|------------|-------------------------------|--------------------|-----------------------------------|--------------------------|
| Sample: 2025-SO-HS-21/Kitchen Double Sink (by Window Wall & Detergent Dispenser) Faucet 2 (Right when Facing) | | | | | | | | | |
| | | | | Lims Reference ID: | ED57425-21 | Matrix: Drinking Water | | Sampled: 11/22/25 00:00:00 | |
| Metals | | | | | | | | | |
| Lead | 3.0 | 1 | | 1.0 | µg/L | 12/02/25 11:20 | 12/02/25 11:20 | JH | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 2025-SO-HS-22/Kitchen Island Sink by Stove | | | | | | | | | |
| | | | | Lims Reference ID: | ED57425-22 | Matrix: Drinking Water | | Sampled: 11/22/25 00:00:00 | |
| Metals | | | | | | | | | |
| Lead | 7.0 | 1 | | 1.0 | µg/L | 12/02/25 11:21 | 12/02/25 11:21 | JH | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 2025-SO-HS-23/Kitchen Ice Machine | | | | | | | | | |
| | | | | Lims Reference ID: | ED57425-23 | Matrix: Drinking Water | | Sampled: 11/22/25 00:00:00 | |
| Metals | | | | | | | | | |
| Lead | < 1.0 | 1 | | 1.0 | µg/L | 12/02/25 11:23 | 12/02/25 11:23 | JH | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 2025-SO-HS-24/Kitchen Sink Faucet by Pizza Serving Line | | | | | | | | | |
| | | | | Lims Reference ID: | ED57425-24 | Matrix: Drinking Water | | Sampled: 11/22/25 00:00:00 | |
| Metals | | | | | | | | | |
| Lead | 9.0 | 1 | | 1.0 | µg/L | 12/02/25 11:24 | 12/02/25 11:24 | JH | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 2025-SO-HS-25/Kitchen Sink Faucet by Deli Serving Line | | | | | | | | | |
| | | | | Lims Reference ID: | ED57425-25 | Matrix: Drinking Water | | Sampled: 11/22/25 00:00:00 | |
| Metals | | | | | | | | | |
| Lead | 3.7 | 1 | | 1.0 | µg/L | 12/02/25 11:25 | 12/02/25 11:25 | JH | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 2025-SO-HS-26/Trainer's Room Sink | | | | | | | | | |
| | | | | Lims Reference ID: | ED57425-26 | Matrix: Drinking Water | | Sampled: 11/22/25 00:00:00 | |
| Metals | | | | | | | | | |
| Lead | < 1.0 | 1 | | 1.0 | µg/L | 12/02/25 11:26 | 12/02/25 11:26 | JH | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 2025-SO-HS-27/Trainer's Room Ice Machine | | | | | | | | | |
| | | | | Lims Reference ID: | ED57425-27 | Matrix: Drinking Water | | Sampled: 11/22/25 00:00:00 | |
| Metals | | | | | | | | | |
| Lead | < 1.0 | 1 | | 1.0 | µg/L | 12/02/25 11:28 | 12/02/25 11:28 | JH | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 2025-SO-HS-28/Gymnasium/Hall of Fame Lobby Water Cooler Fountain (Combo Unit) - Mouth | | | | | | | | | |
| | | | | Lims Reference ID: | ED57425-28 | Matrix: Drinking Water | | Sampled: 11/22/25 00:00:00 | |



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557425

LIMS Reference ID: ED57425

EMSL Customer ID: ROCL63

Attention: Dawn Izenman
Rockland Boces (Health & Safety Dept.) [ROCL63]
65 Parrott Road Bldg. 4
West Nyack, NY 10994
(845) 627-4764
dizenman@rboces.org

Project Name: 2025 South Orangetown, Tappan Zee High School
Project ID: _Master Project-ROCL63
Customer PO: 26-00590
Sales Rep: Jeromy Bish
Received: 11/26/2025 09:15
Reported: 12/03/2025 16:52

Analytical Results
(Continued)

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---|--------|---|----|-----|-------|--------------------|--------------------|------------------|--------------------------|
| Sample: 2025-SO-HS-28/Gymnasium/Hall of Fame Lobby Water Cooler Fountain (Combo Unit) - Mouth (Continued) Lims Reference ID: ED57425-28 Matrix: Drinking Water Sampled: 11/22/25 00:00:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | < 1.0 | | 1 | 1.0 | µg/L | 12/02/25 11:40 | 12/02/25 11:40 | JH | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 2025-SO-HS-29/Gymnasium/Hall of Fame Lobby Water Cooler Fountain (Combo Unit) - Bottle Filler Lims Reference ID: ED57425-29 Matrix: Drinking Water Sampled: 11/22/25 00:00:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | < 1.0 | | 1 | 1.0 | µg/L | 12/02/25 11:44 | 12/02/25 11:44 | JH | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 2025-SO-HS-30/Room 124 Woodshop Classroom Sink Faucet Lims Reference ID: ED57425-30 Matrix: Drinking Water Sampled: 11/22/25 00:00:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | 1.6 | | 1 | 1.0 | µg/L | 12/02/25 11:45 | 12/02/25 11:45 | JH | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 2025-SO-HS-31/Room 124 Weight Room Fitness Center Water Fountain - Mouth only - left when facing Lims Reference ID: ED57425-31 Matrix: Drinking Water Sampled: 11/22/25 00:00:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | 1.4 | | 1 | 1.0 | µg/L | 12/02/25 11:47 | 12/02/25 11:47 | JH | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 2025-SO-HS-32/Room 124 Weight Room Fitness Center Water Fountain - Mouth only - right when facing Lims Reference ID: ED57425-32 Matrix: Drinking Water Sampled: 11/22/25 00:00:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | 1.6 | | 1 | 1.0 | µg/L | 12/02/25 11:48 | 12/02/25 11:48 | JH | EPA 200.8 (DA)/EPA 200.8 |



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557425

LIMS Reference ID: ED57425

EMSL Customer ID: ROCL63

Attention: Dawn Izenman
Rockland Boces (Health & Safety Dept.) [ROCL63]
65 Parrott Road Bldg. 4
West Nyack, NY 10994
(845) 627-4764
dizenman@rboces.org

Project Name: 2025 South Orangetown, Tappan Zee High School

Project ID: _Master Project-ROCL63
Customer PO: 26-00590
Sales Rep: Jeromy Bish
Received: 11/26/2025 09:15
Reported: 12/03/2025 16:52

Certified Analyses included in this Report

| Analyte | Certifications |
|------------------------------------|----------------|
| <i>EPA 200.8 in Drinking Water</i> | |
| Lead | 06-NYSELAP |

List of Certifications

| Code | Description | Number | Expires |
|--------------------|---|---------|------------|
| 06-NYSELAP | NY NYS ELAP | 11469 | 04/01/2026 |
| 06-NYSDOH | New York State Department of Health | 11469 | 04/01/2026 |
| 06-CTDPH | Connecticut Department of Public Health | PH-0249 | 03/31/2027 |
| 06-California ELAP | California Water Boards | 2339 | 04/01/2026 |
| 06-AIHA LAP | American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP | 102344 | 08/01/2026 |

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557425

LIMS Reference ID: ED57425

EMSL Customer ID: ROCL63

Attention: Dawn Izenman
Rockland Boces (Health & Safety Dept.) [ROCL63]
65 Parrott Road Bldg. 4
West Nyack, NY 10994
(845) 627-4764
dizenman@rboces.org

Project Name: 2025 South Orangetown, Tappan Zee High School

Project ID: _Master Project-ROCL63
Customer PO: 26-00590
Sales Rep: Jeromy Bish
Received: 11/26/2025 09:15
Reported: 12/03/2025 16:52

Notes and Definitions

| Item | Definition |
|-------------|---|
| (Dig) | For metals analysis, sample was digested. |
| [2C] | Reported from the second channel in dual column analysis. |
| DA | Direct Analysis |
| DF | Dilution Factor |
| MDL | Method Detection Limit. |
| ND | Analyte was NOT DETECTED at or above the detection limit. |
| NR | Spike/Surrogate showed no recovery. |
| Q | Qualifier |
| RCS | Respirable Crystalline Silica |
| RL | Reporting Limit |
| Wet | Sample is not dry weight corrected. |

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

EDS 7425

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

| | | | |
|--|--|---------------------|---|
| Customer Information | Customer ID: ROCL63 | Billing Information | Billing ID: ROCL63 |
| | Company Name: Tappan Zee High School | | Company Name: Rockland BOCES |
| | Contact Name: Dawn Izenman | | Billing Contact: Dawn Izenman |
| | Street Address: 15 Dutch Hill Road | | Street Address: 65 Parrott Road |
| | City, State, Zip: Orangeburg NY 10962 Country: USA | | City, State, Zip: W. Nyack, NY 10994 Country: USA |
| Phone: 845-627-4764 | Phone: 845-627-4764 | | |
| Email(s) for Report: dizenman@rboces.org | Email(s) for Invoice: dizenman@rboces.org | | |

Project Information

Project Name/No: 2025 South Orangetown Purchase Order: 26-00590

EMSL LIMS Project ID: (If applicable, EMSL will provide) US State where samples collected: NY State of Connecticut (CT) must select project location: Commercial (Taxable) Residential (Non-Taxable)

Sampled By Name: Dawn Izenman Sampled By Signature: No. of Samples in Shipment: 32

Turn-Around-Time (TAT)

3 Hour
 6 Hour
 24 Hour
 32 Hour
 48 Hour
 72 Hour
 96 Hour
 1 Week
 2 Week

Please call ahead for large projects and/or turnaround times 6 Hours or Less. *32 Hour TAT available for select tests only; samples must be submitted by 11:30am.

| MATRIX | METHOD | INSTRUMENT | REPORTING LIMIT | SELECTION |
|--|--------------------------------|-------------------------|------------------|--------------------------|
| CHIPS <input type="checkbox"/> % by wt. <input type="checkbox"/> ppm (mg/kg) <input type="checkbox"/> mg/cm ² | SW 846-7000B | Flame Atomic Absorption | 0.008% (80ppm) | <input type="checkbox"/> |
| *Reporting Limit based on a minimum 0.25g sample weight. | SW 846-6010D* | ICP-OES | 0.0004% (4ppm) | <input type="checkbox"/> |
| **Not appropriate for Ceramic Tiles - XRF is recommended | NIOSH 7082 | Flame Atomic Absorption | 4µg/filter | <input type="checkbox"/> |
| AIR | NIOSH 7303M | ICP-OES | 1.0µg/filter | <input type="checkbox"/> |
| | NIOSH 7303M | ICP-MS | 0.05µg/filter | <input type="checkbox"/> |
| WIPE <input type="checkbox"/> ASTM <input type="checkbox"/> NON-ASTM | SW 846-7000B | Flame Atomic Absorption | 10µg/wipe | <input type="checkbox"/> |
| *If no box is checked, non-ASTM Wipe is assumed | SW 846-6010D* | ICP-OES | 1.0µg/wipe | <input type="checkbox"/> |
| TCLP | SW 846-1311 / 7000B / SM 3111B | Flame Atomic Absorption | 0.4 mg/L (ppm) | <input type="checkbox"/> |
| | SW 846-1311 / SW 846-6010D* | ICP-OES | 0.1 mg/L (ppm) | <input type="checkbox"/> |
| SPLP | SW 846-1312 / 7000B / SM 3111B | Flame Atomic Absorption | 0.4 mg/L (ppm) | <input type="checkbox"/> |
| | SW 846-1312 / SW 846-6010D* | ICP-OES | 0.1 mg/L (ppm) | <input type="checkbox"/> |
| TTLIC | 22 CCR App. II, 7000B | Flame Atomic Absorption | 40mg/kg (ppm) | <input type="checkbox"/> |
| | 22 CCR App. II, SW 846-6010D* | ICP-OES | 2mg/kg (ppm) | <input type="checkbox"/> |
| STLC | 22 CCR App. II, 7000B | Flame Atomic Absorption | 0.4 mg/L (ppm) | <input type="checkbox"/> |
| | 22 CCR App. II, SW 846-6010D* | ICP-OES | 0.1 mg/L (ppm) | <input type="checkbox"/> |
| Soil | SW 846-7000B | Flame Atomic Absorption | 40mg/kg (ppm) | <input type="checkbox"/> |
| | SW 846-6010D* | ICP-OES | 2mg/kg (ppm) | <input type="checkbox"/> |
| Wastewater | SM 3111B / SW 846-7000B | Flame Atomic Absorption | 0.4 mg/L (ppm) | <input type="checkbox"/> |
| Unpreserved <input type="checkbox"/> | EPA 200.7 | ICP-OES | 0.020 mg/L (ppm) | <input type="checkbox"/> |
| Preserved with HNO3 <input type="checkbox"/> PH<2 | EPA 200.5 | ICP-OES | 0.003 mg/L (ppm) | <input type="checkbox"/> |
| Drinking Water | EPA 200.8 | ICP-MS | 0.001 mg/L (ppm) | <input type="checkbox"/> |
| Unpreserved <input type="checkbox"/> | 40 CFR Part 50 | ICP-OES | 12 µg/filter | <input type="checkbox"/> |
| Preserved with HNO3 <input checked="" type="checkbox"/> PH<2 | Other: | | | <input type="checkbox"/> |

RECEIVED
EMSL ANALYTICAL, INC.
200 Route 130 North
Cinnaminson, NJ 08077
11/22/25 11:09:14

5/11/21 mmm
 8-002 9b
 12/2/25

| Sample Number | Sample Location | Volume / Area | Date / Time Sampled |
|---------------|---|---------------|---------------------|
| 2025-SO-HS-1 | Library Office Sink Faucet | 250 ml. | 11/22/25 7:01 am |
| 2025-SO-HS-2 | 300's Wing Hallway - Water Cooler Fountain (Combo Unit) - Mouth | 250 ml. | 11/22/25 6:59 am |
| 2025-SO-HS-3 | 300's Wing Hallway - Water Cooler Fountain (Combo Unit) - Bottle Filler | 250 ml. | 11/22/25 7:00 am |
| 2025-SO-HS-4 | Teacher's Lounge Room 304 | 250 ml. | 11/22/25 7:37 am |
| 2025-SO-HS-5 | 400's Wing Hallway - Water Cooler Fountain (Combo Unit) - Mouth | 250 ml. | 11/22/25 6:57am |

Method of Shipment: Sample Condition Upon Receipt:

Relinquished by: Dawn Izenman Date/Time: 11/25/25 9am Received by: Sean Cull Date/Time: 11/26/25 9:14 AM

Relinquished by: Date/Time: Received by: Date/Time:

Controlled Document - COC-25 Lead R18 04/04/2024

*6010C Available Upon Request

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document electronically.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of this document constitutes acceptance and acknowledgment of all terms and conditions by Customer.



Analytical, Inc.

2008
 Pb
 12/2/25



Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

EPS 7425

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

| Sample Number | Sample Location | Volume / Area | Date / Time Sampled |
|---------------|--|---------------|---------------------|
| 2025-SO-HS-6 | 400's Wing Hallway - Water Cooler Fountain (Combo Unit) - Bottle Filler | 250 ml. | 11/22/25 6:58 am |
| 2025-SO-HS-7 | 500's Wing Hallway - Water Cooler Fountain (Combo Unit) - Mouth | 250 ml. | 11/22/25 7:04am |
| 2025-SO-HS-8 | 500's Wing Hallway - Water Cooler Fountain (Combo Unit) - Bottle Filler | 250 ml. | 11/22/25 7:05 am |
| 2025-SO-HS-9 | 500's Wing Hallway Water Cooler Fountain by Gender Neutral Bthrm/Elevator (Combo Unit) - Mouth | 250 ml. | 11/22/25 7:07 am |
| 2025-SO-HS-10 | 500's Wing Hallway Water Cooler Fountain by Gender Neutral Bthrm/Elevator (Combo Unit) - Bottle Filler | 250 ml. | 11/22/25 7:08 am |
| 2025-SO-HS-11 | Main Office Hallway across from SRO office / 600's Wing - Water Cooler Fountain (Combo Unit) - Mouth | 250 ml. | 11/22/25 7:11 am |
| 2025-SO-HS-12 | Main Office Hallway across from SRO office / 600's Wing - Water Cooler Fountain (Combo Unit) - Bottle Filler | 250 ml. | 11/22/25 7:12 am |
| 2025-SO-HS-13 | 1ST Floor C-13 - School Store Kitchen Faucet | 250 ml. | 11/22/25 7:34 am |
| 2025-SO-HS-14 | Classroom 950 (Testing Room) Sink Faucet | 250 ml. | 11/22/25 7:15 am |
| 2025-SO-HS-15 | Auditorium Hallway - Water Cooler Fountain (Combo Unit) - Mouth | 250 ml. | 11/22/25 7:12 am |
| 2025-SO-HS-16 | Auditorium Hallway - Water Cooler Fountain (Combo Unit) - Bottle Filler | 250 ml. | 11/22/25 7:13 am |
| 2025-SO-HS-17 | Kitchen Prep Double Sink Faucet 1 (by Refrigerator Wall & Eyewash - Left When Facing) | 250 ml. | 11/22/25 7:22 am |
| 2025-SO-HS-18 | Kitchen Prep Double Sink Faucet 2 (by Refrigerator Wall & Eyewash - Right When Facing) | 250 ml. | 11/22/25 7:23 am |
| 2025-SO-HS-19 | Kitchen Single Hand Washing (White) Sink Faucet | 250 ml. | 11/22/25 7:25 am |
| 2025-SO-HS-20 | Kitchen Single Sink Faucet (by Window Wall) | 250 ml. | 11/22/25 7:24 am |
| 2025-SO-HS-21 | Kitchen Double Sink (by Window Wall & Detergent Dispensers) Faucet 2 (Right When Facing) | 250 ml. | 11/22/25 7:26 am |
| 2025-SO-HS-22 | Kitchen Island Sink by Stove | 250 ml. | 11/22/25 7:33 am |
| 2025-SO-HS-23 | Kitchen Ice Machine | 250 ml. | 11/22/25 7:28 am |
| 2025-SO-HS-24 | Kitchen Sink Faucet by Pizza Serving Line | 250 ml. | 11/22/25 7:30 am |
| 2025-SO-HS-25 | Kitchen Sink Faucet by Deli Serving Line | 250 ml. | 11/22/25 7:31 am |
| 2025-SO-HS-26 | Trainer's Room Sink | 250 ml. | 11/22/25 7:45 am |
| 2025-SO-HS-27 | Trainer's Room Ice Machine | 250 ml. | 11/22/25 7:46 am |
| 2025-SO-HS-28 | Gymnasium/Hall of Fame Lobby Water Cooler Fountain (Combo Unit) - Mouth | 250 ml. | 11/22/25 7:42 am |
| 2025-SO-HS-29 | Gymnasium/Hall of Fame Lobby Water Cooler Fountain (Combo Unit) - Bottle Filler | 250 ml. | 11/22/25 7:43 am |
| 2025-SO-HS-30 | Room 124 Woodshop Classroom Sink Faucet | 250 ml. | 11/22/25 7:50 am |

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
NOV 26 25 11:07:14

Pb 200-8
Kathleen W 12/1/25

| | | | |
|-------------------------------|-------------------------|--------------------------------|----------------------------|
| Method of Shipment: | | Sample Condition Upon Receipt: | |
| Relinquished by: Dawn Izenman | Date/Time: 11/25/25 9am | Received by: <i>Sen</i> | Date/Time: 11/26/25 9:14AM |
| Relinquished by: | Date/Time: | Received by: | Date/Time: |

Controlled Document - COC-25 Lead R18 04/04/2024

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

200-8
Pb JSC 12/2/25

