

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample Results (in parts per billion)	Remediation Action -- Required for any outle > 5.0 parts per billion	Resampling Dates -- Required after Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ parts per billion	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
2025-SO-TZE-1	SO	Tappan Zee ES	1	Kitchen Double Sink (left when facing) Faucet #1	11/21/2025	2.3	Not Required	Not Required	2.3	Yes	11/21/2025	Not Applicable
2025-SO-TZE-2	SO	Tappan Zee ES	1	Kitchen Double Sink (right when facing) Faucet #2	11/21/2025	1.6	Not Required	Not Required	1.6	Yes	11/21/2025	Not Applicable
2025-SO-TZE-3	SO	Tappan Zee ES	1	Kitchen Triple Sink (Left when Facing) Faucet #1	11/21/2025	3.8	Not Required	Not Required	3.8	Yes	11/21/2025	Not Applicable
2025-SO-TZE-4	SO	Tappan Zee ES	1	Kitchen Triple Sink (Middle) Faucet #2	11/21/2025	3.3	Not Required	Not Required	3.3	Yes	11/21/2025	Not Applicable
2025-SO-TZE-6	SO	Tappan Zee ES	1	Classroom 108 Sink Faucet	11/21/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/21/2025	Not Applicable
2025-SO-TZE-7	SO	Tappan Zee ES	1	Classroom 107 A/B Sink Faucet	11/21/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/21/2025	Not Applicable
2025-SO-TZE-8	SO	Tappan Zee ES	1	Classroom 104 (Staff Lounge) Sink Faucet	11/21/2025	3.7	Not Required	Not Required	3.7	Yes	11/21/2025	Not Applicable
2025-SO-TZE-9	SO	Tappan Zee ES	1	Room 120 (Custodial Office) Sink Faucet	11/21/2025	1.9	Not Required	Not Required	1.9	Yes	11/21/2025	Not Applicable
2025-SO-TZE-10	SO	Tappan Zee ES	1	Nurses Office (Room 105) Main Area Sink Faucet	11/21/2025	4.8	Not Required	Not Required	4.8	Yes	11/21/2025	Not Applicable
2025-SO-TZE-11	SO	Tappan Zee ES	1	Classroom 204 Sink Faucet	11/21/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/21/2025	Not Applicable
2025-SO-TZE-12	SO	Tappan Zee ES	1	Classroom 205 Sink Faucet	11/21/2025	1.3	Not Required	Not Required	1.3	Yes	11/21/2025	Not Applicable
2025-SO-TZE-14	SO	Tappan Zee ES	1	Classroom 207 Sink Faucet	11/21/2025	3.1	Not Required	Not Required	3.1	Yes	11/21/2025	Not Applicable
2025-SO-TZE-15	SO	Tappan Zee ES	1	Classroom 208 Sink Faucet	11/21/2025	2.7	Not Required	Not Required	2.7	Yes	11/21/2025	Not Applicable
2025-SO-TZE-16	SO	Tappan Zee ES	1	Classroom 209 Sink Faucet	11/21/2025	3.5	Not Required	Not Required	3.5	Yes	11/21/2025	Not Applicable

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample Results (in parts per billion)	Remediation Action -- Required for any outle > 5.0 parts per billion	Resampling Dates -- Required after Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ parts per billion	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
2025-SO-TZE-17	SO	Tappan Zee ES	1	Classroom 211 Sink Faucet	11/21/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/21/2025	Not Applicable
2025-SO-TZE-18	SO	Tappan Zee ES	1	Classroom 212 Sink Faucet	11/21/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/21/2025	Not Applicable
2025-SO-TZE-19	SO	Tappan Zee ES	1	Classroom 213 Sink Faucet	11/21/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/21/2025	Not Applicable
2025-SO-TZE-20	SO	Tappan Zee ES	1	Classroom 214 Sink Faucet	11/21/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/21/2025	Not Applicable
2025-SO-TZE-21	SO	Tappan Zee ES	1	Classroom 215 Sink Faucet	11/21/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/21/2025	Not Applicable
2025-SO-TZE-22	SO	Tappan Zee ES	1	Classroom 216 Sink Faucet	11/21/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/21/2025	Not Applicable
2025-SO-TZE-23	SO	Tappan Zee ES	1	Classroom 306 Sink Faucet	11/21/2025	4.8	Not Required	Not Required	4.8	Yes	11/21/2025	Not Applicable
2025-SO-TZE-24	SO	Tappan Zee ES	1	Hallway Outside Room 305 - Water Cooler Fountain (Combo Unit) - Mouth	11/21/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/21/2025	Not Applicable
2025-SO-TZE-25	SO	Tappan Zee ES	1	Hallway Outside Room 305 - Water Cooler Fountain (Combo Unit) - Bottle Filler	11/21/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/21/2025	Not Applicable
2025-SO-TZE-26	SO	Tappan Zee ES	1	Classroom 307 Classroom Sink Faucet	11/21/2025	2.1	Not Required	Not Required	2.1	Yes	11/21/2025	Not Applicable
2025-SO-TZE-27	SO	Tappan Zee ES	1	Classroom 308 Sink Faucet	11/21/2025	3.8	Not Required	Not Required	3.8	Yes	11/21/2025	Not Applicable
2025-SO-TZE-29	SO	Tappan Zee ES	1	Classroom 314 Faucet	11/21/2025	2.9	Not Required	Not Required	2.9	Yes	11/21/2025	Not Applicable
2025-SO-TZE-31	SO	Tappan Zee ES	1	Classroom 402 (BOCES Main Office) Sink Faucet	11/21/2025	4.6	Not Required	Not Required	4.6	Yes	11/21/2025	Not Applicable
2025-SO-TZE-32	SO	Tappan Zee ES	1	Classroom 402 (BOCES Main Office) Sink Fountain	11/21/2025	1.5	Not Required	Not Required	1.5	Yes	11/21/2025	Not Applicable

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample Results (in parts per billion)	Remediation Action -- Required for any outle > 5.0 parts per billion	Resampling Dates -- Required after Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ parts per billion	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Non-Applicable Outlets Below - these are outlets that were determined by the District to not be used for cooking or drinking by staff or students.												
Not Sampled	SO	Tappan Zee ES	Exterior	Exterior Hose Bib #1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	Exterior	Exterior Hose Bib #2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	Exterior	Exterior Hose Bib #3	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	Exterior	Exterior Hose Bib #4	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	Exterior	Exterior Hose Bib #5	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	Exterior	Exterior Hose Bib #6	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Kitchen Ladies Room Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Kitchen Triple Sink (Right when facing) Faucet #3 (dishwasher sprayer)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Hallway Outside Boiler Room Bubbler Water Fountain Outlet permanently shut down	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Not Applicable	Not Applicable	Not Applicable	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Between 116/118 Gender Neutral Bathroom Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Nurses Office (Room 105) Bathroom Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
2025-SO-TZE-5	SO	Tappan Zee ES	1	Classroom 110 Sink Faucet	11/21/2025	16.8	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.	Not Required	Not Required	Outlet classified as "non applicable". DO NOT DRINK signage displayed.	11/21/2025	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Custodial Closet by across from Room 115 -- Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample Results (in parts per billion)	Remediation Action -- Required for any outle > 5.0 parts per billion	Resampling Dates -- Required after Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ parts per billion	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	SO	Tappan Zee ES	1	Fred Keller Main Office Bathroom Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Fred Keller Main Office Hallway Gender Neutral Bathroom Near Security Desk Sink Faucet #1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Fred Keller Main Office Hallway Gender Neutral Bathroom Near Security Desk Sink Faucet #2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Fred Keller Main Office Hallway Gender Neutral Bathroom Sink Faucet #1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Hallway Outside Room 209 Bubbler Water Fountain Outlet permanently shut down	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Not Applicable	Not Applicable	Not Applicable	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Hallway Outside Room 204 Mens Bubbler Water Fountain Outlet permanently shut down	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Not Applicable	Not Applicable	Not Applicable	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Outside of Girls Bathroom by Room 205 Sink (left when facing) Faucet #1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Outside of Boys Bathroom by Room 204 Sink (left when facing) Faucet #1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Outside of Girls Bathroom by Room 205 Tempered Sink (right when facing) Faucet #2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Outside of Boys Bathroom by Room 204 Sink (right when facing) Faucet #2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
2025-SO-TZE-13	SO	Tappan Zee ES	1	Classroom 206 Sink Faucet	11/21/2025	6.6	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.	Not Required	Not Required	Outlet classified as "non applicable". DO NOT DRINK signage displayed.	11/21/2025	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES		Custodial Closet across from 209 Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Outside of Girls Bathroom next to Room 217 Sink (left when facing) Faucet #1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Outside of Girls Bathroom next to Room 217 Sink (right when facing) Faucet #2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample Results (in parts per billion)	Remediation Action -- Required for any outle > 5.0 parts per billion	Resampling Dates -- Required after Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ parts per billion	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	SO	Tappan Zee ES	1	Outside of Boys Bathroom next to Room 218 Sink (left when facing) Faucet #1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Outside of Boys Bathroom next to Room 218 Sink (right when facing) Faucet #2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Hallway Outside Room 302 Bubbler Water Fountain Outlet permanently shut down	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Applicable	Not Applicable	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES		Across From Room 303 Custodial Closet Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Classroom 303 Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Classroom 304 Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Classroom 305 Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Classroom 306 Bathroom Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Classroom 307 Bathroom Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Classroom 308 Bathroom Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Classroom 309 Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Classroom 309 Bathroom Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
2025-SO-TZE-28	SO	Tappan Zee ES	1	Classroom 310 Faucet	11/21/2025	6.3	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.	Not Required	Not Required	Outlet classified as "non applicable". DO NOT DRINK signage displayed.	11/21/2025	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Classroom 311 Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Pending	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample Results (in parts per billion)	Remediation Action -- Required for any outle > 5.0 parts per billion	Resampling Dates -- Required after Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ parts per billion	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	SO	Tappan Zee ES	1	Classroom 311 Bathroom Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Classroom 313 Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Pending	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Outside of Girls Bathroom next to Room 314 Sink (left when facing) Faucet #1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Outside of Girls Bathroom next to Room 314 Sink (right when facing) Faucet #2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Outside of Boys Bathroom next to Room 314 Sink (left when facing) Faucet #1	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Outside of Boys Bathroom next to Room 314 Sink (right when facing) Faucet #2	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Classroom 401 (BOCES Guidance Office) Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Pending	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Classroom 401 (BOCES Guidance Office) Bathroom Sink Fountain	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
2025-SO-TZE-30	SO	Tappan Zee ES	1	Classroom 401 (BOCES Guidance Office) Sink Fountain	11/21/2025	20.6	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.	Not Required	Not Required	Outlet classified as "non applicable". DO NOT DRINK signage displayed.	11/21/2025	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Classroom 402 (BOCES Main Office) Bathroom Sink Fountain	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Classroom 302 Sink Faucet	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Classroom 302 Sink Fountain	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Classroom 303 Sink Fountain	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	SO	Tappan Zee ES	1	Classroom 308 Sink Fountain	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

2025 Sample Number	District	School	Floor	Location/Classroom #	First Sample Date	First Sample Results (in parts per billion)	Remediation Action -- Required for any outle > 5.0 parts per billion	Resampling Dates -- Required after Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ parts per billion	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
Not Sampled	SO	Tappan Zee ES	1	Classroom 311 Fountain	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.