



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557340

LIMS Reference ID: ED57340

EMSL Customer ID: ROCL63

Attention: Dawn Izenman
Rockland Boces (Health & Safety Dept.) [ROCL63]
65 Parrott Road Bldg. 4
West Nyack, NY 10994
(845) 627-4764
dizenman@rboces.org

Project Name: 2025 South Orangetown, Tappan Zee Elementary School
Project ID: _Master Project-ROCL63
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/22/2025 10:14
Reported: 12/04/2025 15:55

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 2025-SO-TZE-1/Kitchen Double Sink (Left When Facing) Faucet #1 Lims Reference ID: ED57340-01 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	2.3		1	1.0	µg/L	11/24/25 17:51	11/24/25 17:51	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-2/Kitchen Double Sink (Right When Facing) Faucet #2 Lims Reference ID: ED57340-02 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	1.6		1	1.0	µg/L	11/24/25 17:52	11/24/25 17:52	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-3/Kitchen Triple Sink (Left When Facing) Faucet #1 Lims Reference ID: ED57340-03 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	3.8		1	1.0	µg/L	11/24/25 17:54	11/24/25 17:54	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-4/Kitchen Double Sink (Middle)Faucet #2 Lims Reference ID: ED57340-04 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	3.3		1	1.0	µg/L	11/24/25 18:11	11/24/25 18:11	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-5/Classroom 110 Sink Faucet Lims Reference ID: ED57340-05 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	16.8		1	1.0	µg/L	11/24/25 18:15	11/24/25 18:15	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-6/Classroom 108 Sink Faucet Lims Reference ID: ED57340-06 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	11/24/25 18:16	11/24/25 18:16	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-7/Classroom 107 A/B Sink Faucet Lims Reference ID: ED57340-07 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	11/24/25 18:17	11/24/25 18:17	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-8/Classroo 104 (Staff Lounge) Sink Faucet Lims Reference ID: ED57340-08 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557340

LIMS Reference ID: ED57340

EMSL Customer ID: ROCL63

Attention: Dawn Izenman
Rockland Boces (Health & Safety Dept.) [ROCL63]
65 Parrott Road Bldg. 4
West Nyack, NY 10994
(845) 627-4764
dizenman@rboces.org

Project Name: 2025 South Orangetown, Tappan Zee Elementary School
Project ID: _Master Project-ROCL63
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/22/2025 10:14
Reported: 12/04/2025 15:55

**Analytical Results
(Continued)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 2025-SO-TZE-8/Classroom 104 (Staff Lounge) Sink Faucet (Continued) Lims Reference ID: ED57340-08 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	3.7		1	1.0	µg/L	11/24/25 18:21	11/24/25 18:21	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-9/Room 120 (Custodial Office) Sink Faucet Lims Reference ID: ED57340-09 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	1.9		1	1.0	µg/L	11/24/25 18:23	11/24/25 18:23	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-10/Nurses Office (Room 105) Main Area Sink Faucet Lims Reference ID: ED57340-10 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	4.8		1	1.0	µg/L	11/24/25 18:24	11/24/25 18:24	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-11/Classroom 204 Sink Faucet Lims Reference ID: ED57340-11 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	11/24/25 18:25	11/24/25 18:25	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-12/Classroom 205 Sink Faucet Lims Reference ID: ED57340-12 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	1.3		1	1.0	µg/L	11/24/25 18:26	11/24/25 18:26	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-13/Classroom 206 Sink Faucet Lims Reference ID: ED57340-13 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	6.6		1	1.0	µg/L	11/24/25 18:28	11/24/25 18:28	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-14/Classroom 207 Sink Faucet Lims Reference ID: ED57340-14 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	3.1		1	1.0	µg/L	11/24/25 18:29	11/24/25 18:29	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-15/Classroom 208 Sink Faucet Lims Reference ID: ED57340-15 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	2.7		1	1.0	µg/L	11/24/25 18:33	11/24/25 18:33	KT1	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557340

LIMS Reference ID: ED57340

EMSL Customer ID: ROCL63

Attention: Dawn Izenman
Rockland Boces (Health & Safety Dept.) [ROCL63]
65 Parrott Road Bldg. 4
West Nyack, NY 10994
(845) 627-4764
dizenman@rboces.org

Project Name: 2025 South Orangetown, Tappan Zee Elementary School
Project ID: _Master Project-ROCL63
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/22/2025 10:14
Reported: 12/04/2025 15:55

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 2025-SO-TZE-16/Classroom 209 Sink Faucet Lims Reference ID: ED57340-16 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	3.5		1	1.0	µg/L	11/24/25 18:37	11/24/25 18:37	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-17/Classroom 211 Sink Faucet Lims Reference ID: ED57340-17 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	11/24/25 18:38	11/24/25 18:38	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-18/Classroom 212 Sink Faucet Lims Reference ID: ED57340-18 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	11/24/25 18:40	11/24/25 18:40	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-19/Classroom 213 Sink Faucet Lims Reference ID: ED57340-19 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	11/24/25 18:41	11/24/25 18:41	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-20/Classroom 214 Sink Faucet Lims Reference ID: ED57340-20 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	11/24/25 18:42	11/24/25 18:42	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-21/Classroom 215 Sink Faucet Lims Reference ID: ED57340-21 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	11/24/25 18:44	11/24/25 18:44	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-22/Classroom 216 Sink Faucet Lims Reference ID: ED57340-22 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	11/24/25 18:45	11/24/25 18:45	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-23/Classroom 306 Sink Faucet Lims Reference ID: ED57340-23 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	4.8		1	1.0	µg/L	11/24/25 18:46	11/24/25 18:46	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-24/Hallway Outside Room 305 - Water Cooler Fountain (Combo Unit) - Mouth Lims Reference ID: ED57340-24 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557340

LIMS Reference ID: ED57340

EMSL Customer ID: ROCL63

Attention: Dawn Izenman
Rockland Boces (Health & Safety Dept.) [ROCL63]
65 Parrott Road Bldg. 4
West Nyack, NY 10994
(845) 627-4764
dizenman@rboces.org

Project Name: 2025 South Orangetown, Tappan Zee Elementary School
Project ID: _Master Project-ROCL63
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/22/2025 10:14
Reported: 12/04/2025 15:55

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 2025-SO-TZE-24/Hallway Outside Room 305 - Water Cooler Fountain (Combo Unit) - Mouth (Continued) Lims Reference ID: ED57340-24 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	11/27/25 01:12	11/27/25 01:12	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-25/Hallway Outside Room 305 - Water Cooler Fountain (Combo Unit) - Bottle Filler Lims Reference ID: ED57340-25 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	< 1.0		1	1.0	µg/L	11/27/25 01:13	11/27/25 01:13	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-26/Classroom 307 Classroom Sink Faucet Lims Reference ID: ED57340-26 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	2.1		1	1.0	µg/L	11/27/25 01:14	11/27/25 01:14	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-27/Classroom 308 Sink Faucet Lims Reference ID: ED57340-27 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	3.8		1	1.0	µg/L	11/26/25 23:03	11/26/25 23:03	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-28/Classroom 310 Faucet Lims Reference ID: ED57340-28 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	6.3		1	1.0	µg/L	11/26/25 23:07	11/26/25 23:07	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-29/Classroom 314 Faucet Lims Reference ID: ED57340-29 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	2.9		1	1.0	µg/L	11/26/25 23:11	11/26/25 23:11	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-30/Classroom 401 (BOCES Guidance Office) Sink Fountain Lims Reference ID: ED57340-30 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									
Metals									
Lead	20.6		1	1.0	µg/L	11/26/25 23:12	11/26/25 23:12	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-31/Classroom 402 (BOCES Main Office) Sink Faucet Lims Reference ID: ED57340-31 Matrix: Drinking Water Sampled: 11/21/25 00:00:00									



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557340

LIMS Reference ID: ED57340

EMSL Customer ID: ROCL63

Attention: Dawn Izenman
Rockland Boces (Health & Safety Dept.) [ROCL63]
65 Parrott Road Bldg. 4
West Nyack, NY 10994
(845) 627-4764
dizenman@rboces.org

Project Name: 2025 South Orangetown, Tappan Zee Elementary School
Project ID: _Master Project-ROCL63
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/22/2025 10:14
Reported: 12/04/2025 15:55

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 2025-SO-TZE-31/Classroom 402 (BOCES Main Office) Sink Faucet (Continued)									
			Lims Reference ID: ED57340-31		Matrix: Drinking Water			Sampled: 11/21/25 00:00:00	
Metals									
Lead	4.6		1	1.0	µg/L	11/26/25 23:13	11/26/25 23:13	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: 2025-SO-TZE-32/Classroom 402 (BOCES Main Office) Sink Fountain									
			Lims Reference ID: ED57340-32		Matrix: Drinking Water			Sampled: 11/21/25 00:00:00	
Metals									
Lead	1.5		1	1.0	µg/L	11/26/25 23:15	11/26/25 23:15	DAZ	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557340

LIMS Reference ID: ED57340

EMSL Customer ID: ROCL63

Attention: Dawn Izenman
Rockland Boces (Health & Safety Dept.) [ROCL63]
65 Parrott Road Bldg. 4
West Nyack, NY 10994
(845) 627-4764
dizenman@rboces.org

Project Name: 2025 South Orangetown, Tappan Zee Elementary School

Project ID: _Master Project-ROCL63

Customer PO:

Sales Rep: Jeromy Bish

Received: 11/22/2025 10:14

Reported: 12/04/2025 15:55

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557340

LIMS Reference ID: ED57340

EMSL Customer ID: ROCL63

Attention: Dawn Izenman
Rockland Boces (Health & Safety Dept.) [ROCL63]
65 Parrott Road Bldg. 4
West Nyack, NY 10994
(845) 627-4764
dizenman@rboces.org

Project Name: 2025 South Orangetown, Tappan Zee Elementary School
Project ID: _Master Project-ROCL63
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/22/2025 10:14
Reported: 12/04/2025 15:55

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

ED57340

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

pb 200.8 Kalsch 11/24/25

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
2025-SO-TZE-6	Classroom 108 Sink Faucet	250 ml.	11/21/25 6:28 am
2025-SO-TZE-7	Classroom 107 A/B Sink Faucet	250 ml.	11/21/25 6:43 am
2025-SO-TZE-8	Classroom 104 (Staff Lounge) Sink Faucet	250 ml.	11/21/25 6:44 am
2025-SO-TZE-9	Room 120 (Custodial Office) Sink Faucet	250 ml.	11/21/25 7:04 am
2025-SO-TZE-10	Nurses Office (Room 105) Main Area Sink Faucet	250 ml.	11/21/25 6:45 am
2025-SO-TZE-11	Classroom 204 Sink Faucet	250 ml.	11/21/25 6:29 am
2025-SO-TZE-12	Classroom 205 Sink Faucet	250 ml.	11/21/25 6:30 am
2025-SO-TZE-13	Classroom 206 Sink Faucet	250 ml.	11/21/25 6:31 am
2025-SO-TZE-14	Classroom 207 Sink Faucet	250 ml.	11/21/25 6:31 am
2025-SO-TZE-15	Classroom 208 Sink Faucet	250 ml.	11/21/25 6:32 am
2025-SO-TZE-16	Classroom 209 Sink Faucet	250 ml.	11/21/25 6:33 am
2025-SO-TZE-17	Classroom 211 Sink Faucet	250 ml.	11/21/25 6:36 am
2025-SO-TZE-18	Classroom 212 Sink Faucet	250 ml.	11/21/25 6:37 am
2025-SO-TZE-19	Classroom 213 Sink Faucet	250 ml.	11/21/25 6:38 am
2025-SO-TZE-20	Classroom 214 Sink Faucet	250 ml.	11/21/25 6:36 am
2025-SO-TZE-21	Classroom 215 Sink Faucet	250 ml.	11/21/25 6:39 am
2025-SO-TZE-22	Classroom 216 Sink Faucet	250 ml.	11/21/25 6:40 am
2025-SO-TZE-23	Classroom 306 Sink Faucet	250 ml.	11/21/25 6:47 am
2025-SO-TZE-24	"Hallway Outside Room 305 - Water Cooler Fountain (Combo Unit) - Mouth"	250 ml.	11/21/25 6:50 am
2025-SO-TZE-25	Hallway Outside Room 305 - Water Cooler Fountain (Combo Unit) - Bottle Filler	250 ml.	11/21/25 6:50 am
2025-SO-TZE-26	Classroom 307 Classroom Sink Faucet	250 ml.	11/21/25 6:52 am
2025-SO-TZE-27	Classroom 308 Sink Faucet	250 ml.	11/21/25 6:52 am
2025-SO-TZE-28	Classroom 310 Faucet	250 ml.	11/21/25 6:54 am
2025-SO-TZE-29	Classroom 314 Faucet	250 ml.	11/21/25 7:00 am
2025-SO-TZE-30	Classroom 401 (BOCES Guidance Office) Sink Fountain	250 ml.	11/21/25 6:57 am

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
NOV 22 25 - AM 10:14

Method of Shipment:		Sample Condition Upon Receipt:	
Relinquished by: Chris Clifford	Date/Time: 11/21/25	Received by: Sean Wolf	Date/Time: 11/20/25 10:14 AM
Relinquished by:	Date/Time:	Received by:	Date/Time:

Controlled Document - COC-25 Lead R18 04/04/2024

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

