

2/S1.1 SECTION
SCALE 1/2"=1'-0"

1/S1.1 SECTION
SCALE 1/2"=1'-0"



INT. COL W/O PIER



COL W/PIER

4/S1.1 SECTION
SCALE 1/2"=1'-0"

3/S1.1 SECTION
SCALE 1/2"=1'-0"



5/S1.1 PLAN DETAIL
SCALE 1/2"=1'-0"



6/S1.1 SECTION
SCALE 1/2"=1'-0"



CONST. JOINT

FOOTING SCHEDULE

MARK	SIZE	BOTTOM REINFORCING EACH WAY	REMARKS
F-1	3'-0"x 3'-0"x1'-0"	4 #4	
F-2	4'-0"x4'-0"x1'-0"	5#4	
F-3	5'-0"x 5'-0"x1'-0"	5#6	
F-4	3'-0"x 7'-6"x1'-0"	4#4 LW 7#4 SW	
F-5	4'-0"x 7'-6"x1'-0"	4#4 LW 7#4 SW	

COMPRESSIVE STRENGTH TABLE

USE	SLUMP	28 DAY STRENGTH
FOUNDATIONS, SLABS ON GRADE AND ON METAL DECK, MISC. INTERIOR CONCRETE.	2"-4"	3000 PSI
EXTERIOR, WALKS, PAVEMENTS MISC. CONCRETE EXPOSED TO WEATHER.	2"-3"	4000 PSI (AIR - ENTRAINED)

GENERAL FOUNDATION AND CONCRETE NOTES
(EXCEPT AS OTHERWISE SHOWN OR NOTED)

1. FOOTINGS SHALL BEAR ON FIRM UNDISTURBED SOIL OF 3000 PSF BEARING CAPACITY. IF POOR SOIL IS ENCOUNTERED AT DEPTHS INDICATED, NOTIFY THE ARCHITECT IMMEDIATELY BEFORE PROCEEDING IN THAT AREA.
2. CONTRACTOR SHALL NOTIFY SOIL LAB 24 HOURS BEFORE BEING REQUIRED ON JOB.
3. ALL CONCRETE SHALL BE NORMAL WEIGHT CONCRETE WITH THE SLUMP AND MINIMUM COMPRESSIVE STRENGTH INDICATED ON THE CONCRETE COMPRESSIVE STRENGTH TABLE.
4. REINFORCING STEEL SHALL CONFORM TO ASTM A615 GRADE 60.
5. REINFORCING SHALL BE CONTINUOUS; LAP 30 BAR DIA. AT SPLICES AND CONTINUE AROUND CORNERS.
6. SLABS CAST ON GRADE SHALL BE TYPICALLY 5" THICK, REINFORCED WITH 6 X 6 W2.1 X W2.1 WELDED WIRE FABRIC ABOVE CENTER OF SLAB.
7. PROVIDE 4" MIN. MDOT CLASS II GRANULAR FILL UNDER SLABS ON GRADE. COMPACT TO 95% MAXIMUM DENSITY IN ACCORDANCE WITH ASTM D1557.
8. CONTRACTOR SHALL ENSURE STABILITY OF FOUNDATION WALLS DURING CONSTRUCTION BY BRACING AS REQUIRED.
9. CONTRACTOR SHALL REFER TO ARCHITECTURAL DRAWINGS FOR COORDINATION OF STRUCTURAL DRAWING DIMENSIONS.
10. REFER TO CIVIL AND MECHANICAL DRAWINGS FOR THE LOCATION OF UNDERGROUND UTILITIES AND EXISTING SITE CONDITIONS.
11. LOCATE ALL SLEEVES, OPENINGS, DEPRESSIONS, AND EMBEDDED ITEMS WHICH ARE INDICATED ON OTHER DESIGN DRAWINGS PRIOR TO THE PLACING OF CONCRETE IN THE AREA INVOLVED.

FOUNDATION PLAN
SCALE 1/8"=1'-0"



TMP
TMP Associates, Inc.
Architects Engineers Planners
1191 W. Square Lake Rd.
P.O. Box 289
Bloomfield Hills, Mich.
48303-0289
(313) 338-4561

project title
Marshall Elementary Renovation

Livonia Public Schools

sheet title
Foundation Plan and Details Zone "A"

date	issued for
8-24-92	BIDS
8-17-92	9590 REVIEW
5-26-92	DESIGN DEV.

drawn BDM
checked TAB
approved TAB

job no.
92014

sheet no.
S1.1



BASE PL DETAIL FOR SUNSCREEN POSTS

NO SCALE



2/S1.2 SECTION

SCALE ¾"=1'-0"



1/S1.2 SECTION

SCALE ¾"=1'-0"



TYPICAL BASE PLATE DETAIL

DESIGN ROOF LOAD - TYPICAL

LIVE LOAD	* 30 PSF
DEAD LOAD	
RFG. & INS.	10 PSF
STEEL	4 PSF
METAL DECK	3 PSF
MISC.	8 PSF
TOTAL DEAD LOAD	25 PSF

GENERAL NOTES - STRUCTURAL STEEL
(EXCEPT AS OTHERWISE SHOWN OR NOTED)

1. STRUCTURAL STEEL SHALL MEET THE REQUIREMENTS OF THE AISC SPEC. FOR THE DESIGN, FABRICATION, AND ERECTION OF STRUCTURAL STEEL FOR BUILDINGS, LATEST EDITION.
2. ALL STRUCTURAL STEEL SHALL BE ASTM A36 UNLESS OTHERWISE NOTED. SQUARE AND RECTANGULAR TUBES SHALL CONFORM TO ASTM A500 WITH A Fy = 46 ksi. PIPE COLUMNS SHALL CONFORM TO ASTM A-53 WITH A Fy = 36 ksi.
3. ALL FIELD CONNECTIONS SHALL BE MADE WITH 3/4" DIA. ASTM A325N BEARING TYPE BOLTS (WITH THREADS ASSUMED IN THE SHEAR PLANE) UNLESS OTHERWISE NOTED.
4. ALL ROOF BEAM END CONNECTIONS SHALL BE DOUBLE ANGLES CAPABLE OF SUPPORTING 50% OF THE TOTAL UNIFORM LOAD CAPACITY OF THE BEAM UNLESS OTHERWISE NOTED. CONNECTION ANGLES SHALL BE 5/16" MINIMUM THICKNESS.
5. ALL TUBE AND PIPE COLUMN CONNECTIONS TO BE THRU PLATE TYPE WITH 3/8" MINIMUM THICKNESS OR DOUBLE ANGLES.
6. SEE ARCHITECTURAL DRAWINGS FOR ANGLES, CLIPS, BARS, PLATES AND OTHER ITEMS ATTACHED TO STRUCTURAL MEMBERS.
7. VERIFY SIZE AND LOCATION OF ROOF OPENINGS WITH MECHANICAL CONTRACTOR.
8. PROVIDE TEMPORARY BRACING AS REQUIRED TO MAINTAIN ALIGNMENT AND SECURITY OF STRUCTURE DURING CONSTRUCTION.
9. DO NO CUTTING, DRILLING OR MODIFYING OF STRUCTURAL MEMBERS WITHOUT THE APPROVAL OF THE ARCHITECT.
10. CONTRACTOR SHALL VERIFY PERTINENT DIMENSIONS AND CONDITIONS IN THE FIELD AND REPORT ANY DISCREPANCIES TO THE ARCHITECT BEFORE PROCEEDING WITH THE WORK.
11. STEEL JOISTS SHALL BE DESIGNED AND FABRICATED IN ACCORDANCE WITH THE STANDARDS OF THE STEEL JOIST INSTITUTE.
12. ADJACENT OPEN WEB STEEL JOISTS OF SAME DEPTH AND SPAN SHALL HAVE PANEL POINTS ALIGNED FOR CLEAR PASSAGE OF ELECTRICAL AND MECHANICAL SERVICES.



BASE PL DETAIL FOR 6"Ø PIPE COLUMN

NO SCALE



BASE PL DETAIL FOR TS 4x4 & TS 5x5 COL.

NO SCALE



3/S1.2 SECTION

SCALE ¾"=1'-0"


EX. 12 LF 23
EX. 10 LF 29
EX. 12 LF 27
EX. 12 LF 31
EX. 10 LF 25 CONT
EX. 12 LF 29
EX. 12 LF 21
EX. 12 LF 27 CONT
EX. 12 LF 27 CONT (-2'-2½")
EX. 12816.5
EX. 12816.5 BOD EL +10'-3⅜"
EX. 10815
EX. 10817
EX. 10811.5
EX. 2x4 - 4x3x¼
EX. 4 LF 13
EX. 4 LF 15
EX. 8 LF 10
EX. 3" MTL DECK
EX. 3½"Ø PIPE COL. TYP.
EX. 3½"Ø PIPE COL. TYP.
EX. 2½" LT. WT. CONC. ON METAL FORM DECK
EX. 2½" LT. WT. CONC. ON METAL FORM DECK
EX. 2057 W14 ROWS 8 RDG
EX. 2057 W14 ROWS 8 RDG
EX. 145'@ 4'-0" O.C.
EX. 2 L 2½x2½x¼
W10x12
W8x10
W14x28
W14x22
W10x12
W6x9
W18x40
W12x40
W18x35
W12x19
W12x14
W18x50
W10x22
W10x45
W10x49
W10x12
W8x10
W8x10
W8x10