

December 10, 2025

James Hart
North Tonawanda City Schools
176 Walck Road
North Tonawanda, New York 14120

Re: Lead Testing in School Drinking Water

Dear Mr. James Hart:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for North Tonawanda City Schools, including:

- **North Tonawanda High School – 405 Meadow Dr, North Tonawanda, New York**

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: *Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on October 31, 2025. As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 25 sources of potable water in North Tonawanda High School have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion. To comply with NYS regulations, response actions by the district are required. Response actions are outlined in Section 1.3 (*Response Actions Required Under NYS Regulations*).

Thank you for the opportunity to be of service to North Tonawanda City Schools.

Sincerely,
Stohl Environmental, LLC.



Michael Scinta
EPA Lead Risk Assessor

Lead Testing in School Drinking Water

Prepared for:

North Tonawanda City Schools

Prepared by:



**3860 California Road
Orchard Park, New York 14127**

Conditions as of October 30, 2025 / October 31, 2025

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports and Chain of Custody Documents
- 1.5. Laboratory Certifications

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by North Tonawanda City Schools to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- **North Tonawanda High School – 405 Meadow Dr, North Tonawanda, New York**

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within North Tonawanda High School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, **Subpart 67-4: Lead Testing in School Drinking Water**, and the EPA guidance document, **3Ts for Reducing Lead in Drinking Water in Schools**, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at North Tonawanda High School:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
High School	10/30/2025 / 10/31/2025	83	58	25

*NYS Action Level is 5 parts per billion

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis
			(in ppb)
118.7-06	Kitchen 3 Bay Left	Sink	10.7
118.7-15	Room 160 Left	Sink	41.6
118.7-16	Room 160 Center	Sink	37.3
118.7-17	Room 160 Right	Sink	11.0
118.7-18	Room 160 Bubbler	DF	21.3
118.7-25	Room 123	Sink	18.9
118.7-27	Room 128	Sink	11.6
118.7-28	Room 130	Sink	10.1
118.7-29	Room 132 Southeast Left Far From Door Back Wall	Sink	6.2
118.7-30	Room 132 Southwest Sink Left Closest Door	Sink	11.7
118.7-41	Room 322	Sink	7.5
118.7-43	3rd Floor Women's Faculty	Sink	5.5
118.7-44	3rd Floor Men's Faculty	Sink	9.0
118.7-45	Room 308 Left	Sink	62.6
118.7-46	Room 308 Right	Sink	54.8
118.7-48	Nurse's Sink Back Left Exam Room By BR	Sink	85.9
118.7-49	Nurse's Main Sink By Fridge and Windows	Sink	10.0
118.7-50	Nurse's Right Exam Room Behind Desk	Sink	12.9

Sample #	Location	Fixture/Outlet type	Laboratory Analysis
			(in ppb)
118.7-56	Old Gym Girl's Locker Right	Sink	10.2
118.7-57	Basement Maintenance Breakroom	Sink	10.1
118.7-58	Library (Backroom)	Sink	10.5
118.7-60	Old Gym Boys' Locker Coach Office	Sink	11.0
118.7-62	W. Officials	Sink	5.7
118.7-73	Coach/Trainer Office Lav Outside New Gym	Sink	6.3
118.7-84	Varsity Locker Room Spigot	Spigot	31.4

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration more than the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports and Chain of Custody Documents



December 04, 2025

Service Request No:R2514881

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: North Tonawanda - High School

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory November 07, 2025
For your reference, these analyses have been assigned our service request number **R2514881**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: North Tonawanda - High School
Sample Matrix: Drinking Water

Service Request: R2514881
Date Received: 11/07/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 11/07/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 12/04/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 118.7-01		Lab ID: R2514881-001					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.3			1.0	ug/L	200.8	
CLIENT ID: 118.7-06		Lab ID: R2514881-006					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	10.7			1.0	ug/L	200.8	
CLIENT ID: 118.7-07		Lab ID: R2514881-007					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.5			1.0	ug/L	200.8	
CLIENT ID: 118.7-09		Lab ID: R2514881-009					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.0			1.0	ug/L	200.8	
CLIENT ID: 118.7-10		Lab ID: R2514881-010					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.1			1.0	ug/L	200.8	
CLIENT ID: 118.7-11		Lab ID: R2514881-011					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.5			1.0	ug/L	200.8	
CLIENT ID: 118.7-14		Lab ID: R2514881-015					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.1			1.0	ug/L	200.8	
CLIENT ID: 118.7-15		Lab ID: R2514881-016					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	41.6			1.0	ug/L	200.8	
CLIENT ID: 118.7-16		Lab ID: R2514881-017					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	37.3			1.0	ug/L	200.8	
CLIENT ID: 118.7-17		Lab ID: R2514881-018					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	11.0			1.0	ug/L	200.8	
CLIENT ID: 118.7-18		Lab ID: R2514881-019					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	21.3			1.0	ug/L	200.8	
CLIENT ID: 118.7-20		Lab ID: R2514881-022					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.4			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 118.7-22		Lab ID: R2514881-024					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.7			1.0	ug/L	200.8	
CLIENT ID: 118.7-23		Lab ID: R2514881-025					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.1			1.0	ug/L	200.8	
CLIENT ID: 118.7-24		Lab ID: R2514881-026					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.9			1.0	ug/L	200.8	
CLIENT ID: 118.7-25		Lab ID: R2514881-027					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	18.9			1.0	ug/L	200.8	
CLIENT ID: 118.7-27		Lab ID: R2514881-029					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	11.6			1.0	ug/L	200.8	
CLIENT ID: 118.7-28		Lab ID: R2514881-030					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	10.1			1.0	ug/L	200.8	
CLIENT ID: 118.7-29		Lab ID: R2514881-031					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	6.2			1.0	ug/L	200.8	
CLIENT ID: 118.7-30		Lab ID: R2514881-032					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	11.7			1.0	ug/L	200.8	
CLIENT ID: 118.7-31		Lab ID: R2514881-033					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.8			1.0	ug/L	200.8	
CLIENT ID: 118.7-32		Lab ID: R2514881-034					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.1			1.0	ug/L	200.8	
CLIENT ID: 118.7-33A		Lab ID: R2514881-035					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.0			1.0	ug/L	200.8	



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7

Service Request:R2514881

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2514881-001	118.7-01	10/30/2025	
R2514881-002	118.7-02	10/30/2025	
R2514881-003	118.7-03	10/30/2025	
R2514881-004	118.7-04	10/30/2025	
R2514881-005	118.7-05	10/30/2025	
R2514881-006	118.7-06	10/30/2025	
R2514881-007	118.7-07	10/30/2025	
R2514881-008	118.7-08	10/30/2025	
R2514881-009	118.7-09	10/30/2025	
R2514881-010	118.7-10	10/30/2025	
R2514881-011	118.7-11	10/30/2025	
R2514881-012	118.7-12	10/30/2025	
R2514881-013	118.7-13A	10/30/2025	
R2514881-014	118.7-13B	10/30/2025	
R2514881-015	118.7-14	10/30/2025	
R2514881-016	118.7-15	10/30/2025	
R2514881-017	118.7-16	10/30/2025	
R2514881-018	118.7-17	10/30/2025	
R2514881-019	118.7-18	10/30/2025	
R2514881-020	118.7-19A	10/30/2025	
R2514881-021	118.7-19B	10/30/2025	
R2514881-022	118.7-20	10/30/2025	
R2514881-023	118.7-21	10/30/2025	
R2514881-024	118.7-22	10/30/2025	
R2514881-025	118.7-23	10/30/2025	
R2514881-026	118.7-24	10/30/2025	
R2514881-027	118.7-25	10/30/2025	
R2514881-028	118.7-26	10/30/2025	
R2514881-029	118.7-27	10/30/2025	
R2514881-030	118.7-28	10/30/2025	
R2514881-031	118.7-29	10/30/2025	
R2514881-032	118.7-30	10/30/2025	
R2514881-033	118.7-31	10/30/2025	
R2514881-034	118.7-32	10/30/2025	
R2514881-035	118.7-33A	10/30/2025	
R2514881-036	118.7-33B	10/30/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-118.7

Client: North Tonawanda CSD

Contact: James Hart

Building: North Tonawanda High School

Location: 405 Meadow Dr, North Tonawanda, NY 14120

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
118.7-01	Kitchen Serving Handwash North	Sink	4:50
118.7-02	Kitchen Dish Sprayer North Cafe Side	Sink	4:50
118.7-03	Kitchen Single Bay North Cafe Side - Serving Line	Sink	4:51
118.7-04	Kitchen Handwash North Wall Center Room-Serving	Sink	4:52
118.7-05	Kitchen Single Bay Across From 3 Bay	Sink	4:52
118.7-06	Kitchen 3 Bay Left	Sink	4:53
118.7-07	Kitchen 3 Bay Right	Sink	4:54
118.7-08	Kitchen Single Bay Center Prep-Across From Pot Fill	Sink	4:54
118.7-09	Pot Fill	Pot Filler	4:55
118.7-10	Kitchen Handwash South Wall Center Room	Sink	4:56
118.7-11	Kitchen Dish Sprayer South Cafe Side	Sink	4:56
118.7-12	Kitchen Single Bay South Cafe Side	Sink	4:57
118.7-13 A	Fountain in North Cafeteria	DF	5:10
118.7-13 B	Fountain in North Cafeteria	DFB	5:12
118.7-14	Studio D Sink (162/Band Room Middle Corridor)	Sink	5:15
118.7-15	Room 160 Left	Sink	5:18
118.7-16	Room 160 Center	Sink	5:20
118.7-17	Room 160 Right	Sink	5:23

Notes:
 Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to: Mscinta@stohlenvironmental.com

Sampled By: Isaia Sciabarrasi Print Name Isaia Sciabarrasi Stohl Env: Isaia Sciabarrasi Date: 10/30/2025
 Relinquished By: _____ Print Name _____ Stohl Env: Connor Crilly Date: 11/6/2025
 Received (Name / Lab): [Signature] Date: 11/7/25 Time: 08:00
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

R2514881 **5**
 Stohl Environmental
 North Tonawanda - High School



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-118.7

Client: North Tonawanda CSD

Contact: James Hart

Building: North Tonawanda High School

Location: 405 Meadow Dr, North Tonawanda, NY 14120

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
118.7-18	Room 160 Bubbler	DF	5:26
118.7-19 A	Corridor Outside 1st Floor Women's Faculty	DF	5:28
118.7-19 B	Corridor Outside 1st Floor Women's Faculty	DFB	5:31
118.7-20	1st Floor Women's Faculty Left	Sink	5:34
118.7-21	1st Floor Women's Faculty Right	Sink	5:36
118.7-22	1st Floor Men's Faculty - Now "ALE"	Sink	5:39
118.7-23	Corridor Outside 112	DF	5:42
118.7-24	Guidance Office	Sink	5:44
118.7-25	Room 123	Sink	5:47
118.7-26	Room 125	Sink	5:50
118.7-27	Room 128	Sink	5:52
118.7-28	Room 130	Sink	5:55
118.7-29	Room 132 Southeast Left Far From Door Back Wall	Sink	5:58
118.7-30	Room 132 Southwest Sink Left Closest Door	Sink	6:00
118.7-31	Room 132 Northwest Right By Windows Back Wall	Sink	6:03
118.7-32	Room 132 Northeast Right Window Closest to Door	Sink	6:06
118.7-33 A	Science Wing Corridor Between B/G Lavs	DF	6:08
118.7-33 B	Science Wing Corridor Between B/G Lavs	DFB	6:11

Notes:

Please e-mail lab results to labs@stohlenv.com

Mscinta@stohlenvironmental.com

Sampled By: Isaia Sciabarrasi Print Name Isaia Sciabarrasi Stohl Env: Isaia Sciabarrasi Date: 10/30/2025

Relinquished By: [Signature] Print Name Connor Crilly Stohl Env: Connor Crilly Date: 11/6/2025

Received (Name / Lab): [Signature] Date: 11/7/25 Time: 08:00

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



R2514881

5

Stohl Environmental
North Tonawanda - High School



Cooler Receipt and Preservation Check Form

Project/Client Stohl Env. Folder Number _____

Cooler received on 11/7/25 by: KE

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler? <u>KE 11/7/25</u>	Y	N	5a	Did VOA vials have sig* bubbles?	Y	N	NA
2	Custody papers properly completed (ink, signed)?	Y	N	5b	Sig* bubbles: Alk?	Y	N	NA
3	Did all bottles arrive in good condition (unbroken)?	Y	N	6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT		
4	Circle: Wet Ice Dry Ice Gel packs present?	Y	N	7	Soil VOA received as:	Bulk	Encore	5035set <u>NA</u>

8. Temperature Readings Date: 11/7/25 Time: 08:20 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>KE 11/7/25</u>	<u>8.2</u>						
Within 0-6°C?	Y	N	Y	N	Y	N	Y	N
If <0°C, were samples frozen?	Y	N	Y	N	Y	N	Y	N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule

& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMD by KE on 11/7/25 at 08:30
 5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 11/12/25 Time: 11:30 by: TOP

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A
- 14. Air Samples: Cassettes / Tubes Intact Y/N with MS Y/N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
<u>2</u>	<u>202325</u>	HNO ₃		✓			<u>211</u>	<u>4mL</u>	<u>244318</u>	<u>2.2</u>
<u>2</u>		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 081125-2ADD
Explain all Discrepancies/ Other Comments:

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: TOP *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7

Service Request: R2514881

Sample Name: 118.7-01
Lab Code: R2514881-001
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-02
Lab Code: R2514881-002
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-03
Lab Code: R2514881-003
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-04
Lab Code: R2514881-004
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-05
Lab Code: R2514881-005
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7

Service Request: R2514881

Sample Name: 118.7-06
Lab Code: R2514881-006
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-07
Lab Code: R2514881-007
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-08
Lab Code: R2514881-008
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-09
Lab Code: R2514881-009
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-10
Lab Code: R2514881-010
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7

Service Request: R2514881

Sample Name: 118.7-11
Lab Code: R2514881-011
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-12
Lab Code: R2514881-012
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-13A
Lab Code: R2514881-013
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-13B
Lab Code: R2514881-014
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-14
Lab Code: R2514881-015
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7

Service Request: R2514881

Sample Name: 118.7-15
Lab Code: R2514881-016
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-16
Lab Code: R2514881-017
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-17
Lab Code: R2514881-018
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-18
Lab Code: R2514881-019
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-19A
Lab Code: R2514881-020
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7

Service Request: R2514881

Sample Name: 118.7-19B
Lab Code: R2514881-021
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-20
Lab Code: R2514881-022
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-21
Lab Code: R2514881-023
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-22
Lab Code: R2514881-024
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-23
Lab Code: R2514881-025
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7

Service Request: R2514881

Sample Name: 118.7-24
Lab Code: R2514881-026
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-25
Lab Code: R2514881-027
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-26
Lab Code: R2514881-028
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-27
Lab Code: R2514881-029
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-28
Lab Code: R2514881-030
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7

Service Request: R2514881

Sample Name: 118.7-29
Lab Code: R2514881-031
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-30
Lab Code: R2514881-032
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-31
Lab Code: R2514881-033
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-32
Lab Code: R2514881-034
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-33A
Lab Code: R2514881-035
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental

Service Request: R2514881

Project: North Tonawanda - High School/2023L-118.7

Sample Name: 118.7-33B

Date Collected: 10/30/25

Lab Code: R2514881-036

Date Received: 11/7/25

Sample Matrix: Drinking Water

Analysis Method

Extracted/Digested By

Analyzed By

200.8

MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-01
Lab Code: R2514881-001

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	12/02/25 13:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-02
Lab Code: R2514881-002

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 13:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-03
Lab Code: R2514881-003

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 13:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-04
Lab Code: R2514881-004

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 13:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-05
Lab Code: R2514881-005

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 13:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-06
Lab Code: R2514881-006

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	10.7	ug/L	1.0	1	12/02/25 13:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-07
Lab Code: R2514881-007

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	12/02/25 13:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-08
Lab Code: R2514881-008

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 13:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-09
Lab Code: R2514881-009

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.0	ug/L	1.0	1	12/02/25 13:24	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-10
Lab Code: R2514881-010

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	12/02/25 13:25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-11
Lab Code: R2514881-011

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	12/02/25 13:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-12
Lab Code: R2514881-012

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 13:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-13A
Lab Code: R2514881-013

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 13:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-13B
Lab Code: R2514881-014

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 13:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-14
Lab Code: R2514881-015

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	12/02/25 13:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-15
Lab Code: R2514881-016

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	41.6	ug/L	1.0	1	12/02/25 13:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-16
Lab Code: R2514881-017

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	37.3	ug/L	1.0	1	12/02/25 13:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-17
Lab Code: R2514881-018

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	11.0	ug/L	1.0	1	12/02/25 13:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-18
Lab Code: R2514881-019

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	21.3	ug/L	1.0	1	12/02/25 13:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-19A
Lab Code: R2514881-020

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 13:56	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-19B
Lab Code: R2514881-021

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 13:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-20
Lab Code: R2514881-022

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.4	ug/L	1.0	1	12/02/25 13:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-21
Lab Code: R2514881-023

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 14:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-22
Lab Code: R2514881-024

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	12/02/25 14:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-23
Lab Code: R2514881-025

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.1	ug/L	1.0	1	12/02/25 14:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-24
Lab Code: R2514881-026

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.9	ug/L	1.0	1	12/02/25 14:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-25
Lab Code: R2514881-027

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	18.9	ug/L	1.0	1	12/02/25 14:07	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-26
Lab Code: R2514881-028

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 14:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-27
Lab Code: R2514881-029

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	11.6	ug/L	1.0	1	12/02/25 14:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-28
Lab Code: R2514881-030

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	10.1	ug/L	1.0	1	12/02/25 14:14	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-29
Lab Code: R2514881-031

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.2	ug/L	1.0	1	12/02/25 14:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-30
Lab Code: R2514881-032

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	11.7	ug/L	1.0	1	12/02/25 14:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-31
Lab Code: R2514881-033

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.8	ug/L	1.0	1	12/02/25 14:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-32
Lab Code: R2514881-034

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.1	ug/L	1.0	1	12/02/25 14:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-33A
Lab Code: R2514881-035

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0	ug/L	1.0	1	12/02/25 14:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-33B
Lab Code: R2514881-036

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 14:36	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2514881-MB1

Service Request: R2514881
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 12:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2514881-MB2

Service Request: R2514881
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 13:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2514881-MB3

Service Request: R2514881
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 14:25	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25
Date Analyzed: 12/2/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 118.7-12
Lab Code: R2514881-012
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2514881-012MS		Duplicate Matrix Spike R2514881-012DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	22.8	20.0	114	22.8	20.0	114	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25
Date Analyzed: 12/2/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 118.7-13A
Lab Code: R2514881-013
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2514881-013MS		Duplicate Matrix Spike R2514881-013DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	22.5	20.0	113	22.7	20.0	113	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25
Date Analyzed: 12/2/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 118.7-30
Lab Code: R2514881-032
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2514881-032MS		Duplicate Matrix Spike R2514881-032DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	11.7	35.3	20.0	118	35.2	20.0	118	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water

Service Request: R2514881
Date Collected: 10/30/25
Date Received: 11/07/25
Date Analyzed: 12/2/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 118.7-31
Lab Code: R2514881-033
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2514881-033MS		Duplicate Matrix Spike R2514881-033DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	3.8	26.1	20.0	111	25.8	20.0	110	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water

Service Request: R2514881
Date Analyzed: 12/02/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2514881-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.2	20.0	111	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water

Service Request: R2514881
Date Analyzed: 12/02/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2514881-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.0	20.0	110	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: North Tonawanda - High School/2023L-118.7
Sample Matrix: Drinking Water

Service Request: R2514881

Date Analyzed: 12/02/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample
R2514881-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.3	20.0	106	85-115



December 08, 2025

Service Request No:R2514883

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: North Tonawanda CSD - High School

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory November 07, 2025
For your reference, these analyses have been assigned our service request number **R2514883**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | **FAX** +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: North Tonawanda CSD - High School
Sample Matrix: Drinking Water

Service Request: R2514883
Date Received: 11/07/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Forty seven drinking water samples were received for analysis at ALS Environmental on 11/07/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 12/08/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 118.7-38A		Lab ID: R2514883-008					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.9			1.0	ug/L	200.8	
CLIENT ID: 118.7-38B		Lab ID: R2514883-009					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.1			1.0	ug/L	200.8	
CLIENT ID: 118.7-39		Lab ID: R2514883-010					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.9			1.0	ug/L	200.8	
CLIENT ID: 118.7-40		Lab ID: R2514883-011					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.5			1.0	ug/L	200.8	
CLIENT ID: 118.7-41		Lab ID: R2514883-012					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	7.5			1.0	ug/L	200.8	
CLIENT ID: 118.7-43		Lab ID: R2514883-015					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.5			1.0	ug/L	200.8	
CLIENT ID: 118.7-44		Lab ID: R2514883-016					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	9.0			1.0	ug/L	200.8	
CLIENT ID: 118.7-45		Lab ID: R2514883-017					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	62.6			1.0	ug/L	200.8	
CLIENT ID: 118.7-46		Lab ID: R2514883-018					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	54.8			1.0	ug/L	200.8	
CLIENT ID: 118.7-48		Lab ID: R2514883-020					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	85.9			1.0	ug/L	200.8	
CLIENT ID: 118.7-49		Lab ID: R2514883-021					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	10.0			1.0	ug/L	200.8	
CLIENT ID: 118.7-50		Lab ID: R2514883-022					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	12.9			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 118.7-54		Lab ID: R2514883-023					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.8			1.0	ug/L	200.8	
CLIENT ID: 118.7-55		Lab ID: R2514883-024					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.4			1.0	ug/L	200.8	
CLIENT ID: 118.7-56		Lab ID: R2514883-025					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	10.2			1.0	ug/L	200.8	
CLIENT ID: 118.7-57		Lab ID: R2514883-026					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	10.1			1.0	ug/L	200.8	
CLIENT ID: 118.7-58		Lab ID: R2514883-027					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	10.5			1.0	ug/L	200.8	
CLIENT ID: 118.7-59		Lab ID: R2514883-028					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.9			1.0	ug/L	200.8	
CLIENT ID: 118.7-60		Lab ID: R2514883-029					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	11.0			1.0	ug/L	200.8	
CLIENT ID: 118.7-62		Lab ID: R2514883-032					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.7			1.0	ug/L	200.8	
CLIENT ID: 118.7-63		Lab ID: R2514883-033					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.5			1.0	ug/L	200.8	
CLIENT ID: 118.7-65		Lab ID: R2514883-035					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.3			1.0	ug/L	200.8	
CLIENT ID: 118.7-66		Lab ID: R2514883-036					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.7			1.0	ug/L	200.8	
CLIENT ID: 118.7-67		Lab ID: R2514883-037					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.2			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 118.7-68	Lab ID: R2514883-038					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.5			1.0	ug/L	200.8

CLIENT ID: 118.7-71	Lab ID: R2514883-042					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.8			1.0	ug/L	200.8

CLIENT ID: 118.7-72	Lab ID: R2514883-043					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.6			1.0	ug/L	200.8

CLIENT ID: 118.7-73	Lab ID: R2514883-044					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.3			1.0	ug/L	200.8

CLIENT ID: 118.7-75	Lab ID: R2514883-046					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.9			1.0	ug/L	200.8

CLIENT ID: 118.7-84	Lab ID: R2514883-047					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	31.4			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7

Service Request:R2514883

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2514883-001	118.7-34	10/30/2025	
R2514883-002	118.7-35A	10/30/2025	
R2514883-003	118.7-35B	10/30/2025	
R2514883-004	118.7-36A	10/30/2025	
R2514883-005	118.7-36B	10/30/2025	
R2514883-006	118.7-37A	10/30/2025	
R2514883-007	118.7-37B	10/30/2025	
R2514883-008	118.7-38A	10/30/2025	
R2514883-009	118.7-38B	10/30/2025	
R2514883-010	118.7-39	10/30/2025	
R2514883-011	118.7-40	10/30/2025	
R2514883-012	118.7-41	10/30/2025	
R2514883-013	118.7-42A	10/30/2025	
R2514883-014	118.7-42B	10/30/2025	
R2514883-015	118.7-43	10/30/2025	
R2514883-016	118.7-44	10/30/2025	
R2514883-017	118.7-45	10/30/2025	
R2514883-018	118.7-46	10/30/2025	
R2514883-019	118.7-47	10/30/2025	
R2514883-020	118.7-48	10/30/2025	
R2514883-021	118.7-49	10/30/2025	
R2514883-022	118.7-50	10/30/2025	
R2514883-023	118.7-54	10/30/2025	
R2514883-024	118.7-55	10/30/2025	
R2514883-025	118.7-56	10/30/2025	
R2514883-026	118.7-57	10/30/2025	
R2514883-027	118.7-58	10/30/2025	
R2514883-028	118.7-59	10/30/2025	
R2514883-029	118.7-60	10/30/2025	
R2514883-030	118.7-61A	10/30/2025	
R2514883-031	118.7-61B	10/30/2025	
R2514883-032	118.7-62	10/30/2025	
R2514883-033	118.7-63	10/30/2025	
R2514883-034	118.7-64	10/30/2025	
R2514883-035	118.7-65	10/30/2025	
R2514883-036	118.7-66	10/30/2025	
R2514883-037	118.7-67	10/30/2025	
R2514883-038	118.7-68	10/30/2025	
R2514883-039	118.7-69	10/30/2025	
R2514883-040	118.7-70A	10/30/2025	
R2514883-041	118.7-70B	10/30/2025	
R2514883-042	118.7-71	10/30/2025	

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7

Service Request:R2514883

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2514883-043	118.7-72	10/30/2025	
R2514883-044	118.7-73	10/30/2025	
R2514883-045	118.7-74	10/30/2025	
R2514883-046	118.7-75	10/30/2025	
R2514883-047	118.7-84	10/30/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-118.7

Client: North Tonawanda CSD

Contact: James Hart

Building: North Tonawanda High School

Location: 405 Meadow Dr, North Tonawanda, NY 14120

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
118.7-34	DF between Men/Women Faculty Brs Right Room 145	DF	6:14
118.7-35 A	Science Wing Corridor Outside Faculty	DF	6:16
118.7-35 B	Science Wing Corridor Outside Faculty	DFB	6:19
118.7-36 A	Corridor Outside 232 Between M/W Lavs	DF	6:22
118.7-36 B	Corridor Outside 232 Between M/W Lavs	DFB	6:24
118.7-37 A	Corridor Outside 214 Between M/W Lavs	DF	6:27
118.7-37 B	Corridor Outside 214 Between M/W Lavs	DFB	6:30
118.7-38 A	Corridor Outside 332 Between M/W Lavs	DF	6:32
118.7-38 B	Corridor Outside 332 Between M/W Lavs	DFB	6:35
118.7-39	Room 326 Left	Sink	6:38
118.7-40	Room 326 Right	Sink	6:40
118.7-41	Room 322	Sink	6:43
118.7-42 A	Corridor Outside 312 Between M/W Lavs	DF	6:46
118.7-42 B	Corridor Outside 312 Between M/W Lavs	DFB	6:48
118.7-43	3rd Floor Women's Faculty	Sink	6:51
118.7-44	3rd Floor Men's Faculty	Sink	6:54
118.7-45	Room 308 Left	Sink	6:56
118.7-46	Room 308 Right	Sink	6:59

Notes:

Please e-mail lab results to labs@stohlenv.com

Mscinta@stohlenvironmental.com

Sampled By: Isaia Sciabarrasi Print Name Isaia Sciabarrasi Stohl Env: Isaia Sciabarrasi Date: 10/30/2025

Relinquished By: [Signature] Print Name Connor Crilly Stohl Env: Connor Crilly Date: 11/6/2025

Received (Name / Lab): [Signature] Date: 11/7/25 Time: 08:00

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

R2514883 5
 Stohl Environmental
 North Tonawanda CSD - High School



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-118.7

Client: North Tonawanda CSD Contact: James Hart

Building: North Tonawanda High School Location: 405 Meadow Dr, North Tonawanda, NY 14120

LEAD		<i>Turnaround</i>
Water by 200.8	<u>X</u>	<u>10 Days</u>

Sample #	Location	Outlet Type	Time
118.7-47	Nurse's BR Sink	Sink	7:02
118.7-48	Nurse's Sink Back Left Exam Room By BR	Sink	7:04
118.7-49	Nurse's Main Sink By Fridge and Windows	Sink	7:07
118.7-50	Nurse's Right Exam Room Behind Desk	Sink	7:10
118.7-54	Old Gym Girls' Locker Coach Office	Sink	10.31 5:10
118.7-55	Old Gym Girls' Locker Left	Sink	10.31 5:13
118.7-56	Old Gym Girls's Locker Right	Sink	10.31 5:17
118.7-57	Basement Maintenance Breakroom	Sink	10.31 5:20
118.7-58	Library (Backroom)	Sink	10.31 5:24
118.7-59	Old Gym Boys' Locker Left	Sink	10.31 5:27
118.7-60	Old Gym Boys' Locker Coach Office	Sink	10.31 5:31
118.7-61 A	Fountain Outside New Gym	DF	10.31 5:34
118.7-61 B	Fountain Outside New Gym	DFB	10.31 5:38
118.7-62	W. Officials	Sink	10.31 5:41
118.7-63	M. Officials	Sink	10.31 5:45
118.7-64	Athletic Training Room Ice Machine	Ice Machine	10.31 5:48
118.7-65	New Gym Men's Locker Left	Sink	10.31 5:52
118.7-66	New Gym Men's Locker Right	Sink	10.31 5:55

Notes:
 Please e-mail lab results to labs@stohlenv.com Mscinta@stohlenvironmental.com

Sampled By: Isaia Sciabarrasi Print Name Isaia Sciabarrasi Stohl Env: Isaia Sciabarrasi Date: 10/30/2025
 Relinquished By: _____ Print Name _____ Stohl Env: Connor Crilly Date: 11/6/2025
 Received (Name / Lab): [Signature] Date: 11/7/25 Time: 08100
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-118.7

Client: North Tonawanda CSD

Contact: James Hart

Building: North Tonawanda High School

Location: 405 Meadow Dr, North Tonawanda, NY 14120

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
118.7-67	New Gym Women's Locker Fountain	DF	10.31 5:59
118.7-68	New Gym Women's Locker Left	Sink	10.31 6:02
118.7-69	New Gym Women's Locker Right	Sink	10.31 6:06
118.7-70 A	Varsity Locker Room Fountain	DF	10.31 6:09
118.7-70B	Varsity Locker Room Fountain Bottle Fill	DFB	10.31 6:13
118.7-71	Varsity Locker Room Left	Sink	10.31 6:16
118.7-72	Varsity Locker Room Right	Sink	10.31 6:20
118.7-73	Coach/Trainer Office Lav Outside New Gym	Sink	10.31 6:23
118.7-74	Admin Building Hallway Water Cooler 2nd Floor North End	Water Cooler	10.31 6:27
118.7-75	Admin Building Room 11 Breakroom	Sink	10.31 6:30
118.7-84	Varsity Locker Room Spigot	Spigot	10.31 6:55

Notes: Please e-mail lab results to labs@stohlenv.com Mscinta@stohlenvironmental.com

Sampled By: Isaia Sciabarrasi Print Name Isaia Sciabarrasi Stohl Env: Isaia Sciabarrasi Date: 10/30/2025

Relinquished By: [Signature] Print Name Connor Crilly Stohl Env: Connor Crilly Date: 11/6/2025

Received (Name / Lab): [Signature] Date: 11/7/25 Time: 08:00

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Cooler Receipt and Preservation Check Form

R2514883

5

Stohl Environmental
North Tonawanda CSD - High School



Project/Client Stohl Env.

Folder Number _____

Cooler received on 11/7/25

by: ME

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	<u>ME</u>	Y	N
2	Custody papers properly completed (ink, signed)?	<u>ME</u>	Y	N
3	Did all bottles arrive in good condition (unbroken)?	<u>ME</u>	Y	N
4	Circle: Wet Ice Dry Ice Gel packs present?	<u>ME</u>	Y	N

5a	Did VOA vials have sig* bubbles?	Y	N	NA
5b	Sig* bubbles: Alk?	Y	N	NA
	Sulfide?	Y	N	NA
6	Where did the bottles originate?	<u>ALS/ROC</u>	<u>CLIENT</u>	
7	Soil VOA received as: Bulk Encore 5035set	<u>NA</u>		

8. Temperature Readings Date: 11/7/25 Time: 08:20 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>ME</u>	<u>3.2</u>						
Within 0-6°C?	Y	N	Y	N	Y	N	Y	N
If <0°C, were samples frozen?	Y	N	Y	N	Y	N	Y	N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMD by ME on 11/7/25 at 08:30
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 11/12/25 Time: 10:30 by: TSP

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A
- 14. Air Samples: Cassettes / Tubes Intact Y/N with MS Y/N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
2	<u>202325</u>	HNO ₃	<u>✓</u>		<u>24017806</u>	<u>1/27</u>	<u>34-49</u>	<u>4mL</u>	<u>244318</u>	<u><2</u>
2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 072125-2E15, 081125-2ADD
Explain all Discrepancies/ Other Comments:

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: TSP *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7

Service Request: R2514883

Sample Name: 118.7-34
Lab Code: R2514883-001
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-35A
Lab Code: R2514883-002
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-35B
Lab Code: R2514883-003
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-36A
Lab Code: R2514883-004
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-36B
Lab Code: R2514883-005
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7

Service Request: R2514883

Sample Name: 118.7-37A
Lab Code: R2514883-006
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-37B
Lab Code: R2514883-007
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-38A
Lab Code: R2514883-008
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-38B
Lab Code: R2514883-009
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-39
Lab Code: R2514883-010
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7

Service Request: R2514883

Sample Name: 118.7-40
Lab Code: R2514883-011
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-41
Lab Code: R2514883-012
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-42A
Lab Code: R2514883-013
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-42B
Lab Code: R2514883-014
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-43
Lab Code: R2514883-015
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7

Service Request: R2514883

Sample Name: 118.7-44
Lab Code: R2514883-016
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-45
Lab Code: R2514883-017
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 118.7-46
Lab Code: R2514883-018
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-47
Lab Code: R2514883-019
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-48
Lab Code: R2514883-020
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7

Service Request: R2514883

Sample Name: 118.7-49
Lab Code: R2514883-021
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-50
Lab Code: R2514883-022
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-54
Lab Code: R2514883-023
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-55
Lab Code: R2514883-024
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-56
Lab Code: R2514883-025
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7

Service Request: R2514883

Sample Name: 118.7-57
Lab Code: R2514883-026
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-58
Lab Code: R2514883-027
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-59
Lab Code: R2514883-028
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-60
Lab Code: R2514883-029
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-61A
Lab Code: R2514883-030
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7

Service Request: R2514883

Sample Name: 118.7-61B
Lab Code: R2514883-031
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-62
Lab Code: R2514883-032
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-63
Lab Code: R2514883-033
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-64
Lab Code: R2514883-034
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-65
Lab Code: R2514883-035
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7

Service Request: R2514883

Sample Name: 118.7-66
Lab Code: R2514883-036
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-67
Lab Code: R2514883-037
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-68
Lab Code: R2514883-038
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-69
Lab Code: R2514883-039
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-70A
Lab Code: R2514883-040
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7

Service Request: R2514883

Sample Name: 118.7-70B
Lab Code: R2514883-041
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-71
Lab Code: R2514883-042
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-72
Lab Code: R2514883-043
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-73
Lab Code: R2514883-044
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-74
Lab Code: R2514883-045
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7

Service Request: R2514883

Sample Name: 118.7-75
Lab Code: R2514883-046
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 118.7-84
Lab Code: R2514883-047
Sample Matrix: Drinking Water

Date Collected: 10/30/25
Date Received: 11/7/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-34
Lab Code: R2514883-001

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 14:38	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-35A
Lab Code: R2514883-002

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 14:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-35B
Lab Code: R2514883-003

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 14:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-36A
Lab Code: R2514883-004

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 14:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-36B
Lab Code: R2514883-005

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 14:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-37A
Lab Code: R2514883-006

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 14:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-37B
Lab Code: R2514883-007

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 14:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-38A
Lab Code: R2514883-008

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.9	ug/L	1.0	1	12/02/25 14:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-38B
Lab Code: R2514883-009

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.1	ug/L	1.0	1	12/02/25 14:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-39
Lab Code: R2514883-010

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.9	ug/L	1.0	1	12/02/25 14:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-40
Lab Code: R2514883-011

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	12/02/25 14:56	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-41
Lab Code: R2514883-012

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.5	ug/L	1.0	1	12/02/25 14:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-42A
Lab Code: R2514883-013

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 15:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-42B
Lab Code: R2514883-014

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 15:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-43
Lab Code: R2514883-015

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.5	ug/L	1.0	1	12/02/25 15:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-44
Lab Code: R2514883-016

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	9.0	ug/L	1.0	1	12/02/25 15:07	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-45
Lab Code: R2514883-017

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	62.6	ug/L	1.0	1	12/03/25 13:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-46
Lab Code: R2514883-018

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	54.8	ug/L	1.0	1	12/02/25 15:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-47
Lab Code: R2514883-019

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 15:24	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-48
Lab Code: R2514883-020

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	85.9	ug/L	1.0	1	12/02/25 15:25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-49
Lab Code: R2514883-021

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	10.0	ug/L	1.0	1	12/02/25 15:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-50
Lab Code: R2514883-022

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	12.9	ug/L	1.0	1	12/02/25 15:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-54
Lab Code: R2514883-023

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.8	ug/L	1.0	1	12/02/25 15:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-55
Lab Code: R2514883-024

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.4	ug/L	1.0	1	12/02/25 15:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-56
Lab Code: R2514883-025

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	10.2	ug/L	1.0	1	12/02/25 15:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-57
Lab Code: R2514883-026

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	10.1	ug/L	1.0	1	12/02/25 15:38	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-58
Lab Code: R2514883-027

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	10.5	ug/L	1.0	1	12/02/25 15:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-59
Lab Code: R2514883-028

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.9	ug/L	1.0	1	12/02/25 15:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-60
Lab Code: R2514883-029

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	11.0	ug/L	1.0	1	12/02/25 15:42	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-61A
Lab Code: R2514883-030

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 15:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-61B
Lab Code: R2514883-031

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 15:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-62
Lab Code: R2514883-032

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.7	ug/L	1.0	1	12/02/25 15:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-63
Lab Code: R2514883-033

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.5	ug/L	1.0	1	12/02/25 15:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-64
Lab Code: R2514883-034

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 15:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-65
Lab Code: R2514883-035

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.3	ug/L	1.0	1	12/02/25 15:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-66
Lab Code: R2514883-036

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.7	ug/L	1.0	1	12/02/25 15:56	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-67
Lab Code: R2514883-037

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	12/02/25 16:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-68
Lab Code: R2514883-038

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	12/02/25 16:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-69
Lab Code: R2514883-039

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 16:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-70A
Lab Code: R2514883-040

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 16:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-70B
Lab Code: R2514883-041

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 16:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-71
Lab Code: R2514883-042

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.8	ug/L	1.0	1	12/02/25 16:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-72
Lab Code: R2514883-043

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.6	ug/L	1.0	1	12/02/25 16:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-73
Lab Code: R2514883-044

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.3	ug/L	1.0	1	12/02/25 16:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-74
Lab Code: R2514883-045

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 16:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-75
Lab Code: R2514883-046

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.9	ug/L	1.0	1	12/02/25 16:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: 118.7-84
Lab Code: R2514883-047

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	31.4	ug/L	1.0	1	12/02/25 16:33	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2514883-MB1

Service Request: R2514883
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 14:25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2514883-MB2

Service Request: R2514883
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 15:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2514883-MB3

Service Request: R2514883
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/02/25 16:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2514883-MB4

Service Request: R2514883
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/03/25 13:45	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25
Date Analyzed: 12/2/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 118.7-44
Lab Code: R2514883-016
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2514883-016MS		Duplicate Matrix Spike R2514883-016DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	9.0	31.1	20.0	110	30.9	20.0	110	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25
Date Analyzed: 12/2/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 118.7-66
Lab Code: R2514883-036
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2514883-036MS		Result	Duplicate Matrix Spike R2514883-036DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	3.7	26.0	20.0	111	26.5	20.0	114	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water

Service Request: R2514883
Date Collected: 10/30/25
Date Received: 11/07/25
Date Analyzed: 12/2/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 118.7-67
Lab Code: R2514883-037
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2514883-037MS		Duplicate Matrix Spike R2514883-037DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	2.2	24.2	20.0	110	24.6	20.0	112	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water

Service Request: R2514883
Date Analyzed: 12/02/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2514883-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.3	20.0	106	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water

Service Request: R2514883
Date Analyzed: 12/02/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2514883-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.7	20.0	109	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water

Service Request: R2514883

Date Analyzed: 12/02/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample
R2514883-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.6	20.0	113	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: North Tonawanda CSD - High School/2023L-118.7
Sample Matrix: Drinking Water

Service Request: R2514883

Date Analyzed: 12/03/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L


Basis:NA

Lab Control Sample
R2514883-LCS4

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.1	20.0	106	85-115

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2026
Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE
Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. CHRISTINE KUTZER
ALS ENVIRONMENTAL - ROCHESTER
1565 JEFFERSON ROAD BUILDING 300, SUITE 360
ROCHESTER, NY 14623


NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Bacteriology	
Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Collert)
Dissolved Gases	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
Fuel Additives	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
Metals I	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Zinc, Total	EPA 200.7 Rev. 4.4

Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elapublicweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.



Page 1 of 5