

Facility or Building Name	Pillsbury Elementary
Did the facility test using the MDH testing program (WIIN)? (Yes or No)	No
Facility Type (School or Child Care)	School
School ID Number or Child Care License Number	0001-03-155
Facility or Building Address	2250 Garfield St NE, Minneapolis MN 55411
Mailing Address	1225 North 7th Street Minneapolis, MN 55411
Contact Person	Lee Setter
Title	Manager, EH&S
Phone	612-668-0308
Email	Lee.Setter@mpls.k12.mn.us

SUMMARY	ANSWER
Total number of samples	42
Total number of fixtures sampled	42
Total number of results above 5 ppb	0
Total number of remediation actions	0
Next Scheduled Sampling Date (Month/Year)	12/2030

Unique Sample Site Identification Number	Fixture Type	Location Description	Fixture Status	Sample Collection Type	Laboratory Identification Number (optional)	Date/Time Collected	Date/Time Analyzed	Numeric Result	Unit of Measure	Name of Laboratory Used For Analysis	Remediation Action	Other Remediation-Please Describe	Was Remediation Successful (ie. Follow-up testing below 5 ppb)	Additional Notes or Comments
0001-03-155-04	Drinking Fountain	Classroom 110	Active - Consumption	Initial - First Draw	25-14788	12/5/2025 4:18	12/16/2025 10:45	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-05	Drinking Fountain	Classroom 111	Active - Consumption	Initial - First Draw	25-14789	12/5/2025 4:19	12/16/2025 10:51	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-06	Bottle Filler	Classroom 113	Active - Consumption	Initial - First Draw	25-14790	12/5/2025 4:20	12/16/2025 10:57	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-07	Drinking Fountain	Classroom 114	Active - Consumption	Initial - First Draw	25-14791	12/5/2025 4:22	12/16/2025 11:03	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-08	Drinking Fountain	Classroom 117	Active - Consumption	Initial - First Draw	25-14792	12/5/2025 4:23	12/16/2025 11:09	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-09	Drinking Fountain	Classroom 118	Active - Consumption	Initial - First Draw	25-14793	12/5/2025 4:24	12/16/2025 11:15	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-10	Drinking Fountain	Classroom 119	Active - Consumption	Initial - First Draw	25-14794	12/5/2025 4:24	12/16/2025 11:33	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-11	Drinking Fountain	Classroom 120	Active - Consumption	Initial - First Draw	25-14795	12/5/2025 4:25	12/16/2025 11:51	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-12	Drinking Fountain	Classroom 123	Active - Consumption	Initial - First Draw	25-14796	12/5/2025 4:26	12/16/2025 11:57	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-13	Drinking Fountain	Classroom 124-Hallway	Active - Consumption	Initial - First Draw	25-14797	12/5/2025 4:27	12/16/2025 12:03	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-14	Drinking Fountain	Classroom 128	Active - Consumption	Initial - First Draw	25-14798	12/5/2025 4:28	12/16/2025 12:09	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-15	Drinking Fountain	Classroom 129A	Active - Consumption	Initial - First Draw	25-14799	12/5/2025 4:28	12/16/2025 12:15	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-16	Drinking Fountain	Classroom 130-Hallway	Active - Consumption	Initial - First Draw	25-14800	12/5/2025 4:29	12/16/2025 12:21	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-17	Drinking Fountain	Classroom 130	Active - Consumption	Initial - First Draw	25-14801	12/5/2025 4:30	12/16/2025 12:27	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-18	Drinking Fountain	Classroom 131	Active - Consumption	Initial - First Draw	25-14802	12/5/2025 4:32	12/16/2025 12:33	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-19	Drinking Fountain	Classroom 132	Active - Consumption	Initial - First Draw	25-14803	12/5/2025 4:33	12/16/2025 12:39	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-20	Bottle Filler	Classroom 133	Active - Consumption	Initial - First Draw	25-14804	12/5/2025 4:34	12/18/2025 12:27	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-21	Sink	Health Office 100-H	Active - Consumption	Initial - First Draw	25-14805	12/5/2025 4:35	12/18/2025 12:33	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-22	Drinking Fountain	Office room 100-F	Active - Consumption	Initial - First Draw	25-14806	12/5/2025 4:36	12/18/2025 12:39	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-23	Sink	Office room 100-F	Active - Consumption	Initial - First Draw	25-14807	12/5/2025 4:37	12/18/2025 12:45	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-24	Drinking Fountain	Classroom 231	Active - Consumption	Initial - First Draw	25-14808	12/5/2025 4:39	12/18/2025 12:51	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-25	Drinking Fountain	Hallway 229 Restroom	Active - Consumption	Initial - First Draw	25-14809	12/5/2025 4:40	12/18/2025 12:57	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-26	Drinking Fountain	Classroom 227	Active - Consumption	Initial - First Draw	25-14810	12/5/2025 4:42	12/18/2025 13:03	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-27	Drinking Fountain	Classroom 226	Active - Consumption	Initial - First Draw	25-14811	12/5/2025 4:43	12/18/2025 13:09	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-28	Drinking Fountain	Classroom 225	Active - Consumption	Initial - First Draw	25-14812	12/5/2025 4:45	12/18/2025 13:15	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-29	Drinking Fountain	Classroom 224	Active - Consumption	Initial - First Draw	25-14813	12/5/2025 4:47	12/19/2025 12:07	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-30	Drinking Fountain	Classroom 221	Active - Consumption	Initial - First Draw	25-14814	12/5/2025 4:49	12/19/2025 12:55	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-31	Drinking Fountain	Classroom 220	Active - Consumption	Initial - First Draw	25-14815	12/5/2025 4:51	12/19/2025 13:01	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-32	Drinking Fountain	Classroom 219	Active - Consumption	Initial - First Draw	25-14816	12/5/2025 4:54	12/19/2025 13:07	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-33	Drinking Fountain	Classroom 218	Active - Consumption	Initial - First Draw	25-14817	12/5/2025 4:56	12/19/2025 13:13	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-34	Bottle Filler	Hallway 215 Restroom	Active - Consumption	Initial - First Draw	25-14818	12/5/2025 4:57	12/23/2025 11:29	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-35	Drinking Fountain	Classroom 216	Active - Consumption	Initial - First Draw	25-14819	12/5/2025 4:59	12/23/2025 11:47	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-36	Drinking Fountain	Room 209	Active - Consumption	Initial - First Draw	25-14820	12/5/2025 5:03	12/23/2025 11:53	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-37	Drinking Fountain	Room 207	Active - Consumption	Initial - First Draw	25-14821	12/5/2025 5:05	12/23/2025 11:59	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-38	Drinking Fountain	Hallway 208 Hallway	Active - Consumption	Initial - First Draw	25-14822	12/5/2025 5:06	12/23/2025 12:05	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-39	Drinking Fountain	Room 206	Active - Consumption	Initial - First Draw	25-14823	12/5/2025 5:08	12/23/2025 12:11	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-40	Drinking Fountain	Room 204	Active - Consumption	Initial - First Draw	25-14824	12/5/2025 5:10	12/23/2025 12:17	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-41	Drinking Fountain	Room 203	Active - Consumption	Initial - First Draw	25-14825	12/5/2025 5:18	12/23/2025 12:23	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-155-42	Drinking Fountain	Room 202	Active - Consumption	Initial - First Draw	25-14826	12/5/2025 5:19	12/23/2025 12:29	ND	µg/L	Twin City Water Clinic, Inc.				

Definitions of Reporting Fields

Field Name	Response Needed or Definition	Where does this information come from?
Unique Sample Site Identification Number	A unique number or code using numbers and or letters that a facility assigns to each fixture in the building. This prevents confusion about which sample goes with which fixture.	Facility
Fixture Type	Describes the type of fixture such as sink, fountain, bottle filler, ice machine, kitchen kettle, coffee machine, etc..	Facility
Location Description	Specific description of the location of the fixture. Ex. Classroom sink in Room 112 or Left drinking fountain in gym	Facility
Fixture Status	Describes if the fixture is currently being used and how it is used. Examples are Active-Consumption, Inactive-Consumption, Active-Nonconsumption, Inactive-Nonconsumption	Facility
Sample Collection Type	Initial first draw, Initial Flushed, Follow-up First Draw, Follow-up Flushed, Other	Facility
Laboratory Identification Number	Number assigned by the laboratory to each sample. It may be helpful for facilities using this spreadsheet to cross reference to their lab results. (Optional)	Lab
Date/Time Collected	Date and time the sample was collected Ex. 2/12/2024 7:03 PM or 3/8/24 13:02	Lab
Date/Time Analyzed	Date and time the sample was analyzed Ex. 2/12/2024 7:03 PM or 3/8/24 13:02	Lab
Numeric Result	This is the number representing the result reported by the lab. Ex. 5.12, 7.03, 89.02, for results that are not detected please use ND	Lab
Unit of Measure	This is the unit of the result reported by the lab Ex. Parts per billion (ppb), micrograms per liter (ug/L).	Lab
Name of Laboratory Used For Analysis	The name of the laboratory used for sample analysis.	Lab
Remediation Action	Describes the type of remediation (if needed). Select from drop down menu. You only need to complete if result is 5ppb or more. If the action you took is not listed select OTHER and describe	Facility
Other Remediation-Please Describe	Use this field to type in your remediation action if the choice was not listed in the Remediation Action Drop down menu.	Facility
Was Remediation Successful (ie. Follow-up)	Select from the drop down. Options are Yes, No, Not Applicable(N/A), and Pending Results	Facility

Other Important Terms	Definitions
Consumption	For the purposes of this testing consumption means a fixture where the water is used for drinking water or food/formula preparation.
Non-Consumption	A fixture that is not used for drinking water or food preparation such as a laboratory sink or a mop sink in a locked custodial closet. MDH recommends that non-consumption fixtures be labeled as not for drinking if they are not tested.
Active	A fixture currently able to be used.
Inactive	A fixture that has been taken out of service either temporarily or permanently
First Draw	A type of water sample where the water has been stagnant for 8-18 hours before collecting a sample. The most common type of lead sample type.
Flushed	A type of water sample where the water has been allowed to run before collecting. Typically collected when investigating to source of lead or evaluating remediation options.
Initial	This is typically a first draw sample collected during a round of monitoring. A sample may be an initial-first draw or an initial-flushed
Follow-up	This is typically collected if an initial sample collected during a round of sampling is 5ppb or more. Follow-up samples can be repeated first draw samples or flushed samples depending on the type of follow-up activities conducted to reduce lead.