



464 Valley Brook Avenue, Lyndhurst NJ 07071  
129 Sea Girt Avenue, Manasquan NJ 08736  
Phone: (800) 423-0766 • Fax: (201) 438-1798  
www.mccabeenv.com

---

## LEAD IN DRINKING WATER TESTING REPORT

*Conducted for:*

Bayonne Board of Education  
669 Avenue A  
Bayonne, New Jersey 07002

*Conducted at:*

Walter F. Robinson Community School  
18 West 26th Street  
Bayonne, New Jersey 07002

*Submitted by:*

McCabe Environmental Services, L.L.C.  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071

**REPORT DATE:** September 8, 2025

**MES PROJECT NO.:** 25-05225

*Prepared by:*

A handwritten signature in blue ink, appearing to read 'Arlitzzy Lezama'.

**Arlitzzy Lezama**  
**Environmental Scientist**

*Signed for the Company by:*

A handwritten signature in blue ink, appearing to read 'John H. Chiaviello'.

**John H. Chiaviello**  
**Vice President**

## TABLE OF CONTENTS

---

	<b>Page</b>
1.0 INTRODUCTION .....	1
2.0 SCOPE OF WORK.....	1
3.0 PROCEDURES.....	1
4.0 TABLE OF SAMPLE RESULTS .....	2
5.0 DISCUSSION AND CONCLUSION .....	3

### **APPENDIX A**

Laboratory Certificates of Analysis  
&  
Sample Chain of Custody Forms

### **APPENDIX B**

School District Sampling Attachments

**1.0 INTRODUCTION**

McCabe Environmental Services, L.L.C. (McCabe) was retained by Bayonne Board of Education (Client) to conduct lead in drinking water testing at the Walter F. Robinson Community School located at 18 West 26th Street, Bayonne, New Jersey.

The project information is as follows:

<u>Client Name:</u>	Bayonne Board of Education
<u>Contact Person:</u>	Mr. Daniel Castles
<u>Project Name:</u>	Walter F. Robinson Community School – Lead in Drinking Water
<u>Project Location:</u>	18 West 26th Street Bayonne, New Jersey
<u>Date(s) of Service:</u>	June 20, 2025
<u>McCabe Personnel:</u>	Gary Clare & Arlitzzy Lezama

**2.0 SCOPE OF WORK**

Drinking water testing was performed at the Walter F. Robinson Community School located at 18 West 26th Street, Bayonne, New Jersey on June 20, 2025. The purpose of the testing was to determine if the building’s plumbing was having an adverse impact on water quality, specifically with regard to lead concentrations. Samples were collected from various potential drinking water outlets located throughout the building. Testing was followed as per past reports provided by Bayonne Board of Education.

**3.0 PROCEDURES**

After determining which outlets would be sampled, McCabe personnel collected a "first draw" sample at each location. A "first draw" is the initial water that is first to come out of the tap after a period of inactivity. Following the “first draw”, a "30 second flush" sample was also collected where the main service line comes into the building. All samples were collected into 250 mL sterile bottles, labeled with a sample identification, and analyzed in accordance with EPA approved methods to determine the level of lead in drinking water. Samples were analyzed by an accredited laboratory.

The U.S. Environmental Protection Agency (EPA) has established National Primary Drinking Water Regulations (NPDWR) that set mandatory water quality standards for drinking water contaminants. These are enforceable standards called "maximum contaminant levels" or "MCL", which are established to protect the public against consumption of drinking water contaminants that present a risk to human health. An MCL is the maximum allowable amount of a contaminant in drinking water which is delivered to the consumer.

The EPA has established the Lead and Copper Rule that sets standards for state and public water systems. This rule has set an MCL for lead at 15 parts per billion (ppb) for a one liter sample. However, the EPA also established the Lead in Drinking Water at Schools and Child Care Facilities in which the EPA recommends an MCL of 20 ppb for a 250 milliliter first draw sample. In order to be more stringent, for our report purposes we have compared all results to both the 15 ppb and the 20 ppb standards.

**4.0 TABLE OF SAMPLE RESULTS**

The following table presents all sample results in order of sample identification conducted on June 20, 2025:

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
WR-01	First Draw – Café Bottle Filler	< 0.5	Pass	Pass
WR -02	30 Second Draw – Café Bottle Filler	< 0.5	Pass	Pass
WR -03	First Draw – Café Sink	5.9	Pass	Pass
WR -04	First Draw – Bubbler by Room G-3	< 0.5	Pass	Pass
WR -05	First Draw – Lunch Room Faucet - Subbasement	0.6	Pass	Pass
WR -06	First Draw – Bubbler Outside Room 102	< 0.5	Pass	Pass
WR -07	First Draw – Nurse’s Office Faucet	3	Pass	Pass
WR -08	First Draw – Room 101 Faucet	1.1	Pass	Pass
WR -09	First Draw – Bubbler Between East and West Wing	OUT OF ORDER		
WR -10	First Draw – Chiller by Elevator – 1 <sup>st</sup> Floor	< 0.5	Pass	Pass
WR -11	First Draw – Bubbler by Room 211	< 0.5	Pass	Pass
WR -12	First Draw – Chiller by Elevator – 2 <sup>nd</sup> Floor	< 0.5	Pass	Pass
<b>WR -13</b>	<b>First Draw – Bubbler Between East and West Wing – 3<sup>rd</sup> Floor</b>	<b>19.3</b>	<b>Fail</b>	Pass
WR -14	First Draw – Chiller by Elevator – 3 <sup>rd</sup> Floor	< 0.5	Pass	Pass

The following table presents all sample results in order of sample identification conducted on August 23, 2025:

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
WR-13	First Draw – Bubbler Between East and West Wing – 3 <sup>rd</sup> Floor	PERMANENTLY REMOVED		

## 5.0 DISCUSSION AND CONCLUSION

A total of thirteen (13) samples were collected from the Walter F. Robinson Community School. One (1) sample was found to be greater than the EPA Lead and Copper Rule standard of 15 ppb. All other samples were found to be less than the EPA standards of 20 ppb and 15 ppb.

During the follow-up drinking water testing conducted on August 23, 2025 the Bubbler between East and West Wing – 3<sup>rd</sup> Floor was permanently removed and therefore not re-sampled.

In addition, McCabe Environmental recommends annual drinking water sampling to ensure that the building's plumbing is not having an adverse impact on water quality.

**APPENDIX A**

**LABORATORY CERTIFICATES OF ANALYSIS  
&  
SAMPLE CHAIN OF CUSTODY FORMS**



Monday, June 30, 2025

Attn: Jarred Panecki  
McCabe Environmental Services, LLC  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
SDG ID: GCT57974  
Sample ID#s: CT57974 - CT57986

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller  
Laboratory Director

NELAC - #NY11301  
CT Lab Registration #PH-0618  
MA Lab Registration #M-CT007  
ME Lab Registration #CT-007  
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003  
NY Lab Registration #11301  
PA Lab Registration #68-03530  
RI Lab Registration #63  
VT Lab Registration #VT11301



Environmental Laboratories, Inc.  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



## Sample Id Cross Reference

June 30, 2025

SDG I.D.: GCT57974

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION

---

Client Id	Lab Id	Matrix	Col Date
WR-01	CT57974	DRINKING WATER	06/20/25 10:53
WR-02	CT57975	DRINKING WATER	06/20/25 10:55
WR-03	CT57976	DRINKING WATER	06/20/25 10:56
WR-04	CT57977	DRINKING WATER	06/20/25 10:57
WR-05	CT57978	DRINKING WATER	06/20/25 11:00
WR-06	CT57979	DRINKING WATER	06/20/25 11:04
WR-07	CT57980	DRINKING WATER	06/20/25 11:06
WR-08	CT57981	DRINKING WATER	06/20/25 11:06
WR-10	CT57982	DRINKING WATER	06/20/25 11:11
WR-11	CT57983	DRINKING WATER	06/20/25 11:14
WR-12	CT57984	DRINKING WATER	06/20/25 11:16
WR-13	CT57985	DRINKING WATER	06/20/25 11:18
WR-14	CT57986	DRINKING WATER	06/20/25 11:19



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

10:53  
 16:20

## Laboratory Data

SDG ID: GCT57974  
 Phoenix ID: CT57974

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WR-01

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**June 30, 2025**

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

10:55  
 16:20

## Laboratory Data

SDG ID: GCT57974  
 Phoenix ID: CT57975

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WR-02

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**June 30, 2025**

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

10:56  
 16:20

## Laboratory Data

SDG ID: GCT57974  
 Phoenix ID: CT57976

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WR-03

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	5.9	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

10:57  
 16:20

## Laboratory Data

SDG ID: GCT57974  
 Phoenix ID: CT57977

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WR-04

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

11:00  
 16:20

## Laboratory Data

SDG ID: GCT57974  
 Phoenix ID: CT57978

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WR-05

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.6	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

11:04  
 16:20

## Laboratory Data

SDG ID: GCT57974  
 Phoenix ID: CT57979

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WR-06

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

11:06  
 16:20

## Laboratory Data

SDG ID: GCT57974  
 Phoenix ID: CT57980

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WR-07

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	3	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**June 30, 2025**

**Reviewed and Released by: Alejandro Paredes, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

11:06  
 16:20

## Laboratory Data

SDG ID: GCT57974  
 Phoenix ID: CT57981

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WR-08

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.1	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**June 30, 2025**

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

11:11  
 16:20

## Laboratory Data

SDG ID: GCT57974  
 Phoenix ID: CT57982

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WR-10

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

11:14  
 16:20

## Laboratory Data

SDG ID: GCT57974  
 Phoenix ID: CT57983

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WR-11

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**  
**June 30, 2025**

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

11:16  
 16:20

## Laboratory Data

SDG ID: GCT57974  
 Phoenix ID: CT57984

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WR-12

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**  
 June 30, 2025

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

11:18  
 16:20

## Laboratory Data

SDG ID: GCT57974  
 Phoenix ID: CT57985

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WR-13

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	19.3	0.5	2	ppb	15			06/26/25	CPP	E200.8
*** Lead exceeds Action Level of 15 ***										
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director  
 June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

June 30, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

11:19  
 16:20

## Laboratory Data

SDG ID: GCT57974  
 Phoenix ID: CT57986

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: WR-14

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

June 30, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager

# Analysis Report - Summary

June 30, 2025

Attn: Jarred Panecki  
McCabe Environmental Services, LLC  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071



Environmental Laboratories, Inc.  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823

SDG I.D.: GCT57974



Sample	Client Id	Col Date	Parameter	Result	RL	CL	Units	Date Analyzed	Reference
Project: 25-05225 Bayonne Board Of Education									
CT57974	WR-01	06/20/25	Lead	< 0.5	0.5		ppb	06/26/25	E200.8
CT57975	WR-02	06/20/25	Lead	< 0.5	0.5		ppb	06/26/25	E200.8
CT57976	WR-03	06/20/25	Lead	5.9	0.5		ppb	06/26/25	E200.8
CT57977	WR-04	06/20/25	Lead	< 0.5	0.5		ppb	06/26/25	E200.8
CT57978	WR-05	06/20/25	Lead	0.6	0.5		ppb	06/26/25	E200.8
CT57979	WR-06	06/20/25	Lead	< 0.5	0.5		ppb	06/26/25	E200.8
CT57980	WR-07	06/20/25	Lead	3	0.5		ppb	06/26/25	E200.8
CT57981	WR-08	06/20/25	Lead	1.1	0.5		ppb	06/26/25	E200.8
CT57982	WR-10	06/20/25	Lead	< 0.5	0.5		ppb	06/26/25	E200.8
CT57983	WR-11	06/20/25	Lead	< 0.5	0.5		ppb	06/26/25	E200.8
CT57984	WR-12	06/20/25	Lead	< 0.5	0.5		ppb	06/26/25	E200.8
CT57985	WR-13	06/20/25	Lead	19.3	0.5		ppb	06/26/25	E200.8
CT57986	WR-14	06/20/25	Lead	< 0.5	0.5		ppb	06/26/25	E200.8

## Comments:

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
ND=Not detected BDL=Below Detection Level RL=Reporting Level CL=Client Limit

  
Phyllis Shiller  
Laboratory Director  
June 30, 2025



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# QA/QC Report

June 30, 2025

## QA/QC Data

SDG I.D.: GCT57974

Parameter	Blank	BLK RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	--------	---------------	------------	---------	-------	--------	---------	------	-------	--------	--------------	--------------

QA/QC Batch 790693 (mg/L), QC Sample No: CT57968 (CT57974, CT57975, CT57976, CT57977)

### ICP MS Metals - Aqueous

Lead BRL 0.0001 <0.0005 0.0001 NC 107 96.4

QA/QC Batch 790693A (mg/L), QC Sample No: CT57978 (CT57978, CT57979, CT57980, CT57981, CT57982, CT57983, CT57984, CT57985, CT57986)

### ICP MS Metals - Aqueous

Lead BRL 0.0001 107 104

Comment:

This batch does not include a duplicate.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Inf - Interference
- (ISO) - Isotope Dilution

  
 Phyllis Shiller, Laboratory Director  
 June 30, 2025

Monday, June 30, 2025

Criteria: NJ: DW

State: NJ

## Sample Criteria Exceedances Report

GCT57974 - MCCABE-PB

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
CT57985	PB-DW-MS	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	19.3	0.5	15	1	ppb

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



**Environmental Laboratories, Inc.**  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



## Analysis Comments

June 30, 2025

SDG I.D.: GCT57974

---

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

MCCABE ENVIRONMENTAL SERVICES, L.L.C.  
 464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER  
 CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education  
 FIELD INSPECTOR'S NAME: A. Lezama & Ch. Clave  
 MES PROJECT #: 25-05225  
 SAMPLE DATE: 6/20/25  
 SITE ADDRESS: Walter F. Robinson Walter F. Robinson Community School  
 18 West 26th Street, Bayonne, New Jersey 07002  
 TURNAROUND TIME REQUESTED: 2-Week

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED	57974
DW	WR-01	FD - Cafe water filler	10:53 AM	LEAD - 200.8	57975
DW	WR-02	30 sec. flush - Cafe water filler	10:55 AM	LEAD - 200.8	57976
DW	WR-03	FD - Cafe sink	10:56 AM	LEAD - 200.8	57977
DW	WR-04	FD - Bubble by Room G-3	10:57 AM	LEAD - 200.8	57978
DW	WR-05	FD - Lunch Room faucet - Sub-basement	11:00 AM	LEAD - 200.8	57979
DW	WR-06	FD - Bottle filler outside Room 102	11:04 AM	LEAD - 200.8	57980
DW	WR-07	FD - Nurses office faucet	11:06 AM	LEAD - 200.8	57981
DW	WR-08	FD - Zoom 101 faucet	11:06 AM	LEAD - 200.8	57982
DW	WR-09	FD - <del>Bottle</del> Access from 10			
DW	WR-10	FD - Chiller by elevator 1 <sup>st</sup> Floor	11:11 AM	LEAD - 200.8	

Relinquished by (Print) Gary Clave  
 Signature: [Signature] Date: 6/23/25 Time: 10:15  
 Received by: (Print) J. Demers  
 Signature: [Signature] Date: 8-23-2025 Time: 10:15  
 Relinquished by (Print) [Signature]  
 Signature: [Signature] Date: 6/23/25 Time: 16:20  
 Received by: (Print) Abby Lee  
 Signature: [Signature]

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

a.2.2 wcip

**MCCABE ENVIRONMENTAL SERVICES, L.L.C.**

464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

**LEAD in DRINKING WATER  
CHAIN-OF-CUSTODY FORM**

CLIENT NAME: Bayonne Board of Education

SITE ADDRESS: Walter F. Robinson Walter F. Robinson Community School  
18 West 26th Street, Bayonne, New Jersey 07002

FIELD INSPECTOR'S NAME: *A. Letourneau & G. Clark*

TURNAROUND TIME REQUESTED: 2-Week

MES PROJECT #: 25-05225

SAMPLE DATE: 6/20/25

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED	
DW	WR-11	FD - Bubblers by Room 211	11:14 AM	LEAD - 200.8	57983
DW	WR-12	FD - Chiller by elevator	11:16 AM	LEAD - 200.8	57984
DW	WR-13	FD - Bubblers going from East to West 3rd Floor	11:16 AM	LEAD - 200.8	57985
DW	WR-14	FD - Chiller by elevator 3rd Floor	11:19 AM	LEAD - 200.8	57986
DW				LEAD - 200.8	
DW				LEAD - 200.8	
DW				LEAD - 200.8	
DW				LEAD - 200.8	
DW				LEAD - 200.8	
DW				LEAD - 200.8	

Relinquished by (Print) *Gary Clave*

Received by: (Print) *S. Demers*

Signature: *AK*

Date: 6/23/25

Time: 1015

Date: 8-23-2025

Time: 1015

Relinquished by (Print) *APL*

Received by: (Print) *Abby Lee*

Signature: *APL*

Signature: *Abby Lee*

Date: 6/23/25

Time: 1620

Date: 6/23/25

Time: 1620

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

**APPENDIX B**

**SCHOOL DISTRICT SAMPLING  
ATTACHMENTS**

## Attachment A - List of Priority for Sampling

SCHOOL NAME	DATE OF SAMPLING	CERTIFIED LABORATORY	NOTES
Walter F. Robinson Community School	06/20/2025	Phoenix Environmental Laboratories Inc.	

## Attachment B – Plumbing Profile

**Note:** Complete for each school. For additional information see the USEPA publication, "The 3Ts for Reducing Lead in Drinking Water in Schools"

Name of School: Dr. Walter F. Robinson Community School Grade Levels: K-8

Address: 95 West 31st St., Bayonne, NJ 07002

Individual school project officer Signature:  Date: 8/5/2025

Questions	Answers	
<b>Background Information</b>		
1. What year was the original building constructed? Were any buildings or additions added to the original facility?	K-8 Grade School built in 1903 K-8 Addition was added in 2005	
2. If the building was constructed or repaired after 1986, was lead-free plumbing and solder utilized? What type of solder was used? Document all locations where lead solder was used.	Any repairs made after 1986 were done using lead free solder	
3. Where are the most recent plumbing repairs and replacements?	Location: Nurses Office New wing	Description: New sink faucet Replace two water fountains
4. With what materials is the service connection (the pipe that carries water to the school from the public water system's main in the street) made? Where is the Service Line located? (This is the POE location.)	Material: Main Building - Duct Iron  Location: The water main (31st st) enters the basement cafe where the water meter is located and continues to the remainder of the building	
5. Is there point of entry (POE) or point of use (POU) treatment in use?	Y / N No treatment of water Type: at POE  City water comes treated	Location: Main Building 1903

Questions	Answers
6. Are there tanks in your plumbing system (pressure tanks, gravity storage tanks)?	Y / N Yes building has a 75 gallon hot water storage tank new pump room Building has a 50 gallon hot water storage tank boiler room Building has a 38 gallon hot water storage tank gym storage
7. Does the school have a filter maintenance and operation program? If so, who is responsible for this program? What is the process for adding filters?	Yes, Scott Nolan, Andy McCabe, Vinny Caiola, change filters on an as needed basis assign plumbers
8. Have accessible screens or aerators on outlets that provide drinking water been cleaned? Does the school have a screen or aerator maintenance program?	Y / N Yes The district has set up a routine maintenance program to clean screens
9. Have there been any complaints about bad (metallic) taste? Note location(s).	Y / N No  Location:
10. Review records and consult with the public water supplier to determine whether any water samples have been taken in the building for any contaminants. If so, identify: <ul style="list-style-type: none"> <li>• Name of contaminant(s)</li> <li>• Concentrations found</li> <li>• pH level</li> </ul> Is testing done regularly at the building?	No indoor testing by public water supplier
11. Other plumbing background questions include: <ul style="list-style-type: none"> <li>• Are blueprints of the building available?</li> <li>• Are there known plumbing “dead-ends”, low use areas, existing leaks or other “problem areas”?</li> </ul> Are renovations planned for any of the plumbing system?	Not all prints are available No dead-end low use areas All leaks were identified during walk through and have been repaired No plumbing system renovations planned

Questions	Answers	
<b>Walk-Through</b> <i>These questions should be addressed during the walk-through of the facility, while Attachment C- Drinking Water Outlet Inventory is being completed.</i>		
1. Confirm the material of Service Line visually.	Duct iron	
2. Confirm the presence of POE or POU treatment.	No POE or POU treatment	
3. What are the potable water pipes made of in your facility? <ul style="list-style-type: none"> <li>• Lead</li> <li>• Plastic</li> <li>• Galvanized Metal</li> <li>• Cast Iron</li> <li>• Copper</li> <li>• Other</li> </ul> Note the water flow through the building and the areas that receive water first, and which areas receive water last.	Copper Galvanized metal Brass  Water flow through the building shown on the prints	
4. Are electrical wires grounded to Water Pipes? Note location(s).	Y / N  Location:	No  No electrical wires grounded to water pipes
5. Are brass fittings, faucets, or valves used in your drinking water system? Note that most faucets are brass on the inside. Document the locations of any brass water outlet to be sampled.	Complete in "Brass" Column in Attachment C- Water Outlet Inventory. Yes Completed in Attachment C - Wataer Outlet Inventory	
6. Locate all drinking water outlets (i.e. water coolers, bubblers, ice machines, kitchen/ food prep sinks, etc.) in the facility.	Complete in Attachment C-Water Outlet Inventory.	

Questions	Answers	
<p>7. Have the brands and models of the water coolers in the school been compared to the list of recalled water coolers in the Toolkit?</p> <p>Recalled Drinking Water Fountains</p> <p>Make and Model</p>	<p>Y / N Yes all water coolers have been checked and compared to the list of recalled water coolers</p> <p>Yes, Scott Nolan, Andy McCabe, Vinny Caiola, chchfilters on an as needed basis assign plumberschc</p> <p>Type None on the list of recalled water coolers</p>	
<p>8. Have signs of corrosion, such as frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry been detected?</p> <p>Note the locations of water outlets.</p>	<p>Complete in "Signs of Corrosion" column in Attachment C- Drinking Water Outlet Inventory.</p>	
<p>9. Are there any outlets that are not operational and therefore out of service? Permanently? Temporarily?</p> <p style="text-align: right;">Permanently</p> <p style="text-align: right;">Temporarily</p>	<p>Y / N NO</p> <p>Complete "Operational Column" in Attachment C- Drinking Water Outlet Inventory.</p> <p>Type/ Location</p>	<p>Description</p>

## Attachment C – Drinking Water Outlet Inventory

Name of School: Walter F. Robinson Community School      Address: 18 West 26th Street, Bayonne, New Jersey 07002

Grade Levels: Elementary School    Year School Constructed: Unknown    Renovated/Additions: NA

Individual School Project Officer: Scott Nolan

Date Completed: 09/30/22

#1	Type	Location	Code	Operational <sup>2</sup> (Y/N)	Signs of Corrosion <sup>3</sup> (Y/N)	Filter <sup>4</sup> (Y/N)	Brass Fittings, Faucets or valves? (Y/N)	Aerator/ Screen (Y/N)	Motion Activated (Y/N)	Chiller (Y/N)	Water Cooler		Comments
											Make	Model	
01	Water Fountain	Café Bubbler	WR-01	Y	N	N	N	N	N	N	NA	NA	
02	Water Fountain	Café Bubbler	WR -02	Y	N	N	N	N	N	N	NA	NA	Flush
03	Sink	Café	WR -03	Y	N	N	N	N	N	N	NA	NA	
04	Water Fountain	By Room G-3	WR -04	Y	N	N	N	N	N	N	NA	NA	
05	Sink	Lunch Room - Subbasement	WR -05	Y	N	N	N	Y	N	N	NA	NA	
06	Water Fountain	Outside Room 102	WR -06	Y	N	N	N	N	N	N	NA	NA	
07	Sink	Nurse's Office	WR -07	Y	N	Y	N	Y	N	N	NA	NA	
08	Sink	Room 101	WR -08	Y	N	Y	N	Y	Y	N	NA	NA	

<sup>1</sup> Number outlets starting at the closest outlet to the Point of Entry (POE).

<sup>2</sup> Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

<sup>3</sup> Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

<sup>4</sup> Document on Attachment D- Filter Inventory.

09	Water Fountain	Between East and West Wing – 1st Floor	WR -09	N	N	Y	N	N	N	N	NA	NA	Out of Order
10	Chiller	By Elevator – 1st Floor	WR -10	Y	N	Y	N	N	N	Y	NA	NA	
11	Sink	By Room 202	WR -11	Y	N	N	N	N	N	N	NA	NA	
12	Chiller	By Elevator – 2nd Floor	WR -12	Y	N	Y	N	N	N	Y	NA	NA	
13	<b>Water Fountain</b>	<b>Between East and West Wing – 2nd Floor</b>	<b>WR -13</b>	<b>N</b>	<b>N</b>	<b>Y</b>	<b>N</b>	<b>N</b>	<b>N</b>	<b>N</b>	<b>NA</b>	<b>NA</b>	<b>PERMANENTLY REMOVED</b>
14	Chiller	By Elevator – 3rd Floor	WR -14	Y	N	Y	N	N	N	Y	NA	NA	

<sup>1</sup> Number outlets starting at the closest outlet to the Point of Entry (POE).

<sup>1</sup> Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

<sup>1</sup> Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

<sup>1</sup> Document on Attachment D- Filter Inventory.

## Attachment D - Filter Inventory

Name of School: Walter F. Robinson Community School

Grade Levels: Elementary School

Address: 18 West 26th Street, Bayonne, New Jersey 07002

Individual School Project Officer: Scott Nolan

Date: 09/05/2025

Sample Location / Code	Brand	Type (Make & Model)	Date Installed or Replaced	Replacement Frequency	NSF Certified for Lead Reduction Y/N
WR-01	Elkay	LZWSR_1D	N/A	N/A	N/A
WR -02	N/A	N/A	N/A	N/A	N/A
WR -03	N/A	N/A	N/A	N/A	N/A
WR -04	3m Aqua Pure	AP 200	N/A	N/A	N/A
WR -05	N/A	N/A	N/A	N/A	N/A
WR -06	Elkay	LZWSR_1D	N/A	N/A	N/A
WR -07	3M Aqua Pure	AP 200	N/A	N/A	N/A
WR -08	Sloan	N/A	N/A	N/A	N/A
WR -09	Elkay	N/A	N/A	N/A	N/A
WR -10	Elkay	N/A	N/A	N/A	N/A
WR -11	3M Aqua Pure	AP 200	N/A	N/A	N/A
WR -12	Elkay	N/A	N/A	N/A	N/A
<b>WR -13</b>	<b>PERMANENTLY REMOVED</b>				
WR -14	Elkay	EZFS8_1B	N/A	N/A	N/A

### Attachment E – Flushing Log

Name of School: Walter F. Robinson Community School

Address: 18 West 26th Street, Bayonne, New Jersey 07002

Grade Levels: Elementary School

Individual School Project Officer: Scott Nolan

Date: 09/05/2025

Sample Location Description	Sample Location Code	Date	Time	Duration of Flushing	Reason for Flushing
Café Bubbler	WR-01	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Café Bubbler	WR -02	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Café Faucet	WR -03	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Room G-3	WR -04	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Lunch Room Faucet - Subbasement	WR -05	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Outside Room 102	WR -06	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Nurse's Office Faucet	WR -07	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 101 Faucet	WR -08	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Between East and West Wing – 1st Floor	WR -09	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Chiller by Elevator – 1st Floor	WR -10	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Room 202	WR -11	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Chiller by Elevator – 2nd Floor	WR -12	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
<b>Bubbler Between East and West Wing – 2nd Floor</b>	<b>WR -13</b>	<b>PERMANENTLY REMOVED</b>			
Chiller by Elevator – 3rd Floor	WR -14	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling

## Attachment F - Pre - Sampling Water Use Certification

TO BE COMPLETED BY THE BAYONNE BOE DISTRICT REPRESENTATIVE:		
School Name:	<u>Walter F. Robinson Community School</u>	
Sample collection address:	<u>18 West 26th Street, Bayonne, New Jersey 07002</u>	
Water was last used:	<u>Time: 5:30 pm</u>	<u>Date: June 19, 2025</u>
Sample commencement:	<u>Time: 10:53 am</u>	<u>Date: June 20, 2025</u>
I have read the Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.		
Scott Nolan	<u>09/30/22</u>	
Signature	Date	