



464 Valley Brook Avenue, Lyndhurst NJ 07071
129 Sea Girt Avenue, Manasquan NJ 08736
Phone: (800) 423-0766 • Fax: (201) 438-1798
www.mccabeenv.com

LEAD IN DRINKING WATER TESTING REPORT

Conducted for:

Bayonne Board of Education
669 Avenue A
Bayonne, New Jersey 07002

Conducted at:

Lincoln Community School
208 Prospect Avenue
Bayonne, New Jersey 07002

Submitted by:

McCabe Environmental Services, L.L.C.
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

REPORT DATE: September 8, 2025

MES PROJECT NO.: 25-05225

Prepared by:

A handwritten signature in blue ink, appearing to read 'Arlitzzy Lezama'.

Arlitzzy Lezama
Environmental Scientist

Signed for the Company by:

A handwritten signature in blue ink, appearing to read 'John H. Chiaviello'.

John H. Chiaviello
Vice President

TABLE OF CONTENTS

	Page
1.0 INTRODUCTION	1
2.0 SCOPE OF WORK.....	1
3.0 PROCEDURES.....	1
4.0 TABLE OF SAMPLE RESULTS	2
5.0 DISCUSSION AND CONCLUSION	3

APPENDIX A

Laboratory Certificates of Analysis
&
Sample Chain of Custody Forms

APPENDIX B

School District Sampling Attachments

1.0 INTRODUCTION

McCabe Environmental Services, L.L.C. (McCabe) was retained by Bayonne Board of Education (Client) to conduct lead in drinking water testing at Lincoln Community School located at 208 Prospect Avenue, Bayonne, New Jersey 07002.

The project information is as follows:

<u>Client Name:</u>	Bayonne Board of Education
<u>Contact Person:</u>	Mr. Daniel Castles
<u>Project Name:</u>	Lincoln Community School – Lead in Drinking Water
<u>Project Location:</u>	208 Prospect Avenue Bayonne, New Jersey 07002
<u>Date(s) of Service:</u>	June 20, 2025 and August 23, 2025
<u>McCabe Personnel:</u>	Gary Clare and Arllitzy Lezama

2.0 SCOPE OF WORK

Drinking water testing was performed at Lincoln Community School located at 208 Prospect Avenue Bayonne, New Jersey 07002 on June 20, 2025. The purpose of the testing was to determine if the building’s plumbing was having an adverse impact on water quality, specifically with regard to lead concentrations. Samples were collected from various potential drinking water outlets located throughout the building. Follow-up drinking water testing was then performed at the failed locations throughout Lincoln Community School on August 23, 2025. The failed locations were re-sampled with a first draw sample and immediately followed up with a thirty (30) second flush sample. Samples were collected from areas that exceeded the regulatory standards on June 20, 2025. Testing was followed as per past reports provided by Bayonne Board of Education.

3.0 PROCEDURES

After determining which outlets would be sampled, McCabe personnel collected a "first draw" sample at each location. A "first draw" is the initial water that is first to come out of the tap after a period of inactivity. Following the “first draw”, a "30 second flush" sample was also collected where the main service line comes into the building. All samples were collected into 250 mL sterile bottles, labeled with a sample identification, and analyzed in accordance with EPA approved methods to determine the level of lead in drinking water. Samples were analyzed by an accredited laboratory.

The U.S. Environmental Protection Agency (EPA) has established National Primary Drinking Water Regulations (NPDWR) that set mandatory water quality standards for drinking water contaminants. These are enforceable standards called "maximum contaminant levels" or "MCL", which are established to protect the public against consumption of drinking water contaminants that present a risk to human health. An MCL is the maximum allowable amount of a contaminant in drinking water which is delivered to the consumer.

The EPA has established the Lead and Copper Rule that sets standards for state and public water systems. This rule has set an MCL for lead at 15 parts per billion (ppb) for a one liter sample. However, the EPA also established the Lead in Drinking Water at Schools and Child Care Facilities in which the EPA recommends an MCL of 20 ppb for

a 250 milliliter first draw sample. In order to be more stringent, for our report purposes we have compared all results to both the 15 ppb and the 20 ppb standards.

4.0 TABLE OF SAMPLE RESULTS

The following table presents all sample results in order of sample identification conducted on June 20, 2025:

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
LC-01	First Draw – Girl’s Locker Room Bubblers	3.9	Pass	Pass
LC-02	30 Second Flush – Girl’s Locker Room Bubblers	1.3	Pass	Pass
LC-03	First Draw – Chiller Outside Main Office	< 0.5	Pass	Pass
LC-04	First Draw – Chiller Oasis in Pool Room	< 0.5	Pass	Pass
LC-05	First Draw – Boy’s Locker Room Bubblers	PERMANENTLY REMOVED		
LC-06	First Draw – Room 101 Bubblers	PERMANENTLY REMOVED		
LC-07	First Draw – Room 101 Faucet	47.5	Fail	Fail
LC-08	First Draw – Room 111 Faucet – Life Skills	2.2	Pass	Pass
LC-09	First Draw – Room 110 Bubblers	PERMANENTLY REMOVED		
LC-10	First Draw – Room 110 Faucet	< 0.5	Pass	Pass
LC-11	First Draw – Room 112 Bubblers	PERMANENTLY REMOVED		
LC-12	First Draw – Room 112 Faucet	< 5.0	Pass	Pass
LC-13	First Draw – Room 114 Bubblers	PERMANENTLY REMOVED		
LC-14	First Draw – Room 114 Faucet	5.3	Pass	Pass
LC-15	First Draw – Bubblers Across from Room 113	4.1	Pass	Pass
LC-16	First Draw – Bubblers by Room 109	< 0.5	Pass	Pass
LC-17	First Draw – Room 115 Faucet	2.8	Pass	Pass
LC-18	First Draw – 115 Right Faucet	PERMANENTLY REMOVED		

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
LC-19	First Draw – Nurse’s Office Faucet	< 0.5	Pass	Pass
LC-20	First Draw – Chiller Across from Room 122	< 0.5	Pass	Pass
LC-21	First Draw – Room 122 Faucet	34.8	Fail	Fail
LC-22	First Draw – Changing Room Faucet	3.1	Pass	Pass
LC-23	First Draw – Chiller Outside Girls/Boys Room 2 nd Floor	< 0.5	Pass	Pass
LC-24	First Draw – Room 203 Bubblers	OUT OF ORDER		
LC-25	First Draw – Room 203 Faucet	0.6	Pass	Pass
LC-26	First Draw – Room 202 Bubblers	OUT OF ORDER		
LC-27	First Draw – Room 202 Faucet	1.3	Pass	Pass
LC-28	First Draw – Room 201 Bubblers	OUT OF ORDER		
LC-29	First Draw – Room 201 Faucet	0.8	Pass	Pass
LC-30	First Draw – Art Room Faucet – Tower	15.4	Fail	Pass

The following table presents all sample results in order of sample identification from the follow-up lead in drinking water testing conducted on August 23, 2025:

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
LC-07-A	First Draw – Room 101 Faucet	0.7	Pass	Pass
LC-07-B	30 Second Flush – Room 101 Faucet	< 0.5	Pass	Pass
LC-21-A	First Draw – Room 122 Faucet	< 0.5	Pass	Pass
LC-21-B	30 Second Flush – Room 122 Faucet	< 0.5	Pass	Pass
LC-30-A	First Draw – Art Room Faucet – Tower	7.2	Pass	Pass

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
LC-30-B	30 Second Flush – Art Room Faucet - Tower	0.7	Pass	Pass

5.0 DISCUSSION AND CONCLUSION

A total of twenty-one (21) samples were collected from Lincoln Community School. Three (3) samples were found to be greater than the EPA Lead and Copper Rule standard of 15 ppb. Two (2) samples were found to be greater than the EPA Lead and Copper Rule standard of 15 ppb and also greater than the EPA Lead in Drinking Water at Schools and Child Care Facilities standard of 20 ppb. All other samples were found to be less than the EPA standards of 20 ppb and 15 ppb.

As a follow-up to drinking water testing conducted on June 20, 2025, McCabe conducted a follow-up testing August 23, 2025. A total of six (6) samples were collected from Lincoln Community School located at 208 Prospect Avenue, Bayonne, New Jersey 07002. All samples taken during the follow-up inspection were below the regulatory standard.

In addition, McCabe Environmental recommends annual drinking water sampling to ensure that the building’s plumbing is not having an adverse impact on water quality.

APPENDIX A

**LABORATORY CERTIFICATES OF ANALYSIS
&
SAMPLE CHAIN OF CUSTODY FORMS**



Thursday, July 03, 2025

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
SDG ID: GCT57987
Sample ID#s: CT57987 - CT58007

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller
Laboratory Director

NELAC - #NY11301
CT Lab Registration #PH-0618
MA Lab Registration #M-CT007
ME Lab Registration #CT-007
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003
NY Lab Registration #11301
PA Lab Registration #68-03530
RI Lab Registration #63
VT Lab Registration #VT11301



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Sample Id Cross Reference

July 03, 2025

SDG I.D.: GCT57987

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION

Client Id	Lab Id	Matrix	Col Date
LC-01	CT57987	DRINKING WATER	06/20/25 11:36
LC-02	CT57988	DRINKING WATER	06/20/25 11:37
LC-03	CT57989	DRINKING WATER	06/20/25 11:38
LC-04	CT57990	DRINKING WATER	06/20/25 11:39
LC-07	CT57991	DRINKING WATER	06/20/25 11:42
LC-08	CT57992	DRINKING WATER	06/20/25 11:46
LC-10	CT57993	DRINKING WATER	06/20/25 11:47
LC-12	CT57994	DRINKING WATER	06/20/25 11:49
LC-14	CT57995	DRINKING WATER	06/20/25 11:52
LC-15	CT57996	DRINKING WATER	06/20/25 11:54
LC-16	CT57997	DRINKING WATER	06/20/25 11:55
LC-17	CT57998	DRINKING WATER	06/20/25 11:57
LC-19	CT57999	DRINKING WATER	06/20/25 11:59
LC-20	CT58000	DRINKING WATER	06/20/25 12:01
LC-21	CT58001	DRINKING WATER	06/20/25 12:02
LC-22	CT58002	DRINKING WATER	06/20/25 12:04
LC-23	CT58003	DRINKING WATER	06/20/25 12:07
LC-25	CT58004	DRINKING WATER	06/20/25 12:08
LC-27	CT58005	DRINKING WATER	06/20/25 12:09
LC-29	CT58006	DRINKING WATER	06/20/25 12:10
LC-30	CT58007	DRINKING WATER	06/20/25 12:14



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

11:36
 16:20

Laboratory Data

SDG ID: GCT57987
 Phoenix ID: CT57987

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: LC-01

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	3.9	0.5	2	ppb	15			06/26/25	CPP	E200.8
Total Metal Digestion	Completed							06/25/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

11:37
 16:20

Laboratory Data

SDG ID: GCT57987
 Phoenix ID: CT57988

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: LC-02

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.3	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

11:38
 16:20

Laboratory Data

SDG ID: GCT57987
 Phoenix ID: CT57989

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: LC-03

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

11:39
 16:20

Laboratory Data

SDG ID: GCT57987
 Phoenix ID: CT57990

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: LC-04

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

11:42
 16:20

Laboratory Data

SDG ID: GCT57987
 Phoenix ID: CT57991

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: LC-07

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	47.5	0.5	2	ppb	15			06/30/25	CPP	E200.8
*** Lead exceeds Action Level of 15 ***										
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director
 July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

11:46
 16:20

Laboratory Data

SDG ID: GCT57987
 Phoenix ID: CT57992

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: LC-08

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2.2	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

11:47
 16:20

Laboratory Data

SDG ID: GCT57987
 Phoenix ID: CT57993

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: LC-10

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

11:49
 16:20

Laboratory Data

SDG ID: GCT57987
 Phoenix ID: CT57994

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: LC-12

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

11:52
 16:20

Laboratory Data

SDG ID: GCT57987
 Phoenix ID: CT57995

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: LC-14

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	5.3	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

11:54
 16:20

Laboratory Data

SDG ID: GCT57987
 Phoenix ID: CT57996

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: LC-15

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	4.1	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

11:55
 16:20

Laboratory Data

SDG ID: GCT57987
 Phoenix ID: CT57997

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: LC-16

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

11:57
 16:20

Laboratory Data

SDG ID: GCT57987
 Phoenix ID: CT57998

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: LC-17

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2.8	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

11:59
 16:20

Laboratory Data

SDG ID: GCT57987
 Phoenix ID: CT57999

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: LC-19

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

12:01
 16:20

Laboratory Data

SDG ID: GCT57987
 Phoenix ID: CT58000

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: LC-20

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

12:02
 16:20

Laboratory Data

SDG ID: GCT57987
 Phoenix ID: CT58001

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: LC-21

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	34.8	0.5	2	ppb	15			06/30/25	CPP	E200.8
*** Lead exceeds Action Level of 15 ***										
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director
 July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

12:04
 16:20

Laboratory Data

SDG ID: GCT57987
 Phoenix ID: CT58002

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: LC-22

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	3.1	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

12:07
 16:20

Laboratory Data

SDG ID: GCT57987
 Phoenix ID: CT58003

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: LC-23

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

12:08
 16:20

Laboratory Data

SDG ID: GCT57987
 Phoenix ID: CT58004

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: LC-25

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.6	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

12:09
 16:20

Laboratory Data

SDG ID: GCT57987
 Phoenix ID: CT58005

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: LC-27

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.3	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

12:10
 16:20

Laboratory Data

SDG ID: GCT57987
 Phoenix ID: CT58006

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: LC-29

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.8	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC
 Received by: CP
 Analyzed by: see "By" below

Date

06/20/25
 06/23/25

Time

12:14
 16:20

Laboratory Data

SDG ID: GCT57987
 Phoenix ID: CT58007

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: LC-30

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	15.4	0.5	2	ppb	15			06/30/25	CPP	E200.8
*** Lead exceeds Action Level of 15 ***										
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director
 July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager

Analysis Report - Summary

July 03, 2025

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

SDG I.D.: GCT57987



Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
Project:	25-05225 Bayonne Board Of Education							
CT57987	LC-01	06/20/25	Lead	3.9	0.5	ppb	06/26/25	E200.8
CT57988	LC-02	06/20/25	Lead	1.3	0.5	ppb	06/30/25	E200.8
CT57989	LC-03	06/20/25	Lead	< 0.5	0.5	ppb	06/30/25	E200.8
CT57990	LC-04	06/20/25	Lead	< 0.5	0.5	ppb	06/30/25	E200.8
CT57991	LC-07	06/20/25	Lead	47.5	0.5	ppb	06/30/25	E200.8
CT57992	LC-08	06/20/25	Lead	2.2	0.5	ppb	06/30/25	E200.8
CT57993	LC-10	06/20/25	Lead	< 0.5	0.5	ppb	06/30/25	E200.8
CT57994	LC-12	06/20/25	Lead	< 0.5	0.5	ppb	06/30/25	E200.8
CT57995	LC-14	06/20/25	Lead	5.3	0.5	ppb	06/30/25	E200.8
CT57996	LC-15	06/20/25	Lead	4.1	0.5	ppb	06/30/25	E200.8
CT57997	LC-16	06/20/25	Lead	< 0.5	0.5	ppb	06/30/25	E200.8
CT57998	LC-17	06/20/25	Lead	2.8	0.5	ppb	06/30/25	E200.8
CT57999	LC-19	06/20/25	Lead	< 0.5	0.5	ppb	06/30/25	E200.8
CT58000	LC-20	06/20/25	Lead	< 0.5	0.5	ppb	06/30/25	E200.8
CT58001	LC-21	06/20/25	Lead	34.8	0.5	ppb	06/30/25	E200.8
CT58002	LC-22	06/20/25	Lead	3.1	0.5	ppb	06/30/25	E200.8
CT58003	LC-23	06/20/25	Lead	< 0.5	0.5	ppb	06/30/25	E200.8
CT58004	LC-25	06/20/25	Lead	0.6	0.5	ppb	06/30/25	E200.8
CT58005	LC-27	06/20/25	Lead	1.3	0.5	ppb	06/30/25	E200.8
CT58006	LC-29	06/20/25	Lead	0.8	0.5	ppb	06/30/25	E200.8
CT58007	LC-30	06/20/25	Lead	15.4	0.5	ppb	06/30/25	E200.8

Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
--------	-----------	-------------	-----------	--------	----	-------	------------------	-----------

Comments:

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

ND=Not detected BDL=Below Detection Level RL=Reporting Level CL=Client Limit



Phyllis Shiller
Laboratory Director

July 03, 2025



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



QA/QC Report

July 03, 2025

QA/QC Data

SDG I.D.: GCT57987

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	-----------	------------------	---------------	------------	----------	-----------	------------	---------	----------	-----------	--------------------	--------------------

QA/QC Batch 790693A (mg/L), QC Sample No: CT57978 (CT57987)

ICP MS Metals - Aqueous

Lead	BRL	0.0001				107					104		
------	-----	--------	--	--	--	-----	--	--	--	--	-----	--	--

Comment:

This batch does not include a duplicate.

QA/QC Batch 790954 (mg/L), QC Sample No: CT57988 (CT57988, CT57989, CT57990, CT57991, CT57992, CT57993, CT57994, CT57995, CT57996, CT57997)

ICP MS Metals - Aqueous

Lead	BRL	0.0001	0.0013	0.0013	0	92.8					92.2		
------	-----	--------	--------	--------	---	------	--	--	--	--	------	--	--

QA/QC Batch 790954A (mg/L), QC Sample No: CT57998 (CT57998, CT57999, CT58000, CT58001, CT58002, CT58003, CT58004, CT58005, CT58006, CT58007)

ICP MS Metals - Aqueous

Lead	BRL	0.0001				92.8					90.0		
------	-----	--------	--	--	--	------	--	--	--	--	------	--	--

Comment:

This batch does not include a duplicate.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Inf - Interference
- (ISO) - Isotope Dilution


 Phyllis Shiller, Laboratory Director
 July 03, 2025

Thursday, July 03, 2025

Criteria: NJ: DW

State: NJ

Sample Criteria Exceedances Report

GCT57987 - MCCABE-PB

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
CT57991	PB-DW-MS	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	47.5	0.5	15	1	ppb
CT58001	PB-DW-MS	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	34.8	0.5	15	1	ppb
CT58007	PB-DW-MS	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	15.4	0.5	15	1	ppb

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Comments

July 03, 2025

SDG I.D.: GCT57987

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

2.2" WCLP

MCCABE ENVIRONMENTAL SERVICES, L.L.C.
 464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER
 CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education
 SITE ADDRESS: Lincoln Community School
 208 Prospect Ave, Bayonne, NJ 07002

FIELD INSPECTOR'S NAME: A. J. Clare & G. Clare
 TURNAROUND TIME REQUESTED: 2-Week
 MES PROJECT #: 25-05225
 SAMPLE DATE: 6/20/25

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	LC-01	First row - Girl's Locker Room Bubble	11:36 AM	LEAD - 200.8
DW	LC-02	30 sec. Flush - Girl's Locker Room Bubble	11:37 AM	LEAD - 200.8
DW	LC-03	FD - Chiller outside Main Office	11:38 AM	LEAD - 200.8
DW	LC-04	FD - Chiller oasis in Pool Room	11:39 AM	LEAD - 200.8
DW	LC-07	FD - Room 101 sink	11:42 AM	LEAD - 200.8
DW	LC-08	FD - Room 111 faucet - life skills	11:46 AM	LEAD - 200.8
DW	LC-10	FD - Room 110 faucet	11:47 AM	LEAD - 200.8
DW	LC-12	FD - Room 112 faucet	11:49 AM	LEAD - 200.8
DW	LC-14	FD - Room 114 faucet	11:52 AM	LEAD - 200.8
DW	LC-15	FD - Bubble Across Room 113	11:54 AM	LEAD - 200.8

Relinquished by (Print) G. Clare
 Date: 6/23/25 10:15
 Signature: *G. Clare*

Received by: (Print) J. Demers
 Signature: *J. Demers*
 Date: 8-23 2025 10:15

Relinquished by (Print)
 Date:
 Signature: *AM*

Received by: (Print) Abby Lee
 Signature: *Abby Lee*
 Date: 6/23/25 10:20

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

NJ Certified WBE

2.2" w.c.1P

MCCABE ENVIRONMENTAL SERVICES, L.L.C.
 464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER
 CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education
 FIELD INSPECTOR'S NAME: A. Letama & G. Clare
 MES PROJECT #: 25-05225
 SAMPLE DATE: 6/20/25

SITE ADDRESS: Lincoln Community School
 208 Prospect Ave, Bayonne, NJ 07002

TURNAROUND TIME REQUESTED: 2-Week

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED	57997
DW	LC-16	FD - Bubblers by Room 109	11:55AM	LEAD - 200.8	57998
DW	LC-17	FD - Room 115 faucet	11:57AM	LEAD - 200.8	57999
DW	LC-19	FD - Nurses Office faucet	11:59AM	LEAD - 200.8	58000
DW	LC-20	FD - Chiller Across from Room 122	12:01 PM	LEAD - 200.8	58001
DW	LC-21	FD - Room 122 faucet	12:02 PM	LEAD - 200.8	58002
DW	LC-22	FD - Changing Room faucet	12:04 PM	LEAD - 200.8	58003
DW	LC-23	FD - Chiller outside Boys/Girls Rest Room	12:07 PM	LEAD - 200.8	58004
DW	LC-25	FD - Room 203 faucet	12:08 PM	LEAD - 200.8	58005
DW	LC-27	FD - Room 202 faucet	12:09 PM	LEAD - 200.8	58006
DW	LC-29	FD - Room 201 faucet	12:10 PM	LEAD - 200.8	

Relinquished by (Print) Guy Clare
 Signature: [Signature] Date: 6/23/25 Time: 10:15
 Received by: (Print) S. Demers
 Signature: [Signature] Date: 8-23-2025 Time: 10:15
 Relinquished by (Print) [Signature]
 Signature: [Signature] Date: 6/23/25 Time: 16:20
 Received by: (Print) Abby Lee
 Signature: [Signature] Date: 6/23/25 Time: 16:20

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

NJ Certified WBE

2.2° WCIP

MCCABE ENVIRONMENTAL SERVICES, L.L.C.
464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER
CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education		SITE ADDRESS: Lincoln Community School 208 Prospect Ave, Bayonne, NJ 07002	
FIELD INSPECTOR'S NAME: A. Uzuma & G. Clave		TURNAROUND TIME REQUESTED: 2-Week	
MES PROJECT #: 25-05225	SAMPLE DATE: 6/20/25		
Matrix	SAMPLE ID	SAMPLE LOCATION	ANALYSIS REQUESTED
DW	LC-30	FD - Art Room faucet - Tower	LEAD - 200.8
DW			LEAD - 200.8
DW			LEAD - 200.8
DW			LEAD - 200.8
DW			LEAD - 200.8
DW			LEAD - 200.8
DW			LEAD - 200.8
DW			LEAD - 200.8
DW			LEAD - 200.8
DW			LEAD - 200.8
DW			LEAD - 200.8
DW			LEAD - 200.8
DW			LEAD - 200.8
Relinquished by (Print) Gury Clave		Received by: (Print) J. Demers	Date: 8-23-2025
Signature: <i>[Signature]</i>		Signature: <i>[Signature]</i>	Time: 1015
Relinquished by (Print)		Received by: (Print) Abby Lee	Date: 6/23/25
Signature: <i>[Signature]</i>		Signature: <i>[Signature]</i>	Time: 1620
Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories			

58007

NJ Certified WBE



Wednesday, September 03, 2025

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION
SDG ID: GCU09451
Sample ID#s: CU09451 - CU09456

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller
Laboratory Director

NELAC - #NY11301
CT Lab Registration #PH-0618
MA Lab Registration #M-CT007
ME Lab Registration #CT-007
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003
NY Lab Registration #11301
PA Lab Registration #68-03530
RI Lab Registration #63
VT Lab Registration #VT11301



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Sample Id Cross Reference

September 03, 2025

SDG I.D.: GCU09451

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION

Client Id	Lab Id	Matrix	Col Date
LC-07-A	CU09451	DRINKING WATER	08/23/25 7:41
LC-07-B	CU09452	DRINKING WATER	08/23/25 7:42
LC-21-A	CU09453	DRINKING WATER	08/23/25 7:45
LC-21-B	CU09454	DRINKING WATER	08/23/25 7:45
LC-30-A	CU09455	DRINKING WATER	08/23/25 7:48
LC-30-B	CU09456	DRINKING WATER	08/23/25 7:49



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

September 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/25
 08/25/25

Time

7:41
 19:05

Laboratory Data

SDG ID: GCU09451
 Phoenix ID: CU09451

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION
 Client ID: LC-07-A

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.7	0.5	2	ppb	15			09/02/25	CPP	E200.8
Total Metal Digestion	Completed							08/30/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

September 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/25
 08/25/25

Time

7:42
 19:05

Laboratory Data

SDG ID: GCU09451
 Phoenix ID: CU09452

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION
 Client ID: LC-07-B

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			09/02/25	CPP	E200.8
Total Metal Digestion	Completed							08/30/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

September 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/25
 08/25/25

Time

7:45
 19:05

Laboratory Data

SDG ID: GCU09451
 Phoenix ID: CU09453

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION
 Client ID: LC-21-A

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			09/02/25	CPP	E200.8
Total Metal Digestion	Completed							08/30/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

September 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/25
 08/25/25

Time

7:45
 19:05

Laboratory Data

SDG ID: GCU09451
 Phoenix ID: CU09454

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION
 Client ID: LC-21-B

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			09/02/25	CPP	E200.8
Total Metal Digestion	Completed							08/30/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

September 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/25
 08/25/25

Time

7:48
 19:05

Laboratory Data

SDG ID: GCU09451
 Phoenix ID: CU09455

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION
 Client ID: LC-30-A

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	7.2	0.5	2	ppb	15			09/02/25	CPP	E200.8
Total Metal Digestion	Completed							08/30/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

September 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/25
 08/25/25

Time

7:49
 19:05

Laboratory Data

SDG ID: GCU09451
 Phoenix ID: CU09456

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION
 Client ID: LC-30-B

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.7	0.5	2	ppb	15			09/02/25	CPP	E200.8
Total Metal Digestion	Completed							08/30/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager

Analysis Report - Summary

September 03, 2025

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

SDG I.D.: GCU09451



Sample	Client Id	Col Date	Parameter	Result	RL	CL	Units	Date Analyzed	Reference
Project: 25-05225-1 Bayonne Board Of Education									
CU09451	LC-07-A	08/23/25	Lead	0.7	0.5		ppb	09/02/25	E200.8
CU09452	LC-07-B	08/23/25	Lead	< 0.5	0.5		ppb	09/02/25	E200.8
CU09453	LC-21-A	08/23/25	Lead	< 0.5	0.5		ppb	09/02/25	E200.8
CU09454	LC-21-B	08/23/25	Lead	< 0.5	0.5		ppb	09/02/25	E200.8
CU09455	LC-30-A	08/23/25	Lead	7.2	0.5		ppb	09/02/25	E200.8
CU09456	LC-30-B	08/23/25	Lead	0.7	0.5		ppb	09/02/25	E200.8

Comments:

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
ND=Not detected BDL=Below Detection Level RL=Reporting Level CL=Client Limit


Phyllis Shiller
Laboratory Director
September 03, 2025



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



QA/QC Report

September 03, 2025

QA/QC Data

SDG I.D.: GCU09451

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
QA/QC Batch 800979 (mg/L), QC Sample No: CU09447 (CU09451, CU09452, CU09453, CU09454, CU09455, CU09456)													
<u>ICP MS Metals - Aqueous</u>													
Lead	BRL	0.0001	0.0008	0.0007	NC	104					101		

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference
- (ISO) - Isotope Dilution


 Phyllis Shiller, Laboratory Director
 September 03, 2025

Wednesday, September 03, 2025

Criteria: NJ: DW

State: NJ

Sample Criteria Exceedances Report

GCU09451 - MCCABE-PB

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

*** No Data to Display ***

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Comments

September 03, 2025

SDG I.D.: GCU09451

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

MCCABE ENVIRONMENTAL SERVICES, L.L.C.

464 VALLEY BROOK AVENUE LYNDHURST, NJ 07071 • PHONE: (201) 438-4839 FAX: (201) 438-1798

**LEAD in DRINKING WATER
CHAIN-OF-CUSTODY FORM**

1.1 WCLP

CLIENT NAME: Bayonne Board of Education

SITE ADDRESS: Lincoln Community School
208 Prospect Ave, Bayonne, NJ 07002

FIELD INSPECTOR'S NAME: A. Lezanne

TURNAROUND TIME REQUESTED: 2-Week

MES PROJECT #: 25-05275-1 | SAMPLE DATE: 8/23/25

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	LC-07-A	FD - Room 101 Faucet	7:41 AM	LEAD - 200.8
DW	LC-07-B	30 sec. Flush - Room 101 Faucet	7:42 AM	LEAD - 200.8
DW	LC-21-A	FD - Room 122 Faucet	7:45 AM	LEAD - 200.8
DW	LC-21-B	30 sec. Flush - Room 122 Faucet	7:45 AM	LEAD - 200.8
DW	LC-30-A	FD - Art Room Faucet - Tower	7:48 AM	LEAD - 200.8
DW	LC-30-B	30 sec. Flush - Art Room Faucet - Tower	7:49 AM	LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8

Relinquished by (Print) <i>Allyce Lezanne</i>	Date: 8/25/25	Received by: (Print) <i>J. Demons</i>	Date: 8-25-2025
Signature: <i>Allyce Lezanne</i>	Time:	Signature: <i>JD</i>	Time: 1245
Relinquished by (Print)	Date:	Received by: (Print)	Date:
Signature: <i>AL</i>	Time:	Signature: <i>JD</i>	Time: 660

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): *JD* Phoenix Environmental Laboratories 8/25/25 1905

APPENDIX B

**SCHOOL DISTRICT SAMPLING
ATTACHMENTS**

Attachment A - List of Priority for Sampling

SCHOOL NAME	DATE OF SAMPLING	CERTIFIED LABORATORY	NOTES
Lincoln Community School	06/20/2025	Phoenix Environmental Laboratories Inc.	

Attachment A - List of Priority for Sampling

SCHOOL NAME	DATE OF SAMPLING	CERTIFIED LABORATORY	NOTES
Lincoln Community School	8/23/2025	Phoenix Environmental Laboratories Inc.	

Attachment B - Plumbing Profile

Note: Complete for each school. For additional information see the USEPA publication, "The 3Ts for Reducing Lead in Drinking Water in Schools"

Name of School: Lincoln Community School Grade Levels: K-8

Address: 208 Prospect Ave., Bayonne, NJ 07002

Individual school project officer Signature: *Scott Nolan* Date: 8/5/2025

Questions	Answers	
Background Information		
1. What year was the original building constructed? Were any buildings or additions added to the original facility?	K-8 Grade School Built in 1919 K-8 Grade School Addition in 1976	
2. If the building was constructed or repaired after 1986, was lead-free plumbing and solder utilized? What type of solder was used? Document all locations where lead solder was used.	Any repairs made after 1986 were done using lead free solder	
3. Where are the most recent plumbing repairs and replacements?	Location: Nurses Office Room 101	Description: New Faucet New Faucet
4. With what materials is the service connection (the pipe that carries water to the school from the public water system's main in the street) made? Where is the Service Line located? (This is the POE location.)	Material: Main Building - Duct Iron Location: The water main (30th St) enters the first floor girls locker room where the water meter is located flows through the building to the boiler room and continues to the remainder of the building	
5. Is there point of entry (POE) or point of use (POU) treatment in use?	Y / N No treatment of water Type: at POE City water comes treated	Location: New wing girls room 1976

Questions	Answers
6. Are there tanks in your plumbing system (pressure tanks, gravity storage tanks)?	Y / N Yes Building has a pvi 3000 gallon hot water storage tank located in boiler room
7. Does the school have a filter maintenance and operation program? If so, who is responsible for this program? What is the process for adding filters?	Yes, Scott Nolan, Andy McCabe, Vinny Caiola, change filters on an as needed basis assign plumbers
8. Have accessible screens or aerators on outlets that provide drinking water been cleaned? Does the school have a screen or aerator maintenance program?	Y / N Yes The district has set-up a routine maintenance program to clean screens
9. Have there been any complaints about bad (metallic) taste? Note location(s).	Y / N NO Location:
10. Review records and consult with the public water supplier to determine whether any water samples have been taken in the building for any contaminants. If so, identify: <ul style="list-style-type: none"> • Name of contaminant(s) • Concentrations found • pH level Is testing done regularly at the building?	No indoor testing by public water supplier
11. Other plumbing background questions include: <ul style="list-style-type: none"> • Are blueprints of the building available? • Are there known plumbing “dead-ends”, low use areas, existing leaks or other “problem areas”? Are renovations planned for any of the plumbing system?	Not all prints are available No dead-end low areas All leaks were identified during walk through and have been repaired No plumbing system renovations

Questions	Answers	
Walk-Through <i>These questions should be addressed during the walk-through of the facility, while Attachment C- Drinking Water Outlet Inventory is being completed.</i>		
1. Confirm the material of Service Line visually.	Duct iron	
2. Confirm the presence of POE or POU treatment.	No POE or POU treatment	
3. What are the potable water pipes made of in your facility? <ul style="list-style-type: none"> • Lead • Plastic • Galvanized Metal • Cast Iron • Copper • Other Note the water flow through the building and the areas that receive water first, and which areas receive water last.	Cooper Galvanized Metal Brass Water flow through the building shown on the prints	
4. Are electrical wires grounded to Water Pipes? Note location(s).	Y / N Location:	No No electrical wires grounded to water pipes
5. Are brass fittings, faucets, or valves used in your drinking water system? Note that most faucets are brass on the inside. Document the locations of any brass water outlet to be sampled.	Complete in "Brass" Column in Attachment C- Water Outlet Inventory. Yes Completed in Attachment C - Water Outlet Inventory	
6. Locate all drinking water outlets (i.e. water coolers, bubblers, ice machines, kitchen/ food prep sinks, etc.) in the facility.	Complete in Attachment C-Water Outlet Inventory.	

Questions	Answers	
<p>7. Have the brands and models of the water coolers in the school been compared to the list of recalled water coolers in the Toolkit?</p> <p>Recalled Drinking Water Fountains</p> <p>Make and Model</p>	<p>Y / N Yes all water coolers have been checked and compared to the list of recalled water coolers</p> <p>Type None on the list of recalled water coolers</p>	
<p>8. Have signs of corrosion, such as frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry been detected?</p> <p>Note the locations of water outlets.</p>	<p>Complete in "Signs of Corrosion" column in Attachment C- Drinking Water Outlet Inventory.</p>	
<p>9. Are there any outlets that are not operational and therefore out of service? Permanently? Temporarily?</p> <p style="text-align: right;">Permanently</p> <p style="text-align: right;">Temporarily</p>	<p>Y / N</p> <p>Complete "Operational Column" in Attachment C- Drinking Water Outlet Inventory.</p> <p>Type/ Location</p>	<p>Description</p>

Attachment C – Drinking Water Outlet Inventory

Name of School: Lincoln Community School

Address: 208 Prospect Avenue, Bayonne, New Jersey 07002

Grade Levels: Elementary School Year School Constructed: Unknown Renovated/Additions: NA

Individual School Project Officer: Scott Nolan

Date Completed: 09/05/2025

# ¹	Type	Location	Code	Operational ² (Y/N)	Signs of Corrosion ³ (Y/N)	Filter ⁴ (Y/N)	Brass Fittings, Faucets or valves? (Y/N)	Aerator/ Screen (Y/N)	Motion Activated (Y/N)	Chiller (Y/N)	Water Cooler		Comments
											Make	Model	
01	Water Fountain	Girl's Locker Room	LC-01	Y	N	N	N	N	N	N	NA	NA	
02	Water Fountain	Girl's Locker Room	LC-02	Y	N	N	N	N	N	N	NA	NA	Flush
03	Chiller	Outside Main Office	LC-03	Y	N	Y	N	N	N	Y	NA	NA	
04	Bottle Filling Station	Pool Room	LC-04	Y	N	Y	N	N	Y	Y	NA	NA	
05	Water Fountain	Boys Locker Room	LC-05	N	N	Y	N	N	N	N	NA	NA	PERMANENTLY REMOVED
06	Water Fountain	Room 101	LC-06	N	N	N	N	N	N	N	NA	NA	PERMANENTLY REMOVED
07	Sink	Room 101	LC-07	Y	N	N	N	Y	N	N	NA	NA	

¹ Number outlets starting at the closest outlet to the Point of Entry (POE).

² Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

³ Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

⁴ Document on Attachment D- Filter Inventory.

08	Sink	Room 111 – Life Skills	LC-08	Y	N	N	N	Y	N	N	NA	NA	
09	Water Fountain	Room 110	LC-09	N	NA	NA	PERMANENTLY REMOVED						
10	Sink	Room 110	LC-10	Y	N	N	N	N	N	N	NA	NA	
11	Water Fountain	Room 112	LC-11	Y	N	N	N	N	N	N	NA	NA	PERMANENTLY REMOVED
12	Sink	Room 112	LC-12	Y	N	N	N	Y	N	N	NA	NA	
13	Water Fountain	Room 114	LC-13	N	NA	NA	PERMANENTLY REMOVED						
14	Sink	Room 114	LC-14	Y	N	N	N	Y	N	N	NA	NA	
15	Water Fountain	Across from Room 113	LC-15	Y	N	Y	N	N	N	N	NA	NA	
16	Chiller	by Room 109	LC-16	Y	N	Y	N	N	N	Y	NA	NA	
17	Sink	Room 115 Left Faucet	LC-17	Y	N	Y	N	N	N	N	NA	NA	
18	Sink	Room 115 Right Faucet	LC-18	N	N	N	N	Y	N	N	NA	NA	PERMANENTLY REMOVED
19	Sink	Nurse's Office	LC-19	Y	N	N	N	Y	N	N	NA	NA	
20	Chiller	Across from Room 122	LC-20	Y	N	N	N	Y	N	N	NA	NA	
21	Sink	Room 122	LC-21	Y	N	N	N	Y	N	N	NA	NA	
22	Sink	Changing Room	LC-22	Y	N	N	N	Y	N	N	NA	NA	
23	Chiller	Outside Girls/Boys Room 1st Floor	LC-23	Y	N	Y	N	N	N	Y	NA	NA	
24	Water Fountain	Room 203	LC-24	N	N	N	N	N	N	N	NA	NA	
25	Sink	Room 203	LC-25	Y	N	N	N	Y	N	N	NA	NA	
26	Water Fountain	Room 202	LC-26	N	N	N	N	N	N	N	NA	NA	
27	Sink	Room 202	LC-27	Y	N	N	N	Y	N	N	NA	NA	
28	Water Fountain	Room 201	LC-28	N	N	N	N	N	N	N	NA	NA	

29	Sink	Room 201	LC-29	Y	N	N	N	Y	N	N	NA	NA	
30	Sink	Art Room – Tower	LC-30	Y	N	N	N	N	N	N	NA	NA	

¹ Number outlets starting at the closest outlet to the Point of Entry (POE).

¹ Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

¹ Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

¹ Document on Attachment D- Filter Inventory.

Attachment D - Filter Inventory

Name of School: Lincoln Community School Grade Levels: Elementary School

Address: 208 Prospect Avenue, Bayonne, New Jersey 07002

Individual School Project Officer: Scott Nolan

Date: 09/05/2025

Sample Location / Code	Brand	Type (Make & Model)	Date Installed or Replaced	Replacement Frequency	NSF Certified for Lead Reduction Y/N
LC-01	American Standard	N/A	N/A	N/A	N/A
LC-02	American Standard	N/A	N/A	N/A	N/A
LC-03	Elkay	OHFAVR8_1J (Aqua Pure)	N/A	N/A	N/A
LC-04	Elkay	LZS8WSLP	N/A	N/A	N/A
LC-05	PERMANENTLY REMOVED				
LC-06	PERMANENTLY REMOVED				
LC-07	3M Aqua Pure	AP200	8/13/2025	N/A	N/A
LC-08	N/A	N/A	N/A	N/A	N/A
LC-09	PERMANENTLY REMOVED				
LC-10	N/A	N/A	N/A	N/A	N/A
LC-11	PERMANENTLY REMOVED				
LC-12	N/A	N/A	N/A	N/A	N/A
LC-13	PERMANENTLY REMOVED				
LC-14	N/A	N/A	N/A	N/A	N/A
LC-15	Halsey Taylor	HRFS_B	N/A	N/A	N/A
LC-16	Elkay	EHFA81F (Aqua Pure)	N/A	N/A	N/A
LC-17	3M Aqua Pure	3MFF101	N/A	N/A	N/A
LC-18	PERMANENTLY REMOVED				
LC-19	N/A	N/A	N/A	N/A	N/A
LC-20	Elkay	LZWSR 1D	N/A	N/A	N/A
LC-21	3M Aqua Pure	AP200	8/13/2025	N/A	N/A

LC-22	N/A	N/A	N/A	N/A	N/A
LC-23	Elkay	EHFSA 1K	N/A	N/A	N/A
LC-24	N/A	N/A	N/A	N/A	N/A
LC-25	N/A	N/A	N/A	N/A	N/A
LC-26	N/A	N/A	N/A	N/A	N/A
LC-27	N/A	N/A	N/A	N/A	N/A
LC-28	N/A	N/A	N/A	N/A	N/A
LC-29	N/A	N/A	N/A	N/A	N/A
LC-30	3M Aqua Pure	AP200	8/13/2025	N/A	N/A

Attachment E – Flushing Log

Name of School: Lincoln Community School

Address: 208 Prospect Avenue, Bayonne, New Jersey 07002

Grade Levels: Elementary School

Individual School Project Officer: Scott Nolan

Date: 09/05/2025

Sample Location Description	Sample Location Code	Date	Time	Duration of Flushing	Reason for Flushing
Girl's Locker Room Bubbler	LC-01	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Girl's Locker Room Bubbler	LC-02	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Chiller Outside Main Office	LC-03	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Chiller Oasis in Pool Room	LC-04	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Boys Locker Room Bubbler	LC-05	PERMANENTLY REMOVED			
Room 101 Bubbler	LC-06	PERMANENTLY REMOVED			
Room 101 Faucet	LC-07	August 22, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 111 Faucet – Life Skills	LC-08	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 110 Bubbler	LC-09	PERMANENTLY REMOVED			
Room 110 Faucet	LC-10	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 112 Bubbler	LC-11	PERMANENTLY REMOVED			
Room 112 Faucet	LC-12	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 114 Bubbler	LC-13	PERMANENTLY REMOVED			
Room 114 Faucet	LC-14	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Across from 113	LC-15	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Room 109	LC-16	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 115 Left Faucet	LC-17	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 115 Right Faucet	LC-18	PERMANENTLY REMOVED			
Nurse's Office Faucet	LC-19	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Chiller Across from Room 122	LC-20	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 122 Faucet	LC-21	August 22, 2025	5:30 pm	2-3 Minutes	Water Sampling
Changing Room Faucet	LC-22	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling

Bayonne BOE: Sampling Plan

Chiller Outside Girls/Boys Room 1st Floor	LC-23	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 203 Bubbler	LC-24	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 203 Faucet	LC-25	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 202 Bubbler	LC-26	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 202 Faucet	LC-27	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 201 Bubbler	LC-28	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 201 Faucet	LC-29	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Art Room Faucet – Tower	LC-30	August 22, 2025	5:30 pm	2-3 Minutes	Water Sampling

Attachment F - Pre - Sampling Water Use Certification

TO BE COMPLETED BY THE BAYONNE BOE DISTRICT REPRESENTATIVE:		
School Name:	<u>Lincoln Community School</u>	
Sample collection address:	<u>208 Prospect Avenue, Bayonne, New Jersey 07002</u>	
Water was last used:	<u>Time: 5:30 pm</u>	<u>Date: June 19, 2025</u>
Sample commencement:	<u>Time: 10:15 am</u>	<u>Date: June 20, 2025</u>
I have read the Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.		
Scott Nolan	<u>07/18/2025</u>	
Signature	Date	

Attachment F - Pre - Sampling Water Use Certification

TO BE COMPLETED BY THE BAYONNE BOE DISTRICT REPRESENTATIVE:		
School Name:	<u>Lincoln Community School</u>	
Sample collection address:	<u>208 Prospect Avenue, Bayonne, New Jersey 07002</u>	
Water was last used:	<u>Time: 5:30 pm</u>	<u>Date: August 22, 2025</u>
Sample commencement:	<u>Time: 7:41 am</u>	<u>Date: August 23, 2025</u>
I have read the Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.		
Scott Nolan	<u>09/05/2025</u>	
Signature	Date	