



464 Valley Brook Avenue, Lyndhurst NJ 07071
129 Sea Girt Avenue, Manasquan NJ 08736
Phone: (800) 423-0766 • Fax: (201) 438-1798
www.mccabeenv.com

LEAD IN DRINKING WATER TESTING REPORT

Conducted for:

Bayonne Board of Education
669 Avenue A
Bayonne, New Jersey 07002

Conducted at:

John M. Bailey Community School
75 W 10th Street
Bayonne, New Jersey 07002

Submitted by:

McCabe Environmental Services, L.L.C.
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

REPORT DATE: September 8, 2025

MES PROJECT NO.: 25-05225

Prepared by:

A handwritten signature in blue ink, appearing to read 'Arlitzzy Lezama'.

Arlitzzy Lezama
Environmental Scientist

Signed for the Company by:

A handwritten signature in blue ink, appearing to read 'John H. Chiaviello'.

John H. Chiaviello
Vice President

TABLE OF CONTENTS

	Page
1.0 INTRODUCTION	1
2.0 SCOPE OF WORK.....	1
3.0 PROCEDURES.....	1
4.0 TABLE OF SAMPLE RESULTS	2
5.0 DISCUSSION AND CONCLUSION	3

APPENDIX A

Laboratory Certificates of Analysis
&
Sample Chain of Custody Forms

APPENDIX B

School District Sampling Attachments

1.0 INTRODUCTION

McCabe Environmental Services, L.L.C. (McCabe) was retained by Bayonne Board of Education (Client) to conduct lead in drinking water testing at John M. Bailey Community School located at 75 W 10th Street, Bayonne, New Jersey 07002.

The project information is as follows:

<u>Client Name:</u>	Bayonne Board of Education
<u>Contact Person:</u>	Mr. Daniel Castles
<u>Project Name:</u>	John M. Bailey Community School – Lead in Drinking Water Testing
<u>Project Location:</u>	75 W 10 th Street Bayonne, New Jersey 07002
<u>Date(s) of Service:</u>	June 21, 2025 and August 23, 2025
<u>McCabe Personnel:</u>	Gary Clare, Kevin Brossok, & Arlitz Lezama

2.0 SCOPE OF WORK

Drinking water testing was performed at John M. Bailey Elementary School on June 21, 2025. The purpose of the testing was to determine if the building’s plumbing was having an adverse impact on water quality, specifically with regard to lead concentrations. Samples were collected from various potential drinking water outlets located throughout the building. Follow-up drinking water testing was then performed at the failed locations in John M. Bailey Community School on August 23, 2025. The failed locations were re-sampled with a first draw sample and immediately followed up with a thirty (30) second flush sample. Samples were collected from areas that exceeded the regulatory standards on June 21, 2025. Testing was followed as per past reports provided by Bayonne Board of Education.

3.0 PROCEDURES

After determining which outlets would be sampled, McCabe personnel collected a "first draw" sample at each location. A "first draw" is the initial water that is first to come out of the tap after a period of inactivity. Following the “first draw”, a "30 second flush" sample was also collected closest to where the main service line comes into the building. All samples were collected into 250 mL sterile bottles, labeled with a sample identification, and analyzed in accordance with EPA approved methods to determine the level of lead in drinking water. Samples were analyzed by an accredited laboratory.

The U.S. Environmental Protection Agency (EPA) has established National Primary Drinking Water Regulations (NPDWR) that set mandatory water quality standards for drinking water contaminants. These are enforceable standards called "maximum contaminant levels" or "MCL", which are established to protect the public against consumption of drinking water contaminants that present a risk to human health. An MCL is the maximum allowable amount of a contaminant in drinking water which is delivered to the consumer.

The EPA has established the Lead and Copper Rule that sets standards for state and public water systems. This rule has set an MCL for lead at 15 parts per billion (ppb) for a one liter sample. However, the EPA also established the Lead in Drinking Water at Schools and Child Care Facilities in which the EPA recommends an MCL of 20 ppb for

a 250 milliliter first draw sample. In order to be more stringent, for our report purposes we have compared all results to both the 15 ppb and the 20 ppb standards.

4.0 TABLE OF SAMPLE RESULTS

The following table presents all sample results in order of sample identification conducted on June 21, 2025:

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
BM-01	First Draw – Left Bubblers by Room G6	< 1	Pass	Pass
BM-02	30 Second Flush – Left Bubblers by Room G6	< 1	Pass	Pass
BM-03	First Draw – Right Bubblers by Room G6	< 1	Pass	Pass
BM-04	First Draw – Room G9 Faucet	3.6	Pass	Pass
BM-05	First Draw – Bubblers by Room G5 – Left	5.2	Pass	Pass
BM-06	First Draw – Bubblers by Room G5 – Right	11.5	Pass	Pass
BM-07	First Draw – Bottle Filler by Room G4	< 1	Pass	Pass
BM-08	First Draw – Bottle Filler by Room 11	< 1	Pass	Pass
BM-09	First Draw – Chiller Outside Main Office	< 1	Pass	Pass
BM-10	First Draw – Bubblers by Room 2	PERMANENTLY REMOVED		
BM-11	First Draw – Room 1 Faucet	< 1	Pass	Pass
BM-12	First Draw – Bottle Filler Outside Room 5	< 1	Pass	Pass
BM-13	First Draw – Pre-K Room 5 Bathroom Sink	< 1	Pass	Pass
BM-14	First Draw – Pre-K Room 4 Bathroom	< 1	Pass	Pass
BM-15	First Draw – Nurse’s Office Faucet	45.8	Fail	Fail

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
BM-16	First Draw – Bubblers by Room 27	< 1	Pass	Pass
BM-17	First Draw – Teacher’s Room Faucet	< 1	Pass	Pass
BM-18	First Draw – Bottle Filler by Room 20	< 1	Pass	Pass

The following table presents all sample results in order of sample identification from the follow-up lead in drinking water testing conducted on August 23, 2025:

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
BM-15-A	First Draw – Nurse’s Office Faucet	0.6	Pass	Pass
BM-15-B	30 Second Flush – Nurse’s Office Faucet	< 0.5	Pass	Pass

5.0 DISCUSSION AND CONCLUSION

A total of seventeen (17) samples were collected from John M. Bailey Elementary School. One (1) sample was found to be greater than the EPA Lead and Copper Rule standard of 15 ppb and also greater than the EPA Lead in Drinking Water at Schools and Child Care Facilities standard of 20 ppb. All other samples were found to be less than the EPA standards of 20 ppb and 15 ppb.

As a follow-up to drinking water testing conducted on June 21, 2025, McCabe conducted a follow-up testing August 23, 2025. A total of two (2) samples were collected from John M. Bailey Community School located at 75 West 10th Street, Bayonne, New Jersey 07002. All samples taken during the follow-up inspection were below the regulatory standard.

In addition, McCabe Environmental recommends annual drinking water sampling to ensure that the building’s plumbing is not having an adverse impact on water quality.

APPENDIX A

**LABORATORY CERTIFICATES OF ANALYSIS
&
SAMPLE CHAIN OF CUSTODY FORMS**



Thursday, July 03, 2025

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
SDG ID: GCT58227
Sample ID#s: CT58227 - CT58243

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller
Laboratory Director

NELAC - #NY11301
CT Lab Registration #PH-0618
MA Lab Registration #M-CT007
ME Lab Registration #CT-007
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003
NY Lab Registration #11301
PA Lab Registration #68-03530
RI Lab Registration #63
VT Lab Registration #VT11301



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Sample Id Cross Reference

July 03, 2025

SDG I.D.: GCT58227

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION

Client Id	Lab Id	Matrix	Col Date
BM-01	CT58227	DRINKING WATER	06/21/25 12:06
BM-02	CT58228	DRINKING WATER	06/21/25 12:07
BM-03	CT58229	DRINKING WATER	06/21/25 12:08
BM-04	CT58230	DRINKING WATER	06/21/25 12:09
BM-05	CT58231	DRINKING WATER	06/21/25 12:12
BM-06	CT58232	DRINKING WATER	06/21/25 12:12
BM-07	CT58233	DRINKING WATER	06/21/25 12:14
BM-08	CT58234	DRINKING WATER	06/21/25 12:17
BM-09	CT58235	DRINKING WATER	06/21/25 12:17
BM-11	CT58236	DRINKING WATER	06/21/25 12:21
BM-12	CT58237	DRINKING WATER	06/21/25 12:23
BM-13	CT58238	DRINKING WATER	06/21/25 12:24
BM-14	CT58239	DRINKING WATER	06/21/25 12:25
BM-15	CT58240	DRINKING WATER	06/21/25 12:30
BM-16	CT58241	DRINKING WATER	06/21/25 12:32
BM-17	CT58242	DRINKING WATER	06/21/25 12:34
BM-18	CT58243	DRINKING WATER	06/21/25 12:35



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

12:06
 16:20

Laboratory Data

SDG ID: GCT58227
 Phoenix ID: CT58227

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: BM-01

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			07/01/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

12:07
 16:20

Laboratory Data

SDG ID: GCT58227
 Phoenix ID: CT58228

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: BM-02

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			07/01/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

12:08
 16:20

Laboratory Data

SDG ID: GCT58227
 Phoenix ID: CT58229

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: BM-03

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			07/01/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

12:09
 16:20

Laboratory Data

SDG ID: GCT58227
 Phoenix ID: CT58230

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: BM-04

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	3.6	1	1	ppb	15			07/01/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

12:12
 16:20

Laboratory Data

SDG ID: GCT58227
 Phoenix ID: CT58231

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: BM-05

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	5.2	1	1	ppb	15			07/01/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

12:12
 16:20

Laboratory Data

SDG ID: GCT58227
 Phoenix ID: CT58232

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: BM-06

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	11.5	1	1	ppb	15			07/01/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

12:14
 16:20

Laboratory Data

SDG ID: GCT58227
 Phoenix ID: CT58233

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: BM-07

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			07/01/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

12:17
 16:20

Laboratory Data

SDG ID: GCT58227
 Phoenix ID: CT58234

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: BM-08

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			07/01/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

12:17
 16:20

Laboratory Data

SDG ID: GCT58227
 Phoenix ID: CT58235

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: BM-09

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			07/01/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

12:21
 16:20

Laboratory Data

SDG ID: GCT58227
 Phoenix ID: CT58236

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: BM-11

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			07/01/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

12:23
 16:20

Laboratory Data

SDG ID: GCT58227
 Phoenix ID: CT58237

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: BM-12

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			07/01/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

12:24
 16:20

Laboratory Data

SDG ID: GCT58227
 Phoenix ID: CT58238

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: BM-13

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			07/01/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

12:25
 16:20

Laboratory Data

SDG ID: GCT58227
 Phoenix ID: CT58239

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: BM-14

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			07/01/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

12:30
 16:20

Laboratory Data

SDG ID: GCT58227
 Phoenix ID: CT58240

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: BM-15

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	45.8	1	1	ppb	15			07/01/25	CPP	E200.5
*** Lead exceeds Action Level of 15 ***										
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director
 July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

12:32
 16:20

Laboratory Data

SDG ID: GCT58227
 Phoenix ID: CT58241

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: BM-16

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			07/01/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

12:34
 16:20

Laboratory Data

SDG ID: GCT58227
 Phoenix ID: CT58242

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: BM-17

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			07/01/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

12:35
 16:20

Laboratory Data

SDG ID: GCT58227
 Phoenix ID: CT58243

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: BM-18

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			07/01/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager

Analysis Report - Summary

July 03, 2025

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

SDG I.D.: GCT58227



Sample	Client Id	Col Date	Parameter	Result	RL	CL	Units	Date Analyzed	Reference
Project: 25-05225 Bayonne Board Of Education									
CT58227	BM-01	06/21/25	Lead	< 1	1		ppb	07/01/25	E200.5
CT58228	BM-02	06/21/25	Lead	< 1	1		ppb	07/01/25	E200.5
CT58229	BM-03	06/21/25	Lead	< 1	1		ppb	07/01/25	E200.5
CT58230	BM-04	06/21/25	Lead	3.6	1		ppb	07/01/25	E200.5
CT58231	BM-05	06/21/25	Lead	5.2	1		ppb	07/01/25	E200.5
CT58232	BM-06	06/21/25	Lead	11.5	1		ppb	07/01/25	E200.5
CT58233	BM-07	06/21/25	Lead	< 1	1		ppb	07/01/25	E200.5
CT58234	BM-08	06/21/25	Lead	< 1	1		ppb	07/01/25	E200.5
CT58235	BM-09	06/21/25	Lead	< 1	1		ppb	07/01/25	E200.5
CT58236	BM-11	06/21/25	Lead	< 1	1		ppb	07/01/25	E200.5
CT58237	BM-12	06/21/25	Lead	< 1	1		ppb	07/01/25	E200.5
CT58238	BM-13	06/21/25	Lead	< 1	1		ppb	07/01/25	E200.5
CT58239	BM-14	06/21/25	Lead	< 1	1		ppb	07/01/25	E200.5
CT58240	BM-15	06/21/25	Lead	45.8	1		ppb	07/01/25	E200.5
CT58241	BM-16	06/21/25	Lead	< 1	1		ppb	07/01/25	E200.5
CT58242	BM-17	06/21/25	Lead	< 1	1		ppb	07/01/25	E200.5
CT58243	BM-18	06/21/25	Lead	< 1	1		ppb	07/01/25	E200.5

Comments:

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

ND=Not detected BDL=Below Detection Level RL=Reporting Level CL=Client Limit

Phyllis Shiller
Laboratory Director
July 03, 2025



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



QA/QC Report

July 03, 2025

QA/QC Data

SDG I.D.: GCT58227

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	--------	---------------	------------	---------	-------	--------	---------	------	-------	--------	--------------	--------------

QA/QC Batch 791298 (mg/L), QC Sample No: CT58224 (CT58227, CT58228, CT58229, CT58230, CT58231, CT58232, CT58233)

ICP Metals - Aqueous

Lead	BRL	0.0010	<0.0010	<0.0010	NC	102			105			85 - 115	20
------	-----	--------	---------	---------	----	-----	--	--	-----	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 791298A (mg/L), QC Sample No: CT58234 (CT58234, CT58235, CT58236, CT58237, CT58238, CT58239, CT58240, CT58241, CT58242, CT58243)

ICP Metals - Aqueous

Lead	BRL	0.0010				102			105			85 - 115	20
------	-----	--------	--	--	--	-----	--	--	-----	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference
- (ISO) - Isotope Dilution


 Phyllis Shiller, Laboratory Director
 July 03, 2025

Thursday, July 03, 2025

Criteria: NJ: DW

State: NJ

Sample Criteria Exceedances Report

GCT58227 - MCCABE-PB

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
CT58240	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	45.8	1	15	1	ppb

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Comments

July 03, 2025

SDG I.D.: GCT58227

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

MCCABE ENVIRONMENTAL SERVICES, L.L.C.
 464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER
 CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education
 SITE ADDRESS: John M. Bailey Community School
 75 W 10th St, Bayonne, NJ 07002

FIELD INSPECTOR'S NAME: Alexandre G. Clark, K. Brossek
 MES PROJECT #: 25-05225
 SAMPLE DATE: 6/2/25
 TURNAROUND TIME REQUESTED: 2-Week

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED	
DW	BM-01	FD - left Bubble, by Room G6	12:06 P.M	LEAD - 200.8	58227
DW	BM-02	30sec. flush - left bubble, by Room G6	12:07 P.M	LEAD - 200.8	58228
DW	BM-03	FD - Right Bubble by Room G6	12:08 P.M	LEAD - 200.8	58229
DW	BM-04	FD - Room G9 faucet	12:09 P.M	LEAD - 200.8	58230
DW	BM-05	FD - Bubble by Room G5 - left.	12:12 P.M	LEAD - 200.8	58231
DW	BM-06	FD - Bubble by Room G5 - Right	12:12 P.M	LEAD - 200.8	58232
DW	BM-07	FD - Bottle filler by Room G4	12:14 P.M	LEAD - 200.8	58233
DW	BM-08	FD - Bottle filler by Room 11	12:17 P.M	LEAD - 200.8	58234
DW	BM-09	FD - Chiller outside Main office	12:17 P.M	LEAD - 200.8	58235
DW	BM-10	FD - Room 1 faucet	12:21 P.M	LEAD - 200.8	58236

Relinquished by (Print) Gary Clare
 Signature: [Signature] Date: 6/2/25 Time: 1015
 Received by: (Print) J.D. Demers
 Signature: [Signature] Date: 6/2/25 Time: 1015

Relinquished by (Print) [Signature]
 Signature: [Signature] Date: 6/2/25 Time: 1020
 Received by: (Print) Abby Lee
 Signature: Abby Lee Date: 6/2/25 Time: 1020

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

2.2°C WCIP

MCCABE ENVIRONMENTAL SERVICES, L.L.C.

464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

**LEAD in DRINKING WATER
CHAIN-OF-CUSTODY FORM**

CLIENT NAME: Bayonne Board of Education

SITE ADDRESS: John M. Bailey Community School
75 W 10th St, Bayonne, NJ 07002

TURNAROUND TIME REQUESTED: 2-Week

FIELD INSPECTOR'S NAME: A. LEGGIMA, G. CLARE, K. BRASSER
MES PROJECT #: 25-05225
SAMPLE DATE: 6/21/15

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED	
DW	BM-12	FD - Bottle filler outside Room 5	12:23 P.M.	LEAD - 200.8	58237
DW	BM-13	FD - Prek Room 5 Bathroom sink	12:24 P.M.	LEAD - 200.8	58238
DW	BM-14	FD - Prek Room 4 Bathroom Sink	12:25 P.M.	LEAD - 200.8	58239
DW	BM-15	FD - Nurse's office faucet.	12:30 P.M.	LEAD - 200.8	58240
DW	BM-16	FD - Bubler by Room 27	12:32 P.M.	LEAD - 200.8	58241
DW	BM-17	FD - Teacher's Room faucet	12:34 P.M.	LEAD - 200.8	58242
DW	BM-18	FD - Bottle filler by Room 20	12:35 P.M.	LEAD - 200.8	58243
DW				LEAD - 200.8	
DW				LEAD - 200.8	
DW				LEAD - 200.8	

Relinquished by (Print) Gary Clare
Signature: [Signature]

Date: 6/23/15 1015
Received by: (Print) J. P. [Signature]
Signature: [Signature]

Date: 8/23 1615
Time: 1615

Relinquished by (Print) [Signature]
Signature: [Signature]

Date: 6/23/15
Received by: (Print) Abby Lee
Signature: Abby Lee

Date: 6/23/15 1620
Time: 1620

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): [Signature] Phoenix Environmental Laboratories

NJ Certified WBE



Wednesday, September 03, 2025

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION
SDG ID: GCU09459
Sample ID#s: CU09459 - CU09460

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller
Laboratory Director

NELAC - #NY11301
CT Lab Registration #PH-0618
MA Lab Registration #M-CT007
ME Lab Registration #CT-007
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003
NY Lab Registration #11301
PA Lab Registration #68-03530
RI Lab Registration #63
VT Lab Registration #VT11301



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Sample Id Cross Reference

September 03, 2025

SDG I.D.: GCU09459

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION

Client Id	Lab Id	Matrix	Col Date
BM-15-A	CU09459	DRINKING WATER	08/23/25 8:26
BM-15-B	CU09460	DRINKING WATER	08/23/25 8:27



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

September 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/25
 08/25/25

Time

8:26
 19:05

Laboratory Data

SDG ID: GCU09459
 Phoenix ID: CU09459

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION
 Client ID: BM-15-A

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.6	0.5	2	ppb	15			09/02/25	CPP	E200.8
Total Metal Digestion	Completed							08/30/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

September 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/25
 08/25/25

Time

8:27
 19:05

Laboratory Data

SDG ID: GCU09459
 Phoenix ID: CU09460

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION
 Client ID: BM-15-B

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			09/02/25	CPP	E200.8
Total Metal Digestion	Completed							08/30/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager

Analysis Report - Summary

September 03, 2025

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

SDG I.D.: GCU09459



Sample	Client Id	Col Date	Parameter	Result	RL	CL	Units	Date Analyzed	Reference
Project: 25-05225-1 Bayonne Board Of Education									
CU09459	BM-15-A	08/23/25	Lead	0.6	0.5		ppb	09/02/25	E200.8
CU09460	BM-15-B	08/23/25	Lead	< 0.5	0.5		ppb	09/02/25	E200.8

Comments:

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
ND=Not detected BDL=Below Detection Level RL=Reporting Level CL=Client Limit


Phyllis Shiller
Laboratory Director
September 03, 2025



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



QA/QC Report

September 03, 2025

QA/QC Data

SDG I.D.: GCU09459

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	-----------	------------------	---------------	------------	----------	-----------	------------	---------	----------	-----------	--------------------	--------------------

QA/QC Batch 800979A (mg/L), QC Sample No: CU09457 (CU09459, CU09460)

ICP MS Metals - Aqueous

Lead	BRL	0.0001				104			103				
------	-----	--------	--	--	--	-----	--	--	-----	--	--	--	--

Comment:

This batch does not include a duplicate.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference
- (ISO) - Isotope Dilution


 Phyllis Shiller, Laboratory Director
 September 03, 2025

Wednesday, September 03, 2025

Criteria: NJ: DW

State: NJ

Sample Criteria Exceedances Report

GCU09459 - MCCABE-PB

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

*** No Data to Display ***

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Comments

September 03, 2025

SDG I.D.: GCU09459

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

MCCABE ENVIRONMENTAL SERVICES, L.L.C.

464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER
CHAIN-OF-CUSTODY FORM

1.1 WCTD

CLIENT NAME: Bayonne Board of Education

SITE ADDRESS: John M. Bailey Community School
75 W 10th St, Bayonne, NJ 07002

FIELD INSPECTOR'S NAME: A. Lezama

TURNAROUND TIME REQUESTED: 2-Week

MES PROJECT #: 25-05 225-1 SAMPLE DATE: 8/23/25

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	09459 BM-15-A	FD - Nurse's office faucet	8:26 AM	LEAD - 200.8
DW	09460 BM-15-B	30 sec - Flush - Nurse's office faucet	8:27 AM	LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8

Relinquished by (Print) <i>A. Lezama</i>	Date: 8/25/25	Received by: (Print) <i>J. Demers</i>	Date: 8/25/25
Signature: <i>A. Lezama</i>	Time:	Signature: <i>J. Demers</i>	Time: 12:45
Relinquished by (Print)	Date:	Received by: (Print)	Date: 8/25/25
Signature: <i>[Signature]</i>	Time:	Signature: <i>[Signature]</i>	Time: 16:00

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories *[Signature]* 8/25/25 19:05

NJ Certified WBE

APPENDIX B

**SCHOOL DISTRICT SAMPLING
ATTACHMENTS**

Attachment A - List of Priority for Sampling

SCHOOL NAME	DATE OF SAMPLING	CERTIFIED LABORATORY	NOTES
John M. Bailey Community School	06/21/2025	Phoenix Environmental Laboratories Inc.	

Attachment A - List of Priority for Sampling

SCHOOL NAME	DATE OF SAMPLING	CERTIFIED LABORATORY	NOTES
John M. Bailey Community School	08/23/2025	Phoenix Environmental Laboratories Inc.	

Attachment B – Plumbing Profile

Note: Complete for each school. For additional information see the USEPA publication, "The 3Ts for Reducing Lead in Drinking Water in Schools"

Name of School: John M. Bailey Community School Grade Levels: K-8

Address: 75 West 10th St., Bayonne, NJ 07002

Individual school project officer Signature: *Scott Nelson* Date: 8/5/2025

Questions	Answers	
Background Information		
1. What year was the original building constructed? Were any buildings or additions added to the original facility?	K-8 Grade School Built in 1911 K-8 Grade School Addition in 2000	
2. If the building was constructed or repaired after 1986, was lead-free plumbing and solder utilized? What type of solder was used? Document all locations where lead solder was used.	Any repairs made after 1986 were done using lead free solder	
3. Where are the most recent plumbing repairs and replacements?	Location: Hallway fountains Basement sink	Description: Replacement fountains Replace P trap leaking
4. With what materials is the service connection (the pipe that carries water to the school from the public water system's main in the street) made? Where is the Service Line located? (This is the POE location.)	Material: Main Building - Duct Iron Location: the water main (11th St) enters the ground in the boys bathroom flows through building to the boiler room where the water meter is located and continues to the remainder of the building	
5. Is there point of entry (POE) or point of use (POU) treatment in use?	Y / N No treatment of water Type: at POE City water comes treated	Main building 1911 Location:

Questions	Answers
6. Are there tanks in your plumbing system (pressure tanks, gravity storage tanks)?	Y / N Yes the building has a 75 gallon hot water storage tank located in the old boiler room The building has a 40 gallon hot water heater located in the new wing cafe storage closet
7. Does the school have a filter maintenance and operation program? If so, who is responsible for this program? What is the process for adding filters?	Yes, Scott Nolan, Andy McCabe, Vinny Caiola, change filters on an as needed basis assign plumbers
8. Have accessible screens or aerators on outlets that provide drinking water been cleaned? Does the school have a screen or aerator maintenance program?	Y / N Yes The district has set-up a routine maintenance program to clean screens
9. Have there been any complaints about bad (metallic) taste? Note location(s).	Y / N NO Location:
10. Review records and consult with the public water supplier to determine whether any water samples have been taken in the building for any contaminants. If so, identify: <ul style="list-style-type: none"> • Name of contaminant(s) • Concentrations found • pH level Is testing done regularly at the building?	No indoor testing by public water supplier
11. Other plumbing background questions include: <ul style="list-style-type: none"> • Are blueprints of the building available? • Are there known plumbing “dead-ends”, low use areas, existing leaks or other “problem areas”? Are renovations planned for any of the plumbing system?	Not all prints are available No dead-end low use areas All leaks were identified during walk through and have been repaired No plumbing system renovations planned

Questions	Answers	
Walk-Through <i>These questions should be addressed during the walk-through of the facility, while Attachment C- Drinking Water Outlet Inventory is being completed.</i>		
1. Confirm the material of Service Line visually.	Duct iron	
2. Confirm the presence of POE or POU treatment.		
3. What are the potable water pipes made of in your facility? <ul style="list-style-type: none"> • Lead • Plastic • Galvanized Metal • Cast Iron • Copper • Other Note the water flow through the building and the areas that receive water first, and which areas receive water last.	Cooper Galvanized Metal Brass Water flow through the building shown on the prints	
4. Are electrical wires grounded to Water Pipes? Note location(s).	Y / N Location:	No No electrical wires grounded to water pipes
5. Are brass fittings, faucets, or valves used in your drinking water system? Note that most faucets are brass on the inside. Document the locations of any brass water outlet to be sampled.	Complete in "Brass" Column in Attachment C- Water Outlet Inventory. Yes Completed in Attachment C - Water Outlet Inventory	
6. Locate all drinking water outlets (i.e. water coolers, bubblers, ice machines, kitchen/ food prep sinks, etc.) in the facility.	Complete in Attachment C-Water Outlet Inventory.	

Questions	Answers	
<p>7. Have the brands and models of the water coolers in the school been compared to the list of recalled water coolers in the Toolkit?</p> <p>Recalled Drinking Water Fountains</p> <p>Make and Model</p>	<p>Y / N Yes all water coolers have been checked and compared to the list of recalled water coolers</p> <p>Type None on the list of recalled water coolers</p>	
<p>8. Have signs of corrosion, such as frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry been detected?</p> <p>Note the locations of water outlets.</p>	<p>Complete in "Signs of Corrosion" column in Attachment C- Drinking Water Outlet Inventory.</p>	
<p>9. Are there any outlets that are not operational and therefore out of service? Permanently? Temporarily?</p> <p style="text-align: right;">Permanently</p> <p style="text-align: right;">Temporarily</p>	<p>Y / N</p> <p>Complete "Operational Column" in Attachment C- Drinking Water Outlet Inventory.</p> <p>Type/ Location</p>	<p>Description</p>

Attachment C – Drinking Water Outlet Inventory

Name of School: John M. Bailey Community School

Address: 75 W 10th Street, Bayonne, New Jersey 07002

Grade Levels: Elementary School Year School Constructed: Unknown Renovated/Additions: NA

Individual School Project Officer: Scott Nolan

Date Completed: 09/05/2025

#1	Type	Location	Code	Operational ² (Y/N)	Signs of Corrosion ³ (Y/N)	Filter ⁴ (Y/N)	Brass Fittings, Faucets or valves? (Y/N)	Aerator/ Screen (Y/N)	Motion Activated (Y/N)	Chiller (Y/N)	Water Cooler		Comments
											Make	Model	
01	Water Fountain	Left Bubblers by Room G6	BM-01	Y	N	N	N	Y	N	N	NA	NA	
02	Water Fountain	Left Bubblers by Room G6	BM-02	Y	N	N	N	N	N	N	NA	NA	Flush
03	Water Fountain	Right Bubblers by Room G6	BM-03	Y	N	N	N	N	N	N	NA	NA	
04	Sink	Room G9	BM-04	Y	N	N	N	N	N	N	NA	NA	
05	Water Fountain	Left Bubblers by Room G5	BM-05	Y	N	N	N	N	N	N	NA	NA	
06	Water Fountain	Right Bubblers by Room G5	BM-06	Y	N	N	N	N	N	N	NA	NA	
07	Chiller	Chiller by Room G4	BM-07	Y	N	Y	N	N	N	Y	NA	NA	

¹ Number outlets starting at the closest outlet to the Point of Entry (POE).

² Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

³ Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

⁴ Document on Attachment D- Filter Inventory.

08	Water Fountain	Bubbler by Room 11	BM-08	Y	N	N	Y	N	N	N	NA	NA	
09	Chiller	Chiller Outside Main Office	BM-09	Y	N	Y	N	N	N	Y	NA	NA	
10	Water Fountain	Bubbler by Room 2	BM-10	N	NA	NA	PERMANENTLY REMOVED						
11	Sink	Room 1	BM-11	Y	N	Y	N	Y	N	N	NA	NA	
12	Chiller	Chiller Outside Room 5	BM-12	Y	N	Y	N	N	N	Y	NA	NA	
13	Sink	Pre-K Room 5 Bathroom	BM-13	Y	N	N	N	N	N	N	NA	NA	
14	Sink	Pre-K Room 4 Bathroom	BM-14	Y	N	N	N	N	N	N	NA	NA	
15	Sink	Nurse's Office Faucet	BM-15	Y	N	N	N	N	N	N	NA	NA	
16	Water Fountain	Bubbler by Room 27	BM-16	Y	N	N	N	N	N	N	NA	NA	
17	Sink	Teacher's Room	BM-17	N	N	Y	N	N	N	N	NA	NA	
18	Chiller	Chiller by Room 20	BM-18	N	N	Y	N	N	N	Y	NA	NA	

¹ Number outlets starting at the closest outlet to the Point of Entry (POE).

¹ Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

¹ Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

¹ Document on Attachment D- Filter Inventory.

Attachment D - Filter Inventory

Name of School: John M. Bailey Community School Grade Levels: Elementary School

Address: 75 W 10th Street, Bayonne, New Jersey 07002

Individual School Project Officer: Scott Nolan

Date: 09/05/2025

Sample Location / Code	Brand	Type (Make & Model)	Date Installed or Replaced	Replacement Frequency	NSF Certified for Lead Reduction Y/N
BM-01	Aqua Pure	AP 200	N/A	N/A	N/A
BM-02	Aqua Pure	AP 200	N/A	N/A	N/A
BM-03	Aqua Pure	AP 200	N/A	N/A	N/A
BM-04	N/A	N/A	N/A	N/A	N/A
BM-05	N/A	N/A	N/A	N/A	N/A
BM-06	N/A	N/A	N/A	N/A	N/A
BM-07	Elkay	E2FS8_1F	N/A	N/A	N/A
BM-08	Elkay	LZWSR_1D	N/A	N/A	N/A
BM-09	Elkay	EFA8_1L	N/A	N/A	N/A
BM-10	PERMANENTLY REMOVED				
BM-11	3M Delta Metered	N/A	N/A	N/A	N/A
BM-12	Elkay	LZWSR_1D	N/A	N/A	N/A
BM-13	N/A	N/A	N/A	N/A	N/A
BM-14	N/A	N/A	N/A	N/A	N/A
BM-15	3M Aqua Pure	AP 200	08/08/2025	N/A	N/A
BM-16	Aqua Pure	AP 200	N/A	N/A	N/A
BM-17	N/A	N/A	N/A	N/A	N/A
BM-18	Elkay	EBFSAB	N/A	N/A	N/A

Attachment E – Flushing Log

Name of School: John M. Bailey Community School

Address: 75 W 10th Street, Bayonne, New Jersey 07002

Grade Levels: Elementary School

Individual School Project Officer: Scott Nolan

Date: 09/05/2025

Sample Location Description	Sample Location Code	Date	Time	Duration of Flushing	Reason for Flushing
Left Bubbler by Room G6	BM-01	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Left Bubbler by Room G6	BM-02	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Right Bubbler by Room G6	BM-03	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room G9	BM-04	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Left Bubbler by Room G5	BM-05	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Right Bubbler by Room G5	BM-06	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Chiller by Room G4	BM-07	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Room 11	BM-08	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Chiller Outside Main Office	BM-09	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Room 2	BM-10	PERMANENTLY REMOVED			
Room 1	BM-11	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 1	BM-12	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Chiller Outside Room 5	BM-13	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Pre-K Room 5 Bathroom	BM-14	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Pre-K Room 4 Bathroom	BM-15	August 22, 2025	5:30 pm	2-3 Minutes	Water Sampling
Nurse's Office Faucet	BM-16	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Room 27	BM-17	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Teacher's Room	BM-18	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Chiller by Room 20	BM-19	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling

Attachment F - Pre - Sampling Water Use Certification

TO BE COMPLETED BY THE BAYONNE BOE DISTRICT REPRESENTATIVE:		
School Name:	<u>John M. Bailey Community School</u>	
Sample collection address:	<u>75 W 10th Street, Bayonne, New Jersey 07002</u>	
Water was last used:	<u>Time: 5:30 pm</u>	<u>Date: June 20, 2025</u>
Sample commencement:	<u>Time: 12:06 PM</u>	<u>Date: June 21, 2025</u>
I have read the Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.		
Scott Nolan	<u>07/18/2025</u>	
Signature	Date	

Attachment F - Pre - Sampling Water Use Certification

TO BE COMPLETED BY THE BAYONNE BOE DISTRICT REPRESENTATIVE:		
School Name:	<u>John M. Bailey Community School</u>	
Sample collection address:	<u>75 W 10th Street, Bayonne, New Jersey 07002</u>	
Water was last used:	<u>Time: 5:30 pm</u>	<u>Date: August 22, 2025</u>
Sample commencement:	<u>Time: 8:26 AM</u>	<u>Date: August 23, 2025</u>
I have read the Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.		
Scott Nolan	<u>9/5/2025</u>	
Signature	Date	