



464 Valley Brook Avenue, Lyndhurst NJ 07071  
129 Sea Girt Avenue, Manasquan NJ 08736  
Phone: (800) 423-0766 • Fax: (201) 438-1798  
www.mccabeenv.com

---

## LEAD IN DRINKING WATER TESTING REPORT

*Conducted for:*

Bayonne Board of Education  
669 Avenue A  
Bayonne, New Jersey 07002

*Conducted at:*

Philip G. Vroom Community School  
18 West 26<sup>th</sup> Street  
Bayonne, New Jersey 07002

*Submitted by:*

McCabe Environmental Services, L.L.C.  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071

**REPORT DATE:** September 8, 2025

**MES PROJECT NO.:** 25-05225

*Prepared by:*

A handwritten signature in blue ink, appearing to read 'Arllitzy Lezama'.

**Arllitzy Lezama**  
**Environmental Scientist**

*Signed for the Company by:*

A handwritten signature in blue ink, appearing to read 'John H. Chiaviello'.

**John H. Chiaviello**  
**Vice President**

## **TABLE OF CONTENTS**

	<b>Page</b>
1.0 INTRODUCTION .....	1
2.0 SCOPE OF WORK.....	1
3.0 PROCEDURES.....	1
4.0 TABLE OF SAMPLE RESULTS .....	2
5.0 DISCUSSION AND CONCLUSION .....	3

### **APPENDIX A**

Laboratory Certificates of Analysis  
&  
Sample Chain of Custody Forms

### **APPENDIX B**

School District Sampling Attachments

**1.0 INTRODUCTION**

McCabe Environmental Services, L.L.C. (McCabe) was retained by Bayonne Board of Education (Client) to conduct lead in drinking water testing at Philip G. Vroom Community School located at 18 West 26<sup>th</sup> Street, Bayonne, New Jersey 07002.

The project information is as follows:

Client Name: Bayonne Board of Education  
Contact Person: Mr. Daniel Castles

Project Name: Philip G. Vroom Community School – Lead in Drinking Water  
Project Location: 18 West 26<sup>th</sup> Street  
Bayonne, New Jersey 07002

Date(s) of Service: June 20, 2025 and August 23, 2025

McCabe Personnel: Gary Clare & Arlitzzy Lezama

**2.0 SCOPE OF WORK**

Drinking water testing was performed at Philip G. Vroom Community School located at 18 West 26<sup>th</sup> Street, Bayonne, New Jersey 07002 on June 20, 2025. The purpose of the testing was to determine if the building’s plumbing was having an adverse impact on water quality, specifically with regard to lead concentrations. Samples were collected from various potential drinking water outlets located throughout the building. Follow-up drinking water testing was then performed at the failed locations throughout Philip G. Vroom Community School on August 23, 2025. The failed locations were re-sampled with a first draw sample and immediately followed up with a thirty (30) second flush sample. Testing was followed as per past reports provided by Bayonne Board of Education.

**3.0 PROCEDURES**

After determining which outlets would be sampled, McCabe personnel collected a "first draw" sample at each location. A "first draw" is the initial water that is first to come out of the tap after a period of inactivity. Following the “first draw”, a "30 second flush" sample was also collected closest to where the main service line comes into the building. All samples were collected into 250 mL sterile bottles, labeled with a sample identification, and analyzed in accordance with EPA approved methods to determine the level of lead in drinking water. Samples were analyzed by an accredited laboratory.

The U.S. Environmental Protection Agency (EPA) has established National Primary Drinking Water Regulations (NPDWR) that set mandatory water quality standards for drinking water contaminants. These are enforceable standards called "maximum contaminant levels" or "MCL", which are established to protect the public against consumption of drinking water contaminants that present a risk to human health. An MCL is the maximum allowable amount of a contaminant in drinking water which is delivered to the consumer.

The EPA has established the Lead and Copper Rule that sets standards for state and public water systems. This rule has set an MCL for lead at 15 parts per billion (ppb) for a one liter sample. However, the EPA also established the Lead in Drinking Water at Schools and Child Care Facilities in which the EPA recommends an MCL of 20 ppb for a 250 milliliter first draw sample. In order to be more stringent, for our report purposes we have compared all results to both the 15 ppb and the 20 ppb standards.

**4.0 TABLE OF SAMPLE RESULTS**

The following table presents all sample results in order of sample identification conducted on June 20, 2025:

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
PG- 01	First Draw – Bottle Filler Across from Computer Lab	< 0.5	Pass	Pass
PG - 02	30 Second Flush – Bottle Filler Across from Computer Lab	< 0.5	Pass	Pass
<b>PG - 03</b>	<b>First Draw – Food Service Room Faucet</b>	<b>16</b>	<b>Fail</b>	<b>Pass</b>
PG - 04	First Draw – Music Room Faucet	9	Pass	Pass
PG - 05	First Draw – Bubble Across Music Room	2	Pass	Pass
PG - 06	First Draw – Art Room Faucet – Right	4.3	Pass	Pass
PG - 07	First Draw – Room 111 Teachers Room Faucet	2.2	Pass	Pass
PG - 08	First Draw – Bubblers Across from Room 107	2.4	Pass	Pass
PG - 09	First Draw – Room 108 Faucet	< 0.5	Pass	Pass
PG - 10	First Draw – Bottle Filling Station Across from Room 104	< 0.5	Pass	Pass
PG - 11	First Draw – Room 104 Faucet	3.6	Pass	Pass
PG - 12	First Draw – Room 103 Faucet	5.7	Pass	Pass
PG - 13	First Draw – Room 102 Faucet	5.8	Pass	Pass
PG - 14	First Draw – Room 101 Faucet	3.9	Pass	Pass
PG - 15	First Draw – Nurses Office Faucet	7.3	Pass	Pass
PG - 16	First Draw – Bottle Filler Across from Room 207	< 0.5	Pass	Pass
PG - 17	First Draw – Room 203 Faucet	1.1	Pass	Pass
PG - 18	First Draw – Room 202 Faucet	3.9	Pass	Pass

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
PG - 19	First Draw – Room 201 Faucet	0.8	Pass	Pass
PG - 20	First Draw – Bottle Filler Across from Room 304	< 0.5	Pass	Pass

The following table presents all sample results in order of sample identification from the follow-up lead in drinking water testing conducted on August 23, 2025:

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
PG- 03-A	First Draw – Food Service Room Faucet	12.9	Pass	Pass
PG-03-B	30 Second Flush – Food Service Room Faucet	< 0.5	Pass	Pass

**5.0 DISCUSSION AND CONCLUSION**

A total of twenty (20) samples were collected from Philip G. Vroom Community School. One (1) sample was found to be greater than the EPA Lead and Copper Rule standard of 15 ppb. All other samples were found to be less than the EPA standards of 20 ppb and 15 ppb.

As a follow-up to drinking water testing conducted on June 21, 2025, McCabe conducted a follow-up testing August 23, 2025. A total of two (2) samples were collected from Philip G. Vroom Community School located at 18 West 26<sup>th</sup> Street, Bayonne, New Jersey 07002. All samples taken during the follow-up inspection were below the regulatory standard.

In addition, McCabe Environmental recommends annual drinking water sampling to ensure that the building’s plumbing is not having an adverse impact on water quality.

**APPENDIX A**

**LABORATORY CERTIFICATES OF ANALYSIS  
&  
SAMPLE CHAIN OF CUSTODY FORMS**



Thursday, July 03, 2025

Attn: Jarred Panecki  
McCabe Environmental Services, LLC  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
SDG ID: GCT58020  
Sample ID#s: CT58020 - CT58039

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Phyllis Shiller".

Phyllis Shiller  
Laboratory Director

NELAC - #NY11301  
CT Lab Registration #PH-0618  
MA Lab Registration #M-CT007  
ME Lab Registration #CT-007  
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003  
NY Lab Registration #11301  
PA Lab Registration #68-03530  
RI Lab Registration #63  
VT Lab Registration #VT11301



Environmental Laboratories, Inc.  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



## Sample Id Cross Reference

July 03, 2025

SDG I.D.: GCT58020

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION

---

Client Id	Lab Id	Matrix	Col Date
PG-01	CT58020	DRINKING WATER	06/20/25 13:13
PG-02	CT58021	DRINKING WATER	06/20/25 13:14
PG-03	CT58022	DRINKING WATER	06/20/25 13:16
PG-04	CT58023	DRINKING WATER	06/20/25 13:16
PG-05	CT58024	DRINKING WATER	06/20/25 13:18
PG-06	CT58025	DRINKING WATER	06/20/25 13:19
PG-07	CT58026	DRINKING WATER	06/20/25 13:23
PG-08	CT58027	DRINKING WATER	06/20/25 13:25
PG-09	CT58028	DRINKING WATER	06/20/25 13:27
PG-10	CT58029	DRINKING WATER	06/20/25 13:30
PG-11	CT58030	DRINKING WATER	06/20/25 13:32
PG-12	CT58031	DRINKING WATER	06/20/25 13:34
PG-13	CT58032	DRINKING WATER	06/20/25 13:35
PG-14	CT58033	DRINKING WATER	06/20/25 13:36
PG-15	CT58034	DRINKING WATER	06/20/25 13:38
PG-16	CT58035	DRINKING WATER	06/20/25 13:40
PG-17	CT58036	DRINKING WATER	06/20/25 13:42
PG-18	CT58037	DRINKING WATER	06/20/25 13:43
PG-19	CT58038	DRINKING WATER	06/20/25 13:44
PG-20	CT58039	DRINKING WATER	06/20/25 13:46



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

13:13  
 16:20

## Laboratory Data

SDG ID: GCT58020  
 Phoenix ID: CT58020

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: PG-01

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

13:14  
 16:20

## Laboratory Data

SDG ID: GCT58020  
 Phoenix ID: CT58021

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: PG-02

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 03, 2025**

**Reviewed and Released by: Rashmi Makol, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

13:16  
 16:20

## Laboratory Data

SDG ID: GCT58020  
 Phoenix ID: CT58022

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: PG-03

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	16	0.5	2	ppb	15			06/30/25	CPP	E200.8
*** Lead exceeds Action Level of 15 ***										
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director  
 July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

13:16  
 16:20

## Laboratory Data

SDG ID: GCT58020  
 Phoenix ID: CT58023

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: PG-04

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	9	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

13:18  
 16:20

## Laboratory Data

SDG ID: GCT58020  
 Phoenix ID: CT58024

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: PG-05

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

13:19  
 16:20

## Laboratory Data

SDG ID: GCT58020  
 Phoenix ID: CT58025

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: PG-06

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	4.3	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

13:23  
 16:20

## Laboratory Data

SDG ID: GCT58020  
 Phoenix ID: CT58026

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: PG-07

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2.2	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 03, 2025**

**Reviewed and Released by: Rashmi Makol, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

13:25  
 16:20

## Laboratory Data

SDG ID: GCT58020  
 Phoenix ID: CT58027

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: PG-08

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2.4	0.5	2	ppb	15			06/30/25	CPP	E200.8
Total Metal Digestion	Completed							06/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

13:27  
 16:20

## Laboratory Data

SDG ID: GCT58020  
 Phoenix ID: CT58028

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: PG-09

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	MGH	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 03, 2025**

**Reviewed and Released by: Rashmi Makol, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

13:30  
 16:20

## Laboratory Data

SDG ID: GCT58020  
 Phoenix ID: CT58029

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: PG-10

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 03, 2025**

**Reviewed and Released by: Rashmi Makol, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

13:32  
 16:20

## Laboratory Data

SDG ID: GCT58020  
 Phoenix ID: CT58030

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: PG-11

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	3.6	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

13:34  
 16:20

## Laboratory Data

SDG ID: GCT58020  
 Phoenix ID: CT58031

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: PG-12

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	5.7	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

13:35  
 16:20

## Laboratory Data

SDG ID: GCT58020  
 Phoenix ID: CT58032

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: PG-13

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	5.8	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

13:36  
 16:20

## Laboratory Data

SDG ID: GCT58020  
 Phoenix ID: CT58033

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: PG-14

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	3.9	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

13:38  
 16:20

## Laboratory Data

SDG ID: GCT58020  
 Phoenix ID: CT58034

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: PG-15

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	7.3	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

13:40  
 16:20

## Laboratory Data

SDG ID: GCT58020  
 Phoenix ID: CT58035

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: PG-16

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 03, 2025**

**Reviewed and Released by: Rashmi Makol, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

13:42  
 16:20

## Laboratory Data

SDG ID: GCT58020  
 Phoenix ID: CT58036

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: PG-17

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.1	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 03, 2025**

**Reviewed and Released by: Rashmi Makol, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

13:43  
 16:20

## Laboratory Data

SDG ID: GCT58020  
 Phoenix ID: CT58037

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: PG-18

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	3.9	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

13:44  
 16:20

## Laboratory Data

SDG ID: GCT58020  
 Phoenix ID: CT58038

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: PG-19

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.8	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 03, 2025**

**Reviewed and Released by: Rashmi Makol, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/20/25  
 06/23/25

Time

13:46  
 16:20

## Laboratory Data

SDG ID: GCT58020  
 Phoenix ID: CT58039

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: PG-20

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			07/01/25	JM	E200.8
Total Metal Digestion	Completed							06/27/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager

# Analysis Report - Summary

July 03, 2025

Attn: Jarred Panecki  
McCabe Environmental Services, LLC  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071



Environmental Laboratories, Inc.  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823

SDG I.D.: GCT58020



Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
Project: 25-05225 Bayonne Board Of Education								
CT58020	PG-01	06/20/25	Lead	< 0.5	0.5	ppb	06/30/25	E200.8
CT58021	PG-02	06/20/25	Lead	< 0.5	0.5	ppb	06/30/25	E200.8
CT58022	PG-03	06/20/25	Lead	16	0.5	ppb	06/30/25	E200.8
CT58023	PG-04	06/20/25	Lead	9	0.5	ppb	06/30/25	E200.8
CT58024	PG-05	06/20/25	Lead	2	0.5	ppb	06/30/25	E200.8
CT58025	PG-06	06/20/25	Lead	4.3	0.5	ppb	06/30/25	E200.8
CT58026	PG-07	06/20/25	Lead	2.2	0.5	ppb	06/30/25	E200.8
CT58027	PG-08	06/20/25	Lead	2.4	0.5	ppb	06/30/25	E200.8
CT58028	PG-09	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58029	PG-10	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58030	PG-11	06/20/25	Lead	3.6	0.5	ppb	07/01/25	E200.8
CT58031	PG-12	06/20/25	Lead	5.7	0.5	ppb	07/01/25	E200.8
CT58032	PG-13	06/20/25	Lead	5.8	0.5	ppb	07/01/25	E200.8
CT58033	PG-14	06/20/25	Lead	3.9	0.5	ppb	07/01/25	E200.8
CT58034	PG-15	06/20/25	Lead	7.3	0.5	ppb	07/01/25	E200.8
CT58035	PG-16	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8
CT58036	PG-17	06/20/25	Lead	1.1	0.5	ppb	07/01/25	E200.8
CT58037	PG-18	06/20/25	Lead	3.9	0.5	ppb	07/01/25	E200.8
CT58038	PG-19	06/20/25	Lead	0.8	0.5	ppb	07/01/25	E200.8
CT58039	PG-20	06/20/25	Lead	< 0.5	0.5	ppb	07/01/25	E200.8

Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
--------	-----------	-------------	-----------	--------	----	-------	------------------	-----------

Comments:

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

ND=Not detected BDL=Below Detection Level RL=Reporting Level CL=Client Limit



Phyllis Shiller  
Laboratory Director

July 03, 2025



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# QA/QC Report

July 03, 2025

## QA/QC Data

SDG I.D.: GCT58020

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	--------	---------------	------------	---------	-------	--------	---------	------	-------	--------	--------------	--------------

QA/QC Batch 790955A (mg/L), QC Sample No: CT58018 (CT58020, CT58021, CT58022, CT58023, CT58024, CT58025, CT58026, CT58027)

### ICP MS Metals - Aqueous

Lead BRL 0.0001 92.8 88.6

Comment:

This batch does not include a duplicate.

QA/QC Batch 791169 (mg/L), QC Sample No: CT58028 (CT58028, CT58029, CT58030, CT58031, CT58032, CT58033, CT58034, CT58035, CT58036, CT58037)

### ICP MS Metals - Aqueous

Lead BRL 0.0001 <0.0005 0.0002 NC 100 93.8

QA/QC Batch 791169A (mg/L), QC Sample No: CT58038 (CT58038, CT58039)

### ICP MS Metals - Aqueous

Lead BRL 0.0001 100 89.8

Comment:

This batch does not include a duplicate.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Inf - Interference
- (ISO) - Isotope Dilution

  
 Phyllis Shiller, Laboratory Director  
 July 03, 2025

Thursday, July 03, 2025

Criteria: NJ: DW

State: NJ

## Sample Criteria Exceedances Report

GCT58020 - MCCABE-PB

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
CT58022	PB-DW-MS	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	16	0.5	15	1	ppb

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



**Environmental Laboratories, Inc.**  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



## Analysis Comments

July 03, 2025

SDG I.D.: GCT58020

---

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

**MCCABE ENVIRONMENTAL SERVICES, L.L.C.**

464 VALLEY BROOK AVENUE LYNDDHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

**LEAD in DRINKING WATER  
CHAIN-OF-CUSTODY FORM**

<b>CLIENT NAME:</b> Bayonne Board of Education		<b>SITE ADDRESS:</b> Philip G. Vroom Community School 18 West 26th Street, Bayonne, New Jersey 07002		
<b>FIELD INSPECTOR'S NAME:</b> A. Lozama & G. CLAYE		<b>TURNAROUND TIME REQUESTED:</b> 2-Week		
<b>MES PROJECT #:</b> 25-05225		<b>SAMPLE DATE:</b> 6/26/25		
Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	PG-01	Bottle filler FD - <del>Bottle</del> across from Computer lab	1:13 PM	LEAD - 200.8
DW	PG-02	30 Sec. Flush - Bottle filler across from Comp. Lab	1:14 PM	LEAD - 200.8
DW	PG-03	FD - Food service faucet RM	1:16 PM	LEAD - 200.8
DW	PG-04	FD - Music Room faucet	1:16 PM	LEAD - 200.8
DW	PG-05	FD - Bubbler across music Room	1:18 PM	LEAD - 200.8
DW	PG-06	FD - ART Room faucet - Right	1:19 PM	LEAD - 200.8
DW	PG-07	FD - Room 111 Teachers Room faucet	1:23 PM	LEAD - 200.8
DW	PG-08	FD - Bubble Across from Room 107	1:25 PM	LEAD - 200.8
DW	PG-09	FD - Room 108 faucet	1:27 PM	LEAD - 200.8
DW	PG-10	FD - Bottle filling station across from Rm 104	1:30 PM	LEAD - 200.8
<b>Relinquished by (Print)</b> Gary Clare		<b>Date:</b> 6/25/25	<b>Time:</b> 10:15	<b>Date:</b> 8/23/25
<b>Signature:</b> <i>AKC</i>		<b>Received by: (Print)</b> J. Demers	<b>Signature:</b> <i>JD</i>	<b>Time:</b> 10:15
<b>Relinquished by (Print)</b>		<b>Date:</b>	<b>Time:</b>	<b>Date:</b> 6/23/25
<b>Signature:</b> <i>CA</i>		<b>Received by: (Print)</b> Abby Lee	<b>Signature:</b> <i>Abby Lee</i>	<b>Time:</b> 16:20
<b>Laboratory Analysis Performed by (Analyst Signature, Laboratory Name &amp; Location):</b> Phoenix Environmental Laboratories				

58020  
58021  
58022  
58023  
58024  
58025  
58026  
58027  
58028  
58029

2.2<sup>nd</sup> WCIP

MCCABE ENVIRONMENTAL SERVICES, L.L.C.  
 464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER  
 CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education  
 SITE ADDRESS: Philip G. Vroom Community School  
 18 West 26th Street, Bayonne, New Jersey 07002

FIELD INSPECTOR'S NAME: A. Velazquez & G. Clark  
 TURNAROUND TIME REQUESTED: 2-Week

MES PROJECT #: 25-05225  
 SAMPLE DATE: 6/20/25

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED	
DW	PG-11	FD - Room 104 faucet	1:32 PM	LEAD - 200.8	58030
DW	PG-12	FD - Room 103 faucet	1:34 PM	LEAD - 200.8	58031
DW	PG-13	FD - Room 102 faucet	1:35 PM	LEAD - 200.8	58032
DW	PG-14	FD - Room 101 faucet	1:36 PM	LEAD - 200.8	58033
DW	PG-15	FD - Nurse's Office faucet	1:38 PM	LEAD - 200.8	58034
DW	PG-16	FD - <del>104</del> Bottle filler across from Room 207	1:40 PM	LEAD - 200.8	58035
DW	PG-17	FD - Room 203 faucet	1:42 PM	LEAD - 200.8	58036
DW	PG-18	FD - Room 202 faucet	1:43 PM	LEAD - 200.8	58037
DW	PG-19	FD - Room 201 faucet	1:44 PM	LEAD - 200.8	58038
DW	PG-20	FD - Bottle filler across from Rm 304	1:46 PM	LEAD - 200.8	58039

Relinquished by (Print) G. Clark  
 Date: 6/24/25 Time: 10:15  
 Signature: [Signature]  
 Received by: (Print) J. Demers  
 Date: 8-23 Time: 1615  
 Signature: [Signature]

Relinquished by (Print)  
 Date: Time:  
 Signature: [Signature]

Relinquished by (Print) Abby Lee  
 Date: 6/23/25 Time: 1620  
 Signature: [Signature]

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

NJ Certified WBE



Wednesday, September 03, 2025

Attn: Jarred Panecki  
McCabe Environmental Services, LLC  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION  
SDG ID: GCU09457  
Sample ID#s: CU09457 - CU09458

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller  
Laboratory Director

NELAC - #NY11301  
CT Lab Registration #PH-0618  
MA Lab Registration #M-CT007  
ME Lab Registration #CT-007  
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003  
NY Lab Registration #11301  
PA Lab Registration #68-03530  
RI Lab Registration #63  
VT Lab Registration #VT11301



Environmental Laboratories, Inc.  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



## Sample Id Cross Reference

September 03, 2025

SDG I.D.: GCU09457

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION

---

Client Id	Lab Id	Matrix	Col Date
PG-03-A	CU09457	DRINKING WATER	08/23/25 7:59
PG-03-B	CU09458	DRINKING WATER	08/23/25 8:00



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

September 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

08/23/25  
 08/25/25

Time

7:59  
 19:05

## Laboratory Data

SDG ID: GCU09457  
 Phoenix ID: CU09457

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION  
 Client ID: PG-03-A

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	12.9	0.5	2	ppb	15			09/02/25	CPP	E200.8
Total Metal Digestion	Completed							08/30/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**September 03, 2025**

**Reviewed and Released by: Rashmi Makol, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

September 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

08/23/25  
 08/25/25

Time

8:00  
 19:05

## Laboratory Data

SDG ID: GCU09457  
 Phoenix ID: CU09458

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION  
 Client ID: PG-03-B

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			09/02/25	CPP	E200.8
Total Metal Digestion	Completed							08/30/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**September 03, 2025**

**Reviewed and Released by: Rashmi Makol, Project Manager**

# Analysis Report - Summary

September 03, 2025

Attn: Jarred Panecki  
McCabe Environmental Services, LLC  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071



Environmental Laboratories, Inc.  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823

SDG I.D.: GCU09457



Sample	Client Id	Col Date	Parameter	Result	RL	CL	Units	Date Analyzed	Reference
Project: 25-05225-1 Bayonne Board Of Education									
CU09457	PG-03-A	08/23/25	Lead	12.9	0.5		ppb	09/02/25	E200.8
CU09458	PG-03-B	08/23/25	Lead	< 0.5	0.5		ppb	09/02/25	E200.8

## Comments:

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
ND=Not detected BDL=Below Detection Level RL=Reporting Level CL=Client Limit

  
Phyllis Shiller  
Laboratory Director  
September 03, 2025



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# QA/QC Report

September 03, 2025

## QA/QC Data

SDG I.D.: GCU09457

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	--------	---------------	------------	---------	-------	--------	---------	------	-------	--------	--------------	--------------

QA/QC Batch 800979A (mg/L), QC Sample No: CU09457 (CU09457, CU09458)

### ICP MS Metals - Aqueous

Lead	BRL	0.0001				104			103				
------	-----	--------	--	--	--	-----	--	--	-----	--	--	--	--

Comment:

This batch does not include a duplicate.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference
- (ISO) - Isotope Dilution

Phyllis Shiller, Laboratory Director  
 September 03, 2025

Wednesday, September 03, 2025

Criteria: NJ: DW

State: NJ

## Sample Criteria Exceedances Report

GCU09457 - MCCABE-PB

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

\*\*\* No Data to Display \*\*\*

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



**Environmental Laboratories, Inc.**  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



## Analysis Comments

September 03, 2025

SDG I.D.: GCU09457

---

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

MCCABE ENVIRONMENTAL SERVICES, L.L.C.

464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER  
CHAIN-OF-CUSTODY FORM

1-1 WUP

CLIENT NAME: Bayonne Board of Education

SITE ADDRESS: Philip G. Vroom Community School  
18 West 26th Street, Bayonne, New Jersey 07002

FIELD INSPECTOR'S NAME: A. Lezama

TURNAROUND TIME REQUESTED: 2-Week

MES PROJECT #: 2505225-1

SAMPLE DATE: 8/23/25

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	PG-03-A	FD- Food service Room - faucet	7:59 AM	LEAD - 200.8
DW	PG-03-B	30 sec. Flush - Food service Room faucet	8:00 AM	LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8

Relinquished by (Print) <i>Anilitz Lezama</i>	Date: <i>8/25/25</i>	Time:	Received by: (Print) <i>J. Dames</i>	Date: <i>8-25 2025</i>	Time: <i>1245</i>
Signature: <i>[Signature]</i>			Signature: <i>[Signature]</i>		
Relinquished by (Print)	Date:	Time:	Received by: (Print)	Date: <i>8/25/25</i>	Time: <i>1600</i>
Signature: <i>[Signature]</i>			Signature: <i>[Signature]</i>		

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): *[Signature]* Phoenix Environmental Laboratories

**APPENDIX B**

**SCHOOL DISTRICT SAMPLING  
ATTACHMENTS**

## Attachment A - List of Priority for Sampling

SCHOOL NAME	DATE OF SAMPLING	CERTIFIED LABORATORY	NOTES
Philip G. Vroom Community School	06/20/2025	Phoenix Environmental Laboratories Inc.	

## Attachment A - List of Priority for Sampling

SCHOOL NAME	DATE OF SAMPLING	CERTIFIED LABORATORY	NOTES
Philip G. Vroom Community School	08/23/2025	Phoenix Environmental Laboratories Inc.	

## Attachment B – Plumbing Profile

**Note:** Complete for each school. For additional information see the USEPA publication, “The 3Ts for Reducing Lead in Drinking Water in Schools”

Name of School: P. G. Vroom Community School Grade Levels: K-8

Address: 18 West 26th St., Bayonne, NJ 07002

Individual school project officer Signature:  Date: 8/5/2025

Questions	Answers	
<b>Background Information</b>		
1. What year was the original building constructed? Were any buildings or additions added to the original facility?	K-8 Grade School built in 1914	
2. If the building was constructed or repaired after 1986, was lead-free plumbing and solder utilized? What type of solder was used? Document all locations where lead solder was used.	Any repairs made after 1986 were done using lead free solder	
3. Where are the most recent plumbing repairs and replacements?	Location: Nurse Office Art Room 1st Floor Pre-K	Description: Replace faucet/sink Replace faucet/sink Built new bathroom
4. With what materials is the service connection (the pipe that carries water to the school from the public water system’s main in the street) made? Where is the Service Line located? (This is the POE location.)	Material: Duct iron  Location: The water main (West 26th st) enters the basement floor in the girls bathroom where the water meter is located and continues to the remainder of the building	
5. Is there point of entry (POE) or point of use (POU) treatment in use?	Y / N No treatment of water Type: at POE  City water comes treated	Location: Main Building 1914

Questions	Answers
6. Are there tanks in your plumbing system (pressure tanks, gravity storage tanks)?	Y / N    Yes - 1914 main building 75 gallon hot water storage tank
7. Does the school have a filter maintenance and operation program? If so, who is responsible for this program? What is the process for adding filters?	Yes, Scott Nolan, Andy McCabe, Vinny Caiola, change filters on an as needed basis assign plumbers
8. Have accessible screens or aerators on outlets that provide drinking water been cleaned? Does the school have a screen or aerator maintenance program?	Y / N Yes The district has set up a routine maintenance program to clean screens
9. Have there been any complaints about bad (metallic) taste? Note location(s).	Y / N    No  None Location:
10. Review records and consult with the public water supplier to determine whether any water samples have been taken in the building for any contaminants. If so, identify: <ul style="list-style-type: none"> <li>• Name of contaminant(s)</li> <li>• Concentrations found</li> <li>• pH level</li> </ul> Is testing done regularly at the building?	No indoor testing by public water supplier
11. Other plumbing background questions include: <ul style="list-style-type: none"> <li>• Are blueprints of the building available?</li> <li>• Are there known plumbing “dead-ends”, low use areas, existing leaks or other “problem areas”?</li> </ul> Are renovations planned for any of the plumbing system?	Not all parints are available No dead-end low use areas All leaks were identified during walk through and have been repaired No plumbing system renovations planned

Questions	Answers	
<b>Walk-Through</b> <i>These questions should be addressed during the walk-through of the facility, while Attachment C- Drinking Water Outlet Inventory is being completed.</i>		
1. Confirm the material of Service Line visually.	Duct iron	
2. Confirm the presence of POE or POU treatment.		
3. What are the potable water pipes made of in your facility? <ul style="list-style-type: none"> <li>• Lead</li> <li>• Plastic</li> <li>• Galvanized Metal</li> <li>• Cast Iron</li> <li>• Copper</li> <li>• Other</li> </ul> Note the water flow through the building and the areas that receive water first, and which areas receive water last.	Copper Galvanized metal Brass  Water flow through the building shown on the prints	
4. Are electrical wires grounded to Water Pipes? Note location(s).	Y / N  Location:	No  No electrical wires grounded to water pipes
5. Are brass fittings, faucets, or valves used in your drinking water system? Note that most faucets are brass on the inside. Document the locations of any brass water outlet to be sampled.	Complete in "Brass" Column in Attachment C- Water Outlet Inventory. Yes Completed in Attachment C - Water Outlet Inventory	
6. Locate all drinking water outlets (i.e. water coolers, bubblers, ice machines, kitchen/ food prep sinks, etc.) in the facility.	Complete in Attachment C-Water Outlet Inventory.	

Questions	Answers	
<p>7. Have the brands and models of the water coolers in the school been compared to the list of recalled water coolers in the Toolkit?</p> <p>Recalled Drinking Water Fountains</p> <p>Make and Model</p>	<p>Y / N Yes all water coolers have been checked and compared to the list of recalled water coolers</p> <p>Type None on the list of recalled water coolers</p>	
<p>8. Have signs of corrosion, such as frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry been detected?</p> <p>Note the locations of water outlets.</p>	<p>Complete in "Signs of Corrosion" column in Attachment C- Drinking Water Outlet Inventory.</p>	
<p>9. Are there any outlets that are not operational and therefore out of service? Permanently? Temporarily?</p> <p>Permanently</p> <p>Temporarily</p>	<p>Y / N NO</p> <p>Complete "Operational Column" in Attachment C- Drinking Water Outlet Inventory.</p> <p>Type/ Location</p>	<p>Description</p>

## Attachment C – Drinking Water Outlet Inventory

Name of School: Philip G. Vroom Community School

Address: 18 West 26th Street, Bayonne, New Jersey 07002

Grade Levels: Elementary School Year School Constructed: Unknown Renovated/Additions: NA

Individual School Project Officer: Scott Nolan

Date Completed: 09/05/2025

# <sup>1</sup>	Type	Location	Code	Operational <sup>2</sup> (Y/N)	Signs of Corrosion <sup>3</sup> (Y/N)	Filter <sup>4</sup> (Y/N)	Brass Fittings, Faucets or valves? (Y/N)	Aerator/ Screen (Y/N)	Motion Activated (Y/N)	Chiller (Y/N)	Water Cooler		Comments
											Make	Model	
01	Water Fountain	Across Computer Lab	PG-01	Y	N	N	N	N	N	N	NA	NA	
02	Water Fountain	Across Computer Lab	PG-02	Y	N	N	N	N	N	N	NA	NA	Flush
03	Sink	Food Service Room	PG-03	Y	N	N	N	N	N	N	NA	NA	
04	Sink	Music Room	PG-04	Y	N	N	N	N	N	N	NA	NA	
05	Water Fountain	Across Music Room	PG-05	Y	N	N	N	N	N	N	NA	NA	

<sup>1</sup> Number outlets starting at the closest outlet to the Point of Entry (POE).

<sup>2</sup> Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

<sup>3</sup> Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

<sup>4</sup> Document on Attachment D- Filter Inventory.

06	Sink	Art Room Faucet – Right	PG-06	Y	N	N	N	Y	N	N	NA	NA	
07	Chiller	Sec Office	PG-07	Y	N	N	N	Y	N	Y	NA	NA	
08	Water Fountain	Across from 109	PG-08	Y	N	N	N	N	N	N	NA	NA	
09	Sink	Room 108	PG-09	Y	N	N	N	Y	N	N	NA	NA	
10	Bottle Filling Station	Across from Room 104	PG-10	Y	N	Y	N	N	Y	Y	NA	NA	
11	Sink	Room 104	PG-11	Y	N	N	N	N	N	N	NA	NA	
12	Sink	Room 103	PG-12	Y	N	N	N	Y	N	N	NA	NA	
13	Sink	Room 102	PG-13	Y	N	N	N	Y	N	N	NA	NA	
14	Sink	Room 101	PG-14	Y	N	N	N	Y	N	N	NA	NA	
15	Sink	Nurse's Office	PG-15	Y	N	N	N	Y	N	N	NA	NA	
16	Water Fountain	Across from Room 207	PG-16	Y	N	N	N	N	N	N	NA	NA	
17	Sink	Room 203	PG-17	Y	N	N	N	Y	N	N	NA	NA	
18	Sink	Room 202	PG-18	Y	N	N	N	Y	N	N	NA	NA	
19	Sink	Room 201	PG-19	Y	N	N	N	Y	N	N	NA	NA	
20	Bottle Filling Station	Bottle Filling Station Across from 304	PG-20	Y	N	Y	N	N	Y	Y	NA	NA	

<sup>1</sup> Number outlets starting at the closest outlet to the Point of Entry (POE).

<sup>1</sup> Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

<sup>1</sup> Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

<sup>1</sup> Document on Attachment D- Filter Inventory.

## Attachment D - Filter Inventory

Name of School: Philip G. Vroom Community School Grade Levels: Elementary School

Address: 18 West 26th Street, Bayonne, New Jersey 07002

Individual School Project Officer: Scott Nolan

Date: 09/05/2025

Sample Location / Code	Brand	Type (Make & Model)	Date Installed or Replaced	Replacement Frequency	NSF Certified for Lead Reduction Y/N
PG-01	Elkay	LZWSR_1D	N/A	N/A	N/A
PG-02	Elkay	LZWSR_1D	N/A	N/A	N/A
PG-03	NA	NA	N/A	N/A	N/A
PG-04	N/A	N/A	N/A	N/A	N/A
PG-05	Elkay	LZWSR_1D	N/A	N/A	N/A
PG-06	N/A	N/A	N/A	N/A	N/A
PG-07	N/A	N/A	N/A	N/A	N/A
PG-08	Elkay	N/A	N/A	N/A	N/A
PG-09	N/A	N/A	N/A	N/A	N/A
PG-10	Elkay	LZS8WSLP	N/A	N/A	N/A
PG-11	N/A	N/A	N/A	N/A	N/A
PG-12	N/A	N/A	N/A	N/A	N/A
PG-13	N/A	N/A	N/A	N/A	N/A
PG-14	N/A	N/A	N/A	N/A	N/A
PG-15	3M Aqua Pure	N/A	N/A	N/A	N/A
PG-16	Halsey Taylor	HRFSB	N/A	N/A	N/A
PG-17	N/A	N/A	N/A	N/A	N/A
PG-18	N/A	N/A	N/A	N/A	N/A
PG-19	N/A	N/A	N/A	N/A	N/A
PG-20	Elkay	LZS8WSLP	N/A	N/A	N/A

### Attachment E – Flushing Log

Name of School: Philip G. Vroom Community School

Address: 18 West 26<sup>th</sup> Street, Bayonne, New Jersey 07002

Grade Levels: Elementary School

Individual School Project Officer: Scott Nolan

Date: 09/05/2025

Sample Location Description	Sample Location Code	Date	Time	Duration of Flushing	Reason for Flushing
Bubbler Across Computer Lab	PG-01	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Across Computer Lab	PG-02	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Food Service Room Faucet	PG-03	August 22, 2025	5:30 pm	2-3 Minutes	Water Sampling
Music Room Faucet	PG-04	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Across Music Room	PG-05	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Art Room Faucet – Right	PG-06	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 111 Teachers Room Faucet	PG-07	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Across from 109	PG-08	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 108 Faucet	PG-09	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bottle Filling Station Across from Room 104	PG-10	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 104 Faucet	PG-11	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 103 Faucet	PG-12	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 102 Faucet	PG-13	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 101 Faucet	PG-14	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Nurse’s Office Faucet	PG-15	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bottle Filling Station Across from Room 207	PG-16	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 203 Faucet	PG-17	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 202 Faucet	PG-18	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling

Room 201 Faucet	PG-19	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bottle Filling Station Across from 304	PG-20	June 19, 2025	5:30 pm	2-3 Minutes	Water Sampling

## Attachment F - Pre - Sampling Water Use Certification

TO BE COMPLETED BY THE BAYONNE BOE DISTRICT REPRESENTATIVE:		
School Name:	<u>Philip G. Vroom Community School</u>	
Sample collection address:	<u>18 West 26th Street, Bayonne, New Jersey 07002</u>	
Water was last used:	<u>Time: 5:30 pm</u>	<u>Date: June 19, 2025</u>
Sample commencement:	<u>Time: 1:13 pm</u>	<u>Date: June 20, 2025</u>
I have read the Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.		
Scott Nolan	<u>07/22/2025</u>	
Signature	Date	

## Attachment F - Pre - Sampling Water Use Certification

TO BE COMPLETED BY THE BAYONNE BOE DISTRICT REPRESENTATIVE:		
School Name:	<u>Philip G. Vroom Community School</u>	
Sample collection address:	<u>18 West 26th Street, Bayonne, New Jersey 07002</u>	
Water was last used:	<u>Time: 5:30 pm</u>	<u>Date: August 22, 2025</u>
Sample commencement:	<u>Time: 7:59 am</u>	<u>Date: August 23, 2025</u>
I have read the Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.		
Scott Nolan	<u>07/22/2025</u>	
Signature	Date	