



464 Valley Brook Avenue, Lyndhurst NJ 07071  
129 Sea Girt Avenue, Manasquan NJ 08736  
Phone: (800) 423-0766 • Fax: (201) 438-1798  
www.mccabeenv.com

---

## LEAD IN DRINKING WATER TESTING REPORT

*Conducted for:*

Bayonne Board of Education  
669 Avenue A  
Bayonne, New Jersey 07002

*Conducted at:*

Henry Harris Community School  
135 Avenue C  
Bayonne, New Jersey 07002

*Submitted by:*

McCabe Environmental Services, L.L.C.  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071

**REPORT DATE:** September 8, 2025

**MES PROJECT NO.:** 25-05225

*Prepared by:*

A handwritten signature in black ink, appearing to read 'Arllitzy Lezama'.

**Arllitzy Lezama**  
**Environmental Scientist**

*Signed for the Company by:*

A handwritten signature in black ink, appearing to read 'John H. Chiaviello'.

**John H. Chiaviello**  
**Vice President**

## TABLE OF CONTENTS

	<b>Page</b>
1.0 INTRODUCTION .....	1
2.0 SCOPE OF WORK.....	1
3.0 PROCEDURES.....	1
4.0 TABLE OF SAMPLE RESULTS .....	2
5.0 DISCUSSION AND CONCLUSION .....	4

### **APPENDIX A**

Laboratory Certificates of Analysis  
&  
Sample Chain of Custody Forms

### **APPENDIX B**

School District Sampling Attachments

**1.0 INTRODUCTION**

McCabe Environmental Services, L.L.C. (McCabe) was retained by Bayonne Board of Education (Client) to conduct lead in drinking water testing at the Henry Harris Community School located at 135 Avenue C, Bayonne, New Jersey.

The project information is as follows:

<u>Client Name:</u>	Bayonne Board of Education
<u>Contact Person:</u>	Mr. Daniel Castles
<u>Project Name:</u>	Henry Harris Community School – Lead in Drinking Water
<u>Project Location:</u>	135 Avenue C Bayonne, New Jersey 07002
<u>Date(s) of Service:</u>	June 21, 2025 and August 23, 2025
<u>McCabe Personnel:</u>	Gary Clare and Arllitz Lezama

**2.0 SCOPE OF WORK**

Drinking water testing was performed at the Henry Harris Community School located at 135 Avenue C, Bayonne, New Jersey on June 21, 2025. The purpose of the testing was to determine if the building’s plumbing was having an adverse impact on water quality, specifically with regard to lead concentrations. Samples were collected from various potential drinking water outlets located throughout the building. Follow-up drinking water testing was then performed at the failed location in Henry Harris Community School on August 23, 2025. The failed location was re-sampled with a first draw sample and immediately followed up with a thirty (30) second flush sample. Samples were collected from areas that exceeded the regulatory standard on June 21, 2025. Testing was followed as per past reports provided by Bayonne Board of Education.

**3.0 PROCEDURES**

After determining which outlets would be sampled, McCabe personnel collected a "first draw" sample at each location. A "first draw" is the initial water that is first to come out of the tap after a period of inactivity. Following the “first draw”, a "30 second flush" sample was also collected where the main service line comes into the building. All samples were collected into 250 mL sterile bottles, labeled with a sample identification, and analyzed in accordance with EPA approved methods to determine the level of lead in drinking water. Samples were analyzed by an accredited laboratory.

The U.S. Environmental Protection Agency (EPA) has established National Primary Drinking Water Regulations (NPDWR) that set mandatory water quality standards for drinking water contaminants. These are enforceable standards called "maximum contaminant levels" or "MCL", which are established to protect the public against consumption of drinking water contaminants that present a risk to human health. An MCL is the maximum allowable amount of a contaminant in drinking water which is delivered to the consumer.

The EPA has established the Lead and Copper Rule that sets standards for state and public water systems. This rule has set an MCL for lead at 15 parts per billion (ppb) for a one liter sample. However, the EPA also established the Lead in Drinking Water at Schools and Child Care Facilities in which the EPA recommends an MCL of 20 ppb for

a 250 milliliter first draw sample. In order to be more stringent, for our report purposes we have compared all results to both the 15 ppb and the 20 ppb standards.

**4.0 TABLE OF SAMPLE RESULTS**

The following table presents all sample results in order of sample identification conducted on June 21, 2025:

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
HH-01	First Draw – Right Bubbler by Room 102	1.6	Pass	Pass
HH-02	30 Second Flush – Right Bubbler by Room 102	< 1	Pass	Pass
HH-03	First Draw – Left Bubbler by Room 102	< 1	Pass	Pass
HH-04	First Draw – Bubbler by Principal’s Office	4.9	Pass	Pass
<b>HH-05</b>	<b>First Draw – Main Office Faucet</b>	<b>20.6</b>	<b>Fail</b>	<b>Fail</b>
HH-06	First Draw – Pre-K Bathroom Sink, Left Side	2.3	Pass	Pass
HH-07	First Draw – Pre-K Bathroom Sink, Right Side	1.8	Pass	Pass
HH-08	First Draw – Lunchroom Faucet	2	Pass	Pass
HH-09	First Draw – Left Bubbler by Lunchroom	2.9	Pass	Pass
HH-10	First Draw – Right Bubbler by Lunchroom	< 1	Pass	Pass
HH-11	First Draw – Pre-K Room 108 Sink	2.5	Pass	Pass
HH-12	First Draw – Pre-K Room 108 Bathroom Sink	< 1	Pass	Pass
HH-13	First Draw – Pre-K Room 107 Sink	1.2	Pass	Pass
HH-14	First Draw – Pre-K 107 Bathroom Sink	< 1	Pass	Pass
HH-15	First Draw – Pre-K Room 106 Bathroom Sink	< 1	Pass	Pass
HH-16	First Draw – Left Bubbler by Room 201	< 1	Pass	Pass

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
HH-17	First Draw – Right Bubbler by Room 201	3.5	Pass	Pass
<b>HH-18</b>	<b>First Draw – Library Faucet</b>	<b>24.3</b>	<b>Fail</b>	<b>Fail</b>
HH-19	First Draw – Faculty Room Faucet	1.7	Pass	Pass
HH-20	First Draw – Bubbler Across from the Nurse	OUT OF ORDER		
HH-21	First Draw – Nurse’s Office Faucet	OUT OF ORDER		
HH-22	First Draw – Bubbler by Room 21	4.2	Pass	Pass
HH-23	First Draw – Left Bubbler by Room 20	1.5	Pass	Pass
HH-24	First Draw – Right Bubbler by Room 20	OUT OF ORDER		
HH-25	First Draw – Copy Room Bubbler	2.3	Pass	Pass
HH-26	First Draw – Copy Room Sink	< 1	Pass	Pass
HH-27	First Draw – Bubbler by 302, Left Side	7.8	Pass	Pass
HH-28	First Draw – Bubbler by 302, Right Side	10.2	Pass	Pass
HH-29	First Draw – Bubbler Across Room 37	< 1	Pass	Pass
HH-30	First Draw – Bubbler by Room 31, Left Side	1.1	Pass	Pass
HH-31	First Draw – Bubbler by Room 31, Right Side	< 1	Pass	Pass
HH-32	First Draw – Chiller by Room 306	OUT OF ORDER		
HH-33	First Draw – Bubbler Between 306 and 307	1.5	Pass	Pass
HH-34	First Draw – Sink Between 306 and 307	1.6	Pass	Pass

The following table presents all sample results in order of sample identification from the follow-up lead in drinking water testing conducted on August 23, 2025:

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
HH-05-A	First Draw – Main Office Faucet	1.1	Pass	Pass
HH-05-B	30 Second Flush – Main Office Faucet	< 0.5	Pass	Pass
HH-18	First Draw – Library Faucet	PERMANENTLY REMOVED		

## 5.0 DISCUSSION AND CONCLUSION

A total of thirty (30) samples were collected from the Henry Harris Community School. Two (2) samples were found to be greater than the EPA Lead and Copper Rule standard of 15 ppb and also greater than the EPA Lead in Drinking Water at Schools and Child Care Facilities standard of 20 ppb. All other samples were found to be less than the EPA standards of 20 ppb and 15 ppb.

As a follow-up to drinking water testing conducted on June 21, 2025, McCabe conducted follow-up testing on August 23, 2025. A total of two (2) samples were collected from the Main Office Faucet and the Library Faucet was permanently removed from Henry Harris Community School located at 135 Avenue C, Bayonne, New Jersey 07002. All samples taken during the follow-up inspection were below the regulatory standard.

In addition, McCabe Environmental recommends annual drinking water sampling to ensure that the building's plumbing is not having an adverse impact on water quality.

**APPENDIX A**

**LABORATORY CERTIFICATES OF ANALYSIS  
&  
SAMPLE CHAIN OF CUSTODY FORMS**



Thursday, July 03, 2025

Attn: Jarred Panecki  
McCabe Environmental Services, LLC  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
SDG ID: GCT58094  
Sample ID#s: CT58094 - CT58123

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller  
Laboratory Director

NELAC - #NY11301  
CT Lab Registration #PH-0618  
MA Lab Registration #M-CT007  
ME Lab Registration #CT-007  
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003  
NY Lab Registration #11301  
PA Lab Registration #68-03530  
RI Lab Registration #63  
VT Lab Registration #VT11301



Environmental Laboratories, Inc.  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



## Sample Id Cross Reference

July 03, 2025

SDG I.D.: GCT58094

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION

Client Id	Lab Id	Matrix	Col Date
HH-01	CT58094	DRINKING WATER	06/21/25 7:10
HH-02	CT58095	DRINKING WATER	06/21/25 7:13
HH-03	CT58096	DRINKING WATER	06/21/25 7:14
HH-04	CT58097	DRINKING WATER	06/21/25 7:17
HH-05	CT58098	DRINKING WATER	06/21/25 7:18
HH-06	CT58099	DRINKING WATER	06/21/25 7:20
HH-07	CT58100	DRINKING WATER	06/21/25 7:21
HH-08	CT58101	DRINKING WATER	06/21/25 7:22
HH-09	CT58102	DRINKING WATER	06/21/25 7:23
HH-10	CT58103	DRINKING WATER	06/21/25 7:23
HH-11	CT58104	DRINKING WATER	06/21/25 7:25
HH-12	CT58105	DRINKING WATER	06/21/25 7:26
HH-13	CT58106	DRINKING WATER	06/21/25 7:27
HH-14	CT58107	DRINKING WATER	06/21/25 7:28
HH-15	CT58108	DRINKING WATER	06/21/25 7:29
HH-16	CT58109	DRINKING WATER	06/21/25 7:34
HH-17	CT58110	DRINKING WATER	06/21/25 7:34
HH-18	CT58111	DRINKING WATER	06/21/25 7:35
HH-19	CT58112	DRINKING WATER	06/21/25 7:36
HH-22	CT58113	DRINKING WATER	06/21/25 7:41
HH-23	CT58114	DRINKING WATER	06/21/25 7:43
HH-25	CT58115	DRINKING WATER	06/21/25 7:44
HH-26	CT58116	DRINKING WATER	06/21/25 7:44
HH-27	CT58117	DRINKING WATER	06/21/25 7:48
HH-28	CT58118	DRINKING WATER	06/21/25 7:48
HH-29	CT58119	DRINKING WATER	06/21/25 7:48
HH-30	CT58120	DRINKING WATER	06/21/25 7:51
HH-31	CT58121	DRINKING WATER	06/21/25 7:51
HH-33	CT58122	DRINKING WATER	06/21/25 7:53
HH-34	CT58123	DRINKING WATER	06/21/25 7:53



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:10  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58094

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-01

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.6	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/23/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:13  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58095

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-02

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/23/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:14  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58096

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-03

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/23/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:17  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58097

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-04

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	4.9	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/23/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:18  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58098

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-05

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	20.6	1	1	ppb	15			06/26/25	TH	E200.5
*** Lead exceeds Action Level of 15 ***										
Total Metal Digestion	Completed							06/23/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director  
 July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:20  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58099

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-06

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2.3	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/23/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 03, 2025**

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:21  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58100

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-07

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.8	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/23/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:22  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58101

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-08

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/23/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:23  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58102

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-09

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2.9	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/23/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:23  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58103

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-10

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/23/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:25  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58104

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-11

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2.5	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/23/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:26  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58105

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-12

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/23/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:27  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58106

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-13

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.2	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/23/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 03, 2025**

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:28  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58107

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-14

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/23/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:29  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58108

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-15

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/23/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:34  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58109

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-16

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/23/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:34  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58110

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-17

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	3.5	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/23/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:35  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58111

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-18

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	24.3	1	1	ppb	15			06/26/25	TH	E200.5
*** Lead exceeds Action Level of 15 ***										
Total Metal Digestion	Completed							06/23/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director  
 July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:36  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58112

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-19

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.7	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/23/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 03, 2025**

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:41  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58113

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-22

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	4.2	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/23/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:43  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58114

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-23

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.5	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:44  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58115

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-25

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2.3	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:44  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58116

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-26

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 03, 2025**

**Reviewed and Released by: Alejandro Paredes, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:48  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58117

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-27

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	7.8	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 03, 2025**

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:48  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58118

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-28

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	10.2	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 03, 2025**

**Reviewed and Released by: Alejandro Paredes, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:48  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58119

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-29

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 03, 2025**

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:51  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58120

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-30

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.1	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:51  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58121

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-31

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/26/25	TH	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 03, 2025**

**Reviewed and Released by: Alejandro Paredes, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

Date

06/21/25  
 06/23/25

Time

7:53  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58122

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-33

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.5	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**July 03, 2025**

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

## Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

## Custody Information

Collected by: AL, GC  
 Received by: CP  
 Analyzed by: see "By" below

## Date

06/21/25  
 06/23/25

## Time

7:53  
 16:20

## Laboratory Data

SDG ID: GCT58094  
 Phoenix ID: CT58123

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-34

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.6	1	1	ppb	15			06/26/25	CPP	E200.5
Total Metal Digestion	Completed							06/25/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

### Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager

# Analysis Report - Summary

July 03, 2025

Attn: Jarred Panecki  
McCabe Environmental Services, LLC  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071



Environmental Laboratories, Inc.  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823

SDG I.D.: GCT58094



Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
Project: 25-05225 Bayonne Board Of Education								
CT58094	HH-01	06/21/25	Lead	1.6	1	ppb	06/26/25	E200.5
CT58095	HH-02	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58096	HH-03	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58097	HH-04	06/21/25	Lead	4.9	1	ppb	06/26/25	E200.5
CT58098	HH-05	06/21/25	Lead	20.6	1	ppb	06/26/25	E200.5
CT58099	HH-06	06/21/25	Lead	2.3	1	ppb	06/26/25	E200.5
CT58100	HH-07	06/21/25	Lead	1.8	1	ppb	06/26/25	E200.5
CT58101	HH-08	06/21/25	Lead	2	1	ppb	06/26/25	E200.5
CT58102	HH-09	06/21/25	Lead	2.9	1	ppb	06/26/25	E200.5
CT58103	HH-10	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58104	HH-11	06/21/25	Lead	2.5	1	ppb	06/26/25	E200.5
CT58105	HH-12	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58106	HH-13	06/21/25	Lead	1.2	1	ppb	06/26/25	E200.5
CT58107	HH-14	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58108	HH-15	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58109	HH-16	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58110	HH-17	06/21/25	Lead	3.5	1	ppb	06/26/25	E200.5
CT58111	HH-18	06/21/25	Lead	24.3	1	ppb	06/26/25	E200.5
CT58112	HH-19	06/21/25	Lead	1.7	1	ppb	06/26/25	E200.5
CT58113	HH-22	06/21/25	Lead	4.2	1	ppb	06/26/25	E200.5
CT58114	HH-23	06/21/25	Lead	1.5	1	ppb	06/26/25	E200.5
CT58115	HH-25	06/21/25	Lead	2.3	1	ppb	06/26/25	E200.5
CT58116	HH-26	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58117	HH-27	06/21/25	Lead	7.8	1	ppb	06/26/25	E200.5
CT58118	HH-28	06/21/25	Lead	10.2	1	ppb	06/26/25	E200.5

Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
CT58119	HH-29	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58120	HH-30	06/21/25	Lead	1.1	1	ppb	06/26/25	E200.5
CT58121	HH-31	06/21/25	Lead	< 1	1	ppb	06/26/25	E200.5
CT58122	HH-33	06/21/25	Lead	1.5	1	ppb	06/26/25	E200.5
CT58123	HH-34	06/21/25	Lead	1.6	1	ppb	06/26/25	E200.5

Comments:

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

ND=Not detected BDL=Below Detection Level RL=Reporting Level CL=Client Limit



Phyllis Shiller  
Laboratory Director  
July 03, 2025



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# QA/QC Report

July 03, 2025

## QA/QC Data

SDG I.D.: GCT58094

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	--------	---------------	------------	---------	-------	--------	---------	------	-------	--------	--------------	--------------

QA/QC Batch 790356 (mg/L), QC Sample No: CT58094 (CT58094, CT58095, CT58096, CT58097, CT58098, CT58099, CT58100, CT58101, CT58102, CT58103)

### ICP Metals - Aqueous

Lead	BRL	0.0010	0.0016	<0.0010	NC	103						106	85 - 115	20
------	-----	--------	--------	---------	----	-----	--	--	--	--	--	-----	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 790356A (mg/L), QC Sample No: CT58104 (CT58104, CT58105, CT58106, CT58107, CT58108, CT58109, CT58110, CT58111, CT58112, CT58113)

### ICP Metals - Aqueous

Lead	BRL	0.0010				103						103	85 - 115	20
------	-----	--------	--	--	--	-----	--	--	--	--	--	-----	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 790690 (mg/L), QC Sample No: CT58114 (CT58114, CT58115, CT58116, CT58117, CT58118, CT58119, CT58120, CT58121, CT58122, CT58123)

### ICP Metals - Aqueous

Lead	BRL	0.0010	0.0015	0.0022	NC	105						105	85 - 115	20
------	-----	--------	--------	--------	----	-----	--	--	--	--	--	-----	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Inf - Interference
- (ISO) - Isotope Dilution

  
 Phyllis Shiller, Laboratory Director  
 July 03, 2025

Thursday, July 03, 2025

Criteria: NJ: DW

State: NJ

## Sample Criteria Exceedances Report

GCT58094 - MCCABE-PB

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
CT58098	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	20.6	1	15	1	ppb
CT58111	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	24.3	1	15	1	ppb

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



**Environmental Laboratories, Inc.**  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



## Analysis Comments

July 03, 2025

SDG I.D.: GCT58094

---

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

2.2" WCAP

MCCABE ENVIRONMENTAL SERVICES, L.L.C.  
 464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER  
 CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education		SITE ADDRESS: Henry Harris Community School 135 Avenue C, Bayonne, NJ 07002		
FIELD INSPECTOR'S NAME: <u>A. Alvarez &amp; G. Clare</u>		TURNAROUND TIME REQUESTED: 2-Week		
MES PROJECT #: 25-05225		SAMPLE DATE: <u>6/21/25</u>		
Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	HH-01	FD - Right + Bubblers by <del>Room 102</del> <sup>(4)</sup> Gill's Bathroom	7:10 AM	LEAD - 200.8
DW	HH-02	30 second flush - Right bubbler by Gill's Bathroom	7:13 AM	LEAD - 200.8
DW	HH-03	FD - Left bubbler by Room 102	7:14 AM	LEAD - 200.8
DW	HH-04	FD - Bubblers by Principal Office	7:17 AM	LEAD - 200.8
DW	HH-05	FD - Main faucet @ office faucet	7:18 AM	LEAD - 200.8
DW	HH-06	FD - Prek Bathroom sink - Left	7:20 AM	LEAD - 200.8
DW	HH-07	FD - Prek Bathroom sink - Right	7:21 AM	LEAD - 200.8
DW	HH-08	FD - Lunch Room faucet	7:22 AM	LEAD - 200.8
DW	HH-09	FD - Left Bubbler by Lunch Room	7:23 AM	LEAD - 200.8
DW	HH-10	FD - Bottle filler by Lunch Room	7:23 AM	LEAD - 200.8
Relinquished by (Print) <u>Gary Clare</u>		Date:	Received by: (Print) <u>JJ Demers</u>	Date: <u>8-23</u>
Signature: <u>[Signature]</u>		Time: <u>10:15</u>	Signature:	Time: <u>10:15</u>
Relinquished by (Print) <u>[Signature]</u>		Date:	Received by: (Print) <u>Abby Lee</u>	Date: <u>6/23/25</u>
Signature: <u>[Signature]</u>		Time:	Signature:	Time: <u>16:20</u>
Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): <u>Phoenix Environmental Laboratories</u>				

58094  
58095  
58096  
58097  
58098  
58099  
58100  
58101  
58102  
58103

NJ Certified WBE

2.2" WCIP

MCCABE ENVIRONMENTAL SERVICES, L.L.C.  
 464 VALLEY BROOK AVENUE LYNTHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER  
 CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education  
 FIELD INSPECTOR'S NAME: A. Letzama, G. Clare  
 MES PROJECT #: 25-05225  
 SAMPLE DATE: 6/21/25  
 SITE ADDRESS: Henry Harris Community School  
 135 Avenue C, Bayonne, NJ 07002  
 TURNAROUND TIME REQUESTED: 2-Week

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	HH-11	FD - Prek Room 108 sink	7:25 AM	LEAD - 200.8
DW	HH-12	FD - Prek Room 108 Bathroom Sink	7:26 AM	LEAD - 200.8
DW	HH-13	FD - Prek Room 107 sink	7:27 AM	LEAD - 200.8
DW	HH-14	FD - Prek Room 107 Bathroom	7:28 AM	LEAD - 200.8
DW	HH-15	FD - Prek Room 106 Bathroom Sink	7:29 AM	LEAD - 200.8
DW	HH-16	FD - Left Bottle filler by Library	7:34 AM	LEAD - 200.8
DW	HH-17	FD - Right bubbler by Library	7:34 AM	LEAD - 200.8
DW	HH-18	FD - Library faucet	7:35 AM	LEAD - 200.8
DW	HH-19	FD - Faculty Room faucet	7:36 AM	LEAD - 200.8
DW	HH-22	FD - Bubble by Room 21	7:41 AM	LEAD - 200.8

Relinquished by (Print) Gary Clare  
 Signature: *[Signature]* Date: 6/23/25 Time: 1015  
 Received by: (Print) J. James  
 Signature: *[Signature]* Date: 8/23/2025 Time: 1015  
 Relinquished by (Print)  
 Signature: *[Signature]* Date: 6/23/25 Time: 1620  
 Received by: (Print) Abby Lee  
 Signature: *[Signature]* Date: 6/23/25 Time: 1620

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

NJ Certified WBE

2.2° WCIP

MCCABE ENVIRONMENTAL SERVICES, L.L.C.  
 464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER  
 CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education  
 SITE ADDRESS: Henry Harris Community School  
 135 Avenue C, Bayonne, NJ 07002

FIELD INSPECTOR'S NAME: A. Letzme, G. Clure  
 TURNAROUND TIME REQUESTED: 2-Week  
 MES PROJECT #: 25-05225  
 SAMPLE DATE: 6/21/25

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED	
DW	HH-23	FD - left bubbler by Room 203	7:43 AM	LEAD - 200.8	58114
DW	HH-25	FD - Copyroom bubbler	7:44 AM	LEAD - 200.8	58115
DW	HH-26	FD - Copy Room Sink	7:44 AM	LEAD - 200.8	58116
DW	HH-27	FD - Bubbler by Room 301 Left	7:48 AM	LEAD - 200.8	58117
DW	HH-28	FD - Bubbler by Room 301 Right	7:48 AM	LEAD - 200.8	58118
DW	HH-29	FD - Bubbler Across Room 37	7:48 AM	LEAD - 200.8	58119
DW	HH-30	FD - Bubbler by Room 31 - Left	7:51 AM	LEAD - 200.8	58120
DW	HH-31	FD - Bubbler by Room 31 - Right	7:51 AM	LEAD - 200.8	58121
DW	HH-33	FD - Bubbler in Room between 306 & 307	7:53 AM	LEAD - 200.8	58122
DW	HH-34	FD - sink in Room <del>between</del> Between 306 & 307	7:53 AM	LEAD - 200.8	58123

Relinquished by (Print) Gary Clure  
 Date: 6/23/25 Time: 1015  
 Signature: *[Signature]*  
 Received by: (Print) J. Demers  
 Signature: *[Signature]*  
 Date: 8-23 Time: 1015

Relinquished by (Print)  
 Date: Time:  
 Signature: *[Signature]*  
 Received by: (Print) Abby Lee  
 Signature: *[Signature]*  
 Date: 6/23/25 Time: 1020

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

NJ Certified WBE



Wednesday, September 03, 2025

Attn: Jarred Panecki  
McCabe Environmental Services, LLC  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION  
SDG ID: GCU09461  
Sample ID#s: CU09461 - CU09462

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller  
Laboratory Director

NELAC - #NY11301  
CT Lab Registration #PH-0618  
MA Lab Registration #M-CT007  
ME Lab Registration #CT-007  
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003  
NY Lab Registration #11301  
PA Lab Registration #68-03530  
RI Lab Registration #63  
VT Lab Registration #VT11301



Environmental Laboratories, Inc.  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



## Sample Id Cross Reference

September 03, 2025

SDG I.D.: GCU09461

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION

---

Client Id	Lab Id	Matrix	Col Date
HH-05-A	CU09461	DRINKING WATER	08/23/25 8:39
HH-05-B	CU09462	DRINKING WATER	08/23/25 8:40



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

September 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

08/23/25  
 08/25/25

Time

8:39  
 19:05

## Laboratory Data

SDG ID: GCU09461  
 Phoenix ID: CU09461

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-05-A

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.1	0.5	2	ppb	15			09/02/25	CPP	E200.8
Total Metal Digestion	Completed							08/30/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**September 03, 2025**

**Reviewed and Released by: Rashmi Makol, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

September 03, 2025

FOR: Attn: Jarred Panecki  
 McCabe Environmental Services, LLC  
 464 Valley Brook Avenue  
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER  
 Location Code: MCCABE-PB  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

08/23/25  
 08/25/25

Time

8:40  
 19:05

## Laboratory Data

SDG ID: GCU09461  
 Phoenix ID: CU09462

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION  
 Client ID: HH-05-B

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			09/02/25	CPP	E200.8
Total Metal Digestion	Completed							08/30/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**September 03, 2025**

**Reviewed and Released by: Rashmi Makol, Project Manager**

# Analysis Report - Summary

September 03, 2025

Attn: Jarred Panecki  
McCabe Environmental Services, LLC  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071



Environmental Laboratories, Inc.  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823

SDG I.D.: GCU09461



Sample	Client Id	Col Date	Parameter	Result	RL	CL	Units	Date Analyzed	Reference
Project: 25-05225-1 Bayonne Board Of Education									
CU09461	HH-05-A	08/23/25	Lead	1.1	0.5		ppb	09/02/25	E200.8
CU09462	HH-05-B	08/23/25	Lead	< 0.5	0.5		ppb	09/02/25	E200.8

## Comments:

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
ND=Not detected BDL=Below Detection Level RL=Reporting Level CL=Client Limit

  
Phyllis Shiller  
Laboratory Director  
September 03, 2025



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# QA/QC Report

September 03, 2025

## QA/QC Data

SDG I.D.: GCU09461

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	-----------	------------------	---------------	------------	----------	-----------	------------	---------	----------	-----------	--------------------	--------------------

QA/QC Batch 800979A (mg/L), QC Sample No: CU09457 (CU09461, CU09462)

### ICP MS Metals - Aqueous

Lead	BRL	0.0001				104			103				
------	-----	--------	--	--	--	-----	--	--	-----	--	--	--	--

Comment:

This batch does not include a duplicate.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference
- (ISO) - Isotope Dilution

  
 Phyllis Shiller, Laboratory Director  
 September 03, 2025

Wednesday, September 03, 2025

Criteria: NJ: DW

State: NJ

## Sample Criteria Exceedances Report

GCU09461 - MCCABE-PB

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

\*\*\* No Data to Display \*\*\*

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



**Environmental Laboratories, Inc.**  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



## Analysis Comments

September 03, 2025

SDG I.D.: GCU09461

---

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

**MCCABE ENVIRONMENTAL SERVICES, L.L.C.**

464 VALLEY BROOK AVENUE LYNDHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

**LEAD in DRINKING WATER  
CHAIN-OF-CUSTODY FORM**

1.1 WCUP

CLIENT NAME: Bayonne Board of Education		SITE ADDRESS: Henry Harris Community School 135 Avenue C, Bayonne, NJ 07002		
FIELD INSPECTOR'S NAME: A. Iezama		TURNAROUND TIME REQUESTED: 2-Week		
MES PROJECT #: 25-05225-1	SAMPLE DATE: 8/23/25			
Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	09461 HH-05-A	FD - Main Office faucet	8:39 A.M	LEAD - 200.8
DW	09462 HH-05-B	30 sec. Flush - Main office faucet.	8:40 A.M	LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
Relinquished by (Print) A. Iezama		Date: 8/25/25	Received by: (Print) J. Demers	Date: 8-25-2025
Signature: <i>A. Iezama</i>		Time:	Signature: <i>J. Demers</i>	Time: 1245
Relinquished by (Print)		Date:	Received by: (Print)	Date:
Signature: <i>[Signature]</i>		Time:	Signature: <i>[Signature]</i>	Time: 1610
Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories				

NJ Certified WBE

**APPENDIX B**

**SCHOOL DISTRICT SAMPLING  
ATTACHMENTS**

## Attachment A - List of Priority for Sampling

SCHOOL NAME	DATE OF SAMPLING	CERTIFIED LABORATORY	NOTES
Henry Harris Community School	06/21/2025	Phoenix Environmental Laboratories Inc.	

## Attachment A - List of Priority for Sampling

SCHOOL NAME	DATE OF SAMPLING	CERTIFIED LABORATORY	NOTES
Henry Harris Community School	08/23/2025	Phoenix Environmental Laboratories Inc.	

## Attachment B - Plumbing Profile

**Note:** Complete for each school. For additional information see the USEPA publication, "The 3Ts for Reducing Lead in Drinking Water in Schools"

Name of School: Henry Harris Community School Grade Levels: K-8

Address: 135 Avenue C, Bayonne, NJ 07002

Individual school project officer Signature: *Scott Nolan* Date: 8/5/2025

Questions	Answers	
<b>Background Information</b>		
1. What year was the original building constructed? Were any buildings or additions added to the original facility?	K-8 Grade School Built in 1920 First Addition was added in 1975 Next Addition was added in 2000	
2. If the building was constructed or repaired after 1986, was lead-free plumbing and solder utilized? What type of solder was used? Document all locations where lead solder was used.	Any repairs made after 1986 were done using lead free solder	
3. Where are the most recent plumbing repairs and replacements?	<b>Location: House 5</b> Nurse Office      Hallway Fountains Art Room            Main Building - Duct Iron Teachers Room Library	<b>Description:</b> Faucet    Replace Fountains Faucet Faucet Faucet
4. With what materials is the service connection (the pipe that carries water to the school from the public water system's main in the street) made? Where is the Service Line located? (This is the POE location.)	<b>Material: Main Building - Duct Iron</b>  <b>Location:</b> The water main (5th St) enters the first floor flows through building to the custodial room where the water meter is located and continues to the remainder of the building	
5. Is there point of entry (POE) or point of use (POU) treatment in use?	Y / N No treatment of water Type: at POE  City water comes treated	<b>Location: Main Building 1920</b>

Questions	Answers
<p>6. Are there tanks in your plumbing system (pressure tanks, gravity storage tanks)?</p>	<p>Y / N      YES - Building has a 75 gallon hot water storage tank. Boiler Room</p> <p>40 Gallon Hot water tank sub basement 38 Gallon Hot water tank new wing</p>
<p>7. Does the school have a filter maintenance and operation program? If so, who is responsible for this program? What is the process for adding filters?</p>	<p>Yes, Scott Nolan, Andy McCabe, Vinny Caiola, change filters on an as needed basis assign plumbers</p> <p>Change on an as needed basis</p>
<p>8. Have accessible screens or aerators on outlets that provide drinking water been cleaned? Does the school have a screen or aerator maintenance program?</p>	<p>Y / N YES</p> <p>The district has set up a routine maintenance program to clean screens</p>
<p>9. Have there been any complaints about bad (metallic) taste? Note location(s).</p>	<p>Y / N      No</p> <p>Location:</p>
<p>10. Review records and consult with the public water supplier to determine whether any water samples have been taken in the building for any contaminants. If so, identify:</p> <ul style="list-style-type: none"> <li>• Name of contaminant(s)</li> <li>• Concentrations found</li> <li>• pH level</li> </ul> <p>Is testing done regularly at the building?</p>	<p>No indoor testing by public water supplier</p>
<p>11. Other plumbing background questions include:</p> <ul style="list-style-type: none"> <li>• Are blueprints of the building available?</li> <li>• Are there known plumbing “dead-ends”, low use areas, existing leaks or other “problem areas”?</li> </ul> <p>Are renovations planned for any of the plumbing system?</p>	<p>Not all prints are available No dead end low use areas All leaks were identified during walk through and have been repaired</p> <p>No plumbing system renovations planned</p>

Questions	Answers	
<b>Walk-Through</b> <i>These questions should be addressed during the walk-through of the facility, while Attachment C- Drinking Water Outlet Inventory is being completed.</i>		
1. Confirm the material of Service Line visually.	Duct iron	
2. Confirm the presence of POE or POU treatment.	No POE or POU treatment	
3. What are the potable water pipes made of in your facility? <ul style="list-style-type: none"> <li>• Lead</li> <li>• Plastic</li> <li>• Galvanized Metal</li> <li>• Cast Iron</li> <li>• Copper</li> <li>• Other</li> </ul> Note the water flow through the building and the areas that receive water first, and which areas receive water last.	Copper Galvanized metal Brass  Water flow through the building shown on the prints	
4. Are electrical wires grounded to Water Pipes? Note location(s).	Y / N  Location:	No  No electrical wires grounded to water pipes
5. Are brass fittings, faucets, or valves used in your drinking water system? Note that most faucets are brass on the inside. Document the locations of any brass water outlet to be sampled.	Complete in "Brass" Column in Attachment C- Water Outlet Inventory. Yes See Attachment C	
6. Locate all drinking water outlets (i.e. water coolers, bubblers, ice machines, kitchen/ food prep sinks, etc.) in the facility.	Complete in Attachment C-Water Outlet Inventory. See Attachment C	

Questions	Answers	
<p>7. Have the brands and models of the water coolers in the school been compared to the list of recalled water coolers in the Toolkit?</p> <p>Recalled Drinking Water Fountains</p> <p>Make and Model</p>	<p>Y / N YES, all water coolers have been checked and compared to the list of recalled water coolers</p> <p>None on the list of recalled water coolers</p> <p>Type</p>	
<p>8. Have signs of corrosion, such as frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry been detected?</p> <p>Note the locations of water outlets.</p>	<p>Complete in "Signs of Corrosion" column in Attachment C- Drinking Water Outlet Inventory.</p>	
<p>9. Are there any outlets that are not operational and therefore out of service? Permanently? Temporarily?</p> <p>Permanently</p> <p>Temporarily</p>	<p>Y / N</p> <p>Complete "Operational Column" in Attachment C- Drinking Water Outlet Inventory.</p> <p>Type/ Location</p>	<p>Description</p>

## Attachment C – Drinking Water Outlet Inventory

Name of School: Henry Harris Community School

Address: 135 Avenue C, Bayonne, New Jersey 07002

Grade Levels: Elementary School Year School Constructed: Unknown Renovated/Additions: NA

Individual School Project Officer: Scott Nolan

Date Completed: 09/05/2025

# <sup>1</sup>	Type	Location	Code	Operational <sup>2</sup> (Y/N)	Signs of Corrosion <sup>3</sup> (Y/N)	Filter <sup>4</sup> (Y/N)	Brass Fittings, Faucets or valves? (Y/N)	Aerator/Screen (Y/N)	Motion Activated (Y/N)	Chiller (Y/N)	Water Cooler		Comments
											Make	Model	
01	Water Fountain	Right Bubbler by Room 102	HH-01	Y	Y	N	Y	N	N	N	NA	NA	
02	Water Fountain	Right Bubbler by Room 102	HH-02	Y	Y	N	Y	N	N	N	NA	NA	Flush
03	Water Fountain	Left Bubbler by Room 102	HH-03	Y	Y	Y	Y	N	N	N	NA	NA	
04	Water Fountain	Bubbler by Principal's Office	HH-04	Y	N	N	N	N	N	N	NA	NA	
05	Sink	Main Office Faucet	HH-05	Y	N	Y	Y	Y	N	N	NA	NA	
06	Sink	Bathroom Sink, Left Side	HH-06	Y	N	N	N	Y	N	N	NA	NA	

<sup>1</sup> Number outlets starting at the closest outlet to the Point of Entry (POE).

<sup>2</sup> Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

<sup>3</sup> Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

<sup>4</sup> Document on Attachment D- Filter Inventory.

07	Sink	Bathroom Sink, Right Side	HH-07	Y	N	N	N	Y	N	N	NA	NA	
08	Sink	Lunchroom Faucet	HH-08	Y	N	N	N	N	N	N	NA	NA	
09	Water Fountain	Left Bubbler by Lunchroom	HH-09	Y	N	N	N	N	N	N	NA	NA	
10	Water Fountain	Right Bubbler by Lunchroom	HH-10	Y	N	N	N	N	N	N	NA	NA	
11	Sink	Pre-K Room 108 Sink	HH-11	Y	N	N	N	Y	N	N	NA	NA	
12	Sink	Pre-K Room 108 Bathroom Sink	HH-12	Y	N	Y	N	Y	N	N	NA	NA	
13	Sink	Pre-K Room 107 Sink	HH-13	Y	N	N	N	Y	N	N	NA	NA	
14	Sink	Pre-K 107 Bathroom Sink	HH-14	Y	N	Y	N	Y	N	N	NA	NA	
15	Sink	Pre-K Room 106 Bathroom Sink	HH-15	Y	N	Y	N	Y	N	N	NA	NA	
16	Water Fountain	Left Bubbler by Room 201	HH-16	Y	N	Y	N	N	N	N	NA	NA	
17	Water Fountain	Right Bubbler by Room 201	HH-17	Y	N	Y	N	N	N	N	NA	NA	
18	<b>Sink</b>	<b>Library Faucet</b>	<b>HH-18</b>	<b>N</b>	<b>NA</b>	<b>NA</b>	<b>Permanently Removed</b>						
19	Sink	Faculty Room Faucet	HH-19	Y	N	Y	N	Y	N	N	NA	NA	
20	Water Fountain	Bubbler Across from Nurse's Office	HH-20	N	N	Y	N	N	N	N	NA	NA	Out of Order
21	Sink	Nurse's Office Faucet	HH-21	N	N	Y	N	Y	N	N	NA	NA	Out of Order
22	Water Fountain	Bubbler by Room 21	HH-22	Y	N	Y	N	N	N	N	NA	NA	
23	Water Fountain	Left Bubbler by Room 20	HH-23	Y	N	Y	N	N	N	N	NA	NA	

24	Water Fountain	Right Bubbler by Room 20	HH-24	N	N	Y	N	N	N	N	NA	NA	Out of Order
25	Water Fountain	Copy Room Bubbler	HH-25	Y	N	N	N	N	N	N	NA	NA	
26	Sink	Copy Room Sink	HH-26	Y	N	N	N	Y	N	N	NA	NA	
27	Water Fountain	Bubbler by 302, Left Side	HH-27	Y	N	Y	N	N	N	N	NA	NA	
28	Water Fountain	Bubbler by 302, Right Side	HH-28	Y	Y	N	N	N	N	N	NA	NA	
29	Water Fountain	Bubbler Across Room 37	HH-29	Y	N	Y	N	N	N	N	NA	NA	
30	Water Fountain	Bubbler by Room 31, Left Side	HH-30	Y	N	Y	N	N	N	N	NA	NA	
31	Water Fountain	Bubbler by Room 31, Right Side	HH-31	Y	N	Y	N	N	N	N	NA	NA	
32	Chiller	Chiller by Room 306	HH-32	N	N	Y	N	N	N	N	NA	NA	Out of Order
33	Water Fountain	Bubbler Between 306 and 307	HH-33	Y	N	Y	N	N	N	N	NA	NA	
34	Water Fountain	Sink Between 306 and 307	HH-34	Y	N	N	N	Y	N	N	NA	NA	

<sup>1</sup> Number outlets starting at the closest outlet to the Point of Entry (POE).

<sup>1</sup> Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

<sup>1</sup> Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

<sup>1</sup> Document on Attachment D- Filter Inventory.

### Attachment D - Filter Inventory

Name of School: Henry Harris Community School      Grade Levels: Elementary School

Address: 135 Avenue C, Bayonne, New Jersey 07002

Individual School Project Officer: Scott Nolan

Date: 09/05/2025

Sample Location / Code	Brand	Type (Make & Model)	Date Installed or Replaced	Replacement Frequency	NSF Certified for Lead Reduction Y/N
HH-01	American Standard	N/A	N/A	N/A	N/A
HH-02	American Standard	N/A	N/A	N/A	N/A
HH-03	Halsey T.	N/A	1935	N/A	N/A
HH-04	N/A	N/A	N/A	N/A	N/A
HH-05	3M Aqua Pure	AP200	8/4/2025	N/A	N/A
HH-06	N/A	N/A	N/A	N/A	N/A
HH-07	N/A	N/A	N/A	N/A	N/A
HH-08	N/A	N/A	N/A	N/A	N/A
HH-09	Halsey T.	N/A	1935	N/A	N/A
HH-10	Halsey T.	N/A	1935	N/A	N/A
HH-11	N/A	N/A	N/A	N/A	N/A
HH-12	N/A	N/A	N/A	N/A	N/A
HH-13	N/A	N/A	N/A	N/A	N/A
HH-14	Gerber	N/A	N/A	N/A	N/A
HH-15	American Standard	N/A	N/A	N/A	N/A
HH-16	American Standard	N/A	1935	N/A	N/A
HH-17	American Standard	N/A	1935	N/A	N/A
HH-18	PERMANENTLY REMOVED				
HH-19	Elkay	N/A	N/A	N/A	N/A
HH-20	OUT OF ORDER				
HH-21	OUT OF ORDER				
HH-22	Halsey T.	N/A	1935	N/A	N/A

HH-23	Halsey T.	N/A	1935	N/A	N/A
HH-24	OUT OF ORDER				
HH-25	N/A	N/A	N/A	N/A	N/A
HH-26	N/A	N/A	N/A	N/A	N/A
HH-27	Elkay	N/A	N/A	N/A	N/A
HH-28	American Standard	N/A	N/A	N/A	N/A
HH-29	Halsey T.	N/A	1935	N/A	N/A
HH-30	American Standard	AP200	N/A	N/A	N/A
HH-31	American Standard	AP200	N/A	N/A	N/A
HH-32	OUT OF ORDER				
HH-33	N/A	N/A	N/A	N/A	N/A
HH-34	N/A	N/A	N/A	N/A	N/A

**Attachment E – Flushing Log**

Name of School: Henry Harris Community School

Address: 135 Avenue C, Bayonne, New Jersey 07002

Grade Levels: Elementary School

Individual School Project Officer: Scott Nolan

Date: 09/05/2025

Sample Location Description	Sample Location Code	Date	Time	Duration of Flushing	Reason for Flushing
Right Bubbler by Room 102	HH-01	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Right Bubbler by Room 102	HH-02	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Left Bubbler by Room 102	HH-03	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Principal's Office	HH-04	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Main Office Faucet	HH-05	August 22, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bathroom Sink, Left Side	HH-06	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bathroom Sink, Right Side	HH-07	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Lunchroom Faucet	HH-08	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Left Bubbler by Lunchroom	HH-09	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Right Bubbler by Lunchroom	HH-10	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Pre-K Room 108 Sink	HH-11	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Pre-K Room 108 Bathroom Sink	HH-12	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Pre-K Room 107 Sink	HH-13	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Pre-K 107 Bathroom Sink	HH-14	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Pre-K Room 106 Bathroom Sink	HH-15	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Left Bubbler by Room 201	HH-16	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Right Bubbler by Room 201	HH-17	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
<b>Library Faucet</b>	<b>HH-18</b>	<b>August 23, 2025</b>	<b>PERMANENTLY REMOVED</b>		
Faculty Room Faucet	HH-19	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Across from Nurse's Office	HH-20	June 21, 2025	OUT OF ORDER		

Bayonne County: Sampling Plan

Nurse's Office Faucet	HH-21	June 21, 2025	OUT OF ORDER		
Bubbler by Room 21	HH-22	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Left Bubbler by Room 20	HH-23	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Right Bubbler by Room 20	HH-24	June 21, 2025	OUT OF ORDER		
Copy Room Bubbler	HH-25	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Copy Room Sink	HH-26	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by 302, Left Side	HH-27	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by 302, Right Side	HH-28	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler Across Room 37	HH-29	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Room 31, Left Side	HH-30	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Room 31, Right Side	HH-31	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Chiller by Room 306	HH-32	June 21, 2025	OUT OF ORDER		
Bubbler Between 306 and 307	HH-33	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling
Sink Between 306 and 307	HH-34	June 21, 2025	5:30 pm	2-3 Minutes	Water Sampling

## Attachment F - Pre - Sampling Water Use Certification

TO BE COMPLETED BY THE BAYONNE BOE DISTRICT REPRESENTATIVE:		
School Name:	<u>Henry Harris Community</u>	
<u>School</u>		
Sample collection address:	<u>135 Avenue C, Bayonne, New Jersey 07002</u>	
Water was last used:	<u>Time: 5:30 pm</u>	<u>Date: June 20, 2025</u>
Sample commencement:	<u>Time: 7:10 am</u>	<u>Date: June 21, 2025</u>
I have read the Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.		
Scott Nolan	<u>07/22/2025</u>	
Signature	Date	

## Attachment F - Pre - Sampling Water Use Certification

TO BE COMPLETED BY THE BAYONNE BOE DISTRICT REPRESENTATIVE:		
School Name:	<u>Henry Harris Community</u>	
<u>School</u>		
Sample collection address:	135 Avenue C, Bayonne, New Jersey 07002	
Water was last used:	Time: 5:30 pm	Date: August 22, 2025
Sample commencement:	Time: 8:39 am	Date: August 23, 2025
I have read the Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.		
Scott Nolan	09/05/2025	
Signature	Date	