



464 Valley Brook Avenue, Lyndhurst NJ 07071
129 Sea Girt Avenue, Manasquan NJ 08736
Phone: (800) 423-0766 • Fax: (201) 438-1798
www.mccabeenv.com

LEAD IN DRINKING WATER TESTING REPORT

Conducted for:

Bayonne Board of Education
669 Avenue A
Bayonne, New Jersey 07002

Conducted at:

Washington Community School
191 Avenue B
Bayonne, New Jersey 07002

Submitted by:

McCabe Environmental Services, L.L.C.
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

REPORT DATE: September 8, 2025

MES PROJECT NO.: 25-05225

Prepared by:

A handwritten signature in blue ink, appearing to read 'Arlitzzy Lezama'.

Arlitzzy Lezama
Environmental Scientist

Signed for the Company by:

A handwritten signature in blue ink, appearing to read 'John H. Chiaviello'.

John H. Chiaviello
Vice President

TABLE OF CONTENTS

	Page
1.0 INTRODUCTION	1
2.0 SCOPE OF WORK.....	1
3.0 PROCEDURES.....	1
4.0 TABLE OF SAMPLE RESULTS	2
5.0 DISCUSSION AND CONCLUSION	3

APPENDIX A

Laboratory Certificates of Analysis
&
Sample Chain of Custody Forms

APPENDIX B

School District Sampling Attachments

1.0 INTRODUCTION

McCabe Environmental Services, L.L.C. (McCabe) was retained by Bayonne Board of Education (Client) to conduct lead in drinking water testing at the Washington Community School located at 191 Avenue B, Bayonne, New Jersey.

The project information is as follows:

<u>Client Name:</u>	Bayonne Board of Education
<u>Contact Person:</u>	Mr. Daniel Castles
<u>Project Name:</u>	Washington Community School – Lead in Drinking Water
<u>Project Location:</u>	191 Avenue B Bayonne, New Jersey 07002
<u>Date(s) of Service:</u>	June 21, 2025 and August 23, 2025
<u>McCabe Personnel:</u>	Gary Clare, Kevin Brossok & Arllitzy Lezama

2.0 SCOPE OF WORK

Drinking water testing was performed at the Washington Community School located at 191 Avenue B, Bayonne, New Jersey on June 21, 2025. The purpose of the testing was to determine if the building’s plumbing was having an adverse impact on water quality, specifically with regard to lead concentrations. Samples were collected from various potential drinking water outlets located throughout the building. Follow-up drinking water testing was then performed at the failed locations throughout Washington Community School on August 23, 2025. The failed locations were re-sampled with a first draw sample and immediately followed up with a thirty (30) second flush sample. Samples were collected from areas that exceeded the regulatory standards on June 21, 2025. Testing was followed as per past reports provided by Bayonne Board of Education.

3.0 PROCEDURES

After determining which outlets would be sampled, McCabe personnel collected a "first draw" sample at each location. A "first draw" is the initial water that is first to come out of the tap after a period of inactivity. Following the “first draw”, a "30 second flush" sample was also collected where the main service line comes into the building. All samples were collected into 250 mL sterile bottles, labeled with a sample identification, and analyzed in accordance with EPA approved methods to determine the level of lead in drinking water. Samples were analyzed by an accredited laboratory.

The U.S. Environmental Protection Agency (EPA) has established National Primary Drinking Water Regulations (NPDWR) that set mandatory water quality standards for drinking water contaminants. These are enforceable standards called "maximum contaminant levels" or "MCL", which are established to protect the public against consumption of drinking water contaminants that present a risk to human health. An MCL is the maximum allowable amount of a contaminant in drinking water which is delivered to the consumer.

The EPA has established the Lead and Copper Rule that sets standards for state and public water systems. This rule has set an MCL for lead at 15 parts per billion (ppb) for a one liter sample. However, the EPA also established the Lead in Drinking Water at Schools and Child Care Facilities in which the EPA recommends an MCL of 20 ppb for

a 250 milliliter first draw sample. In order to be more stringent, for our report purposes we have compared all results to both the 15 ppb and the 20 ppb standards.

4.0 TABLE OF SAMPLE RESULTS

The following table presents all sample results in order of sample identification conducted on June 21, 2025:

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
WC-01	First Draw – Room 114 Faucet	1.9	Pass	Pass
WC-02	30 Second Flush – Room 114 Faucet	< 1	Pass	Pass
WC-03	First Draw – Room 114A Sink	1.3	Pass	Pass
WC-04	First Draw – Café Faucet	45.1	Fail	Fail
WC-05	First Draw – 113A Faucet	40.4	Fail	Fail
WC-06	First Draw – Bottle Filler by Room 113	< 1	Pass	Pass
WC-07	First Draw – Vice Principal’s Office Sink	19.5	Fail	Pass
WC-08	First Draw – Main Office Faucet	2.5	Pass	Pass
WC-09	First Draw – Room 105 Faucet	8.9	Pass	Pass
WC-10	First Draw – Room 104 Faucet - Art	8.1	Pass	Pass
WC-11	First Draw – Room 101 Bubbler	PERMANENTLY REMOVED		
WC-12	First Draw – Room 101 Faucet	2.2	Pass	Pass
WC-13	First Draw – Bottle Filler by Room 101	< 1	Pass	Pass
WC-14	First Draw – Room 100 Faucet	< 1	Pass	Pass
WC-15	Frist Draw – Room 214 Bubbler	< 1	Pass	Pass
WC-16	First Draw – Room 214 Sink	1.3	Pass	Pass
WC-17	First Draw – Bottle Filler by Room 212	< 1	Pass	Pass
WC-18	First Draw – Room 211 Faucet – Life Skills Room	1.9	Pass	Pass
WC-19	First Draw – Nurse’s Office Faucet	4.5	Pass	Pass

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
WC-20	First Draw – Bubblers by Room 201A	< 1	Pass	Pass
WC-21	First Draw – Faculty Room Faucet	2.2	Pass	Pass
WC-22	First Draw – Room 316 Bubblers	< 1	Pass	Pass
WC-23	First Draw – Room 316 Faucet	< 1	Pass	Pass
WC-24	First Draw – Bottle Filler by Room 314	< 1	Pass	Pass
WC-25	First Draw – Bottle Filler by Room 302	< 1	Pass	Pass
WC-26	First Draw – Room 300 Bubblers	1.3	Pass	Pass
WC-27	First Draw – Room 300 Faucet	2.2	Pass	Pass

The following table presents all sample results in order of sample identification from the follow-up lead in drinking water testing conducted on August 23, 2025:

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
WC-04-A	First Draw – Café Faucet	3.6	Pass	Pass
WC-04-B	30 Second Flush – Café Faucet	< 0.5	Pass	Pass
WC-05-A	First Draw – 113A Faucet	0.8	Pass	Pass
WC-05-B	30 Second Flush – 113A Faucet	< 0.5	Pass	Pass
WC-07-A	First Draw – Vice Principal’s Office Sink	2.3	Pass	Pass
WC-07-B	30 Second Flush – Vice Principal’s Office Sink	< 0.5	Pass	Pass

5.0 DISCUSSION AND CONCLUSION

A total of twenty-six (26) samples were collected from the Washington Community School. Three (3) sample was found to be greater than the EPA Lead and Copper Rule standard of 15 ppb and two (2) of those samples were greater than the EPA Lead in Drinking Water at Schools and Child Care Facilities standard of 20 ppb. All other samples were found to be less than the EPA standards of 20 ppb and 15 ppb.

As a follow-up to drinking water testing conducted on June 21, 2025, McCabe conducted a follow-up testing August 23, 2025. A total of six (6) samples were collected from Washington Community School located at 191 Avenue B, Bayonne, New Jersey 07002. All samples taken during the follow-up inspection were below the regulatory standard.

In addition, McCabe Environmental recommends annual drinking water sampling to ensure that the building's plumbing is not having an adverse impact on water quality.

APPENDIX A

**LABORATORY CERTIFICATES OF ANALYSIS
&
SAMPLE CHAIN OF CUSTODY FORMS**



Thursday, July 03, 2025

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
SDG ID: GCT58172
Sample ID#s: CT58172 - CT58197

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller
Laboratory Director

NELAC - #NY11301
CT Lab Registration #PH-0618
MA Lab Registration #M-CT007
ME Lab Registration #CT-007
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003
NY Lab Registration #11301
PA Lab Registration #68-03530
RI Lab Registration #63
VT Lab Registration #VT11301



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Sample Id Cross Reference

July 03, 2025

SDG I.D.: GCT58172

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION

Client Id	Lab Id	Matrix	Col Date
WC-01	CT58172	DRINKING WATER	06/21/25 10:05
WC-02	CT58173	DRINKING WATER	06/21/25 10:06
WC-03	CT58174	DRINKING WATER	06/21/25 10:08
WC-04	CT58175	DRINKING WATER	06/21/25 10:09
WC-05	CT58176	DRINKING WATER	06/21/25 10:10
WC-06	CT58177	DRINKING WATER	06/21/25 10:11
WC-07	CT58178	DRINKING WATER	06/21/25 10:12
WC-08	CT58179	DRINKING WATER	06/21/25 10:13
WC-09	CT58180	DRINKING WATER	06/21/25 10:15
WC-10	CT58181	DRINKING WATER	06/21/25 10:16
WC-12	CT58182	DRINKING WATER	06/21/25 10:18
WC-13	CT58183	DRINKING WATER	06/21/25 10:19
WC-14	CT58184	DRINKING WATER	06/21/25 10:20
WC-15	CT58185	DRINKING WATER	06/21/25 10:25
WC-16	CT58186	DRINKING WATER	06/21/25 10:25
WC-17	CT58187	DRINKING WATER	06/21/25 10:26
WC-18	CT58188	DRINKING WATER	06/21/25 10:27
WC-19	CT58189	DRINKING WATER	06/21/25 10:29
WC-20	CT58190	DRINKING WATER	06/21/25 10:32
WC-21	CT58191	DRINKING WATER	06/21/25 10:33
WC-22	CT58192	DRINKING WATER	06/21/25 10:37
WC-23	CT58193	DRINKING WATER	06/21/25 10:38
WC-24	CT58194	DRINKING WATER	06/21/25 10:39
WC-25	CT58195	DRINKING WATER	06/21/25 10:41
WC-26	CT58196	DRINKING WATER	06/21/25 10:44
WC-27	CT58197	DRINKING WATER	06/21/25 10:44



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:05
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58172

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-01

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.9	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/27/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:06
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58173

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-02

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/27/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:08
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58174

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-03

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.3	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/27/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:09
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58175

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-04

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	45.1	1	1	ppb	15			06/30/25	CPP	E200.5
*** Lead exceeds Action Level of 15 ***										
Total Metal Digestion	Completed							06/27/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director
 July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:10
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58176

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-05

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	40.4	1	1	ppb	15			06/30/25	CPP	E200.5
*** Lead exceeds Action Level of 15 ***										
Total Metal Digestion	Completed							06/27/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director
 July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:11
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58177

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-06

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/27/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:12
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58178

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-07

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	19.5	1	1	ppb	15			06/30/25	CPP	E200.5
*** Lead exceeds Action Level of 15 ***										
Total Metal Digestion	Completed							06/27/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director
 July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:13
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58179

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-08

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2.5	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/27/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:15
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58180

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-09

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	8.9	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/27/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:16
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58181

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-10

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	8.1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/27/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:18
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58182

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-12

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2.2	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/27/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:19
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58183

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-13

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/27/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:20
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58184

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-14

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:25
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58185

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-15

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:25
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58186

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-16

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.3	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:26
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58187

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-17

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:27
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58188

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-18

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.9	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:29
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58189

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-19

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	4.5	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:32
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58190

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-20

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:33
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58191

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-21

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2.2	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:37
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58192

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-22

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:38
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58193

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-23

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:39
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58194

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-24

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:41
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58195

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-25

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 1	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:44
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58196

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-26

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.3	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

July 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: AL, GC, KB
 Received by: CP
 Analyzed by: see "By" below

Date

06/21/25
 06/23/25

Time

10:44
 16:20

Laboratory Data

SDG ID: GCT58172
 Phoenix ID: CT58197

Project ID: 25-05225 BAYONNE BOARD OF EDUCATION
 Client ID: WC-27

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2.2	1	1	ppb	15			06/30/25	CPP	E200.5
Total Metal Digestion	Completed							06/28/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

July 03, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager

Analysis Report - Summary

July 03, 2025

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

SDG I.D.: GCT58172



Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
Project: 25-05225 Bayonne Board Of Education								
CT58172	WC-01	06/21/25	Lead	1.9	1	ppb	06/30/25	E200.5
CT58173	WC-02	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58174	WC-03	06/21/25	Lead	1.3	1	ppb	06/30/25	E200.5
CT58175	WC-04	06/21/25	Lead	45.1	1	ppb	06/30/25	E200.5
CT58176	WC-05	06/21/25	Lead	40.4	1	ppb	06/30/25	E200.5
CT58177	WC-06	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58178	WC-07	06/21/25	Lead	19.5	1	ppb	06/30/25	E200.5
CT58179	WC-08	06/21/25	Lead	2.5	1	ppb	06/30/25	E200.5
CT58180	WC-09	06/21/25	Lead	8.9	1	ppb	06/30/25	E200.5
CT58181	WC-10	06/21/25	Lead	8.1	1	ppb	06/30/25	E200.5
CT58182	WC-12	06/21/25	Lead	2.2	1	ppb	06/30/25	E200.5
CT58183	WC-13	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58184	WC-14	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58185	WC-15	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58186	WC-16	06/21/25	Lead	1.3	1	ppb	06/30/25	E200.5
CT58187	WC-17	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58188	WC-18	06/21/25	Lead	1.9	1	ppb	06/30/25	E200.5
CT58189	WC-19	06/21/25	Lead	4.5	1	ppb	06/30/25	E200.5
CT58190	WC-20	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58191	WC-21	06/21/25	Lead	2.2	1	ppb	06/30/25	E200.5
CT58192	WC-22	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58193	WC-23	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58194	WC-24	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58195	WC-25	06/21/25	Lead	< 1	1	ppb	06/30/25	E200.5
CT58196	WC-26	06/21/25	Lead	1.3	1	ppb	06/30/25	E200.5

Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
CT58197	WC-27	06/21/25	Lead	2.2	1	ppb	06/30/25	E200.5

Comments:

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

ND=Not detected BDL=Below Detection Level RL=Reporting Level CL=Client Limit



Phyllis Shiller
Laboratory Director

July 03, 2025



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



QA/QC Report

July 03, 2025

QA/QC Data

SDG I.D.: GCT58172

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	--------	---------------	------------	---------	-------	--------	---------	------	-------	--------	--------------	--------------

QA/QC Batch 791249 (mg/L), QC Sample No: CT58164 (CT58172, CT58173)

ICP Metals - Aqueous

Lead	BRL	0.0010	0.0018	0.0019	NC	105			105			85 - 115	20
------	-----	--------	--------	--------	----	-----	--	--	-----	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 791249A (mg/L), QC Sample No: CT58174 (CT58174, CT58175, CT58176, CT58177, CT58178, CT58179, CT58180, CT58181, CT58182, CT58183)

ICP Metals - Aqueous

Lead	BRL	0.0010				105			104			85 - 115	20
------	-----	--------	--	--	--	-----	--	--	-----	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 791296 (mg/L), QC Sample No: CT58184 (CT58184, CT58185, CT58186, CT58187, CT58188, CT58189, CT58190, CT58191, CT58192, CT58193)

ICP Metals - Aqueous

Lead	BRL	0.0010	<0.0010	0.0013	NC	104			106			85 - 115	20
------	-----	--------	---------	--------	----	-----	--	--	-----	--	--	----------	----

Comment:

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

QA/QC Batch 791296A (mg/L), QC Sample No: CT58194 (CT58194, CT58195, CT58196, CT58197)

ICP Metals - Aqueous

Lead	BRL	0.0010				104			107			85 - 115	20
------	-----	--------	--	--	--	-----	--	--	-----	--	--	----------	----

Comment:

This batch does not include a duplicate.

Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Inf - Interference
- (ISO) - Isotope Dilution


Phyllis Shiller, Laboratory Director
July 03, 2025

Thursday, July 03, 2025

Criteria: NJ: DW

State: NJ

Sample Criteria Exceedances Report

GCT58172 - MCCABE-PB

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
CT58175	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	45.1	1	15	1	ppb
CT58176	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	40.4	1	15	1	ppb
CT58178	PB-DWICP	Lead	EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs	19.5	1	15	1	ppb

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedances. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedance information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Comments

July 03, 2025

SDG I.D.: GCT58172

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

2.2" WCIP

MCCABE ENVIRONMENTAL SERVICES, L.L.C.
 464 VALLEY BROOK AVENUE LYNDDHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER
 CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education
 SITE ADDRESS: Washington Community School
 191 Avenue B, Bayonne, NJ 07002

FIELD INSPECTOR'S NAME: *Alexandra G. Glave, K. Brassoak*
 MES PROJECT #: 25-05225
 SAMPLE DATE: *6/2/25*
 TURNAROUND TIME REQUESTED: 2-Week

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED	
DW	WC-01	FD - Rm 114 Faucet	10:05 AM	LEAD - 200.8	58172
DW	WC-02	30 second flush - Rm 114 faucet	10:06 AM	LEAD - 200.8	58173
DW	WC-03	FD - Rm 114A sink	10:08 AM	LEAD - 200.8	58174
DW	WC-04	FD - Cante faucet	10:09 AM	LEAD - 200.8	58175
DW	WC-05	FD - 113A faucet	10:10 AM	LEAD - 200.8	58176
DW	WC-06	FD - Bottle filler by Room 113	10:11 AM	LEAD - 200.8	58177
DW	WC-07	FD - Vice Principal's office sink	10:12 AM	LEAD - 200.8	58178
DW	WC-08	FD - Main office faucet	10:13 AM	LEAD - 200.8	58179
DW	WC-09	FD - Room 105 faucet	10:15 AM	LEAD - 200.8	58180
DW	WC-10	FD - Room 104 faucet - Art	10:16 AM	LEAD - 200.8	58181

Relinquished by (Print) *Devine Babean* Date: *6/2/25* Time: *1015*
 Signature: *Devine Babean* Received by: (Print) *J. Demers* Signature: *J.D.* Date: *8.23.2025* Time: *1015*

Relinquished by (Print) *[Signature]* Date: *6/23/25* Time: *1620*
 Signature: *[Signature]* Received by: (Print) *Abby Lee* Signature: *Abby Lee* Date: *6/23/25* Time: *1620*

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): *[Signature]* Phoenix Environmental Laboratories

2.2.15 WCIIP

MCCABE ENVIRONMENTAL SERVICES, L.L.C.
 464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER
 CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education		SITE ADDRESS: Washington Community School 191 Avenue B, Bayonne, NJ 07002	
FIELD INSPECTOR'S NAME: A. J. Lituma, G. Clark, K. Brusseick		TURNAROUND TIME REQUESTED: 2-Week	
MES PROJECT #: 25-05225		SAMPLE DATE: 6/21/25	
Matrix	SAMPLE ID	SAMPLE LOCATION	ANALYSIS REQUESTED
DW	WC-12	FD-Room 101 faucet	LEAD - 200.8
DW	WC-13	FD-Bottle filler by Room 101	LEAD - 200.8
DW	WC-14	FD-Room 100 faucet	LEAD - 200.8
DW	WC-15	FD-Room 214 bubbler	LEAD - 200.8
DW	WC-16	FD-Room 214 faucet	LEAD - 200.8
DW	WC-17	FD-Bottle filler by Room 212	LEAD - 200.8
DW	WC-18	FD-Room 211 faucet - life skills room	LEAD - 200.8
DW	WC-19	FD-Nurse's Office faucet	LEAD - 200.8
DW	WC-20	FD-Bottle filler by Room 201A	LEAD - 200.8
DW	WC-21	FD-Faculty Room faucet	LEAD - 200.8
Relinquished by (Print) Denis Bibeau		Received by: (Print) J. Dennis	Date: 6-23-2025
Signature: Denis Bibeau		Signature: [Signature]	Time: 1015
Relinquished by (Print)		Received by: (Print) Abby Lee	Date: 6/23/25
Signature: [Signature]		Signature: Abby Lee	Time: 1620
Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories			

58182
58183
58184
58185
58186
58187
58188
58189
58190
58191

NJ Certified WBE

MCCABE ENVIRONMENTAL SERVICES, L.L.C.
 464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER
 CHAIN-OF-CUSTODY FORM

CLIENT NAME: Bayonne Board of Education
 FIELD INSPECTOR'S NAME: A. Letzama, G. Glave, & K. Prossok
 MES PROJECT #: 25-05225
 SAMPLE DATE: 6/21/25
 SITE ADDRESS: Washington Community School
 191 Avenue B, Bayonne, NJ 07002
 TURNAROUND TIME REQUESTED: 2-Week

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED	
DW	WC-22	FD- Room 316 bubbler	10:37 AM	LEAD - 200.8	58192
DW	WC-23	FD- Room 316 faucet	10:38 AM	LEAD - 200.8	58193
DW	WC-24	FD- Bottle filler by Room 314	10:39 AM	LEAD - 200.8	58194
DW	WC-25	FD- Bottle filler by Room 302	10:41 AM	LEAD - 200.8	58195
DW	WC-26	FD- Room 300 bubbler	10:44 AM	LEAD - 200.8	58196
DW	WC-27	FD- Room 300 faucet	10:44 AM	LEAD - 200.8	58197
DW				LEAD - 200.8	
DW				LEAD - 200.8	
DW				LEAD - 200.8	
DW				LEAD - 200.8	

Relinquished by (Print) Denise Bibeau
 Signature: Denise Bibeau
 Date: 6/23/25
 Time: 1015
 Received by: (Print) J. Demers
 Signature: J. Demers
 Date: 8-23-2025
 Time: 1045

Relinquished by (Print) [Signature]
 Signature: [Signature]
 Date: [Blank]
 Time: [Blank]

Received by: (Print) Abby Lee
 Signature: Abby Lee
 Date: 6/23/25
 Time: 1620

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories



Wednesday, September 03, 2025

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION
SDG ID: GCU09445
Sample ID#s: CU09445 - CU09450

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Phyllis Shiller".

Phyllis Shiller
Laboratory Director

NELAC - #NY11301
CT Lab Registration #PH-0618
MA Lab Registration #M-CT007
ME Lab Registration #CT-007
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003
NY Lab Registration #11301
PA Lab Registration #68-03530
RI Lab Registration #63
VT Lab Registration #VT11301



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Sample Id Cross Reference

September 03, 2025

SDG I.D.: GCU09445

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION

Client Id	Lab Id	Matrix	Col Date
WC-04-A	CU09445	DRINKING WATER	08/23/25 7:14
WC-04-B	CU09446	DRINKING WATER	08/23/25 7:15
WC-05-A	CU09447	DRINKING WATER	08/23/25 7:17
WC-05-B	CU09448	DRINKING WATER	08/23/25 7:18
WC-07-A	CU09449	DRINKING WATER	08/23/25 7:20
WC-07-B	CU09450	DRINKING WATER	08/23/25 7:21



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

September 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/25
 08/25/25

Time

7:14
 19:05

Laboratory Data

SDG ID: GCU09445
 Phoenix ID: CU09445

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION
 Client ID: WC-04-A

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	3.6	0.5	2	ppb	15			08/28/25	CPP	E200.8
Total Metal Digestion	Completed							08/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

September 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/25
 08/25/25

Time

7:15
 19:05

Laboratory Data

SDG ID: GCU09445
 Phoenix ID: CU09446

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION
 Client ID: WC-04-B

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			08/28/25	CPP	E200.8
Total Metal Digestion	Completed							08/26/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

September 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/25
 08/25/25

Time

7:17
 19:05

Laboratory Data

SDG ID: GCU09445
 Phoenix ID: CU09447

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION
 Client ID: WC-05-A

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.8	0.5	2	ppb	15			09/02/25	CPP	E200.8
Total Metal Digestion	Completed							08/30/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

September 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/25
 08/25/25

Time

7:18
 19:05

Laboratory Data

SDG ID: GCU09445
 Phoenix ID: CU09448

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION
 Client ID: WC-05-B

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			09/02/25	CPP	E200.8
Total Metal Digestion	Completed							08/30/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 September 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/25
 08/25/25

Time

7:20
 19:05

Laboratory Data

SDG ID: GCU09445
 Phoenix ID: CU09449

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION
 Client ID: WC-07-A

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2.3	0.5	2	ppb	15			09/02/25	CPP	E200.8
Total Metal Digestion	Completed							08/30/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report

September 03, 2025

FOR: Attn: Jarred Panecki
 McCabe Environmental Services, LLC
 464 Valley Brook Avenue
 Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
 Location Code: MCCABE-PB
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

08/23/25
 08/25/25

Time

7:21
 19:05

Laboratory Data

SDG ID: GCU09445
 Phoenix ID: CU09450

Project ID: 25-05225-1 BAYONNE BOARD OF EDUCATION
 Client ID: WC-07-B

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			09/02/25	CPP	E200.8
Total Metal Digestion	Completed							08/30/25	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 03, 2025

Reviewed and Released by: Rashmi Makol, Project Manager

Analysis Report - Summary

September 03, 2025

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

SDG I.D.: GCU09445



Sample	Client Id	Col Date	Parameter	Result	RL	CL	Units	Date Analyzed	Reference
Project: 25-05225-1 Bayonne Board Of Education									
CU09445	WC-04-A	08/23/25	Lead	3.6	0.5		ppb	08/28/25	E200.8
CU09446	WC-04-B	08/23/25	Lead	< 0.5	0.5		ppb	08/28/25	E200.8
CU09447	WC-05-A	08/23/25	Lead	0.8	0.5		ppb	09/02/25	E200.8
CU09448	WC-05-B	08/23/25	Lead	< 0.5	0.5		ppb	09/02/25	E200.8
CU09449	WC-07-A	08/23/25	Lead	2.3	0.5		ppb	09/02/25	E200.8
CU09450	WC-07-B	08/23/25	Lead	< 0.5	0.5		ppb	09/02/25	E200.8

Comments:

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.
ND=Not detected BDL=Below Detection Level RL=Reporting Level CL=Client Limit


Phyllis Shiller
Laboratory Director
September 03, 2025



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



QA/QC Report

September 03, 2025

QA/QC Data

SDG I.D.: GCU09445

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	-----------	------------------	---------------	------------	----------	-----------	------------	---------	----------	-----------	--------------------	--------------------

QA/QC Batch 800107A (mg/L), QC Sample No: CU08552 (CU09445, CU09446)

ICP MS Metals - Aqueous

Lead	BRL	0.0001				100						94.4	
------	-----	--------	--	--	--	-----	--	--	--	--	--	------	--

Comment:

This batch does not include a duplicate.


QA/QC Batch 800979 (mg/L), QC Sample No: CU09447 (CU09447, CU09448, CU09449, CU09450)

ICP MS Metals - Aqueous

Lead	BRL	0.0001	0.0008	0.0007	NC	104						101	
------	-----	--------	--------	--------	----	-----	--	--	--	--	--	-----	--

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference
- (ISO) - Isotope Dilution


 Phyllis Shiller, Laboratory Director
 September 03, 2025

Wednesday, September 03, 2025

Criteria: NJ: DW

State: NJ

Sample Criteria Exceedances Report

GCU09445 - MCCABE-PB

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

*** No Data to Display ***

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Comments

September 03, 2025

SDG I.D.: GCU09445

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

MCCABE ENVIRONMENTAL SERVICES, L.L.C.

464 VALLEY BROOK AVENUE LYNDBURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER

CHAIN-OF-CUSTODY FORM

1.1 WJF

CLIENT NAME: Bayonne Board of Education		SITE ADDRESS: Washington Community School 191 Avenue B, Bayonne, NJ 07002		
FIELD INSPECTOR'S NAME: A. Iezuma		TURNAROUND TIME REQUESTED: 2-Week		
MES PROJECT #: 25-05225 - 1	SAMPLE DATE: 8/23/25			
Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	09445 WC-04-A	FD - Cafe faucet	7:14 AM	LEAD - 200.8
DW	09446 WC-04-B	30 sec. flush - Cafe faucet	7:15 AM	LEAD - 200.8
DW	09447 WC-05-A	FD - 13A Faucet	7:17 AM	LEAD - 200.8
DW	09448 WC-05-B	30 sec. Flush - 13A faucet	7:18 AM	LEAD - 200.8
DW	09449 WC-07-A	FD - Vice Principal's office sink	7:20 AM	LEAD - 200.8
DW	09450 WC-07-B	30 sec. Flush - Vice Principal's office sink	7:21 AM	LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
DW				LEAD - 200.8
Relinquished by (Print) Arithya Iezuma		Date: 8/25/25	Time: 12:45	
Signature: <i>Arithya Iezuma</i>		Received by: (Print) J. Demers	Signature: <i>J. Demers</i>	Date: 8-25-2025
Relinquished by (Print)		Date:	Time:	
Signature: <i>[Signature]</i>		Received by: (Print) <i>[Signature]</i>	Signature: <i>[Signature]</i>	Date: 8/25/25
Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories		Signature: <i>[Signature]</i> 8/25/25 1905		

APPENDIX B

**SCHOOL DISTRICT SAMPLING
ATTACHMENTS**

Attachment A - List of Priority for Sampling

SCHOOL NAME	DATE OF SAMPLING	CERTIFIED LABORATORY	NOTES
Washington Community School	06/21/2025	Phoenix Environmental Laboratories Inc.	

Attachment A - List of Priority for Sampling

SCHOOL NAME	DATE OF SAMPLING	CERTIFIED LABORATORY	NOTES
Washington Community School	08/23/2025	Phoenix Environmental Laboratories Inc.	

Attachment B – Plumbing Profile

Note: Complete for each school. For additional information see the USEPA publication, “The 3Ts for Reducing Lead in Drinking Water in Schools”

Name of School: Washington Community School Grade Levels: K-8

Address: 191 Avenue B, Bayonne, NJ 07002

Individual school project officer Signature: *Scott Nelson* Date: 8/5/2025

Questions	Answers	
Background Information		
1. What year was the original building constructed? Were any buildings or additions added to the original facility?	K-8 Grade School Built in 1917 K-8 Grade School Addition in 2000	
2. If the building was constructed or repaired after 1986, was lead-free plumbing and solder utilized? What type of solder was used? Document all locations where lead solder was used.	Any repairs made after 1986 were done using lead free solder	
3. Where are the most recent plumbing repairs and replacements?	Location: New wing Pre-K	Description: New bathroom
4. With what materials is the service connection (the pipe that carries water to the school from the public water system’s main in the street) made? Where is the Service Line located? (This is the POE location.)	Material: Main Building - Duct Iron Location: The water main (48th St) enters the boys bathroom where the water meter is located and continues to the remainder of the building	
5. Is there point of entry (POE) or point of use (POU) treatment in use?	Y / N No treatment of water Type: at POE City water comes treated	Main Building 1917 Location:

Questions	Answers
<p>6. Are there tanks in your plumbing system (pressure tanks, gravity storage tanks)?</p>	<p>Y / N Yes Building has a 75 gallon hot water storage tank located in boiler room Building has a 38 gallon hot water storage tank new wing Building has a 38 gallon hot water storage tank nurse's office</p>
<p>7. Does the school have a filter maintenance and operation program? If so, who is responsible for this program? What is the process for adding filters?</p>	<p>Yes, Scott Nolan, Andy McCabe, Vinny Caiola, change filters on an as needed basis assign plumbers</p>
<p>8. Have accessible screens or aerators on outlets that provide drinking water been cleaned? Does the school have a screen or aerator maintenance program?</p>	<p>Y / N Yes The district has set-up a routine maintenance program to clean screens</p>
<p>9. Have there been any complaints about bad (metallic) taste? Note location(s).</p>	<p>Y / N NO Location:</p>
<p>10. Review records and consult with the public water supplier to determine whether any water samples have been taken in the building for any contaminants. If so, identify:</p> <ul style="list-style-type: none"> • Name of contaminant(s) • Concentrations found • pH level <p>Is testing done regularly at the building?</p>	<p>No indoor testing by public water supplier</p>
<p>11. Other plumbing background questions include:</p> <ul style="list-style-type: none"> • Are blueprints of the building available? • Are there known plumbing “dead-ends”, low use areas, existing leaks or other “problem areas”? <p>Are renovations planned for any of the plumbing system?</p>	<p>Not all prints are available No dead-end low areas All leaks were identified during walk through and have been repaired No plumbing system renovations</p>

Questions	Answers	
Walk-Through <i>These questions should be addressed during the walk-through of the facility, while Attachment C- Drinking Water Outlet Inventory is being completed.</i>		
1. Confirm the material of Service Line visually.	Duct iron	
2. Confirm the presence of POE or POU treatment.	No POE or POU treatment	
3. What are the potable water pipes made of in your facility? <ul style="list-style-type: none"> • Lead • Plastic • Galvanized Metal • Cast Iron • Copper • Other Note the water flow through the building and the areas that receive water first, and which areas receive water last.	Cooper Galvanized Metal Brass Water flow through the building shown on the prints	
4. Are electrical wires grounded to Water Pipes? Note location(s).	Y / N Location:	No No electrical wires grounded to water pipes
5. Are brass fittings, faucets, or valves used in your drinking water system? Note that most faucets are brass on the inside. Document the locations of any brass water outlet to be sampled.	Complete in "Brass" Column in Attachment C- Water Outlet Inventory. Yes Completed in Attachment C - Water Outlet Inventory	
6. Locate all drinking water outlets (i.e. water coolers, bubblers, ice machines, kitchen/ food prep sinks, etc.) in the facility.	Complete in Attachment C-Water Outlet Inventory.	

Questions	Answers	
<p>7. Have the brands and models of the water coolers in the school been compared to the list of recalled water coolers in the Toolkit?</p> <p>Recalled Drinking Water Fountains</p> <p>Make and Model</p>	<p>Y / N Yes all water coolers have been checked and compared to the list of recalled water coolers</p> <p>Type None on the list of recalled water coolers</p>	
<p>8. Have signs of corrosion, such as frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry been detected?</p> <p>Note the locations of water outlets.</p>	<p>Complete in "Signs of Corrosion" column in Attachment C- Drinking Water Outlet Inventory.</p>	
<p>9. Are there any outlets that are not operational and therefore out of service? Permanently? Temporarily?</p> <p style="text-align: right;">Permanently</p> <p style="text-align: right;">Temporarily</p>	<p>Y / N</p> <p>Complete "Operational Column" in Attachment C- Drinking Water Outlet Inventory.</p> <p>Type/ Location</p>	<p>Description</p>

Attachment C – Drinking Water Outlet Inventory

Name of School: Washington Community School

Address: 191 Avenue B, Bayonne, New Jersey 07002

Grade Levels: Elementary School Year School Constructed: Unknown Renovated/Additions: NA

Individual School Project Officer: Scott Nolan

Date Completed: 07/14/2025

# ¹	Type	Location	Code	Operational ² (Y/N)	Signs of Corrosion ³ (Y/N)	Filter ⁴ (Y/N)	Brass Fittings, Faucets or valves? (Y/N)	Aerator/ Screen (Y/N)	Motion Activated (Y/N)	Chiller (Y/N)	Water Cooler		Comments
											Make	Model	
01	Sink	Room 114	WC-01	Y	N	N	N	Y	N	N	NA	NA	
02	Sink	Room 114	WC-02	Y	N	N	N	Y	N	N	NA	NA	
03	Sink	Room 114A	WC-03	Y	N	N	N	Y	N	N	NA	NA	
04	Sink	Café Faucet	WC-04	Y	N	N	N	N	N	N	NA	NA	
05	Sink	113A Faucet	WC-05	Y	N	N	N	Y	N	N	NA	NA	
06	Water Fountain	Bubbler by Room 113	WC-06	Y	N	Y	N	N	N	N	NA	NA	
07	Sink	Vice Principal's Office	WC-07	Y	N	N	N	Y	N	N	NA	NA	
08	Sink	Main Office	WC-08	Y	N	N	N	Y	N	N	NA	NA	
09	Sink	Room 105	WC-09	Y	N	N	N	Y	N	N	NA	NA	

¹ Number outlets starting at the closest outlet to the Point of Entry (POE).

² Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

³ Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

⁴ Document on Attachment D- Filter Inventory.

10	Sink	Room 104	WC-10	Y	N	N	N	Y	N	N	NA	NA	
11	Water Fountain	Room 101 Bubbler	WC-11	N	NA	NA	Permanently Removed						
12	Sink	Room 101 Faucet	WC-12	Y	N	N	N	Y	N	N	NA	NA	
13	Water Fountain	By Room 101	WC-13	Y	N	N	N	N	N	N	NA	NA	
14	Sink	Room 100	WC-14	Y	N	N	N	Y	N	N	NA	NA	
15	Water Fountain	Room 219 Bubbler	WC-15	Y	N	N	N	N	N	N	NA	NA	
16	Sink	Room 219 Sink	WC-16	Y	N	N	N	Y	N	N	NA	NA	
17	Water Fountain	By Room 212	WC-17	Y	N	N	N	N	N	N	NA	NA	
18	Sink	Room 211	WC-18	Y	N	N	N	Y	N	N	NA	NA	
19	Sink	Nurse's Office	WC-19	Y	N	N	N	Y	N	N	NA	NA	
20	Water Fountain	By Room 202	WC-20	Y	N	N	N	N	N	N	NA	NA	
21	Sink	Faculty Room	WC-21	Y	N	N	N	Y	N	N	NA	NA	
22	Water Fountain	Room 316 Bubbler	WC-22	Y	N	N	N	N	N	N	NA	NA	
23	Sink	Room 316 Faucet	WC-23	Y	N	N	N	Y	N	N	NA	NA	
24	Water Fountain	By Room 319	WC-24	Y	N	N	N	N	N	N	NA	NA	
25	Water Fountain	By Room 302	WC-25	Y	N	N	N	N	N	N	NA	NA	
26	Water Fountain	Room 300 Bubbler	WC-26	Y	N	N	N	N	N	N	NA	NA	
27	Sink	Room 300 Faucet	WC-27	Y	N	N	N	Y	N	N	NA	NA	

¹ Number outlets starting at the closest outlet to the Point of Entry (POE).

¹ Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

¹ Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

¹ Document on Attachment D- Filter Inventory.

Attachment D - Filter Inventory

Name of School: Washington Community School Grade Levels: Elementary School

Address: 191 Avenue B, Bayonne, New Jersey 07002

Individual School Project Officer: Scott Nolan

Date: 09/05/2025

Sample Location / Code	Brand	Type (Make & Model)	Date Installed or Replaced	Replacement Frequency	NSF Certified for Lead Reduction Y/N
WC-01	N/A	N/A	N/A	N/A	N/A
WC-02	N/A	N/A	N/A	N/A	N/A
WC-03	N/A	N/A	N/A	N/A	N/A
WC-04	3M Aqua Pure	AP200	8/14/2025	N/A	N/A
WC-05	3M Aqua Pure	AP200	8/14/2025	N/A	N/A
WC-06	Elkay	LZWSR_1D	N/A	N/A	N/A
WC-07	3M Aqua Pure	AP200	N/A	N/A	N/A
WC-08	N/A	N/A	N/A	N/A	N/A
WC-09	N/A	N/A	N/A	N/A	N/A
WC-10	N/A	N/A	N/A	N/A	N/A
WC-11	PERMANENTLY REMOVED				
WC-12	N/A	N/A	N/A	N/A	N/A
WC-13	Elkay	LZWSR_1D	N/A	N/A	N/A
WC-14	N/A	N/A	N/A	N/A	N/A
WC-15	N/A	N/A	N/A	N/A	N/A
WC-16	N/A	N/A	N/A	N/A	N/A
WC-17	N/A	N/A	N/A	N/A	N/A
WC-18	N/A	N/A	N/A	N/A	N/A
WC-19	N/A	N/A	N/A	N/A	N/A
WC-20	Elkay	LZWSR_1D	N/A	N/A	N/A
WC-21	N/A	N/A	N/A	N/A	N/A
WC-22	N/A	N/A	N/A	N/A	N/A
WC-23	N/A	N/A	N/A	N/A	N/A
WC-24	Elkay	LZWSR_1D	N/A	N/A	N/A
WC-25	Elkay	LZWSR_1D	N/A	N/A	N/A
WC-26	N/A	N/A	N/A	N/A	N/A

WC-27	N/A	N/A	N/A	N/A	N/A
-------	-----	-----	-----	-----	-----



Attachment E – Flushing Log

Name of School: Washington Community School

Address: 191 Avenue B, Bayonne, New Jersey 07002

Grade Levels: Elementary School

Individual School Project Officer: Scott Nolan

Date: 09/05/2025

Sample Location Description	Sample Location Code	Date	Time	Duration of Flushing	Reason for Flushing
Room 114	WC-01	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 114	WC-02	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 114A	WC-03	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Café Faucet	WC-04	August 22, 2025	5:30 pm	2-3 Minutes	Water Sampling
113A Faucet	WC-05	August 22, 2025	5:30 pm	2-3 Minutes	Water Sampling
Bubbler by Room 113	WC-06	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Vice Principal's Office	WC-07	August 22, 2025	5:30 pm	2-3 Minutes	Water Sampling
Main Office	WC-08	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 105	WC-09	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 104	WC-10	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 101 Bubbler	WC-11	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 101 Faucet	WC-12	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
By Room 101	WC-13	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 100	WC-14	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 219 Bubbler	WC-15	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 219 Sink	WC-16	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
By Room 212	WC-17	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 211	WC-18	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Nurse's Office	WC-19	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
By Room 202	WC-20	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Faculty Room	WC-21	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling

Bayonne BOE: Sampling Plan

Room 316 Bubbler	WC-22	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 316 Faucet	WC-23	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
By Room 319	WC-24	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
By Room 302	WC-25	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 300 Bubbler	WC-26	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling
Room 300 Faucet	WC-27	June 20, 2025	5:30 pm	2-3 Minutes	Water Sampling

Attachment F - Pre - Sampling Water Use Certification

TO BE COMPLETED BY THE BAYONNE BOE DISTRICT REPRESENTATIVE:		
School Name:	<u>Washington Community School</u>	
Sample collection address:	<u>191 Avenue B, Bayonne, New Jersey 07002</u>	
Water was last used:	<u>Time: 5:30 pm</u>	<u>Date: June 20, 2025</u>
Sample commencement:	<u>Time: 10:05 am</u>	<u>Date: June 21, 2025</u>
I have read the Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.		
Scott Nolan	<u>7/22/2025</u>	
Signature	Date	

Attachment F - Pre - Sampling Water Use Certification

TO BE COMPLETED BY THE BAYONNE BOE DISTRICT REPRESENTATIVE:		
School Name:	<u>Washington Community School</u>	
Sample collection address:	<u>191 Avenue B, Bayonne, New Jersey 07002</u>	
Water was last used:	<u>Time: 5:30 pm</u>	<u>Date: August 22, 2025</u>
Sample commencement:	<u>Time: 7:14 am</u>	<u>Date: August 23, 2025</u>
I have read the Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.		
Scott Nolan	<u>9/05/2025</u>	
Signature	Date	