

January 5, 2026

Mr. Jeff Beardsley
Pittsford Central School District
100 Mendon Center Road
Pittsford, New York 14534

Re: Lead in Drinking Water Sampling – Pittsford Central School District | Pittsford, New York

Dear Mr. Beardsley,

On November 14, 2025, Paradigm Environmental Services, Inc. was contracted to conduct lead in drinking water sampling and analysis within the following schools:

- Sutherland High School
- Mendon High School
- Barker Road Middle School
- Park Road Elementary School.
- Jefferson Road Elementary School

The sampling was conducted in accordance with the NYS Department of Health Regulation, Lead Testing in School Drinking Water (10 NYCRR Subpart 67-4) and the United States Environmental Protection Agency's ("USEPA") guidance as per the 3Ts for Reducing Lead in Drinking Water in Schools.

The NYSDOH Regulation addresses lead in drinking water for Public School Districts and BOCES. The NYSDOH Regulation states that schools must take remedial measures when lead levels are shown to be above 5 parts per billion (ppb); this is the NYSDOH Action Level for lead in drinking water.

Water Sampling Protocols:

As per NYSDOH Regulation and the USEPA 3Ts Guidance Document, schools are required to collect 250 milliliters ("mL") first-draw samples from water fountains, bubblers, and other outlets used for consumption. First draw samples are defined as a sample of tap water, collected in accordance with the NYSDOH Regulation, that has been standing in plumbing pipes at least 8 hours and not more than 18 hours and is collected without prior flushing of the tap.

Laboratory Analysis:

The water samples were submitted to Accurate Analytical Testing Lab LLC ("AAT") for analyses and were analyzed by lead in drinking water EPA Method 200.5. AAT is an environmental laboratory certified by the NYSDOH Environmental Laboratory Approval Program (ELAP)- Lab ID# 11864.

Drinking Water Samples Results:

The samples results are detailed in the laboratory reports from ATT. Each table below identifies outlets at each school with lead above 5.0 ppb:

Sutherland High School:

One (1) drinking water sample was collected and was not found above the NYSDOH Action level.

Mendon High School:

One (1) drinking water sample was collected and is above the NYSDOH Action Level.

Lead in Drinking Water Results above NYSDOH Action Level				
Sample ID	Location	Results (ppm)	Results (ppb)	NYSDOH Action Level
HS-1-NS-04	Nurse Suite Back Sink	0.1178	117.8	Above

Barker Road Middle School:

One (1) drinking water sample was collected and was not found above the NYSDOH Action level.

Park Road Elementary School:

A total of three (3) drinking water samples were collected. One (1) was found to be below the NYSDOH Action Level

Lead in Drinking Water Results above NYSDOH Action Level				
Sample ID	Location	Results (ppm)	Results (ppb)	NYSDOH Action Level
ES-1-CS-01	A1 Classroom Sink	0.0052	5.2	Above

Jefferson Road Elementary School:

One (1) drinking water sample was collected and was not found above the NYSDOH Action level.

Please refer to the attached laboratory reports for specific analytical data and sample locations throughout the school. If you have any questions, please contact me at (585) 454-1060. We appreciate the opportunity to provide you with our professional services.

Sincerely,



Angela Liddell
Director of Field Operations



30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

Client : Paradigm Enviromental Inc.
179 Lake Avenue
Rochester, NY 14608

Attn : Brad Arthur **Email :** barthur@paradigmenv.com
Phone : 585-254-4126 **Fax :**

AAT Project : 1232979
Sampling Date : 11/14/2025
Date Received : 11/18/2025
Date Analyzed : 11/24/2025
Date Reported : 11/25/2025

Client Project : P25-12988

Collected By: GEOFFREY SIEBERT

WSSN : NP

Project Location : PITTSFORD CSD

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
10993262	ES-1-CS-01	PRES A1-CLASSRM SINK	NA	0702	0.0052	0.0020	Below
10993263	ES-1-CS-02	PRES A2-CLASSRM SINK	NA	0703	0.0023	0.0020	Below
10993264	ES-1-CS-03	PRES D6-CLASSRM SINK	NA	0704	0.0022	0.0020	Below
10993265	HS-1-NS-04	MSHS-NURSE BACK SINK	NA	0712	0.1178	0.0020	Above
10993266	MS-1-KS-05	BRMS-SUPERINTENDENT SINK	NA	0714	<0.0020	0.0020	Below
10993267	ES-1-KS-06	JRES-123 KITCHEN SINK	NA	0724	<0.0020	0.0020	Below
10993268	HS-1-DF-07	PSHS-F200 DRINKING FOUNTAIN	NA	0731	<0.0020	0.0020	Below

Analyst Signature

Joseph Kenwabikise

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm). A '<' indicates the reported result is below AAT's reporting limit. For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated. EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu ; MI Regulatory Limits: 0.012 µg/L for Pb and 1.3 µg/L for Cu. The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 11/25/2025

AAT Project: 1232979



30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

To : Paradigm Environmental Inc.
179 Lake Avenue
Rochester, NY 14608

Attn : Brad Arthur

Email : barthur@paradigmenv.com
Phone : 585-254-4126

AAT Project : 1232979
Client Project : P25-12988
Date Reported 11/25/2025

Project Location : PITTSFORD CSD

Sample	Client Code	Analysis Requested	Completed	Analyst
10993262	ES-1-CS-01	Pb/Cu in Drinking Water	11/24/2025	Joseph Kenwabikise
10993263	ES-1-CS-02	Pb/Cu in Drinking Water	11/24/2025	Joseph Kenwabikise
10993264	ES-1-CS-03	Pb/Cu in Drinking Water	11/24/2025	Joseph Kenwabikise
10993265	HS-1-NS-04	Pb/Cu in Drinking Water	11/24/2025	Joseph Kenwabikise
10993266	MS-1-KS-05	Pb/Cu in Drinking Water	11/24/2025	Joseph Kenwabikise
10993267	ES-1-KS-06	Pb/Cu in Drinking Water	11/24/2025	Joseph Kenwabikise
10993268	HS-1-DF-07	Pb/Cu in Drinking Water	11/24/2025	Joseph Kenwabikise

Reviewed By

Elyse Bidle
Quality Assurance Coordinator

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.

NY State DOH ELAP -Lab ID #11864, Michigan State Lab # 9996

Date Printed: 11/25/2025 8:55AM

AAT Project: 1232979



SUBMITTING COMPANY
Paradigm Environmental, Inc.
179 Lake Ave.
Rochester NY 14608

CONTACT INFORMATION

Office: 585-454-1060

Fax:

Cell:

Email: customersupport@accurate-test.biz

Email: Gs:obon@paradigmny.com

[illegible]

By submitting samples to AAT, the client agrees to AAT's terms and conditions.
AAT is not responsible for shipping delays

Sample Type or Purpose --	Key:	Routine Distribution (RD)	Check Sample (CS)	Raw Water (RW)	Process Water (PW)	Investigation Number (IN)
* Sample Type or Purpose --	Key:	Routine Distribution (RD)	Check Sample (CS)	Raw Water (RW)	Process Water (PW)	Investigation Number (IN)

AAT
143981