

January 14, 2026

Mr. Jeff McCarthy
Manchester Shortsville CSD
1506 State Route 21
Shortsville, New York 14548

Re: Lead Testing in School Drinking Water

Dear Mr. McCarthy:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Manchester Shortsville CSD, including:

- **Manchester Shortsville CSD – 1506 State Route 21, Shortsville, New York 14548**

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: *Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on November 22, 2025. As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 3 sources of potable water at Manchester Shortsville CSD have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion. To comply with NYS regulations, response actions by the district are required. Response actions are outlined in Section 1.3 (*Response Actions Required Under NYS Regulations*).

Thank you for the opportunity to be of service to Manchester Shortsville CSD.

Sincerely,
Stohl Environmental, LLC.



Michael Scinta
EPA Lead Risk Assessor

Lead Testing in School Drinking Water

Prepared for:

Manchester Shortsville Central School District

Prepared by:



Conditions as of November 22, 2025

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports and Chain of Custody Documents
- 1.5. Laboratory Certifications

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Manchester Shortsville CSD to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- **Manchester Shortsville CSD – 1506 State Route 21, Shortsville, New York 14548**

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within Manchester Shortsville CSD defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, **Subpart 67-4: Lead Testing in School Drinking Water**, and the EPA guidance document, **3Ts for Reducing Lead in Drinking Water in Schools**, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at Manchester Shortsville CSD:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Manchester Shortsville CSD	11/22/2025	98	95	3

**NYS Action Level is 5 parts per billion*

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis
			(in ppb)
211.1-56	Room 77	Sink	6.2
211.1-73	MIDDLE SCHOOL ADDITIONS - Gym C Room Officials Shower Right	Shower	7.3
211.1-82	Room 64	Sink	5.3

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration more than the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports and Chain of Custody Documents



December 18, 2025

Service Request No:R2515860

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Manchester Shortsville CSD - Manchester Central S.

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory November 25, 2025
For your reference, these analyses have been assigned our service request number **R2515860**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | **FAX** +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S.
Sample Matrix: Drinking Water

Service Request: R2515860
Date Received: 11/25/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 11/25/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 12/18/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 211.1-01		Lab ID: R2515860-001					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.7			1.0	ug/L	200.8	
CLIENT ID: 211.1-03		Lab ID: R2515860-003					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.1			1.0	ug/L	200.8	
CLIENT ID: 211.1-04		Lab ID: R2515860-004					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.4			1.0	ug/L	200.8	
CLIENT ID: 211.1-08		Lab ID: R2515860-008					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.7			1.0	ug/L	200.8	
CLIENT ID: 211.1-09		Lab ID: R2515860-009					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.0			1.0	ug/L	200.8	
CLIENT ID: 211.1-10		Lab ID: R2515860-010					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.5			1.0	ug/L	200.8	
CLIENT ID: 211.1-11		Lab ID: R2515860-011					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.9			1.0	ug/L	200.8	
CLIENT ID: 211.1-12		Lab ID: R2515860-012					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.7			1.0	ug/L	200.8	
CLIENT ID: 211.1-22B		Lab ID: R2515860-023					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.3			1.0	ug/L	200.8	
CLIENT ID: 211.1-25		Lab ID: R2515860-026					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.0			1.0	ug/L	200.8	
CLIENT ID: 211.1-29		Lab ID: R2515860-030					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.5			1.0	ug/L	200.8	
CLIENT ID: 211.1-30		Lab ID: R2515860-031					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.9			1.0	ug/L	200.8	



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1

Service Request:R2515860

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2515860-001	211.1-01	11/22/2025	
R2515860-002	211.1-02	11/22/2025	
R2515860-003	211.1-03	11/22/2025	
R2515860-004	211.1-04	11/22/2025	
R2515860-005	211.1-05	11/22/2025	
R2515860-006	211.1-06	11/22/2025	
R2515860-007	211.1-07	11/22/2025	
R2515860-008	211.1-08	11/22/2025	
R2515860-009	211.1-09	11/22/2025	
R2515860-010	211.1-10	11/22/2025	
R2515860-011	211.1-11	11/22/2025	
R2515860-012	211.1-12	11/22/2025	
R2515860-013	211.1-13	11/22/2025	
R2515860-014	211.1-14	11/22/2025	
R2515860-015	211.1-15	11/22/2025	
R2515860-016	211.1-16	11/22/2025	
R2515860-017	211.1-17	11/22/2025	
R2515860-018	211.1-18	11/22/2025	
R2515860-019	211.1-19	11/22/2025	
R2515860-020	211.1-20	11/22/2025	
R2515860-021	211.1-21	11/22/2025	
R2515860-022	211.1-22A	11/22/2025	
R2515860-023	211.1-22B	11/22/2025	
R2515860-024	211.1-23	11/22/2025	
R2515860-025	211.1-24	11/22/2025	
R2515860-026	211.1-25	11/22/2025	
R2515860-027	211.1-26	11/22/2025	
R2515860-028	211.1-27	11/22/2025	
R2515860-029	211.1-28	11/22/2025	
R2515860-030	211.1-29	11/22/2025	
R2515860-031	211.1-30	11/22/2025	
R2515860-032	211.1-31	11/22/2025	
R2515860-033	211.1-32A	11/22/2025	
R2515860-034	211.1-32B	11/22/2025	
R2515860-035	211.1-33A	11/22/2025	
R2515860-036	211.1-33B	11/22/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-211

Client: Manchester Shortsville CSD

Contact: Mr. Jeff McCarthy

Building: Manchester Central School

Location: 1506 State Rte 21, Shorstville, NY

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
211.1-01	Room 1 Nurses Office Exam Room	Sink	
211.1-02	Room 1 Nurses Office Bathroom	Sink	
211.1-03	Room 1 Nurses Office Main	Sink	
211.1-04	ELEM SCHOOL ADDITIONS - Room 1 Nurse Office Ice Machine	Ice Machine	
211.1-05	Room 2	Sink	
211.1-06	Room 4	Sink	
211.1-07	Room 6	Sink	
211.1-08	Room 11	Sink	
211.1-09	Room 13	Sink	
211.1-10	Room 12	Sink	
211.1-11	Room 15	Sink	
211.1-12	Room 14	Sink	
211.1-13	Room 17	Sink	
211.1-14	Room 16	Sink	
211.1-15	Room 18	Sink	
211.1-16	Room 19	Sink	
211.1-17	Room 20	Sink	
211.1-18	Room 21	Sink	

Notes:
 Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to: Mscinta@stohlenvironmental.com

Sampled By: Sam Lee Print Name Sam Lee Stohl Env: Sam Lee Date: 11/22/2025
 Relinquished By: [Signature] Print Name Connor Crilly Stohl Env: Connor Crilly Date: 11/25/2025 8:00
 Received (Name / Lab): [Signature] Date: 11-25-25 Time: (P82)
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____





Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-211

Client: Manchester Shortsville CSD

Contact: Mr. Jeff McCarthy

Building: Manchester Central School

Location: 1506 State Rte 21, Shorstville, NY

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
211.1-19	Room 22	Sink	
211.1-20	Room 23	Sink	
211.1-21	ELEM SCHOOL ADDITIONS - Room 10	Sink	
211.1-22A	ELEM SCHOOL ADDITIONS - Fountain Next to Room 30	DFB	
211.1-22B	ELEM SCHOOL ADDITIONS - Fountain Next to Room 30	DF	
211.1-23	Room 30	Sink	
211.1-24	District Office 027 Kitchen	Sink	
211.1-25	District Office 027 Bathroom	Sink	
211.1-26	Faculty Room 33 Sink	Sink	
211.1-27	Faculty Room 33 Fridge Water	Fridge	
211.1-28	Faculty Room 33 Ice Machine	Ice Machine	
211.1-29	Elementary Kitchen Middle of Room	Sink	
211.1-30	Elementary Kitchen Prep Sink Back Room	Sink	
211.1-31	Elementary Kitchen Sprayer	Sprayer	
211.1-32A	ELEM SCHOOL ADDITIONS - Elem Cafeteria Water Fountain	DFB	
211.1-32B	ELEM SCHOOL ADDITIONS - Elem Cafeteria Water Fountain	DF	
211.1-33A	HIGHSCHOOL ADDITIONS - Sophomore Hallway Fountain Left	DFB	
211.1-33B	HIGHSCHOOL ADDITIONS - Sophomore Hallway Fountain Left	DF	

Notes:

Please e-mail lab results to labs@stohlenv.com

Mscinta@stohlenvironmental.com

Sampled By: Sam Lee Print Name Stohl Env: Sam Lee Date: 11/22/2025

Relinquished By: [Signature] Print Name Stohl Env: Connor Crilly Date: 11/25/2025 8:00

Received (Name / Lab): [Signature] Date: 11-25-25 Time: 08:00

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____


Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



R2515860

5

Stahl Environmental
Manchester Shortsville CSD - Manchester Central



Cooler Receipt and Preservation Check

Project/Client _____ Folder Number _____

Cooler received on 11-25-25 by: TRP COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
2	Custody papers properly completed (ink, signed)?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
3	Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>

5a	Did VOA vials have sig* bubbles?	Y N <input checked="" type="checkbox"/> NA
5b	Sig* bubbles: Alk?	Y N <input checked="" type="checkbox"/> NA
	Sulfide?	Y N <input checked="" type="checkbox"/> NA
6	Where did the bottles originate?	<u>ALS/ROO</u> CLIENT
7	Soil VOA received as:	Bulk Encore 5035set <input checked="" type="checkbox"/> NA

8. Temperature Readings Date: 11-25-25 Time: 0800 ID: IR#12 From: Temp Blank Sample Bottle

Temp (°C)	<u>9.5</u>						
Within 0-6°C?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: lead Ice melted Poorly Packed (described below) Same Day Rule & Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMU by TRP on 11-25 at 0820
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 12/1 Time: 2200 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO
- 13. Were dissolved metals filtered in the field? YES NO
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized _____ Tedlar® Bags Inflated

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
<u>2</u>	<u>802325</u>	HNO ₃		<input checked="" type="checkbox"/>	<u>NO Lot Info</u>		<u>All</u>	<u>4mL</u>		<u>2</u>
<u>2</u>		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____
Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG *significant air bubbles: VOA > 5-6 mm: WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1

Service Request: R2515860

Sample Name: 211.1-01
Lab Code: R2515860-001
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-02
Lab Code: R2515860-002
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-03
Lab Code: R2515860-003
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-04
Lab Code: R2515860-004
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-05
Lab Code: R2515860-005
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1

Service Request: R2515860

Sample Name: 211.1-06
Lab Code: R2515860-006
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-07
Lab Code: R2515860-007
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-08
Lab Code: R2515860-008
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-09
Lab Code: R2515860-009
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-10
Lab Code: R2515860-010
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1

Service Request: R2515860

Sample Name: 211.1-11
Lab Code: R2515860-011
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-12
Lab Code: R2515860-012
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-13
Lab Code: R2515860-013
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-14
Lab Code: R2515860-014
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-15
Lab Code: R2515860-015
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1

Service Request: R2515860

Sample Name: 211.1-16
Lab Code: R2515860-016
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-17
Lab Code: R2515860-017
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-18
Lab Code: R2515860-018
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-19
Lab Code: R2515860-019
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-20
Lab Code: R2515860-020
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1

Service Request: R2515860

Sample Name: 211.1-21
Lab Code: R2515860-021
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-22A
Lab Code: R2515860-022
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-22B
Lab Code: R2515860-023
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-23
Lab Code: R2515860-024
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-24
Lab Code: R2515860-025
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1

Service Request: R2515860

Sample Name: 211.1-25
Lab Code: R2515860-026
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-26
Lab Code: R2515860-027
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-27
Lab Code: R2515860-028
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-28
Lab Code: R2515860-029
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-29
Lab Code: R2515860-030
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1

Service Request: R2515860

Sample Name: 211.1-30
Lab Code: R2515860-031
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-31
Lab Code: R2515860-032
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-32A
Lab Code: R2515860-033
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-32B
Lab Code: R2515860-034
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-33A
Lab Code: R2515860-035
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental

Service Request: R2515860

Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1

Sample Name: 211.1-33B

Date Collected: 11/22/25

Lab Code: R2515860-036

Date Received: 11/25/25

Sample Matrix: Drinking Water

Analysis Method

Extracted/Digested By

Analyzed By

200.8

MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-01
Lab Code: R2515860-001

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.7	ug/L	1.0	1	12/16/25 15:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-02
Lab Code: R2515860-002

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 15:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-03
Lab Code: R2515860-003

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	12/16/25 16:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-04
Lab Code: R2515860-004

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.4	ug/L	1.0	1	12/16/25 16:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-05
Lab Code: R2515860-005

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 16:07	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-06
Lab Code: R2515860-006

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 16:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-07
Lab Code: R2515860-007

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 16:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-08
Lab Code: R2515860-008

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	12/16/25 16:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-09
Lab Code: R2515860-009

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.0	ug/L	1.0	1	12/16/25 16:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-10
Lab Code: R2515860-010

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.5	ug/L	1.0	1	12/16/25 16:14	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-11
Lab Code: R2515860-011

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.9	ug/L	1.0	1	12/16/25 16:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-12
Lab Code: R2515860-012

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	12/16/25 16:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-13
Lab Code: R2515860-013

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 16:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-14
Lab Code: R2515860-014

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 16:24	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-15
Lab Code: R2515860-015

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 16:25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-16
Lab Code: R2515860-016

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 16:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-17
Lab Code: R2515860-017

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 16:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-18
Lab Code: R2515860-018

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 16:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-19
Lab Code: R2515860-019

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 16:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-20
Lab Code: R2515860-020

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 16:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-21
Lab Code: R2515860-021

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 16:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-22A
Lab Code: R2515860-022

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 16:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-22B
Lab Code: R2515860-023

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	12/16/25 16:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-23
Lab Code: R2515860-024

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 16:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-24
Lab Code: R2515860-025

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 16:56	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-25
Lab Code: R2515860-026

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0	ug/L	1.0	1	12/16/25 16:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-26
Lab Code: R2515860-027

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 16:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-27
Lab Code: R2515860-028

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 17:00	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-28
Lab Code: R2515860-029

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 17:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-29
Lab Code: R2515860-030

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	12/16/25 17:03	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-30
Lab Code: R2515860-031

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.9	ug/L	1.0	1	12/16/25 17:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-31
Lab Code: R2515860-032

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 17:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-32A
Lab Code: R2515860-033

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 17:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-32B
Lab Code: R2515860-034

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 17:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-33A
Lab Code: R2515860-035

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 17:14	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-33B
Lab Code: R2515860-036

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 17:16	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515860-MB1

Service Request: R2515860
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 15:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515860-MB2

Service Request: R2515860
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 16:36	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25
Date Analyzed: 12/16/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 211.1-17
Lab Code: R2515860-017
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515860-017MS		Duplicate Matrix Spike R2515860-017DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	23.6	20.0	118	22.9	20.0	115	70-130	3	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water

Service Request: R2515860
Date Collected: 11/22/25
Date Received: 11/25/25
Date Analyzed: 12/16/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 211.1-18
Lab Code: R2515860-018
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515860-018MS		Duplicate Matrix Spike R2515860-018DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	23.0	20.0	115	23.3	20.0	116	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water

Service Request: R2515860
Date Analyzed: 12/16/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2515860-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.8	20.0	109	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water

Service Request: R2515860
Date Analyzed: 12/16/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2515860-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.4	20.0	112	85-115



December 18, 2025

Service Request No:R2515852

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Manchester Shortsville CSSD - Manchester Central S

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory November 25, 2025
For your reference, these analyses have been assigned our service request number **R2515852**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S
Sample Matrix: Drinking Water

Service Request: R2515852
Date Received: 11/25/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 11/25/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 12/18/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 211.1-43		Lab ID: R2515852-012					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.6			1.0	ug/L	200.8	
CLIENT ID: 211.1-44		Lab ID: R2515852-013					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.7			1.0	ug/L	200.8	
CLIENT ID: 211.1-47		Lab ID: R2515852-017					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.0			1.0	ug/L	200.8	
CLIENT ID: 211.1-50		Lab ID: R2515852-021					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.3			1.0	ug/L	200.8	
CLIENT ID: 211.1-55A		Lab ID: R2515852-028					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.7			1.0	ug/L	200.8	
CLIENT ID: 211.1-56		Lab ID: R2515852-030					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	6.2			1.0	ug/L	200.8	
CLIENT ID: 211.1-57		Lab ID: R2515852-031					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.7			1.0	ug/L	200.8	
CLIENT ID: 211.1-58		Lab ID: R2515852-032					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.9			1.0	ug/L	200.8	
CLIENT ID: 211.1-59		Lab ID: R2515852-033					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.7			1.0	ug/L	200.8	
CLIENT ID: 211.1-60		Lab ID: R2515852-034					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.6			1.0	ug/L	200.8	
CLIENT ID: 211.1-62		Lab ID: R2515852-036					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.8			1.0	ug/L	200.8	



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1

Service Request:R2515852

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2515852-001	211.1-34A	11/22/2025	
R2515852-002	211.1-34B	11/22/2025	
R2515852-003	211.1-35	11/22/2025	
R2515852-004	211.1-36A	11/22/2025	
R2515852-005	211.1-36B	11/22/2025	
R2515852-006	211.1-37	11/22/2025	
R2515852-007	211.1-38	11/22/2025	
R2515852-008	211.1-39	11/22/2025	
R2515852-009	211.1-40	11/22/2025	
R2515852-010	211.1-41	11/22/2025	
R2515852-011	211.1-42	11/22/2025	
R2515852-012	211.1-43	11/22/2025	
R2515852-013	211.1-44	11/22/2025	
R2515852-014	211.1-45	11/22/2025	
R2515852-015	211.1-46A	11/22/2025	
R2515852-016	211.1-46B	11/22/2025	
R2515852-017	211.1-47	11/22/2025	
R2515852-018	211.1-48A	11/22/2025	
R2515852-019	211.1-48B	11/22/2025	
R2515852-020	211.1-49	11/22/2025	
R2515852-021	211.1-50	11/22/2025	
R2515852-022	211.1-51A	11/22/2025	
R2515852-023	211.1-51B	11/22/2025	
R2515852-024	211.1-52	11/22/2025	
R2515852-025	211.1-53	11/22/2025	
R2515852-026	211.1-54A	11/22/2025	
R2515852-027	211.1-54B	11/22/2025	
R2515852-028	211.1-55A	11/22/2025	
R2515852-029	211.1-55B	11/22/2025	
R2515852-030	211.1-56	11/22/2025	
R2515852-031	211.1-57	11/22/2025	
R2515852-032	211.1-58	11/22/2025	
R2515852-033	211.1-59	11/22/2025	
R2515852-034	211.1-60	11/22/2025	
R2515852-035	211.1-61	11/22/2025	
R2515852-036	211.1-62	11/22/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-211

Client: Manchester Shortsville CSD

Contact: Mr. Jeff McCarthy

Building: Manchester Central School

Location: 1506 State Rte 21, Shorstville, NY

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
211.1-34A	HIGHSCHOOL ADDITIONS - Fountain Across From Room 95 Right	DFB	
211.1-34B	HIGHSCHOOL ADDITIONS - Fountain Across From Room 95 Right	DF	
211.1-35	HIGHSCHOOL ADDITIONS - Fountain Across From Room 95 Left	DF	
211.1-36A	HIGHSCHOOL ADDITIONS - Main Lobby Gym A Fountain Right	DFB	
211.1-36B	HIGHSCHOOL ADDITIONS - Main Lobby Gym A Fountain Right	DF	
211.1-37	HIGHSCHOOL ADDITIONS - Main Lobby Gym A Fountain Left	DF	
211.1-38	HIGHSCHOOL ADDITIONS - Athletics Ice Machine	Ice Machine	
211.1-39	Room 95	Sink	
211.1-40	Room 93	Sink	
211.1-41	Room 91 Kitchen	Sink	
211.1-42	Room 114 Sink	Sink	
211.1-43	Room 117 Left Sink	Sink	
211.1-44	Room 117 Right Sink	Sink	
211.1-45	Room 117 Exam Room	Sink	
211.1-46A	HIGH SCHOOL ADDITIONS - Freshman Hallway Fountain Left	DFB	
211.1-46B	HIGH SCHOOL ADDITIONS - Freshman Hallway Fountain Left	DF	
211.1-47	HIGH SCHOOL ADDITIONS - Freshman Hallway Fountain Right	DF	
211.1-48A	HIGH SCHOOL ADDITIONS - Auditorium Foyer Fountain Right	DFB	

Notes:

Please e-mail lab results to labs@stohlenv.com

Mscinta@stohlenvironmental.com

Sampled By: Sam Lee Print Name Stohl Env: Sam Lee Date: 11/22/2025

Relinquished By: [Signature] Print Name Stohl Env: Connor Crilly Date: 11/25/2025 9:00

Received (Name / Lab): [Signature] Date: 11-25-25 Time: 0800

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____





Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-211

Client: Manchester Shortsville CSD

Contact: Mr. Jeff McCarthy

Building: Manchester Central School

Location: 1506 State Rte 21, Shorstville, NY

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
211.1-48A	HIGH SCHOOL ADDITIONS - Auditorium Foyer Fountain Right	DF	
211.1-49	HIGH SCHOOL ADDITIONS - Auditorium Foyer Fountain Left	DFB	
211.1-50	Kitchenette Outside Room 127	Sink	
211.1-51A	HIGH SCHOOL ADDITIONS - Junior Hallway Fountain Right	DFB	
211.1-51B	HIGH SCHOOL ADDITIONS - Junior Hallway Fountain Right	DF	
211.1-52	HIGH SCHOOL ADDITIONS - Junior Hallway Fountain Left	DF	
211.1-53	Main Office 139 Kitchen	Sink	
211.1-54A	MIDDLE SCHOOL ADDITIONS - Fountain outside Room 141	DFB	
211.1-54B	MIDDLE SCHOOL ADDITIONS - Fountain outside Room 141	DF	
211.1-55A	MIDDLE SCHOOL ADDITIONS - Fountain outside Room 151	DFB	
211.1-55B	MIDDLE SCHOOL ADDITIONS - Fountain outside Room 151	DF	
211.1-56	Room 77	Sink	
211.1-57	Room 76 Back Left	Sink	
211.1-58	Room 76 Back Right	Sink	
211.1-59	Room 76 Left Wall	Sink	
211.1-60	Room 76 Right Wall	Sink	
211.1-61	Room 76 Middle	Sink	
211.1-62	Kitchen Dish Sprayer	Sink	

Notes:

Please e-mail lab results to labs@stohlenv.com

Mscinta@stohlenvironmental.com

Sampled By: Sam Lee Print Name Stohl Env: Sam Lee Date: 11/22/2025

Relinquished By: [Signature] Print Name Stohl Env: Connor Crilly Date: 11/25/2025 9:00 AM

Received (Name / Lab): [Signature] Date: 11-25-25 Time: 0800

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____




Cooler Receipt and Preservation C

R2515852

5

Stoht Environmental
Manchester Shortsville C68D - Manchester Centre



Project/Client _____

Folder Number _____

Cooler received on 11-25-25

by: TJP

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="checkbox"/> N
2	Custody papers properly completed (ink, signed)?	Y <input checked="" type="checkbox"/> N
3	Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="checkbox"/> N
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="checkbox"/> N

5a	Did VOA vials have sig* bubbles?	Y N <input checked="" type="checkbox"/> NA
5b	Sig* bubbles: Alk?	Y N <input checked="" type="checkbox"/> NA
	Sulfide?	Y N <input checked="" type="checkbox"/> NA
6	Where did the bottles originate?	<u>ALS/ROO</u> CLIENT
7	Soil VOA received as:	Bulk Encore 5035set <input checked="" type="checkbox"/> NA

8. Temperature Readings

Date: 11-25-25 Time: 0800

ID: IR#12

From: Temp Blank Sample Bottle

Temp (°C)	<u>9.5</u>						
Within 0-6°C?	Y <input checked="" type="checkbox"/> N	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: lead Ice melted Poorly Packed (described below) Same Day Rule & Client Approval to Run Samples: Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMO by TJP on 11-25 at 0820
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 12/1 Time: 2200 by: AG

- Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- Did all bottle labels and tags agree with custody papers? YES NO
- Were correct containers used for the tests indicated? YES NO
- Were 5035 vials acceptable (no extra labels, not leaking)? 12/1 AG YES NO N/A
- Were dissolved metals filtered in the field? YES NO N/A
- Air Samples: Cassettes / Tubes Intact Y/N with MS Y/N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
<u>2</u>	<u>202325</u>	HNO ₃		X	<u>NO lot in fu</u>		<u>All</u>	<u>4ml</u>		<u>2</u>
<u>2</u>		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____

Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG

*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- | | |
|---|--|
| <p>U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.</p> <p>J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).</p> <p>B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.</p> <p>E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.</p> <p>E Organics- Concentration has exceeded the calibration range for that specific analysis.</p> <p>D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.</p> <p>* Indicates that a quality control parameter has exceeded laboratory limits. Under the “Notes” column of the Form I, this qualifier denotes analysis was performed out of Holding Time.</p> <p>H Analysis was performed out of hold time for tests that have an “immediate” hold time criteria.</p> <p># Spike was diluted out.</p> | <p>+ Correlation coefficient for MSA is <0.995.</p> <p>N Inorganics- Matrix spike recovery was outside laboratory limits.</p> <p>N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.</p> <p>S Concentration has been determined using Method of Standard Additions (MSA).</p> <p>W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.</p> <p>P Concentration >40% difference between the two GC columns.</p> <p>C Confirmed by GC/MS</p> <p>Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).</p> <p>X See Case Narrative for discussion.</p> <p>MRL Method Reporting Limit. Also known as:</p> <p>LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.</p> <p>MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).</p> <p>LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.</p> <p>ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.</p> |
|---|--|

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory’s NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1

Service Request: R2515852

Sample Name: 211.1-34A
Lab Code: R2515852-001
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-34B
Lab Code: R2515852-002
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-35
Lab Code: R2515852-003
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-36A
Lab Code: R2515852-004
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-36B
Lab Code: R2515852-005
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1

Service Request: R2515852

Sample Name: 211.1-37
Lab Code: R2515852-006
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-38
Lab Code: R2515852-007
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-39
Lab Code: R2515852-008
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-40
Lab Code: R2515852-009
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-41
Lab Code: R2515852-010
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1

Service Request: R2515852

Sample Name: 211.1-42
Lab Code: R2515852-011
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-43
Lab Code: R2515852-012
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-44
Lab Code: R2515852-013
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-45
Lab Code: R2515852-014
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-46A
Lab Code: R2515852-015
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1

Service Request: R2515852

Sample Name: 211.1-46B
Lab Code: R2515852-016
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-47
Lab Code: R2515852-017
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-48A
Lab Code: R2515852-018
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-48B
Lab Code: R2515852-019
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-49
Lab Code: R2515852-020
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1

Service Request: R2515852

Sample Name: 211.1-50
Lab Code: R2515852-021
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-51A
Lab Code: R2515852-022
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-51B
Lab Code: R2515852-023
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-52
Lab Code: R2515852-024
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-53
Lab Code: R2515852-025
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1

Service Request: R2515852

Sample Name: 211.1-54A
Lab Code: R2515852-026
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-54B
Lab Code: R2515852-027
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-55A
Lab Code: R2515852-028
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-55B
Lab Code: R2515852-029
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-56
Lab Code: R2515852-030
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1

Service Request: R2515852

Sample Name: 211.1-57
Lab Code: R2515852-031
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-58
Lab Code: R2515852-032
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-59
Lab Code: R2515852-033
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-60
Lab Code: R2515852-034
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-61
Lab Code: R2515852-035
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1

Service Request: R2515852

Sample Name: 211.1-62
Lab Code: R2515852-036
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-34A
Lab Code: R2515852-001

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 14:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-34B
Lab Code: R2515852-002

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 14:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-35
Lab Code: R2515852-003

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 14:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-36A
Lab Code: R2515852-004

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 14:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-36B
Lab Code: R2515852-005

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 14:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-37
Lab Code: R2515852-006

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 14:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-38
Lab Code: R2515852-007

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 14:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-39
Lab Code: R2515852-008

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 14:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-40
Lab Code: R2515852-009

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 14:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-41
Lab Code: R2515852-010

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 14:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-42
Lab Code: R2515852-011

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 14:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-43
Lab Code: R2515852-012

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	12/16/25 14:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-44
Lab Code: R2515852-013

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	12/16/25 14:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-45
Lab Code: R2515852-014

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 14:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-46A
Lab Code: R2515852-015

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 14:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-46B
Lab Code: R2515852-016

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 14:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-47
Lab Code: R2515852-017

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0	ug/L	1.0	1	12/16/25 14:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-48A
Lab Code: R2515852-018

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

<u>Analyte Name</u>	<u>Analysis Method</u>	<u>Result</u>	<u>Units</u>	<u>MRL</u>	<u>Dil.</u>	<u>Date Analyzed</u>	<u>Q</u>
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 14:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-48B
Lab Code: R2515852-019

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 15:00	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-49
Lab Code: R2515852-020

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

<u>Analyte Name</u>	<u>Analysis Method</u>	<u>Result</u>	<u>Units</u>	<u>MRL</u>	<u>Dil.</u>	<u>Date Analyzed</u>	<u>Q</u>
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 15:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-50
Lab Code: R2515852-021

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.3	ug/L	1.0	1	12/16/25 15:07	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-51A
Lab Code: R2515852-022

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 15:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-51B
Lab Code: R2515852-023

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 15:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-52
Lab Code: R2515852-024

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 15:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-53
Lab Code: R2515852-025

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

<u>Analyte Name</u>	<u>Analysis Method</u>	<u>Result</u>	<u>Units</u>	<u>MRL</u>	<u>Dil.</u>	<u>Date Analyzed</u>	<u>Q</u>
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 15:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-54A
Lab Code: R2515852-026

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 15:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-54B
Lab Code: R2515852-027

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 15:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-55A
Lab Code: R2515852-028

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.7	ug/L	1.0	1	12/16/25 15:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-55B
Lab Code: R2515852-029

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 15:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-56
Lab Code: R2515852-030

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.2	ug/L	1.0	1	12/16/25 15:24	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-57
Lab Code: R2515852-031

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	12/16/25 15:25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-58
Lab Code: R2515852-032

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.9	ug/L	1.0	1	12/16/25 15:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-59
Lab Code: R2515852-033

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.7	ug/L	1.0	1	12/16/25 15:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-60
Lab Code: R2515852-034

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	12/16/25 15:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-61
Lab Code: R2515852-035

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 15:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-62
Lab Code: R2515852-036

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.8	ug/L	1.0	1	12/16/25 15:36	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515852-MB1

Service Request: R2515852
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 14:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515852-MB2

Service Request: R2515852
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 14:57	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25
Date Analyzed: 12/16/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 211.1-48A
Lab Code: R2515852-018
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515852-018MS		Duplicate Matrix Spike R2515852-018DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	22.6	20.0	113	22.9	20.0	115	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water

Service Request: R2515852
Date Collected: 11/22/25
Date Received: 11/25/25
Date Analyzed: 12/16/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 211.1-48B
Lab Code: R2515852-019
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515852-019MS		Duplicate Matrix Spike R2515852-019DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	22.9	20.0	114	22.4	20.0	112	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water

Service Request: R2515852
Date Analyzed: 12/16/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2515852-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.1	20.0	105	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Manchester Shortsville CSSD - Manchester Central S/2023L-211.1
Sample Matrix: Drinking Water

Service Request: R2515852
Date Analyzed: 12/16/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2515852-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.0	20.0	110	85-115



December 23, 2025

Service Request No:R2515849

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Manchester Shortsville CSD - Manchester Central S.

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory November 25, 2025
For your reference, these analyses have been assigned our service request number **R2515849**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S.
Sample Matrix: Drinking Water

Service Request: R2515849
Date Received: 11/25/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Twenty six drinking water samples were received for analysis at ALS Environmental on 11/25/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 12/23/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 211.1-71	Lab ID: R2515849-009
----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.9			1.0	ug/L	200.8

CLIENT ID: 211.1-73	Lab ID: R2515849-011
----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	7.3			1.0	ug/L	200.8

CLIENT ID: 211.1-75	Lab ID: R2515849-013
----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.8			1.0	ug/L	200.8

CLIENT ID: 211.1-76A	Lab ID: R2515849-014
-----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.9			1.0	ug/L	200.8

CLIENT ID: 211.1-76B	Lab ID: R2515849-015
-----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.0			1.0	ug/L	200.8

CLIENT ID: 211.1-80	Lab ID: R2515849-020
----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8

CLIENT ID: 211.1-81	Lab ID: R2515849-021
----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.4			1.0	ug/L	200.8

CLIENT ID: 211.1-82	Lab ID: R2515849-022
----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.3			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1

Service Request:R2515849

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2515849-001	211.1-63	11/22/2025	
R2515849-002	211.1-64	11/22/2025	
R2515849-003	211.1-65	11/22/2025	
R2515849-004	211.1-66	11/22/2025	
R2515849-005	211.1-67	11/22/2025	
R2515849-006	211.1-68	11/22/2025	
R2515849-007	211.1-69	11/22/2025	
R2515849-008	211.1-70	11/22/2025	
R2515849-009	211.1-71	11/22/2025	
R2515849-010	211.1-72	11/22/2025	
R2515849-011	211.1-73	11/22/2025	
R2515849-012	211.1-74	11/22/2025	
R2515849-013	211.1-75	11/22/2025	
R2515849-014	211.1-76A	11/22/2025	
R2515849-015	211.1-76B	11/22/2025	
R2515849-016	211.1-77	11/22/2025	
R2515849-017	211.1-78	11/22/2025	
R2515849-018	211.1-79A	11/22/2025	
R2515849-019	211.1-79B	11/22/2025	
R2515849-020	211.1-80	11/22/2025	
R2515849-021	211.1-81	11/22/2025	
R2515849-022	211.1-82	11/22/2025	
R2515849-023	211.1-83	11/22/2025	
R2515849-024	211.1-84A	11/22/2025	
R2515849-025	211.1-84B	11/22/2025	
R2515849-026	211.1-85	11/22/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-211

Client: Manchester Shortsville CSD

Contact: Mr. Jeff McCarthy

Building: Manchester Central School

Location: 1506 State Rte 21, Shorstville, NY

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
211.1-63	Kitchen Island Sink	Sink	
211.1-64	Kettle/Soup Sink	Sink	
211.1-65	Left Sink Next to Stove Kitchen	Sink	
211.1-66	Right Sink Next to Stove Kitchen	Sink	
211.1-67	MIDDLE SCHOOL ADDITIONS - Gym C Room E Shower Right	Shower	
211.1-68	MIDDLE SCHOOL ADDITIONS - Gym C Room E Shower Left	Shower	
211.1-69	MIDDLE SCHOOL ADDITIONS - Gym C Room D Shower Left	Shower	
211.1-70	MIDDLE SCHOOL ADDITIONS - Gym C Room D Shower Right	Shower	
211.1-71	MIDDLE SCHOOL ADDITIONS - Gym C Room I Shower	Shower	
211.1-72	MIDDLE SCHOOL ADDITIONS - Gym C Room Officials Shower Left	Shower	
211.1-73	MIDDLE SCHOOL ADDITIONS - Gym C Room Officials Shower Right	Shower	
211.1-74	Room 71 Nurses Office	Sink	
211.1-75	Room 71 Bathroom	Sink	
211.1-76A	BOCES ADDITIONS - Fountain Outside Room 69	DFB	
211.1-76B	BOCES ADDITIONS - Fountain Outside Room 69	DF	
211.1-77	Room 59	DF	
211.1-78	Room 56	Sink	
211.1-79A	BOCES ADDITIONS - Fountain Outside Room 56	DFB	

Notes:

Please e-mail lab results to labs@stohlenv.com

Mscinta@stohlenvironmental.com

Sampled By: Sam Lee Print Name

Stohl Env: Sam Lee

Date: 11/22/2025

Relinquished By: [Signature] Print Name

Stohl Env: Connor Crilly

Date: 11/25/2025

8:00 AM

Received (Name / Lab): [Signature]

Date: 11-25-25

Time: 0800

Sample Login (Name / Lab): _____

Date: _____

Time: _____

Analysis (Name / Lab): _____

Date: _____

QA/QC Review (Name / Lab): _____

Date: _____

Archived / Released: _____

QA/QC InterLAB Use: _____

Date: _____

R2515849 **5**

Stohl Environmental
 Manchester Shortsville CSD - Manchester Central S



Cooler Receipt and Preservation

R2515849

5

Stahl Environmental
Manchester Shortsville CSD - Manchester Central S



Project/Client _____ Folder Number _____

Cooler received on 11-25-25 by: TOP COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
2	Custody papers properly completed (ink, signed)?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
3	Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>

5a	Did VOA vials have sig* bubbles?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
5b	Sig* bubbles: Alk?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
	Sulfide?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
6	Where did the bottles originate?	<u>ALS/ROO</u> CLIENT
7	Soil VOA received as:	Bulk Encore 5035set <u>NA</u>

8. Temperature Readings Date: 11-25-25 Time: 0800 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>9.5</u>						
Within 0-6°C?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>
If <0°C, were samples frozen?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>

If out of Temperature, note packing/ice condition: Lead Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMD by TOP on 11-25 at 0820
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 12/1 Time: 2200 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO NA
- 13. Were dissolved metals filtered in the field? YES NO NA
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated NA

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
>12		NaOH								
<2	<u>202325</u>	HNO ₃		X	<u>NO Lot INTD</u>		<u>A11</u>	<u>4mL</u>		<u>5.2</u>
<2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____
Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1

Service Request: R2515849

Sample Name: 211.1-63
Lab Code: R2515849-001
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-64
Lab Code: R2515849-002
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-65
Lab Code: R2515849-003
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-66
Lab Code: R2515849-004
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-67
Lab Code: R2515849-005
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1

Service Request: R2515849

Sample Name: 211.1-68
Lab Code: R2515849-006
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-69
Lab Code: R2515849-007
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-70
Lab Code: R2515849-008
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-71
Lab Code: R2515849-009
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-72
Lab Code: R2515849-010
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1

Service Request: R2515849

Sample Name: 211.1-73
Lab Code: R2515849-011
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-74
Lab Code: R2515849-012
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-75
Lab Code: R2515849-013
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-76A
Lab Code: R2515849-014
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-76B
Lab Code: R2515849-015
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1

Service Request: R2515849

Sample Name: 211.1-77
Lab Code: R2515849-016
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-78
Lab Code: R2515849-017
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-79A
Lab Code: R2515849-018
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-79B
Lab Code: R2515849-019
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-80
Lab Code: R2515849-020
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1

Service Request: R2515849

Sample Name: 211.1-81
Lab Code: R2515849-021
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-82
Lab Code: R2515849-022
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-83
Lab Code: R2515849-023
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-84A
Lab Code: R2515849-024
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 211.1-84B
Lab Code: R2515849-025
Sample Matrix: Drinking Water

Date Collected: 11/22/25
Date Received: 11/25/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental

Service Request: R2515849

Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1

Sample Name: 211.1-85

Date Collected: 11/22/25

Lab Code: R2515849-026

Date Received: 11/25/25

Sample Matrix: Drinking Water

Analysis Method

Extracted/Digested By

Analyzed By

200.8

MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-63
Lab Code: R2515849-001

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 13:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-64
Lab Code: R2515849-002

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 13:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-65
Lab Code: R2515849-003

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 13:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-66
Lab Code: R2515849-004

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 13:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-67
Lab Code: R2515849-005

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 13:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-68
Lab Code: R2515849-006

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 13:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-69
Lab Code: R2515849-007

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 13:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-70
Lab Code: R2515849-008

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 13:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-71
Lab Code: R2515849-009

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.9	ug/L	1.0	1	12/16/25 13:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-72
Lab Code: R2515849-010

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 13:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-73
Lab Code: R2515849-011

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.3	ug/L	1.0	1	12/16/25 13:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-74
Lab Code: R2515849-012

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 13:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-75
Lab Code: R2515849-013

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.8	ug/L	1.0	1	12/16/25 13:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-76A
Lab Code: R2515849-014

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.9	ug/L	1.0	1	12/16/25 13:42	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-76B
Lab Code: R2515849-015

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.0	ug/L	1.0	1	12/16/25 13:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-77
Lab Code: R2515849-016

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 13:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-78
Lab Code: R2515849-017

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 13:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-79A
Lab Code: R2515849-018

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 13:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-79B
Lab Code: R2515849-019

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 13:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-80
Lab Code: R2515849-020

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	12/16/25 13:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-81
Lab Code: R2515849-021

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.4	ug/L	1.0	1	12/16/25 13:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-82
Lab Code: R2515849-022

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.3	ug/L	1.0	1	12/16/25 13:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-83
Lab Code: R2515849-023

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 13:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-84A
Lab Code: R2515849-024

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 14:00	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-84B
Lab Code: R2515849-025

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 13:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: 211.1-85
Lab Code: R2515849-026

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25 08:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 13:48	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515849-MB1

Service Request: R2515849
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 12:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515849-MB2

Service Request: R2515849
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/16/25 13:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515849-MB3

Service Request: R2515849
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 13:37	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25
Date Analyzed: 12/16/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 211.1-66
Lab Code: R2515849-004
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515849-004MS		Result	Duplicate Matrix Spike R2515849-004DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	21.3	20.0	107	20.9	20.0	104	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25
Date Analyzed: 12/16/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 211.1-67
Lab Code: R2515849-005
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515849-005MS		Duplicate Matrix Spike R2515849-005DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	22.1	20.0	111	21.4	20.0	107	70-130	3	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water

Service Request: R2515849
Date Collected: 11/22/25
Date Received: 11/25/25
Date Analyzed: 12/16/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 211.1-84A
Lab Code: R2515849-024
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515849-024MS		Duplicate Matrix Spike R2515849-024DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	21.2	20.0	106	21.8	20.0	109	70-130	3	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water

Service Request: R2515849

Date Analyzed: 12/16/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample
R2515849-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.9	20.0	104	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water

Service Request: R2515849
Date Analyzed: 12/16/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2515849-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.5	20.0	103	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Manchester Shortsville CSD - Manchester Central S./2023L-211.1
Sample Matrix: Drinking Water

Service Request: R2515849

Date Analyzed: 12/19/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L


Basis:NA

Lab Control Sample
R2515849-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	18.4	20.0	92	85-115

1.5 Laboratory Certifications

**NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER**



Expires 12:01 AM April 01, 2026
Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE
Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. CHRISTINE KUTZER
ALS ENVIRONMENTAL - ROCHESTER
1565 JEFFERSON ROAD BUILDING 300, SUITE 360
ROCHESTER, NY 14623


NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Bacteriology	
Coliform, Total / E. coli (Qualitative)	SM 20. 21-23 9223B (-04) (Collert)
Dissolved Gases	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
Fuel Additives	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
Metals I	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Zinc, Total	EPA 200.7 Rev. 4.4

Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elapublicweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.



Page 1 of 5