

Lead in School Drinking Water Report

Liberty Ridge Elementary School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-12-17

Date(s) analyzed: 2025-12-22, 2026-01-07

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	414226	Main Building	Fountain/Tap Combo	Pod Sink Outside Of Room 8	1 of 1	Water Fountain	right	120
2	414252	Main Building	Fountain/Tap Combo	Pod Sink Outside Of Room 13	1 of 1	Tap	center	37
3	414225	Main Building	Fountain/Tap Combo	Pod Sink Outside Of Room 8	1 of 1	Tap	center	25
4	414213	Main Building	Fountain/Tap Combo	Room 3	1 of 2	Water Fountain	left	22
5	414216	Main Building	Fountain/Tap Combo	Room 4	1 of 2	Tap	left	18
6	414267	Main Building	Fountain/Tap Combo	Pod Sink Outside Of Room 19	1 of 1	Tap	center	16
7	414258	Main Building	Fountain/Tap Combo	Links Room	1 of 1	Tap	center	10
8	414212	Main Building	Fountain/Tap Combo	Room 3	1 of 2	Tap	left	9
9	414257	Main Building	Fountain/Tap Combo	Room 11	1 of 1	Water Fountain	right	8
10	414219	Main Building	Fountain/Tap Combo	Room 5	1 of 1	Tap	center	7

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	414239	Portable 38	Sink	Portable 38	2 of 2. East side of room	Tap	center	7
12	414271	Main Building	Fountain/Tap Combo	Room 18	1 of 1	Tap	center	7
13	414270	Main Building	Fountain/Tap Combo	Room 20	1 of 1	Water Fountain	right	6
14	414211	Main Building	Fountain/Tap Combo	Room 2a	2 of 2	Water Fountain	right	5
15	414243	Main Building	Fountain/Tap Combo	Room 9	1 of 1	Tap	center	5
16	414245	Main Building	Fountain/Tap Combo	Room 10	1 of 1	Tap	center	5
17	414200	Main Building	Sink	Kitchen	1 of 1	Tap	center	4
18	414202	Main Building	Sink	Nurses Office	1 of 1	Tap	center	4
19	414221	Main Building	Fountain/Tap Combo	Room 7	1 of 1	Tap	center	4
20	414273	Main Building	Fountain/Tap Combo	Room 16	1 of 1	Tap	center	4
21	414275	Main Building	Sink	Library Office	1 of 1	Tap	center	4

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
22	414205	Main Building	Fountain/Tap Combo	Music Room	1 of 1	Tap	center	3
23	414210	Main Building	Fountain/Tap Combo	Room 2a	2 of 2	Tap	right	3
24	414223	Main Building	Fountain/Tap Combo	Room 8	1 of 1	Tap	center	3
25	414231	Main Building	Sink	Work Center	1 of 1	Tap	center	3
26	414247	Main Building	Sink	Pod B Work Center	1 of 1	Tap	center	3
27	414253	Main Building	Fountain/Tap Combo	Pod Sink Outside Of Room 13	1 of 1	Water Fountain	right	3
28	414256	Main Building	Fountain/Tap Combo	Room 11	1 of 1	Tap	center	3
29	414260	Main Building	Fountain/Tap Combo	Room 16	1 of 1	Tap	center	3
30	414265	Main Building	Fountain/Tap Combo	Room 19	1 of 1	Tap	center	3
31	414203	Main Building	Sink - Multi-Compartment	Staff Lounge	1 of 1	Tap	center	2
32	414206	Main Building	Fountain/Tap Combo	Music Room	1 of 1	Water Fountain	left	2
33	414220	Main Building	Fountain/Tap Combo	Room 5	1 of 1	Water Fountain	right	2

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
34	414222	Main Building	Fountain/Tap Combo	Room 7	1 of 1	Water Fountain	right	2
35	414227	Main Building	Fountain/Tap Combo	Room 6	1 of 1	Tap	center	2
36	414229	Main Building	Fountain/Tap Combo	Room 4	1 of 1	Tap	center	2
37	414232	Main Building	Fountain/Tap Combo	Room 2	1 of 1	Tap	center	2
38	414236	Portable 36	Sink	Portable 36	3 of 4	Tap	right	2
39	414248	Main Building	Fountain/Tap Combo	Room 12	1 of 1	Tap	center	2
40	414250	Main Building	Fountain/Tap Combo	Room 14	1 of 1	Tap	center	2
41	414254	Main Building	Fountain/Tap Combo	Room 13	1 of 1	Tap	center	2
42	414262	Main Building	Sink	Pod C Work Center	1 of 1	Tap	center	2
43	414263	Main Building	Fountain/Tap Combo	Room 17	1 of 1	Tap	center	2
44	414268	Main Building	Fountain/Tap Combo	Pod Sink Outside Of Room 19	1 of 1	Water Fountain	right	2
45	414209	Main Building	Fountain/Tap Combo	Room 2a	1 of 2	Tap	left	1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
46	414214	Main Building	Fountain/Tap Combo	Room 3	2 of 2	Tap	right	1
47	414217	Main Building	Fountain/Tap Combo	Room 4	2 of 2	Tap	right	1
48	414218	Main Building	Fountain/Tap Combo	Room 4	2 of 2	Water Fountain	right	1
49	414237	Portable 36	Sink - Multi-Compartment	Portable 36	4 of 4. Kitchenette	Tap	center	1
50	414238	Portable 38	Sink	Portable 38	2 of 2. West side of room	Tap	center	1
51	414251	Main Building	Fountain/Tap Combo	Room 14	1 of 1	Water Fountain	right	1
52	414274	Main Building	Fountain/Tap Combo	Room 16	1 of 1	Water Fountain	right	1
53	414201	Main Building	Sink	Kitchen	1 of 1	Sprayer	center	<1
54	414204	Main Building	Fountain	Hallway Across From Staff Lounge	1 of 1	Water Fountain	right	<1
55	414207	Main Building	Fountain with Bottle Filler	Main Entrance	1 of 1	Water Bottle Filler	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
56	414208	Main Building	Fountain with Bottle Filler	Main Entrance	1 of 1	Water Fountain	right	<1
57	414215	Main Building	Fountain/Tap Combo	Room 3	2 of 2	Water Fountain	right	<1
58	414224	Main Building	Fountain/Tap Combo	Room 8	1 of 1	Water Fountain	right	<1
59	414228	Main Building	Fountain/Tap Combo	Room 6	1 of 1	Water Fountain	right	<1
60	414230	Main Building	Fountain/Tap Combo	Room 4	1 of 1	Water Fountain	right	<1
61	414233	Main Building	Fountain/Tap Combo	Room 2	1 of 1	Water Fountain	right	<1
62	414234	Portable 36	Sink	Portable 36	1 of 4	Tap	left	<1
63	414235	Portable 36	Sink	Portable 36	2 of 4	Tap	center	<1
64	414240	Portable 40	Fountain/Tap Combo	Portable 40	1 of 2	Tap	center	<1
65	414241	Portable 40	Fountain/Tap Combo	Portable 40	1 of 2	Water Fountain	right	<1
66	414242	Portable 40	Sink	Portable 40	2 of 2	Tap	center	<1
67	414244	Main Building	Fountain/Tap Combo	Room 9	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
68	414246	Main Building	Fountain/Tap Combo	Room 10	1 of 1	Water Fountain	right	<1
69	414249	Main Building	Fountain/Tap Combo	Room 12	1 of 1	Water Fountain	right	<1
70	414255	Main Building	Fountain/Tap Combo	Room 13	1 of 1	Water Fountain	right	<1
71	414259	Main Building	Fountain/Tap Combo	Links Room	1 of 1	Water Fountain	right	<1
72	414261	Main Building	Fountain/Tap Combo	Room 16	1 of 1	Water Fountain	right	<1
73	414264	Main Building	Fountain/Tap Combo	Room 17	1 of 1	Water Fountain	right	<1
74	414266	Main Building	Fountain/Tap Combo	Room 19	1 of 1	Water Fountain	right	<1
75	414269	Main Building	Fountain/Tap Combo	Room 20	1 of 1	Tap	center	<1
76	414272	Main Building	Fountain/Tap Combo	Room 18	1 of 1	Water Fountain	right	<1