

Lead in School Drinking Water Report

Bonney Lake High School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-12-20

Date(s) analyzed: 2025-12-24, 2026-01-07

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	411892	Area 100	Pot Filler	Kitchen	2 of 7. Next to knife holder	Sprayer	center	166
2	411899	Area 100	Pot Filler	Kitchen	6 of 7	Tap	right	45
3	411898	Area 100	Pot Filler	Kitchen	6 of 7. Large pot	Tap	left	22
4	414390	Area 400	Sink	Room 459	1 of 1	Tap	center	12
5	411880	Area 300	Sink	Room 309	1 of 1	Tap	center	11
6	414384	Area 300	Sink	Room 359 Faculty Office	1 of 1	Tap	center	11
7	414395	Area 400	Sink	Room 409	1 of 1	Tap	center	11
8	411884	Area 200	Sink	Room 208	1 of 1	Tap	center	8
9	411900	Area 100	Sink	Kitchen	7 of 7. Meat sink	Tap	center	8
10	411893	Area 100	Sink - Multi-Compartment	Kitchen	3 of 7. Prep sink	Tap	center	6

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
					facing NE			
11	411910	Area 500	Fountain/Tap Combo	Room 505	1 of 1	Tap	center	6
12	411890	Area 100	Sink - Multi-Compartment	Kitchen	1 of 7. Wall near exit	Tap	left	5
13	411895	Area 100	Sink - Multi-Compartment	Kitchen	4 of 7. Prep sink facing SW	Tap	center	5
14	414397	Area 300	Fountain/Tap Combo	Room 305	1 of 1	Tap	center	5
15	411888	Area 200	Fountain/Tap Combo	Pod Sink Outside Of Room 202	1 of 1	Tap	center	4
16	411894	Area 100	Sink - Multi-Compartment	Kitchen	3 of 7. Prep sink facing NE	Sprayer	center	4
17	411919	Portable 801	Sink	Portable 801	2 of 4	Tap	left	4
18	411923	Portable 802	Sink - Multi-Compartment	South Side Classroom	1 of 1	Tap	center	4

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
19	414379	Area 200	Fountain/Tap Combo	Room 253	1 of 1	Tap	center	4
20	411889	Area 200	Fountain/Tap Combo	Pod Sink Outside Of Room 202	1 of 1	Water Fountain	right	3
21	411896	Area 100	Sink - Multi-Compartment	Kitchen	4 of 7. Prep sink facing SW	Sprayer	center	3
22	411912	Area 500	Fountain/Tap Combo	Room 506	1 of 1	Tap	center	3
23	414382	Area 300	Fountain/Tap Combo	Pod Sink Outside Of Room 355	1 of 1	Tap	center	3
24	414387	Area 400	Fountain/Tap Combo	Room 455	1 of 1	Tap	center	3
25	414392	Area 400	Fountain/Tap Combo	Room 406	1 of 1	Tap	center	3
26	414396	Area 300	Sink	Room 301c	1 of 1	Tap	center	3
27	414399	Area 300	Fountain/Tap Combo	Pod Sink Outside Of Room 304	1 of 1	Water Fountain	right	3
28	411886	Area 200	Fountain/Tap Combo	Room 203	1 of 1	Tap	center	2

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
29	411887	Area 200	Fountain/Tap Combo	Room 203	1 of 1	Water Fountain	right	2
30	411891	Area 100	Sink - Multi-Compartment	Kitchen	1 of 7. Wall near exit	Tap	right	2
31	411907	Area 100	Sink - Multi-Compartment	Student Store	1 of 1	Tap	center	2
32	411913	Area 600 - Gym	Fountain	Main Gym	1 of 1	Water Fountain	right	2
33	411920	Portable 801	Sink	Portable 801	3 of 4	Tap	right	2
34	411921	Portable 801	Sink - Multi-Compartment	Portable 801	4 of 4. Kitchenette closest to exit	Tap	center	2
35	414376	Area 200	Sink	Nurses Office	1 of 1	Tap	center	2
36	414378	Area 200	Sink - Multi-Compartment	Room 257	1 of 1	Tap	center	2
37	414380	Area 200	Fountain/Tap Combo	Room 253	1 of 1	Water Fountain	right	2
38	414385	Area 400	Sink	450 Wing Office	1 of 1	Tap	center	2
39	414386	Area 400	Fountain/Tap Combo	Pod Sink Outside Of Room 455	1 of 1	Tap	center	2

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
40	414388	Area 400	Fountain/Tap Combo	Room 455	1 of 1	Water Fountain	right	2
41	414391	Area 400	Sink	Room 401c	1 of 1	Tap	center	2
42	414393	Area 400	Fountain/Tap Combo	Pod Sink Outside Of Room 405	1 of 1	Tap	center	2
43	411902	Area 100	Sink - Multi-Compartment	Room 104	2 of 6. station 2	Tap	center	1
44	411906	Area 100	Sink - Multi-Compartment	Room 104	6 of 6. Station 6	Tap	center	1
45	411916	Area 600 - Gym	Fountain	Aux Gym	1 of 1	Water Fountain	right	1
46	414377	Area 200	Sink	Room 251c	1 of 1	Tap	center	1
47	414381	Area 300	Sink	350 Wing Office	1 of 1	Tap	center	1
48	414398	Area 300	Fountain/Tap Combo	Pod Sink Outside Of Room 304	1 of 1	Tap	center	1
49	411881	Area 100	Fountain with Bottle Filler	Cafeteria	1 of 1	Water Bottle Filler	center	<1
50	411882	Area 100	Fountain with Bottle Filler	Cafeteria	1 of 1	Water Fountain	right	<1
51	411883	Area 200	Sink	Room 201c	1 of 1	Tap	center	<1
52	411897	Area 100	Ice Machine	Kitchen	5 of 7	Ice Machine	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
53	411901	Area 100	Sink - Multi-Compartment	Room 104	1 of 6. Station 1	Tap	center	<1
54	411903	Area 100	Sink - Multi-Compartment	Room 104	3 of 6. Station 3	Tap	center	<1
55	411904	Area 100	Sink - Multi-Compartment	Room 104	4 of 6. Station 4	Tap	center	<1
56	411905	Area 100	Sink - Multi-Compartment	Room 104	5 of 6. Station 5	Tap	center	<1
57	411908	Area 500	Sink	Wing Office 500	1 of 1	Tap	center	<1
58	411911	Area 500	Fountain/Tap Combo	Room 505	1 of 1	Water Fountain	right	<1
59	411914	Area 600 - Gym	Fountain with Bottle Filler	Gym Hall	1 of 1	Water Bottle Filler	center	<1
60	411915	Area 600 - Gym	Fountain with Bottle Filler	Gym Hall	1 of 1	Water Fountain	right	<1
61	411917	Area 600 - Gym	Fountain	Hall Next To Training Room	1 of 1	Water Fountain	right	<1
62	411918	Portable 801	Sink - Multi-Compartment	Portable 801	1 of 4	Tap	center	<1
63	411922	Portable 802	Sink - Multi-Compartment	North Side Classroom	1 of 1	Tap	center	<1
64	414375	Area 200	Sink	Staff Lounge	1 of 1	Tap	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
65	414383	Area 300	Fountain/Tap Combo	Pod Sink Outside Of Room 355	1 of 1	Water Fountain	right	<1
66	414394	Area 400	Fountain/Tap Combo	Pod Sink Outside Of Room 405	1 of 1	Water Fountain	right	<1