

Lead in School Drinking Water Report

Maple Lawn Elementary School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-12-19

Date(s) analyzed: 2025-12-30

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	414302	Main Building	Fountain/Tap Combo	Room 28	1 of 1	Tap	center	4
2	414280	Main Building	Sink	Kitchen	1 of 1	Tap	center	2
3	414284	Main Building	Fountain/Tap Combo	Room 20	1 of 1	Tap	center	2
4	414286	Main Building	Fountain/Tap Combo	Room 21	1 of 1	Tap	center	2
5	414292	Main Building	Fountain/Tap Combo	Room 25	1 of 1	Tap	center	2
6	414296	Main Building	Fountain/Tap Combo	Room 27	1 of 1	Tap	center	2
7	414304	Main Building	Fountain	Hallway In Between Restrooms Next To Room 28	1 of 1	Water Fountain	left	2
8	414305	Main Building	Fountain/Tap Combo	Room 10	1 of 1	Tap	center	2
9	414317	Main Building	Fountain/Tap Combo	Room 5	1 of 1	Tap	center	2
10	414369	Main Building	Sink	Nurses Office	1 of 1	Tap	center	2

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	414371	Main Building	Fountain/Tap Combo	Music Room	1 of 1	Tap	center	2
12	414281	Main Building	Fountain - Multi-Level with Bottle Filler	Cafeteria	1 of 1	Water Fountain	left	1
13	414287	Main Building	Fountain/Tap Combo	Room 21	1 of 1	Water Fountain	right	1
14	414288	Main Building	Fountain/Tap Combo	Room 23	1 of 1	Tap	center	1
15	414294	Main Building	Fountain/Tap Combo	Room 24	1 of 1	Tap	center	1
16	414297	Main Building	Fountain/Tap Combo	Room 27	1 of 1	Water Fountain	right	1
17	414303	Main Building	Fountain/Tap Combo	Room 28	1 of 1	Water Fountain	right	1
18	414311	Main Building	Fountain/Tap Combo	Room 8	1 of 1	Tap	center	1
19	414313	Main Building	Fountain/Tap Combo	Room 6	1 of 1	Tap	center	1
20	414319	Main Building	Fountain/Tap Combo	Room 4	1 of 1	Tap	center	1
21	414361	Main Building	Fountain/Tap Combo	Room 2	1 of 1	Tap	center	1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
22	414363	Main Building	Fountain/Tap Combo	Room 3	1 of 2	Tap	left	1
23	414365	Main Building	Fountain/Tap Combo	Room 1	1 of 2	Tap	right	1
24	414367	Main Building	Fountain/Tap Combo	Room 1	2 of 2	Tap	left	1
25	414373	Main Building	Fountain/Tap Combo	Library Office	1 of 1	Tap	center	1
26	414282	Main Building	Fountain - Multi-Level with Bottle Filler	Cafeteria	1 of 1	Water Fountain	right	<1
27	414283	Main Building	Fountain	Gym	1 of 1	Water Fountain	right	<1
28	414285	Main Building	Fountain/Tap Combo	Room 20	1 of 1	Water Fountain	right	<1
29	414289	Main Building	Fountain/Tap Combo	Room 23	1 of 1	Water Fountain	right	<1
30	414290	Main Building	Fountain/Tap Combo	Room 22	1 of 1	Tap	center	<1
31	414291	Main Building	Fountain/Tap Combo	Room 22	1 of 1	Water Fountain	right	<1
32	414293	Main Building	Fountain/Tap Combo	Room 25	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
33	414295	Main Building	Fountain/Tap Combo	Room 24	1 of 1	Water Fountain	right	<1
34	414298	Main Building	Fountain/Tap Combo	Room 29	1 of 1	Tap	center	<1
35	414299	Main Building	Fountain/Tap Combo	Room 29	1 of 1	Water Fountain	left	<1
36	414300	Main Building	Fountain/Tap Combo	Room 26	1 of 1	Tap	center	<1
37	414301	Main Building	Fountain/Tap Combo	Room 26	1 of 1	Water Fountain	right	<1
38	414306	Main Building	Fountain/Tap Combo	Room 10	1 of 1	Water Fountain	right	<1
39	414307	Main Building	Fountain/Tap Combo	Room 11	1 of 1	Tap	center	<1
40	414308	Main Building	Fountain/Tap Combo	Room 11	1 of 1	Water Fountain	right	<1
41	414309	Main Building	Fountain/Tap Combo	Room 9	1 of 1	Tap	center	<1
42	414310	Main Building	Fountain/Tap Combo	Room 9	1 of 1	Water Fountain	right	<1
43	414312	Main Building	Fountain/Tap Combo	Room 8	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
44	414314	Main Building	Fountain/Tap Combo	Room 6	1 of 1	Water Fountain	right	<1
45	414315	Main Building	Fountain/Tap Combo	Room 7	1 of 1	Tap	center	<1
46	414316	Main Building	Fountain/Tap Combo	Room 7	1 of 1	Water Fountain	right	<1
47	414318	Main Building	Fountain/Tap Combo	Room 5	1 of 1	Water Fountain	right	<1
48	414360	Main Building	Fountain/Tap Combo	Room 4	1 of 1	Water Fountain	right	<1
49	414362	Main Building	Fountain/Tap Combo	Room 2	1 of 1	Water Fountain	right	<1
50	414364	Main Building	Fountain/Tap Combo	Room 3	2 of 2	Tap	right	<1
51	414366	Main Building	Fountain/Tap Combo	Room 1	1 of 2	Water Fountain	right	<1
52	414368	Main Building	Fountain/Tap Combo	Room 1	2 of 2	Water Fountain	left	<1
53	414370	Main Building	Sink	Staff Lounge	1 of 1	Tap	center	<1
54	414372	Main Building	Fountain/Tap Combo	Music Room.	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
55	414374	Main Building	Fountain/Tap Combo	Library Office	1 of 1	Water Fountain	right	<1