

January 6, 2026

Ms. Georgia Militello  
Ken-Ton UFSD  
1500 Colvin Boulevard  
Buffalo, New York 14223

**Re: Lead Testing in School Drinking Water**

Dear Ms. Militello:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Ken-Ton UFSD, including:

- **Herbert Hoover Elementary School – 199 Thorncliff Road, Buffalo, NY**

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: Lead Testing in School Drinking Water, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on November 18, 2025. As detailed in Section 1.2 (Executive Summary) of the accompanying report, based upon the sampling and analysis performed, 2 sources of potable water in Herbert Hoover Elementary School have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion. To comply with NYS regulations, response actions by the district are required. Response actions are outlined in Section 1.3 (Response Actions Required Under NYS Regulations).

Thank you for the opportunity to be of service to Ken-Ton UFSD.

Sincerely,  
Stohl Environmental, LLC.



Michael Scinta  
EPA Lead Risk Assessor

**Lead Testing in School Drinking Water**

**Prepared for:**

**Ken-Ton UFSD**

**Prepared by:**



**3860 California Road  
Orchard Park, New York 14127**

**Conditions as of November 18, 2025**

## Summary Tabulation

### Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports and Chain of Custody Documents
- 1.5. Laboratory Certifications

## 1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Ken-Ton UFSD to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- **Herbert Hoover Elementary School – 199 Thorncliff Road, Buffalo, NY**

### Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within Herbert Hoover Elementary School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

### Sampling Protocol:

In accordance with NYS regulations, **Subpart 67-4: Lead Testing in School Drinking Water**, and the EPA guidance document, **3Ts for Reducing Lead in Drinking Water in Schools**, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

**1.2 Executive Summary of Sampling and Analysis:**

**Summary of Samples Collected at Herbert Hoover Elementary School:**

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Herbert Hoover Elementary School	November 18, 2025	113	11	2

*\*NYS Action Level is 5 parts per billion*

**Listing of Outlets Requiring Remediation**

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
102.4-81	Room 220 Sink	Sink	7.4
102.4-82	Room 214 Sink	Sink	11.5

**1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:**

For outlets analyzed with a lead concentration more than the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
  - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
  - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

**1.4 Laboratory Analytical Reports and Chain of Custody Documents**



December 16, 2025

Service Request No:R2515822

Michael Scinta  
Stohl Environmental  
3860 California Road  
Orchard Park, NY 14219

**Laboratory Results for: Kenton UFSD - Herbert Hoover Elementary School**

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory November 21, 2025  
For your reference, these analyses have been assigned our service request number **R2515822**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at [Meghan.Pedro@alsglobal.com](mailto:Meghan.Pedro@alsglobal.com).

Respectfully submitted,

**ALS Group USA, Corp. dba ALS Environmental**

Meghan Pedro  
Project Manager

CC: Rebecca  
Franjoine

**ADDRESS**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

**PHONE** +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.  
dba ALS Environmental



# Narrative Documents

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School  
**Sample Matrix:** Drinking Water

**Service Request:** R2515822  
**Date Received:** 11/21/2025

**CASE NARRATIVE**

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

**Sample Receipt:**

Thirty six drinking water samples were received for analysis at ALS Environmental on 11/21/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

**Metals:**

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by \_\_\_\_\_

Date 12/16/2025



### SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 102.4-7		Lab ID: R2515822-008					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.4			1.0	ug/L	200.8	
CLIENT ID: 102.4-9		Lab ID: R2515822-010					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.8			1.0	ug/L	200.8	
CLIENT ID: 102.4-10		Lab ID: R2515822-011					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.2			1.0	ug/L	200.8	
CLIENT ID: 102.4-12		Lab ID: R2515822-013					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.1			1.0	ug/L	200.8	
CLIENT ID: 102.4-13		Lab ID: R2515822-014					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.8			1.0	ug/L	200.8	
CLIENT ID: 102.4-14		Lab ID: R2515822-015					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.2			1.0	ug/L	200.8	
CLIENT ID: 102.4-16		Lab ID: R2515822-017					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.6			1.0	ug/L	200.8	
CLIENT ID: 102.4-19		Lab ID: R2515822-020					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.1			1.0	ug/L	200.8	
CLIENT ID: 102.4-20		Lab ID: R2515822-021					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.7			1.0	ug/L	200.8	
CLIENT ID: 102.4-22		Lab ID: R2515822-023					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.0			1.0	ug/L	200.8	
CLIENT ID: 102.4-25		Lab ID: R2515822-026					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.3			1.0	ug/L	200.8	



## Sample Receipt Information

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:**R2515822

**SAMPLE CROSS-REFERENCE**

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2515822-001	102.4-1A	11/18/2025	
R2515822-002	102.4-1B	11/18/2025	
R2515822-003	102.4-2	11/18/2025	
R2515822-004	102.4-3	11/18/2025	
R2515822-005	102.4-4	11/18/2025	
R2515822-006	102.4-5	11/18/2025	
R2515822-007	102.4-6	11/18/2025	
R2515822-008	102.4-7	11/18/2025	
R2515822-009	102.4-8	11/18/2025	
R2515822-010	102.4-9	11/18/2025	
R2515822-011	102.4-10	11/18/2025	
R2515822-012	102.4-11	11/18/2025	
R2515822-013	102.4-12	11/18/2025	
R2515822-014	102.4-13	11/18/2025	
R2515822-015	102.4-14	11/18/2025	
R2515822-016	102.4-15	11/18/2025	
R2515822-017	102.4-16	11/18/2025	
R2515822-018	102.4-17	11/18/2025	
R2515822-019	102.4-18	11/18/2025	
R2515822-020	102.4-19	11/18/2025	
R2515822-021	102.4-20	11/18/2025	
R2515822-022	102.4-21	11/18/2025	
R2515822-023	102.4-22	11/18/2025	
R2515822-024	102.4-23	11/18/2025	
R2515822-025	102.4-24	11/18/2025	
R2515822-026	102.4-25	11/18/2025	
R2515822-027	102.4-26	11/18/2025	
R2515822-028	102.4-27	11/18/2025	
R2515822-029	102.4-28	11/18/2025	
R2515822-030	102.4-29	11/18/2025	
R2515822-031	102.4-30	11/18/2025	
R2515822-032	102.4-31	11/18/2025	
R2515822-033	102.4-32	11/18/2025	
R2515822-034	102.4-33	11/18/2025	
R2515822-035	102.4-34	11/18/2025	
R2515822-036	102.4-35	11/18/2025	



# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS  
 STOHL Job # 2023L-102.4

Client: Kenton UFSD Contact: Georgia Militello  
 Building: Herbert Hoover Elementary School Location: 199 Thorncliff Rd, Buffalo, NY 14223

**LEAD**  
 Water by 200.8 X Turnaround 10 Days

Sample #	Location	Outlet Type	Time
102.4-1A	Cafeteria DF	DF	5:05
102.4-1B	Cafeteria DFB	DFB	5:06
102.4-2	Kitchen 3 Bay L	Sink	5:07
102.4-3	Kitchen 3 Bay R	Sink	5:08
102.4-4	Kitchen Dish Sprayer	Sprayer	5:10
102.4-5	Kitchen Hand Wash Next to 3 Bay	Sink	5:11
102.4-6	Kitchen Hand Wash Next to 3 Fridges	Sink	5:12
102.4-7	Kitchen 2 Bay	Sink	5:13
102.4-8	Kitchen Prep Sink	Sink	5:15
102.4-9	Kitchen 2 Bay Back Wall	Sink	5:16
102.4-10	Kitchen L Pot Filler	Pot Filler	5:17
102.4-11	Kitchen R Pot Filler	Pot Filler	5:19
102.4-12	Kitchen Back Wall Hand Wash	Sink	5:20
102.4-13	Kitchen Oven Sprayer	Pressure Cooker	5:21
102.4-14	Kitchen Bathroom Sink	Sink	5:22
102.4-15	Serving Line Spout	Faucet	5:24
102.4-16	Engineer Bathroom Sink	Sink	5:25
102.4-17	136-4 Boys Bathroom Sink	Sink	5:26

Notes:  
 Please e-mail lab results to labs@stohlenv.com  If checked, also e-mail results to: Mscinta@stohlenvironmental.com

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 11/18/2025  
 Relinquished By: \_\_\_\_\_ Print Name \_\_\_\_\_ Stohl Env: Connor Crilly Date: 11/19/2025  
 Received (Name / Lab): EMM Quinn ALS Date: 11/21/25 Time: 8:25  
 Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_





# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.4

Client: Kenton UFSD

Contact: Georgia Militello

Building: Herbert Hoover Elementary School

Location: 199 Thorncliff Rd, Buffalo, NY 14223

**LEAD**

Water by 200.8 X

*Turnaround*

10 Days

Sample #	Location	Outlet Type	Time
102.4-18	136-3 Girls Bathroom Sink	Sink	5:28
102.4-19	Auditorium Womens Bathroom	Sink	5:29
102.4-20	Auditorium Mens Bathroom	Sink	5:30
102.4-21	Room 135 Bathroom Sink	Sink	5:31
102.4-22	Room 130 Bathroom Sink	Sink	5:33
102.4-23	Room 106 Sink	Sink	5:34
102.4-24	Room 106 L Bathroom Sink	Sink	5:35
102.4-25	Room 106 R Bathroom Sink	Sink	5:37
102.4-26	Room 104 Sink	Sink	5:38
102.4-27	Room 104 Bathroom Sink	Sink	5:39
102.4-28	Room 102 Sink	Sink	5:40
102.4-29	Room 102 Bathroom Sink	Sink	5:42
102.4-30	Room 101 Sink	Sink	5:43
102.4-31	Room 101 Bathroom Sink	Sink	5:44
102.4-32	Room 103 Sink	Sink	5:46
102.4-33	Room 103 Bathroom Sink	Sink	5:47
102.4-34	Room 105 Sink	Sink	5:48
102.4-35	Room 105 Bathroom Sink	Sink	5:49

Notes:

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

[Mscinta@stohlenvironmental.com](mailto:Mscinta@stohlenvironmental.com)

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 11/18/2025

Relinquished By: \_\_\_\_\_ Print Name \_\_\_\_\_ Stohl Env: Connor Crilly Date: 11/19/2025

Received (Name / Lab): MM ALS Date: 11/21/25 Time: 8:25

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



**R2515822** **5**  
 Stahl Environmental  
 Kenton UFSD - Herbert Hoover Elementary School

**Cooler Receipt and Preservation Check**

Project/Client Stohl Folder Number \_\_\_\_\_

Cooler received on 11/21/25 by: RM COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>(N)</u>	5a	Did VOA vials have sig* bubbles?	Y N <u>(NA)</u>
2	Custody papers properly completed (ink, signed)?	<u>(Y)</u> N	5b	Sig* bubbles: Alk? Y N <u>(NA)</u> Sulfide? Y N <u>(NA)</u>	
3	Did all bottles arrive in good condition (unbroken)?	<u>(Y)</u> N	6	Where did the bottles originate?	<u>(ALS/ROC)</u> CLIENT
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>(N)</u>	7	Soil VOA received as: Bulk Encore 5035set	<u>(NA)</u>

8. Temperature Readings Date: 11/21/25 Time: 8:32 ID: (IR#12) IR#11 From: Temp Blank (Sample Bottle)

Temp (°C)	<u>10.2</u>						
Within 0-6°C?	Y <u>(N)</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: No ice Ice melted Poorly Packed (described below) Same Day Rule  
 & Client Approval to Run Samples: \_\_\_\_\_ Standing Approval Client aware at drop-off Client notified by: \_\_\_\_\_

All samples held in storage location: SMO by RM on 11/21 at 8:32  
 5035 samples placed in storage location: \_\_\_\_\_ by \_\_\_\_\_ on \_\_\_\_\_ at \_\_\_\_\_ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check\*\*: Date: 11/26 Time: 1546 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO (N/A)
- 13. Were dissolved metals filtered in the field? YES NO (N/A)
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated (N/A)

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
<u>≤2</u>	<u>202325</u>	HNO <sub>3</sub>	<u>X</u>		<u>24017F06</u>	<u>7127</u>				
<u>≤2</u>		H <sub>2</sub> SO <sub>4</sub>								
<4		NaHSO <sub>4</sub>								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> (625, 608, CN), ascorbic (phenol).					
		Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>								
		ZnAcetate	-	-						
		HCl	**	**						

\*\*VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: \_\_\_\_\_  
 Explain all Discrepancies/ Other Comments: \_\_\_\_\_

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG \*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



## Miscellaneous Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



## REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- \* Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ( $\geq 100\%$  Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)  
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

### Rochester Lab ID # for State Accreditations<sup>1</sup>



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

<sup>1</sup> Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

# ALS Laboratory Group

---

## Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:** R2515822

**Sample Name:** 102.4-1A  
**Lab Code:** R2515822-001  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-1B  
**Lab Code:** R2515822-002  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-2  
**Lab Code:** R2515822-003  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-3  
**Lab Code:** R2515822-004  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-4  
**Lab Code:** R2515822-005  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:** R2515822

**Sample Name:** 102.4-5  
**Lab Code:** R2515822-006  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-6  
**Lab Code:** R2515822-007  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-7  
**Lab Code:** R2515822-008  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-8  
**Lab Code:** R2515822-009  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-9  
**Lab Code:** R2515822-010  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:** R2515822

**Sample Name:** 102.4-10  
**Lab Code:** R2515822-011  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-11  
**Lab Code:** R2515822-012  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-12  
**Lab Code:** R2515822-013  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-13  
**Lab Code:** R2515822-014  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-14  
**Lab Code:** R2515822-015  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:** R2515822

**Sample Name:** 102.4-15  
**Lab Code:** R2515822-016  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-16  
**Lab Code:** R2515822-017  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-17  
**Lab Code:** R2515822-018  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-18  
**Lab Code:** R2515822-019  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-19  
**Lab Code:** R2515822-020  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:** R2515822

**Sample Name:** 102.4-20  
**Lab Code:** R2515822-021  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-21  
**Lab Code:** R2515822-022  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-22  
**Lab Code:** R2515822-023  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-23  
**Lab Code:** R2515822-024  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-24  
**Lab Code:** R2515822-025  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:** R2515822

**Sample Name:** 102.4-25  
**Lab Code:** R2515822-026  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-26  
**Lab Code:** R2515822-027  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-27  
**Lab Code:** R2515822-028  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-28  
**Lab Code:** R2515822-029  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-29  
**Lab Code:** R2515822-030  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:** R2515822

**Sample Name:** 102.4-30  
**Lab Code:** R2515822-031  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-31  
**Lab Code:** R2515822-032  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-32  
**Lab Code:** R2515822-033  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-33  
**Lab Code:** R2515822-034  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-34  
**Lab Code:** R2515822-035  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**ALS Group USA, Corp.**

dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental

**Service Request:** R2515822

**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Sample Name:** 102.4-35

**Date Collected:** 11/18/25

**Lab Code:** R2515822-036

**Date Received:** 11/21/25

**Sample Matrix:** Drinking Water

**Analysis Method**

**Extracted/Digested By**

**Analyzed By**

200.8

DWINTER



## PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

### INORGANIC

#### Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

#### Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

### ORGANIC

**Preparation Methods for Organic methods are listed in the header of the Results pages.**

#### Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



# Sample Results

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-1A  
**Lab Code:** R2515822-001

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 16:08	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-1B  
**Lab Code:** R2515822-002

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 16:09	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-2  
**Lab Code:** R2515822-003

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 16:11	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-3  
**Lab Code:** R2515822-004

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 16:12	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-4  
**Lab Code:** R2515822-005

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 16:16	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-5  
**Lab Code:** R2515822-006

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 16:18	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-6  
**Lab Code:** R2515822-007

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 16:19	

**ALS Group USA, Corp.**  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-7  
**Lab Code:** R2515822-008

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

**Inorganic Parameters**

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	2.4	ug/L	1.0	1	12/12/25 16:21	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-8  
**Lab Code:** R2515822-009

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 16:22	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-9  
**Lab Code:** R2515822-010

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.8	ug/L	1.0	1	12/12/25 16:23	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-10  
**Lab Code:** R2515822-011

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	12/12/25 16:25	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-11  
**Lab Code:** R2515822-012

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 16:26	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-12  
**Lab Code:** R2515822-013

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	12/12/25 16:28	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-13  
**Lab Code:** R2515822-014

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.8	ug/L	1.0	1	12/12/25 16:29	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-14  
**Lab Code:** R2515822-015

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	12/12/25 16:33	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-15  
**Lab Code:** R2515822-016

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 16:35	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-16  
**Lab Code:** R2515822-017

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	12/12/25 16:36	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-17  
**Lab Code:** R2515822-018

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 16:37	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-18  
**Lab Code:** R2515822-019

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 16:47	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-19  
**Lab Code:** R2515822-020

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	12/12/25 16:51	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-20  
**Lab Code:** R2515822-021

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	12/12/25 16:53	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-21  
**Lab Code:** R2515822-022

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:04	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-22  
**Lab Code:** R2515822-023

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.0	ug/L	1.0	1	12/12/25 16:56	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-23  
**Lab Code:** R2515822-024

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 16:57	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-24  
**Lab Code:** R2515822-025

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:01	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-25  
**Lab Code:** R2515822-026

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	12/12/25 17:02	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-26  
**Lab Code:** R2515822-027

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:05	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-27  
**Lab Code:** R2515822-028

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:07	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-28  
**Lab Code:** R2515822-029

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:08	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-29  
**Lab Code:** R2515822-030

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:09	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-30  
**Lab Code:** R2515822-031

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:11	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-31  
**Lab Code:** R2515822-032

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:12	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-32  
**Lab Code:** R2515822-033

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:14	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-33  
**Lab Code:** R2515822-034

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:18	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-34  
**Lab Code:** R2515822-035

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:19	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-35  
**Lab Code:** R2515822-036

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:21	



## QC Summary Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2515822-MB1

**Service Request:** R2515822  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 16:00	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2515822-MB2

**Service Request:** R2515822  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 16:44	

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25  
**Date Analyzed:** 12/12/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 102.4-17  
**Lab Code:** R2515822-018  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2515822-018MS		Result	Duplicate Matrix Spike R2515822-018DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	21.6	20.0	108	20.9	20.0	105	70-130	3	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515822  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25  
**Date Analyzed:** 12/12/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 102.4-18  
**Lab Code:** R2515822-019  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2515822-019MS		Duplicate Matrix Spike R2515822-019DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	21.9	20.0	109	21.6	20.0	108	70-130	1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515822

**Date Analyzed:** 12/12/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L

**Basis:**NA

**Lab Control Sample**  
R2515822-LCS1

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	20.8	20.0	104	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515822

**Date Analyzed:** 12/12/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L

**Basis:**NA

**Lab Control Sample**  
R2515822-LCS2

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	21.7	20.0	109	85-115



December 17, 2025

Service Request No:R2515823

Michael Scinta  
Stohl Environmental  
3860 California Road  
Orchard Park, NY 14219

**Laboratory Results for: Kenton UFSD - Herbert Hoover Elementary School**

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory November 21, 2025  
For your reference, these analyses have been assigned our service request number **R2515823**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at [Meghan.Pedro@alsglobal.com](mailto:Meghan.Pedro@alsglobal.com).

Respectfully submitted,

**ALS Group USA, Corp. dba ALS Environmental**

Meghan Pedro  
Project Manager

CC: Rebecca  
Franjoine

**ADDRESS** 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
**PHONE** +1 585 288 5380 | **FAX** +1 585 288 8475  
ALS Group USA, Corp.  
dba ALS Environmental



# Narrative Documents

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School  
**Sample Matrix:** Drinking Water

**Service Request:** R2515823  
**Date Received:** 11/21/2025

**CASE NARRATIVE**

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

**Sample Receipt:**

Thirty six drinking water samples were received for analysis at ALS Environmental on 11/21/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

**Metals:**

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by \_\_\_\_\_

Date 12/17/2025



### SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 102.4-36		Lab ID: R2515823-001					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.2			1.0	ug/L	200.8	
CLIENT ID: 102.4-42		Lab ID: R2515823-008					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.0			1.0	ug/L	200.8	
CLIENT ID: 102.4-43		Lab ID: R2515823-009					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.1			1.0	ug/L	200.8	
CLIENT ID: 102.4-53		Lab ID: R2515823-019					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.2			1.0	ug/L	200.8	
CLIENT ID: 102.4-58		Lab ID: R2515823-024					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.5			1.0	ug/L	200.8	
CLIENT ID: 102.4-59		Lab ID: R2515823-025					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.0			1.0	ug/L	200.8	
CLIENT ID: 102.4-60		Lab ID: R2515823-026					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.91			0.50	ug/L	200.8	
CLIENT ID: 102.4-63		Lab ID: R2515823-029					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.2			1.0	ug/L	200.8	
CLIENT ID: 102.4-64		Lab ID: R2515823-030					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.3			1.0	ug/L	200.8	
CLIENT ID: 102.4-66		Lab ID: R2515823-032					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.1			1.0	ug/L	200.8	
CLIENT ID: 102.4-68		Lab ID: R2515823-034					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.2			1.0	ug/L	200.8	
CLIENT ID: 102.4-70		Lab ID: R2515823-036					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.2			1.0	ug/L	200.8	



## Sample Receipt Information

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:**R2515823

**SAMPLE CROSS-REFERENCE**

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2515823-001	102.4-36	11/18/2025	
R2515823-002	102.4-37	11/18/2025	
R2515823-003	102.4-38	11/18/2025	
R2515823-004	102.4-39	11/18/2025	
R2515823-005	102.4-40A	11/18/2025	
R2515823-006	102.4-40B	11/18/2025	
R2515823-007	102.4-41	11/18/2025	
R2515823-008	102.4-42	11/18/2025	
R2515823-009	102.4-43	11/18/2025	
R2515823-010	102.4-44	11/18/2025	
R2515823-011	102.4-45	11/18/2025	
R2515823-012	102.4-46	11/18/2025	
R2515823-013	102.4-47	11/18/2025	
R2515823-014	102.4-48	11/18/2025	
R2515823-015	102.4-49	11/18/2025	
R2515823-016	102.4-50	11/18/2025	
R2515823-017	102.4-51	11/18/2025	
R2515823-018	102.4-52	11/18/2025	
R2515823-019	102.4-53	11/18/2025	
R2515823-020	102.4-54	11/18/2025	
R2515823-021	102.4-55	11/18/2025	
R2515823-022	102.4-56	11/18/2025	
R2515823-023	102.4-57	11/18/2025	
R2515823-024	102.4-58	11/18/2025	
R2515823-025	102.4-59	11/18/2025	
R2515823-026	102.4-60	11/18/2025	
R2515823-027	102.4-61	11/18/2025	
R2515823-028	102.4-62	11/18/2025	
R2515823-029	102.4-63	11/18/2025	
R2515823-030	102.4-64	11/18/2025	
R2515823-031	102.4-65	11/18/2025	
R2515823-032	102.4-66	11/18/2025	
R2515823-033	102.4-67	11/18/2025	
R2515823-034	102.4-68	11/18/2025	
R2515823-035	102.4-69	11/18/2025	
R2515823-036	102.4-70	11/18/2025	



# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.4

Client: Kenton UFSD

Contact: Georgia Militello

Building: Herbert Hoover Elementary School

Location: 199 Thorncliff Rd, Buffalo, NY 14223

**LEAD**

Water by 200.8 X

*Turnaround*

10 Days

Sample #	Location	Outlet Type	Time
102.4-36	Room 107 Sink	Sink	5:51
102.4-37	Room 107 Bathroom Sink	Sink	5:52
102.4-38	Room 124-1 Bathroom Sink	Sink	5:53
102.4-39	L DF by Door 6	DF	5:55
102.4-40A	R DF by Door 6	DF	5:56
102.4-40B	R DFB by Door 6	DFB	5:57
102.4-41	Room 124-2 Bathroom Sink	Sink	5:58
102.4-42	Room 126 Sink	Sink	6:00
102.4-43	Room 126 Bathroom Sink	Sink	6:01
102.4-44	Room 124 Sink	Sink	6:02
102.4-45	Room 124 Bathroom Sink	Sink	6:04
102.4-46	Room 123 Bathroom Sink	Sink	6:05
102.4-47	Room 123 Bathroom Sink	Sink	6:06
102.4-48	Room 108-d Bathroom	Sink	6:07
102.4-49	Room 122 Sink	Sink	6:09
102.4-50	Room 122 Bathroom Sink	Sink	6:10
102.4-51	Room 121 Sink	Sink	6:11
102.4-52	Room 121 Bathroom Sink	Sink	6:13

Notes:

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

[Mscinta@stohlenvironmental.com](mailto:Mscinta@stohlenvironmental.com)

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 11/18/2025

Relinquished By: \_\_\_\_\_ Print Name \_\_\_\_\_ Stohl Env: Connor Crilly Date: 11/19/2025


Received (Name / Lab): Anna Mammì ALS Date: 11/21/25 Time: 8:25

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_





# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS  
 STOHL Job # 2023L-102.4

Client: Kenton UFSD Contact: Georgia Militello  
 Building: Herbert Hoover Elementary School Location: 199 Thorncliff Rd, Buffalo, NY 14223

**LEAD** Water by 200.8 X Turnaround 10 Days

Sample #	Location	Outlet Type	Time
102.4-53	Room 120 Sink	Sink	6:14
102.4-54	Room 120 Bathroom Sink	Sink	6:15
102.4-55	Room 113 Bathroom Sink	Sink	6:16
102.4-56	Room 112 Bathroom Sink	Sink	6:18
102.4-57	Room 112 DF	DF	6:19
102.4-58	Room 112 Office	Sink	6:20
102.4-59	Room 118 Bathroom Sink R	Sink	6:22
102.4-60	Room 118 Sink	Sink	6:23
102.4-61	Room 118 Bathroom Sink L	Sink	6:24
102.4-62	Room 116 Sink	Sink	6:25
102.4-63	Room 116 L Bathroom Sink	Sink	6:27
102.4-64	Room 116 R Bathroom Sink	Sink	6:28
102.4-65	Room 115 Sink	Sink	6:29
102.4-66	Room 115 Bathroom Sink	Sink	6:30
102.4-67	Room 113 Sink	Sink	6:32
102.4-68	Room 113 Bathroom Sink	Sink	6:33
102.4-69	Room 111 Sink	Sink	6:34
102.4-70	Room 111 Bathroom Sink	Sink	6:36

Notes: Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com) [Mscinta@stohlenvironmental.com](mailto:Mscinta@stohlenvironmental.com)

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 11/18/2025  
 Relinquished By: \_\_\_\_\_ Print Name Connor Crilly Stohl Env: Connor Crilly Date: 11/19/2025  
 Received (Name / Lab): Cam Munn ALS Date: 11/21/25 Time: 8:25  
 Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



**R2515823** **5**  
 Stohl Environmental  
 Kenton UFSD - Herbert Hoover Elementary School

### Cooler Receipt and Preservation Check

Project/Client Stohl Folder Number \_\_\_\_\_

Cooler received on 11/21/25 by: RM COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>(N)</u>	5a	Did VOA vials have sig* bubbles?	Y N <u>(NA)</u>
2	Custody papers properly completed (ink, signed)?	<u>(Y)</u> N	5b	Sig* bubbles: Alk? Y N <u>(NA)</u> Sulfide? Y N <u>(NA)</u>	
3	Did all bottles arrive in good condition (unbroken)?	<u>(Y)</u> N	6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>(N)</u>	7	Soil VOA received as: Bulk Encore 5035set	<u>(NA)</u>

8. Temperature Readings Date: 11/21/25 Time: 8:32 ID: IR#12 IR#11 From: Temp Blank (Sample Bottle)

Temp (°C)	<u>10.2</u>						
Within 0-6°C?	<u>(Y)</u> N	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: No ice Ice melted Poorly Packed (described below) Same Day Rule  
 & Client Approval to Run Samples: \_\_\_\_\_ Standing Approval: Client aware at drop-off Client notified by: \_\_\_\_\_

All samples held in storage location: SMO by RM on 11/21 at 8:32  
 5035 samples placed in storage location: \_\_\_\_\_ by \_\_\_\_\_ on \_\_\_\_\_ at \_\_\_\_\_ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check\*\*: Date: 11/26 Time: 1545 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated (N/A)

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
>12		NaOH								
<2	<u>202325</u>	HNO <sub>3</sub>	<u>X</u>		<u>24017806</u>	<u>7127</u>				
<2		H <sub>2</sub> SO <sub>4</sub>								
<4		NaHSO <sub>4</sub>								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> (625, 608, CN), ascorbic (phenol).					
		Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>								
		ZnAcetate	-	-						
		HCl	**	**						

\*\*VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: \_\_\_\_\_  
 Explain all Discrepancies/ Other Comments: \_\_\_\_\_

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AK \*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



## Miscellaneous Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



## REPORT QUALIFIERS AND DEFINITIONS

- |   |  |
|---|--|
| <p><b>U</b> Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.</p> <p><b>J</b> Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration &gt;40% difference between two GC columns (pesticides/Aroclors).</p> <p><b>B</b> Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.</p> <p><b>E</b> Inorganics- Concentration is estimated due to the serial dilution was outside control limits.</p> <p><b>E</b> Organics- Concentration has exceeded the calibration range for that specific analysis.</p> <p><b>D</b> Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.</p> <p><b>*</b> Indicates that a quality control parameter has exceeded laboratory limits. Under the “Notes” column of the Form I, this qualifier denotes analysis was performed out of Holding Time.</p> <p><b>H</b> Analysis was performed out of hold time for tests that have an “immediate” hold time criteria.</p> <p><b>#</b> Spike was diluted out.</p> | <p><b>+</b> Correlation coefficient for MSA is &lt;0.995.</p> <p><b>N</b> Inorganics- Matrix spike recovery was outside laboratory limits.</p> <p><b>N</b> Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.</p> <p><b>S</b> Concentration has been determined using Method of Standard Additions (MSA).</p> <p><b>W</b> Post-Digestion Spike recovery is outside control limits and the sample absorbance is &lt;50% of the spike absorbance.</p> <p><b>P</b> Concentration &gt;40% difference between the two GC columns.</p> <p><b>C</b> Confirmed by GC/MS</p> <p><b>Q</b> DoD reports: indicates a pesticide/Aroclor is not confirmed (<math>\geq 100\%</math> Difference between two GC columns).</p> <p><b>X</b> See Case Narrative for discussion.</p> <p><b>MRL</b> Method Reporting Limit. Also known as:</p> <p><b>LOQ</b> Limit of Quantitation (LOQ)<br/>The lowest concentration at which the method analyte may be reliably quantified under the method conditions.</p> <p><b>MDL</b> Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).</p> <p><b>LOD</b> Limit of Detection. A value at or above the MDL which has been verified to be detectable.</p> <p><b>ND</b> Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.</p> |
|---|--|

### Rochester Lab ID # for State Accreditations<sup>1</sup>



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

<sup>1</sup> Analyses were performed according to our laboratory’s NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

# ALS Laboratory Group

---

## Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:** R2515823

**Sample Name:** 102.4-36  
**Lab Code:** R2515823-001  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-37  
**Lab Code:** R2515823-002  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-38  
**Lab Code:** R2515823-003  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-39  
**Lab Code:** R2515823-004  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-40A  
**Lab Code:** R2515823-005  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:** R2515823

**Sample Name:** 102.4-40B  
**Lab Code:** R2515823-006  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-41  
**Lab Code:** R2515823-007  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-42  
**Lab Code:** R2515823-008  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-43  
**Lab Code:** R2515823-009  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-44  
**Lab Code:** R2515823-010  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:** R2515823

**Sample Name:** 102.4-45  
**Lab Code:** R2515823-011  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-46  
**Lab Code:** R2515823-012  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-47  
**Lab Code:** R2515823-013  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-48  
**Lab Code:** R2515823-014  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-49  
**Lab Code:** R2515823-015  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:** R2515823

**Sample Name:** 102.4-50  
**Lab Code:** R2515823-016  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-51  
**Lab Code:** R2515823-017  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-52  
**Lab Code:** R2515823-018  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-53  
**Lab Code:** R2515823-019  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-54  
**Lab Code:** R2515823-020  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:** R2515823

**Sample Name:** 102.4-55  
**Lab Code:** R2515823-021  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-56  
**Lab Code:** R2515823-022  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-57  
**Lab Code:** R2515823-023  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-58  
**Lab Code:** R2515823-024  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-59  
**Lab Code:** R2515823-025  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:** R2515823

**Sample Name:** 102.4-60  
**Lab Code:** R2515823-026  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**  
GCONSTANTINO

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-61  
**Lab Code:** R2515823-027  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-62  
**Lab Code:** R2515823-028  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-63  
**Lab Code:** R2515823-029  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-64  
**Lab Code:** R2515823-030  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:** R2515823

**Sample Name:** 102.4-65  
**Lab Code:** R2515823-031  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-66  
**Lab Code:** R2515823-032  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-67  
**Lab Code:** R2515823-033  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-68  
**Lab Code:** R2515823-034  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.4-69  
**Lab Code:** R2515823-035  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**ALS Group USA, Corp.**

dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental

**Service Request:** R2515823

**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Sample Name:** 102.4-70

**Date Collected:** 11/18/25

**Lab Code:** R2515823-036

**Date Received:** 11/21/25

**Sample Matrix:** Drinking Water

**Analysis Method**

**Extracted/Digested By**

**Analyzed By**

200.8

DWINTER



## PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

### INORGANIC

#### Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

#### Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

### ORGANIC

**Preparation Methods for Organic methods are listed in the header of the Results pages.**

#### Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



# Sample Results

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-36  
**Lab Code:** R2515823-001

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	12/12/25 17:22	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-37  
**Lab Code:** R2515823-002

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:23	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-38  
**Lab Code:** R2515823-003

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:33	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-39  
**Lab Code:** R2515823-004

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:37	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-40A  
**Lab Code:** R2515823-005

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:39	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-40B  
**Lab Code:** R2515823-006

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:40	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-41  
**Lab Code:** R2515823-007

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:41	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-42  
**Lab Code:** R2515823-008

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0	ug/L	1.0	1	12/12/25 17:43	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-43  
**Lab Code:** R2515823-009

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	12/12/25 17:47	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-44  
**Lab Code:** R2515823-010

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:48	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-45  
**Lab Code:** R2515823-011

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:50	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-46  
**Lab Code:** R2515823-012

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:51	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-47  
**Lab Code:** R2515823-013

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:52	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-48  
**Lab Code:** R2515823-014

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:54	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-49  
**Lab Code:** R2515823-015

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:55	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-50  
**Lab Code:** R2515823-016

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:57	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-51  
**Lab Code:** R2515823-017

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:58	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-52  
**Lab Code:** R2515823-018

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:59	

**ALS Group USA, Corp.**  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-53  
**Lab Code:** R2515823-019

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

**Inorganic Parameters**

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	1.2	ug/L	1.0	1	12/12/25 18:03	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-54  
**Lab Code:** R2515823-020

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 18:05	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-55  
**Lab Code:** R2515823-021

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 18:06	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-56  
**Lab Code:** R2515823-022

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 18:08	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-57  
**Lab Code:** R2515823-023

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 18:17	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-58  
**Lab Code:** R2515823-024

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.5	ug/L	1.0	1	12/12/25 18:21	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-59  
**Lab Code:** R2515823-025

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	1.0	ug/L	1.0	1	12/12/25 18:23	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-60  
**Lab Code:** R2515823-026

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Date Extracted</b>	<b>Q</b>
Lead, Total	200.8	<b>1.91</b>	ug/L	0.50	1	12/15/25 14:39	12/12/25	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-61  
**Lab Code:** R2515823-027

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 18:24	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-62  
**Lab Code:** R2515823-028

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 18:26	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-63  
**Lab Code:** R2515823-029

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	12/12/25 18:27	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-64  
**Lab Code:** R2515823-030

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	12/12/25 18:31	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-65  
**Lab Code:** R2515823-031

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 18:32	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-66  
**Lab Code:** R2515823-032

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	12/12/25 18:34	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-67  
**Lab Code:** R2515823-033

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 18:35	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-68  
**Lab Code:** R2515823-034

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	1.2	ug/L	1.0	1	12/12/25 18:37	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-69  
**Lab Code:** R2515823-035

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 18:38	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-70  
**Lab Code:** R2515823-036

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	12/12/25 18:39	



## QC Summary Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2515823-MB1

**Service Request:** R2515823  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	ND U	ug/L	0.50	1	12/15/25 14:30	12/12/25	
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 16:44	NA	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2515823-MB2

**Service Request:** R2515823  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 17:30	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2515823-MB3

**Service Request:** R2515823  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 18:15	

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25  
**Date Analyzed:** 12/12/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 102.4-37  
**Lab Code:** R2515823-002  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2515823-002MS		Duplicate Matrix Spike R2515823-002DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	22.6	20.0	113	22.0	20.0	110	70-130	3	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25  
**Date Analyzed:** 12/12/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 102.4-38  
**Lab Code:** R2515823-003  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2515823-003MS		Duplicate Matrix Spike R2515823-003DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	20.2	20.0	101	18.6	20.0	93	70-130	8	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25  
**Date Analyzed:** 12/12/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 102.4-56  
**Lab Code:** R2515823-022  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2515823-022MS		Duplicate Matrix Spike R2515823-022DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	20.7	20.0	104	21.2	20.0	106	70-130	2	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515823  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25  
**Date Analyzed:** 12/12/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 102.4-57  
**Lab Code:** R2515823-023  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2515823-023MS		Duplicate Matrix Spike R2515823-023DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	21.4	20.0	107	21.0	20.0	105	70-130	1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515823  
**Date Analyzed:** 12/12/25 - 12/15/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2515823-LCS1

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	20.9	20.0	104	85-115
Lead, Total	200.8	21.7	20.0	109	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515823

**Date Analyzed:** 12/12/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L

**Basis:**NA

**Lab Control Sample**  
R2515823-LCS2

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	21.9	20.0	109	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515823

**Date Analyzed:** 12/12/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L

**Basis:**NA

**Lab Control Sample**  
R2515823-LCS3

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	21.2	20.0	106	85-115



December 23, 2025

Service Request No:R2515824

Michael Scinta  
Stohl Environmental  
3860 California Road  
Orchard Park, NY 14219

**Laboratory Results for: Kenton UFSD - Herbert Hoover Elementary School**

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory November 21, 2025  
For your reference, these analyses have been assigned our service request number **R2515824**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at [Meghan.Pedro@alsglobal.com](mailto:Meghan.Pedro@alsglobal.com).

Respectfully submitted,

**ALS Group USA, Corp. dba ALS Environmental**

Meghan Pedro  
Project Manager

CC: Rebecca  
Franjoine

**ADDRESS** 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
**PHONE** +1 585 288 5380 | **FAX** +1 585 288 8475  
ALS Group USA, Corp.  
dba ALS Environmental



# Narrative Documents

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School  
**Sample Matrix:** Drinking Water

**Service Request:** R2515824  
**Date Received:** 11/21/2025

**CASE NARRATIVE**

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

**Sample Receipt:**

Forty one drinking water samples were received for analysis at ALS Environmental on 11/21/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

**Metals:**

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by \_\_\_\_\_

Date 12/23/2025





## Sample Receipt Information

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:**R2515824

**SAMPLE CROSS-REFERENCE**

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2515824-001	102.4-71A	11/18/2025	
R2515824-002	102.4-71B	11/18/2025	
R2515824-003	102.4-72	11/18/2025	
R2515824-004	102.4-73	11/18/2025	
R2515824-005	102.4-74	11/18/2025	
R2515824-006	102.4-75	11/18/2025	
R2515824-007	102.4-76	11/18/2025	
R2515824-008	102.4-77A	11/18/2025	
R2515824-009	102.4-77B	11/18/2025	
R2515824-010	102.4-78	11/18/2025	
R2515824-011	102.4-79	11/18/2025	
R2515824-012	102.4-80	11/18/2025	
R2515824-013	102.4-81	11/18/2025	
R2515824-014	102.4-82	11/18/2025	
R2515824-015	102.4-83	11/18/2025	
R2515824-016	102.4-84	11/18/2025	
R2515824-017	102.4-85A	11/18/2025	
R2515824-018	102.4-85B	11/18/2025	
R2515824-019	102.4-86	11/18/2025	
R2515824-020	102.4-87	11/18/2025	
R2515824-021	102.4-88	11/18/2025	
R2515824-022	102.4-89	11/18/2025	
R2515824-023	102.4-90	11/18/2025	
R2515824-024	102.4-91	11/18/2025	
R2515824-025	102.4-92	11/18/2025	
R2515824-026	102.4-93	11/18/2025	
R2515824-027	102.4-94A	11/18/2025	
R2515824-028	102.4-94B	11/18/2025	
R2515824-029	102.4-95	11/18/2025	
R2515824-030	102.4-96	11/18/2025	
R2515824-031	102.4-97	11/18/2025	
R2515824-032	102.4-98	11/18/2025	
R2515824-033	102.4-99	11/18/2025	
R2515824-034	102.4-100A	11/18/2025	
R2515824-035	102.4-100B	11/18/2025	
R2515824-036	102.4-101	11/18/2025	
R2515824-037	102.4-102	11/18/2025	
R2515824-038	102.4-103	11/18/2025	
R2515824-039	102.4-104	11/18/2025	
R2515824-040	102.4-105	11/18/2025	
R2515824-041	102.4-106	11/18/2025	



# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.4

Client: Kenton UFSD

Contact: Georgia Militello

Building: Herbert Hoover Elementary School

Location: 199 Thornduff Rd, Buffalo, NY 14223

**LEAD**

Water by 200.8 X

*Turnaround*

10 Days

Sample #	Location	Outlet Type	Time
102.4-71A	DF Near 111	DF	6:37
102.4-71B	DFB Near 111	DFB	6:38
102.4-72	Room 109 Sink	Sink	6:39
102.4-73	Room 128 Sink	Sink	6:41
102.4-74	Room 131 Sink	Sink	6:42
102.4-75	Room 131 Bathroom Sink	Sink	6:43
102.4-76	Room 216 Sink	Sink	6:45
102.4-77A	DF by 218	DF	6:46
102.4-77B	DFB by 218	DFB	6:47
102.4-78	Bathroom Next to 218	Sink	6:48
102.4-79	Room 218 Sink	Sink	6:50
102.4-80	Room 219 Sink	Sink	6:51
102.4-81	Room 220 Sink	Sink	6:52
102.4-82	Room 214 Sink	Sink	6:54
102.4-83	Room 204 Sink	Sink	6:55
102.4-84	Room 202 Sink	Sink	6:56
102.4-85A	DF Next to 202	DF	6:57
102.4-85B	DFB Next to 202	DFB	6:59

Notes:

Please e-mail lab results to labs@stohlenv.com

Mscinta@stohlenvironmental.com

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 11/18/2025

Relinquished By: \_\_\_\_\_ Print Name \_\_\_\_\_ Stohl Env: Connor Crilly Date: 11/19/2025

Received (Name / Lab): MM ALS Date: 11/21/25

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_





# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.4

Client: Kenton UFSD

Contact: Georgia Militello

Building: Herbert Hoover Elementary School

Location: 199 Thorncliff Rd, Buffalo, NY 14223

**LEAD**

Water by 200.8 X

*Turnaround*

10 Days

Sample #	Location	Outlet Type	Time
102.4-86	L Boys Bathroom by 203	Sink	7:00
102.4-87	R Boys Bathroom by 203	Sink	7:01
102.4-88	Room 201 Sink	Sink	7:03
102.4-89	Room 203 Sink	Sink	7:04
102.4-90	Room 205 Sink	Sink	7:05
102.4-91	Girls Bathroom Next to 207 L	Sink	7:06
102.4-92	Girls Bathroom Next to 207 R	Sink	7:08
102.4-93	Room 207 Sink	Sink	7:09
102.4-94A	DF by 208	DF	7:10
102.4-94B	DFB by 208	DFB	7:12
102.4-95	Room 208 Sink	Sink	7:13
102.4-96	Room 212 Sink	Sink	7:14
102.4-97	Room 213 Sink	Sink	7:15
102.4-98	Boys Bathroom Sink L Next to 211	Sink	7:17
102.4-99	Boys Bathroom Sink R Next to 211	Sink	7:18
102.4-100A	DF Next to 211	DF	7:19
102.4-100B	DFB Next to 211	DFB	7:21
102.4-101	Room 211 Sink	Sink	7:22

Notes:

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

[Mscinta@stohlenvironmental.com](mailto:Mscinta@stohlenvironmental.com)

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 11/18/2025

Relinquished By: \_\_\_\_\_ Print Name \_\_\_\_\_ Stohl Env: Connor Crilly Date: 11/19/2025

Received (Name / Lab): [Signature] ALS Date: 11/21/25 Time: 8:25

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_





R2515824

5

Stohl Environmental  
Kenton UFSD - Herbert Hoover Elementary School



### Cooler Receipt and Preservation

Project/Client Stohl Folder Number \_\_\_\_\_

Cooler received on 11/21/25 by: RM COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>(N)</u>
2	Custody papers properly completed (ink, signed)?	<u>(Y)</u> N
3	Did all bottles arrive in good condition (unbroken)?	<u>(Y)</u> N
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>(N)</u>

5a	Did VOA vials have sig* bubbles?	Y N <u>(NA)</u>
5b	Sig* bubbles: Alk? Y N <u>(NA)</u> Sulfide? Y N <u>(NA)</u>	
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set	<u>(NA)</u>

8. Temperature Readings Date: 11/21/25 Time: 8:32 ID: IR#12 IR#11 From: Temp Blank (Sample Bottle)

Temp (°C)	<u>10.2</u>						
Within 0-6°C?	Y <u>(N)</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: No ice Ice melted Poorly Packed (described below) Same Day Rule  
& Client Approval to Run Samples: \_\_\_\_\_ Standing Approval Client aware at drop-off Client notified by: \_\_\_\_\_

All samples held in storage location: SMO by RM on 11/21 at 8:32  
5035 samples placed in storage location: \_\_\_\_\_ by \_\_\_\_\_ on \_\_\_\_\_ at \_\_\_\_\_ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check\*\*: Date: 11/26 Time: 1745 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? (YES) NO
- 10. Did all bottle labels and tags agree with custody papers? (YES) NO
- 11. Were correct containers used for the tests indicated? (YES) NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO (N/A)
- 13. Were dissolved metals filtered in the field? YES NO (N/A)
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated (N/A)

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>202325</u>	HNO <sub>3</sub>	<u>X</u>		<u>24017806</u>	<u>1107</u>				
≤2		H <sub>2</sub> SO <sub>4</sub>								
<4		NaHSO <sub>4</sub>								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> (625, 608, CN), ascorbic (phenol).					
		Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>								
		ZnAcetate	-	-						
		HCl	**	**						

\*\*VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: \_\_\_\_\_  
Explain all Discrepancies/ Other Comments: \_\_\_\_\_

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG \*significant air bubbles: VOA > 5-6 mm ; WC > 1 in. diameter



# Miscellaneous Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



## REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- \* Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ( $\geq 100\%$  Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)  
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

### Rochester Lab ID # for State Accreditations<sup>1</sup>



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

<sup>1</sup> Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

# ALS Laboratory Group

---

## Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:** R2515824

**Sample Name:** 102.4-71A  
**Lab Code:** R2515824-001  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-71B  
**Lab Code:** R2515824-002  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-72  
**Lab Code:** R2515824-003  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-73  
**Lab Code:** R2515824-004  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-74  
**Lab Code:** R2515824-005  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:** R2515824

**Sample Name:** 102.4-75  
**Lab Code:** R2515824-006  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-76  
**Lab Code:** R2515824-007  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-77A  
**Lab Code:** R2515824-008  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-77B  
**Lab Code:** R2515824-009  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-78  
**Lab Code:** R2515824-010  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:** R2515824

**Sample Name:** 102.4-79  
**Lab Code:** R2515824-011  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-80  
**Lab Code:** R2515824-012  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-81  
**Lab Code:** R2515824-013  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-82  
**Lab Code:** R2515824-014  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-83  
**Lab Code:** R2515824-015  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:** R2515824

**Sample Name:** 102.4-84  
**Lab Code:** R2515824-016  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-85A  
**Lab Code:** R2515824-017  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-85B  
**Lab Code:** R2515824-018  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-86  
**Lab Code:** R2515824-019  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-87  
**Lab Code:** R2515824-020  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:** R2515824

**Sample Name:** 102.4-88  
**Lab Code:** R2515824-021  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-89  
**Lab Code:** R2515824-022  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-90  
**Lab Code:** R2515824-023  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-91  
**Lab Code:** R2515824-024  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-92  
**Lab Code:** R2515824-025  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:** R2515824

**Sample Name:** 102.4-93  
**Lab Code:** R2515824-026  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-94A  
**Lab Code:** R2515824-027  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-94B  
**Lab Code:** R2515824-028  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-95  
**Lab Code:** R2515824-029  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-96  
**Lab Code:** R2515824-030  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:** R2515824

**Sample Name:** 102.4-97  
**Lab Code:** R2515824-031  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-98  
**Lab Code:** R2515824-032  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-99  
**Lab Code:** R2515824-033  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-100A  
**Lab Code:** R2515824-034  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-100B  
**Lab Code:** R2515824-035  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Service Request:** R2515824

**Sample Name:** 102.4-101  
**Lab Code:** R2515824-036  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-102  
**Lab Code:** R2515824-037  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-103  
**Lab Code:** R2515824-038  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-104  
**Lab Code:** R2515824-039  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.4-105  
**Lab Code:** R2515824-040  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/18/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**ALS Group USA, Corp.**

**dba ALS Environmental**

Analyst Summary report

**Client:** Stohl Environmental

**Service Request:** R2515824

**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4

**Sample Name:** 102.4-106

**Date Collected:** 11/18/25

**Lab Code:** R2515824-041

**Date Received:** 11/21/25

**Sample Matrix:** Drinking Water

**Analysis Method**

**Extracted/Digested By**

**Analyzed By**

200.8

MKASTAN



## PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

### INORGANIC

#### Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

#### Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

### ORGANIC

**Preparation Methods for Organic methods are listed in the header of the Results pages.**

#### Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



# Sample Results

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-71A  
**Lab Code:** R2515824-001

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:53	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-71B  
**Lab Code:** R2515824-002

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:54	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-72  
**Lab Code:** R2515824-003

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:56	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-73  
**Lab Code:** R2515824-004

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 16:07	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-74  
**Lab Code:** R2515824-005

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 16:11	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-75  
**Lab Code:** R2515824-006

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 16:13	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-76  
**Lab Code:** R2515824-007

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.8	ug/L	1.0	1	12/18/25 16:14	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-77A  
**Lab Code:** R2515824-008

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 16:16	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-77B  
**Lab Code:** R2515824-009

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 16:17	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-78  
**Lab Code:** R2515824-010

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 16:22	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-79  
**Lab Code:** R2515824-011

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.5	ug/L	1.0	1	12/18/25 16:24	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-80  
**Lab Code:** R2515824-012

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 16:25	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-81  
**Lab Code:** R2515824-013

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.4	ug/L	1.0	1	12/18/25 16:27	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-82  
**Lab Code:** R2515824-014

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	11.5	ug/L	1.0	1	12/18/25 16:28	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-83  
**Lab Code:** R2515824-015

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 16:30	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-84  
**Lab Code:** R2515824-016

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 16:31	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-85A  
**Lab Code:** R2515824-017

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 16:33	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-85B  
**Lab Code:** R2515824-018

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 16:34	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-86  
**Lab Code:** R2515824-019

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 16:36	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-87  
**Lab Code:** R2515824-020

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 16:40	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-88  
**Lab Code:** R2515824-021

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 16:42	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-89  
**Lab Code:** R2515824-022

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 16:44	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-90  
**Lab Code:** R2515824-023

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 16:45	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-91  
**Lab Code:** R2515824-024

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 16:56	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-92  
**Lab Code:** R2515824-025

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 17:00	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-93  
**Lab Code:** R2515824-026

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 17:02	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-94A  
**Lab Code:** R2515824-027

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 17:03	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-94B  
**Lab Code:** R2515824-028

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 17:05	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-95  
**Lab Code:** R2515824-029

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.8	ug/L	1.0	1	12/18/25 17:07	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-96  
**Lab Code:** R2515824-030

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 13:00	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-97  
**Lab Code:** R2515824-031

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 13:02	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-98  
**Lab Code:** R2515824-032

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 13:07	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-99  
**Lab Code:** R2515824-033

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 13:08	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-100A  
**Lab Code:** R2515824-034

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 13:10	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-100B  
**Lab Code:** R2515824-035

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 13:11	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-101  
**Lab Code:** R2515824-036

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	12/19/25 13:13	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-102  
**Lab Code:** R2515824-037

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 13:14	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-103  
**Lab Code:** R2515824-038

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 13:16	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-104  
**Lab Code:** R2515824-039

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 13:17	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-105  
**Lab Code:** R2515824-040

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 13:19	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.4-106  
**Lab Code:** R2515824-041

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 13:21	



## QC Summary Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2515824-MB1

**Service Request:** R2515824  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:14	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2515824-MB2

**Service Request:** R2515824  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 16:04	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2515824-MB3

**Service Request:** R2515824  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 16:53	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2515824-MB4

**Service Request:** R2515824  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 12:48	

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25  
**Date Analyzed:** 12/18/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 102.4-72  
**Lab Code:** R2515824-003  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2515824-003MS		Result	Duplicate Matrix Spike R2515824-003DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	19.8	20.0	99	19.7	20.0	99	70-130	<1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25  
**Date Analyzed:** 12/18/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 102.4-73  
**Lab Code:** R2515824-004  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2515824-004MS		Duplicate Matrix Spike R2515824-004DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	20.2	20.0	101	20.6	20.0	103	70-130	2	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25  
**Date Analyzed:** 12/18/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 102.4-90  
**Lab Code:** R2515824-023  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2515824-023MS		Duplicate Matrix Spike R2515824-023DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	20.0	20.0	100	20.0	20.0	100	70-130	<1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515824  
**Date Collected:** 11/18/25  
**Date Received:** 11/21/25  
**Date Analyzed:** 12/18/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 102.4-91  
**Lab Code:** R2515824-024  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2515824-024MS		Duplicate Matrix Spike R2515824-024DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	20.6	20.0	103	20.6	20.0	103	70-130	<1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515824

**Date Analyzed:** 12/18/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L

**Basis:**NA

**Lab Control Sample**  
R2515824-LCS1

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	19.7	20.0	99	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515824  
**Date Analyzed:** 12/18/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2515824-LCS2

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	20.2	20.0	101	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515824

**Date Analyzed:** 12/18/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L

**Basis:**NA

**Lab Control Sample**  
R2515824-LCS3

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	20.0	20.0	100	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Herbert Hoover Elementary School/2023L-102.4  
**Sample Matrix:** Drinking Water

**Service Request:** R2515824

**Date Analyzed:** 12/19/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L

**Basis:**NA

**Lab Control Sample**  
R2515824-LCS4

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	18.5	20.0	92	85-115

1.5 Laboratory Certifications

**NEW YORK STATE DEPARTMENT OF HEALTH  
 WADSWORTH CENTER**



Expires 12:01 AM April 01, 2026  
 Issued April 01, 2025

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**  
*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

**MS. CHRISTINE KUTZER**  
**ALS ENVIRONMENTAL - ROCHESTER**  
**1565 JEFFERSON ROAD BUILDING 300, SUITE 360**  
**ROCHESTER, NY 14623**

NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
 National Environmental Laboratory Accreditation Conference Standards (2016) for the category  
 ENVIRONMENTAL ANALYSES POTABLE WATER  
 All approved analytes are listed below:*

<b>Bacteriology</b>	
Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Collert)
<b>Dissolved Gases</b>	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
<b>Fuel Additives</b>	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
<b>Metals I</b>	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Zinc, Total	EPA 200.7 Rev. 4.4

Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elapublicweb/>, by phone (518) 485-5570 or by email to [elap@health.ny.gov](mailto:elap@health.ny.gov).

Page 1 of 5

