

January 6, 2026

Ms. Georgia Militello
Ken-Ton UFSD
1500 Colvin Boulevard
Buffalo, New York 14223

Re: Lead Testing in School Drinking Water

Dear Ms. Militello:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Ken-Ton UFSD, including:

- **Herbert Hoover Middle School – 249 Thorncliff Road, Buffalo, NY**

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: Lead Testing in School Drinking Water, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on November 19, 2025 and November 20, 2025. As detailed in Section 1.2 (Executive Summary) of the accompanying report, based upon the sampling and analysis performed, 10 sources of potable water in Herbert Hoover Middle School have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion. To comply with NYS regulations, response actions by the district are required. Response actions are outlined in Section 1.3 (Response Actions Required Under NYS Regulations).

Thank you for the opportunity to be of service to Ken-Ton UFSD.

Sincerely,
Stohl Environmental, LLC.



Michael Scinta
EPA Lead Risk Assessor

Lead Testing in School Drinking Water

Prepared for:

Ken-Ton UFSD

Prepared by:



**3860 California Road
Orchard Park, New York 14127**

Conditions as of November 19, 2025 and November 20, 2025

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports and Chain of Custody Documents
- 1.5. Laboratory Certifications

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Ken-Ton UFSD to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- **Herbert Hoover Middle School – 249 Thorncliff Road, Buffalo, NY**

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within Herbert Hoover Middle School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, **Subpart 67-4: Lead Testing in School Drinking Water**, and the EPA guidance document, **3Ts for Reducing Lead in Drinking Water in Schools**, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at Herbert Hoover Middle School:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Herbert Hoover Middle School	November 19, 2025 & November 20, 2025	168	158	10

**NYS Action Level is 5 parts per billion*

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
102.5-20	Room 112 Sink	Sink	9.8
102.5-21	Room 117 Sink	Sink	26.4
102.5-22	Room 114 Right Sink	Sink	7.0
102.5-26	Room 119 Left Sink	Sink	8.4
102.5-27	Room 119 Right Sink	Sink	21.4
102.5-37	Left Girls Locker Room Bathroom Sink	Sink	41.3
102.5-38	Right Girls Locker Room Bathroom Sink	Sink	37.7
102.5-109	Room 250 Desk Sink	Sink	14.0
102.5-112	206 Sink	Sink	9.7
102.5-115	Room 207 Sink	Sink	5.6

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration more than the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports and Chain of Custody Documents



December 23, 2025

Service Request No:R2515827

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Kenton UFSD - Herber Hoover Middle School

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory November 21, 2025
For your reference, these analyses have been assigned our service request number **R2515827**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | **FAX** +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School
Sample Matrix: Drinking Water

Service Request: R2515827
Date Received: 11/21/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 11/21/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 12/23/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 102.5-2		Lab ID: R2515827-003					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.4			1.0	ug/L	200.8	

CLIENT ID: 102.5-3		Lab ID: R2515827-004					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.4			1.0	ug/L	200.8	

CLIENT ID: 102.5-4		Lab ID: R2515827-005					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.9			1.0	ug/L	200.8	

CLIENT ID: 102.5-7		Lab ID: R2515827-009					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.1			1.0	ug/L	200.8	

CLIENT ID: 102.5-18		Lab ID: R2515827-022					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.8			1.0	ug/L	200.8	

CLIENT ID: 102.5-20		Lab ID: R2515827-024					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	9.8			1.0	ug/L	200.8	

CLIENT ID: 102.5-21		Lab ID: R2515827-025					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	26.4			1.0	ug/L	200.8	

CLIENT ID: 102.5-22		Lab ID: R2515827-026					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	7.0			1.0	ug/L	200.8	

CLIENT ID: 102.5-23		Lab ID: R2515827-027					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.7			1.0	ug/L	200.8	

CLIENT ID: 102.5-24		Lab ID: R2515827-028					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.8			1.0	ug/L	200.8	

CLIENT ID: 102.5-26		Lab ID: R2515827-031					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	8.4			1.0	ug/L	200.8	

CLIENT ID: 102.5-27		Lab ID: R2515827-032					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	21.4			1.0	ug/L	200.8	



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5

Service Request:R2515827

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2515827-001	102.5-1A	11/19/2025	
R2515827-002	102.5-1B	11/19/2025	
R2515827-003	102.5-2	11/19/2025	
R2515827-004	102.5-3	11/19/2025	
R2515827-005	102.5-4	11/19/2025	
R2515827-006	102.5-5A	11/19/2025	
R2515827-007	102.5-5B	11/19/2025	
R2515827-008	102.5-6	11/19/2025	
R2515827-009	102.5-7	11/19/2025	
R2515827-010	102.5-8	11/19/2025	
R2515827-011	102.5-9	11/19/2025	
R2515827-012	102.5-10	11/19/2025	
R2515827-013	102.5-11	11/19/2025	
R2515827-014	102.5-12	11/19/2025	
R2515827-015	102.5-13	11/19/2025	
R2515827-016	102.5-14	11/19/2025	
R2515827-017	102.5-15A	11/19/2025	
R2515827-018	102.5-15B	11/19/2025	
R2515827-019	102.5-16A	11/19/2025	
R2515827-020	102.5-16B	11/19/2025	
R2515827-021	102.5-127	11/19/2025	
R2515827-022	102.5-18	11/19/2025	
R2515827-023	102.5-19	11/19/2025	
R2515827-024	102.5-20	11/19/2025	
R2515827-025	102.5-21	11/19/2025	
R2515827-026	102.5-22	11/19/2025	
R2515827-027	102.5-23	11/19/2025	
R2515827-028	102.5-24	11/19/2025	
R2515827-029	102.5-25A	11/19/2025	
R2515827-030	102.5-25B	11/19/2025	
R2515827-031	102.5-26	11/19/2025	
R2515827-032	102.5-27	11/19/2025	
R2515827-033	102.5-28	11/19/2025	
R2515827-034	102.5-29	11/19/2025	
R2515827-035	102.5-30A	11/19/2025	
R2515827-036	102.5-30B	11/19/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.5

Client: Kenton UFSD

Contact: Georgia Militello

Building: Herbert Hoover Middle School

Location: 249 Thorncliff Rd, Buffalo, NY 14223

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
102.5-1A	MS DF	DF	5:10
102.5-1B	MS DFB	DFB	5:10
102.5-2	Room 101-2 Bathroom Sink	Sink	5:11
102.5-3	Room 101-3 Bathroom Sink	Sink	5:12
102.5-4	Room 103-1 Womens Staff Bathroom Sink	Sink	5:13
102.5-5A	Door 33 DF	DF	5:14
102.5-5B	Door 33 DFB	DFB	5:15
102.5-6	Room 102 Sink	Sink	5:16
102.5-7	Room 104 Main Office Sink	Sink	5:17
102.5-8	Room 109 Sink	Sink	5:18
102.5-9	Room 111 Bathroom Sink	Sink	5:19
102.5-10	Room 111 Exam Room Sink	Sink	5:20
102.5-11	Room 138-1 Sink	Sink	5:21
102.5-12	Room 138 Sink	Sink	5:22
102.5-13	Room 155 Sink	Sink	5:23
102.5-14	Room 159 Sink	Sink	5:24
102.5-15A	DF next to 154	DF	5:25
102.5-15B	DFB next to 154	DFB	5:26

Notes:
 Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to: Mscinta@stohlenvironmental.com

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 11/19/2025 + 11/20/2025

Relinquished By: _____ Print Name _____ Stohl Env: Connor Crilly Date: 11/20/2025

Received (Name / Lab): MM MM ALS Date: 11/21/25 Time: 8:25

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____

QA/QC Review (Name / Lab): _____ Date: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____





Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.5

Client: Kenton UFSD

Contact: Georgia Militello

Building: Herbert Hoover Middle School

Location: 249 Thorncliff Rd, Buffalo, NY 14223

LEAD

Water by 200.8 X

Tumaround

10 Days

Sample #	Location	Outlet Type	Time
102.5-16A	DF next to 110	DF	5:27
102.5-16B	DFB next to 110	DFB	5:28
102.5-17	Room 113A Sink	Sink	5:29
102.5-18	Room 113 Sink	Sink	5:29
102.5-19	Room 115 Sink	Sink	5:30
102.5-20	Room 112 Sink	Sink	5:31
102.5-21	Room 117 Sink	Sink	5:32
102.5-22	Room 114 R Sink	Sink	5:33
102.5-23	Room 114 L Sink	Sink	5:34
102.5-24	Room 116	Sink	5:35
102.5-25A	DF Next to Room 119	DF	5:36
102.5-25B	DFB Next to Room 119	DFB	5:37
102.5-26	Room 119 L Sink	Sink	5:38
102.5-27	Room 119 R Sink	Sink	5:39
102.5-28	Room 123-1 Sink	Sink	5:40
102.5-29	Room 123-2 Sink	Sink	5:41
102.5-30A	DF Next to 130	DF	5:42
102.5-30B	DFB Next to 130	DFB	5:43

Notes:

Please e-mail lab results to labs@stohlenv.com

Mscinta@stohlenvironmental.com

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 11/19/2025 + 11/20/2025

Relinquished By: _____ Print Name _____ Stohl Env: Connor Crilly Date: 11/20/2025

Received (Name / Lab): AM mmm ALS Date: 11/21/25 Time: 8:25

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



R2515827

5

Stohl Environmental
Kenton UFSD - Herber Hoover Middle School

Cooler Receipt and Preservation Check



Project/Client Stohl Folder Number _____

Cooler received on 11/21/25 by: RM

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>(N)</u>
2	Custody papers properly completed (ink, signed)?	Y <u>(N)</u>
3	Did all bottles arrive in good condition (unbroken)?	Y <u>(N)</u>
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>(N)</u>

5a	Did VOA vials have sig* bubbles?	Y N <u>(NA)</u>
5b	Sig* bubbles: Alk? Y N <u>(NA)</u> Sulfide? Y N <u>(NA)</u>	
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set	<u>(NA)</u>

8. Temperature Readings Date: 11/21/25 Time: 8:32 ID: IR#12 IR#11 From: Temp Blank (Sample Bottle)

Temp (°C)	<u>10.2</u>						
Within 0-6°C?	Y <u>(N)</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: No ice Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMO by RM on 11/21 at 8:32
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 11/26 Time: 1545 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO (N/A)
- 13. Were dissolved metals filtered in the field? YES NO (N/A)
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated (N/A)

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
<u>2</u>	<u>202325</u>	HNO ₃	<u>x</u>		<u>24017806</u>	<u>7/27</u>				
<u>2</u>		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____
Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG *significant air bubbles: VOA > 5-6 mm ; WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the “Notes” column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an “immediate” hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory’s NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5

Service Request: R2515827

Sample Name: 102.5-1A
Lab Code: R2515827-001
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-1B
Lab Code: R2515827-002
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-2
Lab Code: R2515827-003
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-3
Lab Code: R2515827-004
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-4
Lab Code: R2515827-005
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5

Service Request: R2515827

Sample Name: 102.5-5A
Lab Code: R2515827-006
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-5B
Lab Code: R2515827-007
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-6
Lab Code: R2515827-008
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-7
Lab Code: R2515827-009
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-8
Lab Code: R2515827-010
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5

Service Request: R2515827

Sample Name: 102.5-9
Lab Code: R2515827-011
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-10
Lab Code: R2515827-012
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-11
Lab Code: R2515827-013
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-12
Lab Code: R2515827-014
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-13
Lab Code: R2515827-015
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5

Service Request: R2515827

Sample Name: 102.5-14
Lab Code: R2515827-016
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-15A
Lab Code: R2515827-017
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-15B
Lab Code: R2515827-018
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-16A
Lab Code: R2515827-019
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-16B
Lab Code: R2515827-020
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5

Service Request: R2515827

Sample Name: 102.5-127
Lab Code: R2515827-021
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-18
Lab Code: R2515827-022
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-19
Lab Code: R2515827-023
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-20
Lab Code: R2515827-024
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-21
Lab Code: R2515827-025
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5

Service Request: R2515827

Sample Name: 102.5-22
Lab Code: R2515827-026
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-23
Lab Code: R2515827-027
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-24
Lab Code: R2515827-028
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-25A
Lab Code: R2515827-029
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-25B
Lab Code: R2515827-030
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5

Service Request: R2515827

Sample Name: 102.5-26
Lab Code: R2515827-031
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-27
Lab Code: R2515827-032
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-28
Lab Code: R2515827-033
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-29
Lab Code: R2515827-034
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-30A
Lab Code: R2515827-035
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By
NMANSEN

Analyzed By
DWINTER

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental

Service Request: R2515827

Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5

Sample Name: 102.5-30B

Date Collected: 11/19/25

Lab Code: R2515827-036

Date Received: 11/21/25

Sample Matrix: Drinking Water

Analysis Method

Extracted/Digested By

Analyzed By

200.8

MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-1A
Lab Code: R2515827-001

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 13:25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-1B
Lab Code: R2515827-002

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 13:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-2
Lab Code: R2515827-003

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.4	ug/L	1.0	1	12/19/25 11:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-3
Lab Code: R2515827-004

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.4	ug/L	1.0	1	12/19/25 11:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-4
Lab Code: R2515827-005

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.9	ug/L	1.0	1	12/19/25 11:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-5A
Lab Code: R2515827-006

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 11:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-5B
Lab Code: R2515827-007

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 11:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-6
Lab Code: R2515827-008

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 11:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-7
Lab Code: R2515827-009

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	12/19/25 11:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-8
Lab Code: R2515827-010

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 11:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-9
Lab Code: R2515827-011

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 11:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-10
Lab Code: R2515827-012

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 11:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-11
Lab Code: R2515827-013

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 11:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-12
Lab Code: R2515827-014

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 11:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-13
Lab Code: R2515827-015

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 11:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-14
Lab Code: R2515827-016

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 11:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-15A
Lab Code: R2515827-017

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 11:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-15B
Lab Code: R2515827-018

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 11:42	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-16A
Lab Code: R2515827-019

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 11:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-16B
Lab Code: R2515827-020

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 11:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-127
Lab Code: R2515827-021

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 11:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-18
Lab Code: R2515827-022

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.8	ug/L	1.0	1	12/19/25 11:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-19
Lab Code: R2515827-023

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 12:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-20
Lab Code: R2515827-024

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	9.8	ug/L	1.0	1	12/19/25 12:07	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-21
Lab Code: R2515827-025

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	26.4	ug/L	1.0	1	12/19/25 12:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-22
Lab Code: R2515827-026

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.0	ug/L	1.0	1	12/19/25 12:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-23
Lab Code: R2515827-027

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.7	ug/L	1.0	1	12/19/25 12:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-24
Lab Code: R2515827-028

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.8	ug/L	1.0	1	12/19/25 12:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-25A
Lab Code: R2515827-029

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 12:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-25B
Lab Code: R2515827-030

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 12:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-26
Lab Code: R2515827-031

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.4	ug/L	1.0	1	12/19/25 12:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-27
Lab Code: R2515827-032

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	21.4	ug/L	1.0	1	12/19/25 12:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-28
Lab Code: R2515827-033

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 12:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-29
Lab Code: R2515827-034

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 12:25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-30A
Lab Code: R2515827-035

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	ND U	ug/L	0.50	1	12/19/25 14:28	12/18/25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-30B
Lab Code: R2515827-036

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 12:27	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515827-MB1

Service Request: R2515827
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	ND U	ug/L	0.50	1	12/19/25 14:25	12/18/25	
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 11:10	NA	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515827-MB2

Service Request: R2515827
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 11:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515827-MB3

Service Request: R2515827
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 12:48	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25
Date Analyzed: 12/19/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.5-2
Lab Code: R2515827-003
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515827-003MS		Result	Duplicate Matrix Spike R2515827-003DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.4	19.9	20.0	92	20.0	20.0	93	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25
Date Analyzed: 12/19/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.5-18
Lab Code: R2515827-022
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515827-022MS		Result	Duplicate Matrix Spike R2515827-022DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.8	20.2	20.0	92	19.9	20.0	90	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515827
Date Collected: 11/19/25
Date Received: 11/21/25
Date Analyzed: 12/19/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.5-19
Lab Code: R2515827-023
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515827-023MS		Result	Duplicate Matrix Spike R2515827-023DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	18.7	20.0	93	19.0	20.0	95	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515827

Date Analyzed: 12/19/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample
R2515827-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.7	20.0	104	85-115
Lead, Total	200.8	19.4	20.0	97	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515827

Date Analyzed: 12/19/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample
R2515827-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.1	20.0	95	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herber Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515827
Date Analyzed: 12/19/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2515827-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	18.5	20.0	92	85-115



December 23, 2025

Service Request No:R2515828

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Kenton UFSD - Herbert Hoover Middle School

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory November 21, 2025
For your reference, these analyses have been assigned our service request number **R2515828**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | FAX +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School
Sample Matrix: Drinking Water

Service Request: R2515828
Date Received: 11/21/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 11/21/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads 'Meghan Pedro'.

Approved by _____

Date 12/23/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 102.5-37		Lab ID: R2515828-008				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	41.3			1.0	ug/L	200.8

CLIENT ID: 102.5-38		Lab ID: R2515828-009				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	37.7			1.0	ug/L	200.8

CLIENT ID: 102.5-40		Lab ID: R2515828-011				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.8			1.0	ug/L	200.8

CLIENT ID: 102.5-45		Lab ID: R2515828-016				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.7			1.0	ug/L	200.8

CLIENT ID: 102.5-46		Lab ID: R2515828-017				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.0			1.0	ug/L	200.8

CLIENT ID: 102.5-47		Lab ID: R2515828-018				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8

CLIENT ID: 102.5-54		Lab ID: R2515828-025				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8

CLIENT ID: 102.5-62		Lab ID: R2515828-034				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8

CLIENT ID: 102.5-63		Lab ID: R2515828-035				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.3			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request:R2515828

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2515828-001	102.5-31	11/19/2025	
R2515828-002	102.5-32	11/19/2025	
R2515828-003	102.5-33	11/19/2025	
R2515828-004	102.5-34	11/19/2025	
R2515828-005	102.5-35	11/19/2025	
R2515828-006	102.5-36A	11/19/2025	
R2515828-007	102.5-36B	11/19/2025	
R2515828-008	102.5-37	11/19/2025	
R2515828-009	102.5-38	11/19/2025	
R2515828-010	102.5-39	11/19/2025	
R2515828-011	102.5-40	11/19/2025	
R2515828-012	102.5-41	11/19/2025	
R2515828-013	102.5-42	11/19/2025	
R2515828-014	102.5-43	11/19/2025	
R2515828-015	102.5-44	11/19/2025	
R2515828-016	102.5-45	11/19/2025	
R2515828-017	102.5-46	11/19/2025	
R2515828-018	102.5-47	11/19/2025	
R2515828-019	102.5-48	11/19/2025	
R2515828-020	102.5-49	11/19/2025	
R2515828-021	102.5-50	11/19/2025	
R2515828-022	102.5-51	11/19/2025	
R2515828-023	102.5-52	11/19/2025	
R2515828-024	102.5-53	11/19/2025	
R2515828-025	102.5-54	11/19/2025	
R2515828-026	102.5-55	11/19/2025	
R2515828-027	102.5-56	11/19/2025	
R2515828-028	102.5-57	11/19/2025	
R2515828-029	102.5-58	11/19/2025	
R2515828-030	102.5-59	11/19/2025	
R2515828-031	102.5-60A	11/19/2025	
R2515828-032	102.5-60B	11/19/2025	
R2515828-033	102.5-61	11/19/2025	
R2515828-034	102.5-62	11/19/2025	
R2515828-035	102.5-63	11/19/2025	
R2515828-036	102.5-64	11/19/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.5

Client: Kenton UFSD

Contact: Georgia Militello

Building: Herbert Hoover Middle School

Location: 249 Thornclyff Rd, Buffalo, NY 14223

LEAD
 Water by 200.8 X

Turnaround
10 Days

Sample #	Location	Outlet Type	Time
102.5-31	Room 125 L Sink	Sink	5:44
102.5-32	Room 125 M Sink	Sink	5:45
102.5-33	Room 125 R Sink	Sink	5:46
102.5-34	Room 127 L Sink	Sink	5:47
102.5-35	Room 127 R Sink	Sink	5:48
102.5-36A	Girls Locker Room DF	DF	5:48
102.5-36B	Girls Locker Room DFB	DFB	5:49
102.5-37	L Girls Locker Room Bathroom Sink	Sink	5:50
102.5-38	R Girls Locker Room Bathroom Sink	Sink	5:51
102.5-39	Girls Locker Room Office Sink	Sink	5:52
102.5-40	Boys Locker Room DF	DF	5:53
102.5-41	Boys Locker Room Sink	Sink	5:54
102.5-42	Boys Locker Room Coaches Office Sink	Sink	5:55
102.5-43	Room 151-1 R Bay L Sink	Sink	5:56
102.5-44	Room 151-1 R Bay M Sink	Sink	5:57
102.5-45	Room 151-1 R Bay R Sink	Sink	5:58
102.5-46	Room 148 L Sink	Sink	5:59
102.5-47	Room 148 R Sink	Sink	6:00

Notes: Please e-mail lab results to labs@stohlenv.com Mscinta@stohlenvironmental.com

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 11/19/2025 + 11/20/2025
 Relinquished By: _____ Print Name _____ Stohl Env: Connor Crilly Date: 11/20/2025
 Received (Name / Lab): AMM MAMM ALS Date: 11/21/25 Time: 8:25
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____
 QA/QC Review (Name / Lab): _____ Date: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____





Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.5

Client: Kenton UFSD

Contact: Georgia Militello

Building: Herbert Hoover Middle School

Location: 249 Thorncliff Rd, Buffalo, NY 14223

LEAD
 Water by 200.8 X

Turnaround
10 Days

Sample #	Location	Outlet Type	Time
102.5-48	Room 149 Sink	Sink	6:01
102.5-49	Girls Upper Locker Room Ms. Siegel Office Sink	Sink	6:02
102.5-50	Girls Upper Locker Room Bathroom L Sink	Sink	6:03
102.5-51	Girls Upper Locker Room DF	DF	6:04
102.5-52	Girls Upper Locker Room Sink	Sink	6:05
102.5-53	Girls Upper Locker Room Faculty Bathroom Sink	Sink	6:06
102.5-54	Laundry Room Sink	Sink	6:07
102.5-55	Kitchen 147 L Sink	Sink	6:07
102.5-56	Kitchen 147 R Sink	Sink	6:08
102.5-57	Room 145 Sink	Sink	6:09
102.5-58	Room 143 Sink	Sink	6:10
102.5-59	Room 142 Ice Machine	Ice Machine	6:11
102.5-60A	DF by 141	DF	6:12
102.5-60B	DFB by 141	DFB	6:13
102.5-61	141 Sink	Sink	6:14
102.5-62	Boys Upper Locker Room L Bathroom Sink	Sink	6:15
102.5-63	Boys Upper Locker Room R Bathroom Sink	Sink	6:16
102.5-64	Boys Upper Locker Room DF	DF	6:17

Notes: Please e-mail lab results to labs@stohlenv.com Mscinta@stohlenvironmental.com

Sampled By: Jared Rider Print Name Jared Rider Stohl Env. Jared Rider Date: 11/19/2025 + 11/20/2025

Relinquished By: _____ Print Name _____ Stohl Env. Connor Crilly Date: 11/20/2025

Received (Name / Lab): MM / ALS Date: 11/21/25 Time: 8:25

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



R2515828

5

Stohl Environmental
Kenton UFSD - Herbert Hoover Middle School



Cooler Receipt and Preservation Check

Project/Client Stohl

Folder Number _____

Cooler received on 11/21/25 by: RM

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>(N)</u>
2	Custody papers properly completed (ink, signed)?	<u>(Y)</u> N
3	Did all bottles arrive in good condition (unbroken)?	<u>(Y)</u> N
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>(N)</u>

5a	Did VOA vials have sig* bubbles?	Y N <u>(NA)</u>
5b	Sig* bubbles: Alk? Y N <u>(NA)</u> Sulfide? Y N <u>(NA)</u>	
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set	<u>(NA)</u>

8. Temperature Readings Date: 11/21/25 Time: 8:32 ID: (IR#12) IR#11 From: Temp Blank (Sample Bottle)

Temp (°C)	<u>10.2</u>						
Within 0-6°C?	<u>(Y)</u> <u>(N)</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: No ice Ice melted Poorly Packed (described below) Same Day Rule & Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMO by RM on 11/21 at 8:32
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 11/26 Time: 1545 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? (YES) NO
- 10. Did all bottle labels and tags agree with custody papers? (YES) NO
- 11. Were correct containers used for the tests indicated? (YES) NO
- 12. Were 5035 vials acceptable (no extra labels; not leaking)? YES NO (N/A)
- 13. Were dissolved metals filtered in the field? YES NO (N/A)
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated (N/A)

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>202325</u>	HNO ₃	<u>X</u>		<u>24017806</u>	<u>7127</u>				
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____
Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG *significant air bubbles: VOA > 5-6 mm ; WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515828

Sample Name: 102.5-31
Lab Code: R2515828-001
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-32
Lab Code: R2515828-002
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-33
Lab Code: R2515828-003
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-34
Lab Code: R2515828-004
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-35
Lab Code: R2515828-005
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515828

Sample Name: 102.5-36A
Lab Code: R2515828-006
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-36B
Lab Code: R2515828-007
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-37
Lab Code: R2515828-008
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-38
Lab Code: R2515828-009
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-39
Lab Code: R2515828-010
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515828

Sample Name: 102.5-40
Lab Code: R2515828-011
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-41
Lab Code: R2515828-012
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-42
Lab Code: R2515828-013
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-43
Lab Code: R2515828-014
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-44
Lab Code: R2515828-015
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515828

Sample Name: 102.5-45
Lab Code: R2515828-016
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-46
Lab Code: R2515828-017
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-47
Lab Code: R2515828-018
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-48
Lab Code: R2515828-019
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-49
Lab Code: R2515828-020
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515828

Sample Name: 102.5-50
Lab Code: R2515828-021
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-51
Lab Code: R2515828-022
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-52
Lab Code: R2515828-023
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-53
Lab Code: R2515828-024
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-54
Lab Code: R2515828-025
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515828

Sample Name: 102.5-55
Lab Code: R2515828-026
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-56
Lab Code: R2515828-027
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-57
Lab Code: R2515828-028
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-58
Lab Code: R2515828-029
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-59
Lab Code: R2515828-030
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515828

Sample Name: 102.5-60A
Lab Code: R2515828-031
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-60B
Lab Code: R2515828-032
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-61
Lab Code: R2515828-033
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-62
Lab Code: R2515828-034
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-63
Lab Code: R2515828-035
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515828

Sample Name: 102.5-64
Lab Code: R2515828-036
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-31
Lab Code: R2515828-001

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 12:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-32
Lab Code: R2515828-002

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 12:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-33
Lab Code: R2515828-003

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 12:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-34
Lab Code: R2515828-004

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 12:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-35
Lab Code: R2515828-005

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 12:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-36A
Lab Code: R2515828-006

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 12:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-36B
Lab Code: R2515828-007

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 12:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-37
Lab Code: R2515828-008

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	41.3	ug/L	1.0	1	12/18/25 17:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-38
Lab Code: R2515828-009

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	37.7	ug/L	1.0	1	12/18/25 17:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-39
Lab Code: R2515828-010

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 17:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-40
Lab Code: R2515828-011

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.8	ug/L	1.0	1	12/18/25 17:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-41
Lab Code: R2515828-012

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 17:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-42
Lab Code: R2515828-013

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 17:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-43
Lab Code: R2515828-014

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 17:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-44
Lab Code: R2515828-015

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 17:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-45
Lab Code: R2515828-016

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.7	ug/L	1.0	1	12/18/25 18:00	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-46
Lab Code: R2515828-017

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.0	ug/L	1.0	1	12/18/25 18:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-47
Lab Code: R2515828-018

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	12/18/25 18:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-48
Lab Code: R2515828-019

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-49
Lab Code: R2515828-020

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-50
Lab Code: R2515828-021

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:07	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-51
Lab Code: R2515828-022

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-52
Lab Code: R2515828-023

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-53
Lab Code: R2515828-024

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:14	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-54
Lab Code: R2515828-025

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	12/18/25 18:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-55
Lab Code: R2515828-026

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-56
Lab Code: R2515828-027

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-57
Lab Code: R2515828-028

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-58
Lab Code: R2515828-029

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-59
Lab Code: R2515828-030

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-60A
Lab Code: R2515828-031

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-60B
Lab Code: R2515828-032

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-61
Lab Code: R2515828-033

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-62
Lab Code: R2515828-034

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	12/18/25 18:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-63
Lab Code: R2515828-035

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	12/18/25 18:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-64
Lab Code: R2515828-036

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:44	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515828-MB1

Service Request: R2515828
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 17:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515828-MB2

Service Request: R2515828
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515828-MB3

Service Request: R2515828
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 11:59	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25
Date Analyzed: 12/19/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.5-36B
Lab Code: R2515828-007
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515828-007MS		Duplicate Matrix Spike R2515828-007DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	18.2	20.0	91	18.1	20.0	91	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25
Date Analyzed: 12/18/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.5-37
Lab Code: R2515828-008
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515828-008MS		Duplicate Matrix Spike R2515828-008DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	41.3	62.7	20.0	107	63.0	20.0	109	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25
Date Analyzed: 12/18/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.5-56
Lab Code: R2515828-027
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515828-027MS		Duplicate Matrix Spike R2515828-027DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	22.6	20.0	113	22.4	20.0	112	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515828
Date Collected: 11/19/25
Date Received: 11/21/25
Date Analyzed: 12/18/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.5-57
Lab Code: R2515828-028
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515828-028MS		Duplicate Matrix Spike R2515828-028DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	21.8	20.0	109	21.8	20.0	109	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515828

Date Analyzed: 12/18/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample
R2515828-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.1	20.0	105	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515828

Date Analyzed: 12/18/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample
R2515828-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.4	20.0	112	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515828
Date Analyzed: 12/19/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2515828-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.1	20.0	95	85-115



December 23, 2025

Service Request No:R2515829

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Kenton UFSD - Herbert Hoover Middle School

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory November 21, 2025
For your reference, these analyses have been assigned our service request number **R2515829**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | **FAX** +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School
Sample Matrix: Drinking Water

Service Request: R2515829
Date Received: 11/21/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 11/21/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 12/23/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 102.5-65		Lab ID: R2515829-001					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.3			1.0	ug/L	200.8	
CLIENT ID: 102.5-74		Lab ID: R2515829-012					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.7			1.0	ug/L	200.8	
CLIENT ID: 102.5-75		Lab ID: R2515829-013					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.5			1.0	ug/L	200.8	
CLIENT ID: 102.5-76		Lab ID: R2515829-014					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.2			1.0	ug/L	200.8	
CLIENT ID: 102.5-77		Lab ID: R2515829-015					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.7			1.0	ug/L	200.8	
CLIENT ID: 102.5-78		Lab ID: R2515829-016					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.6			1.0	ug/L	200.8	
CLIENT ID: 102.5-79		Lab ID: R2515829-017					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.1			1.0	ug/L	200.8	
CLIENT ID: 102.5-80		Lab ID: R2515829-018					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.6			1.0	ug/L	200.8	
CLIENT ID: 102.5-83		Lab ID: R2515829-021					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.0			1.0	ug/L	200.8	
CLIENT ID: 102.5-87		Lab ID: R2515829-025					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.2			1.0	ug/L	200.8	
CLIENT ID: 102.5-88		Lab ID: R2515829-026					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.8			1.0	ug/L	200.8	
CLIENT ID: 102.5-91		Lab ID: R2515829-029					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.8			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 102.5-92	Lab ID: R2515829-030					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.15			0.50	ug/L	200.8

CLIENT ID: 102.5-95	Lab ID: R2515829-034					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.0			1.0	ug/L	200.8

CLIENT ID: 102.5-96	Lab ID: R2515829-035					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request:R2515829

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2515829-001	102.5-65	11/19/2025	
R2515829-002	102.5-66	11/19/2025	
R2515829-003	102.5-67	11/19/2025	
R2515829-004	102.5-68	11/19/2025	
R2515829-005	102.5-69A	11/19/2025	
R2515829-006	102.5-69B	11/19/2025	
R2515829-007	102.5-70	11/19/2025	
R2515829-008	102.5-71	11/19/2025	
R2515829-009	102.5-72	11/19/2025	
R2515829-010	102.5-73A	11/19/2025	
R2515829-011	102.5-73B	11/19/2025	
R2515829-012	102.5-74	11/19/2025	
R2515829-013	102.5-75	11/19/2025	
R2515829-014	102.5-76	11/19/2025	
R2515829-015	102.5-77	11/19/2025	
R2515829-016	102.5-78	11/19/2025	
R2515829-017	102.5-79	11/19/2025	
R2515829-018	102.5-80	11/19/2025	
R2515829-019	102.5-81	11/19/2025	
R2515829-020	102.5-82	11/19/2025	
R2515829-021	102.5-83	11/19/2025	
R2515829-022	102.5-84	11/19/2025	
R2515829-023	102.5-85	11/19/2025	
R2515829-024	102.5-86	11/19/2025	
R2515829-025	102.5-87	11/19/2025	
R2515829-026	102.5-88	11/19/2025	
R2515829-027	102.5-89	11/19/2025	
R2515829-028	102.5-90	11/19/2025	
R2515829-029	102.5-91	11/19/2025	
R2515829-030	102.5-92	11/19/2025	
R2515829-031	102.5-93A	11/19/2025	
R2515829-032	102.5-93B	11/19/2025	
R2515829-033	102.5-94	11/19/2025	
R2515829-034	102.5-95	11/19/2025	
R2515829-035	102.5-96	11/19/2025	
R2515829-036	102.5-97	11/19/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.5

Client: Kenton UFSD

Contact: Georgia Militello

Building: Herbert Hoover Middle School

Location: 249 Thornduff Rd, Buffalo, NY 14223

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
102.5-65	Boys Upper Locker Room Office Sink	Sink	6:18
102.5-66	250-4 Girls Bathroom R Bay L	Sink	6:19
102.5-67	250-4 Girls Bathroom R Bay M	Sink	6:20
102.5-68	250-4 Girls Bathroom R Bay R	Sink	6:21
102.5-69A	DF Near 241	DF	6:22
102.5-69B	DFB Near 241	DFB	6:23
102.5-70	Room 210 Sink	Sink	6:24
102.5-71	Room 210-1 Sink	Sink	6:25
102.5-72	Room 210-2 Sink	Sink	6:26
102.5-73A	DF across from 210	DF	6:26
102.5-73B	DFB across from 210	DFB	6:27
102.5-74	Room 211 L Sink	Sink	6:28
102.5-75	Room 211 ML Sink	Sink	6:29
102.5-76	Room 211 MR Sink	Sink	6:30
102.5-77	Room 211 R Sink	Sink	6:31
102.5-78	Room 213 Sink	Sink	6:32
102.5-79	Room 214 L Sink	Sink	6:33
102.5-80	Room 214 R Sink	Sink	6:34

Notes:

Please e-mail lab results to labs@stohlenv.com

Mscinta@stohlenvironmental.com

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 11/19/2025 + 11/20/2025

Relinquished By: _____ Print Name _____ Stohl Env: Connor Crilly Date: 11/20/2025

Received (Name / Lab): MMM Mami ALS Date: 11/21/25 Time: 8:25

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

R2515829 **5**

Stohl Environmental
 Kenton UFSD - Herbert Hoover Middle School



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.5

Client: Kenton UFSD

Contact: Georgia Militello

Building: Herbert Hoover Middle School

Location: 249 Thorncliff Rd, Buffalo, NY 14223

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
102.5-81	Room 215 Sink	Sink	6:35
102.5-82	Room 217 Sink 1	Sink	6:36
102.5-83	Room 217 Sink 2	Sink	6:37
102.5-84	Room 217 Sink 3	Sink	6:38
102.5-85	Room 217 Sink 4	Sink	6:39
102.5-86	Room 217 Sink 5	Sink	6:40
102.5-87	Room 216 L Sink	Sink	6:41
102.5-88	Room 216 R Sink	Sink	6:42
102.5-89	Room 219 L Sink	Sink	6:43
102.5-90	Room 219 LM Sink	Sink	6:44
102.5-91	Room 219 LR Sink	Sink	6:45
102.5-92	Room 219 R Sink	Sink	6:45
102.5-93A	DF Outside of 219	DF	6:46
102.5-93B	DFB Outside of 219	DFB	6:47
102.5-94	Room 218 L Sink	Sink	6:48
102.5-95	Room 218 R Sink	Sink	6:49
102.5-96	Room 222-1 Sink	Sink	6:50
102.5-97	Room 222-2 Sink	Sink	6:51

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Mscinta@stohlenvironmental.com

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 11/19/2025 + 11/20/2025

Relinquished By: _____ Print Name _____ Stohl Env: Connor Crilly Date: 11/20/2025

Received (Name / Lab): Sam Mearns ALS Date: 8:25 11/21/25 Time: 8:25

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



R2515829 **5**
 Stahl Environmental
 Kenton UFSD - Herbert Hoover Middle School

Cooler Receipt and Preservation

Project/Client Stohl Folder Number _____

Cooler received on 11/21/25 by: RM COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>(N)</u>	5a	Did VOA vials have sig* bubbles?	Y N <u>(NA)</u>
2	Custody papers properly completed (ink, signed)?	<u>(Y)</u> N	5b	Sig* bubbles: Alk? Y N <u>(NA)</u> Sulfide? Y N <u>(NA)</u>	
3	Did all bottles arrive in good condition (unbroken)?	<u>(Y)</u> N	6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>(N)</u>	7	Soil VOA received as: Bulk Encore 5035set	<u>(NA)</u>

8. Temperature Readings Date: 11/21/25 Time: 8:32 ID: (R#12) IR#11 From: Temp Blank (Sample Bottle)

Temp (°C)	<u>10.2</u>						
Within 0-6°C?	Y <u>(N)</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: No ice Ice melted Poorly Packed (described below) Same Day Rule
 & Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMO by RM on 11/21 at 8:32
 5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 11/26 Time: 7:45 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? (YES) NO
- 10. Did all bottle labels and tags agree with custody papers? (YES) NO
- 11. Were correct containers used for the tests indicated? (YES) NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO (N/A)
- 13. Were dissolved metals filtered in the field? YES NO (N/A)
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated (N/A)

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>202325</u>	HNO ₃	<u>X</u>		<u>24077806</u>	<u>7/02</u>				
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____
 Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- | | |
|---|--|
| <p>U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.</p> <p>J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).</p> <p>B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.</p> <p>E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.</p> <p>E Organics- Concentration has exceeded the calibration range for that specific analysis.</p> <p>D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.</p> <p>* Indicates that a quality control parameter has exceeded laboratory limits. Under the “Notes” column of the Form I, this qualifier denotes analysis was performed out of Holding Time.</p> <p>H Analysis was performed out of hold time for tests that have an “immediate” hold time criteria.</p> <p># Spike was diluted out.</p> | <p>+ Correlation coefficient for MSA is <0.995.</p> <p>N Inorganics- Matrix spike recovery was outside laboratory limits.</p> <p>N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.</p> <p>S Concentration has been determined using Method of Standard Additions (MSA).</p> <p>W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.</p> <p>P Concentration >40% difference between the two GC columns.</p> <p>C Confirmed by GC/MS</p> <p>Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).</p> <p>X See Case Narrative for discussion.</p> <p>MRL Method Reporting Limit. Also known as:</p> <p>LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.</p> <p>MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).</p> <p>LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.</p> <p>ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.</p> |
|---|--|

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory’s NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515829

Sample Name: 102.5-65
Lab Code: R2515829-001
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-66
Lab Code: R2515829-002
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-67
Lab Code: R2515829-003
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-68
Lab Code: R2515829-004
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-69A
Lab Code: R2515829-005
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515829

Sample Name: 102.5-69B
Lab Code: R2515829-006
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-70
Lab Code: R2515829-007
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-71
Lab Code: R2515829-008
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-72
Lab Code: R2515829-009
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-73A
Lab Code: R2515829-010
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515829

Sample Name: 102.5-73B
Lab Code: R2515829-011
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-74
Lab Code: R2515829-012
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-75
Lab Code: R2515829-013
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-76
Lab Code: R2515829-014
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-77
Lab Code: R2515829-015
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515829

Sample Name: 102.5-78
Lab Code: R2515829-016
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-79
Lab Code: R2515829-017
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-80
Lab Code: R2515829-018
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-81
Lab Code: R2515829-019
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-82
Lab Code: R2515829-020
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515829

Sample Name: 102.5-83
Lab Code: R2515829-021
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-84
Lab Code: R2515829-022
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-85
Lab Code: R2515829-023
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-86
Lab Code: R2515829-024
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-87
Lab Code: R2515829-025
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515829

Sample Name: 102.5-88
Lab Code: R2515829-026
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-89
Lab Code: R2515829-027
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-90
Lab Code: R2515829-028
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-91
Lab Code: R2515829-029
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-92
Lab Code: R2515829-030
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By
NMANSEN

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515829

Sample Name: 102.5-93A
Lab Code: R2515829-031
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-93B
Lab Code: R2515829-032
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-94
Lab Code: R2515829-033
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-95
Lab Code: R2515829-034
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-96
Lab Code: R2515829-035
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental

Service Request: R2515829

Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Sample Name: 102.5-97

Date Collected: 11/19/25

Lab Code: R2515829-036

Date Received: 11/21/25

Sample Matrix: Drinking Water

Analysis Method

Extracted/Digested By

Analyzed By

200.8

DWINTER



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-65
Lab Code: R2515829-001

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	12/18/25 18:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-66
Lab Code: R2515829-002

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-67
Lab Code: R2515829-003

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-68
Lab Code: R2515829-004

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-69A
Lab Code: R2515829-005

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-69B
Lab Code: R2515829-006

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-70
Lab Code: R2515829-007

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-71
Lab Code: R2515829-008

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-72
Lab Code: R2515829-009

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 19:00	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-73A
Lab Code: R2515829-010

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 19:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-73B
Lab Code: R2515829-011

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 19:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-74
Lab Code: R2515829-012

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	12/18/25 19:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-75
Lab Code: R2515829-013

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.5	ug/L	1.0	1	12/18/25 19:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-76
Lab Code: R2515829-014

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	12/18/25 19:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-77
Lab Code: R2515829-015

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	12/18/25 19:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-78
Lab Code: R2515829-016

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	12/18/25 19:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-79
Lab Code: R2515829-017

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.1	ug/L	1.0	1	12/18/25 19:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-80
Lab Code: R2515829-018

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	12/18/25 19:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-81
Lab Code: R2515829-019

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 19:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-82
Lab Code: R2515829-020

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 19:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-83
Lab Code: R2515829-021

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0	ug/L	1.0	1	12/18/25 19:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-84
Lab Code: R2515829-022

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 19:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-85
Lab Code: R2515829-023

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 19:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-86
Lab Code: R2515829-024

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 19:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-87
Lab Code: R2515829-025

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	12/18/25 19:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-88
Lab Code: R2515829-026

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.8	ug/L	1.0	1	12/18/25 19:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-89
Lab Code: R2515829-027

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 19:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-90
Lab Code: R2515829-028

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 19:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-91
Lab Code: R2515829-029

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.8	ug/L	1.0	1	12/18/25 19:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-92
Lab Code: R2515829-030

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	2.15	ug/L	0.50	1	12/19/25 14:29	12/18/25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-93A
Lab Code: R2515829-031

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 19:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-93B
Lab Code: R2515829-032

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 19:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-94
Lab Code: R2515829-033

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 19:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-95
Lab Code: R2515829-034

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.0	ug/L	1.0	1	12/18/25 20:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-96
Lab Code: R2515829-035

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	12/18/25 20:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-97
Lab Code: R2515829-036

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 20:03	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515829-MB1

Service Request: R2515829
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	ND U	ug/L	0.50	1	12/19/25 14:25	12/18/25	
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 18:25	NA	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515829-MB2

Service Request: R2515829
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 19:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515829-MB3

Service Request: R2515829
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 19:52	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25
Date Analyzed: 12/18/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.5-73B
Lab Code: R2515829-011
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515829-011MS		Duplicate Matrix Spike R2515829-011DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	21.5	20.0	108	22.2	20.0	111	70-130	3	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25
Date Analyzed: 12/18/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.5-74
Lab Code: R2515829-012
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515829-012MS		Duplicate Matrix Spike R2515829-012DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	1.7	21.5	20.0	99	21.8	20.0	100	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25
Date Analyzed: 12/18/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.5-93A
Lab Code: R2515829-031
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515829-031MS		Duplicate Matrix Spike R2515829-031DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	20.6	20.0	103	20.7	20.0	103	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515829
Date Collected: 11/19/25
Date Received: 11/21/25
Date Analyzed: 12/18/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.5-93B
Lab Code: R2515829-032
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515829-032MS		Duplicate Matrix Spike R2515829-032DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	21.0	20.0	105	21.1	20.0	105	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515829
Date Analyzed: 12/18/25 - 12/19/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2515829-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.7	20.0	104	85-115
Lead, Total	200.8	22.4	20.0	112	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515829

Date Analyzed: 12/18/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample
R2515829-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.1	20.0	110	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515829

Date Analyzed: 12/18/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample
R2515829-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.2	20.0	106	85-115



December 22, 2025

Service Request No:R2515830

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Kenton UFSD - Herbert Hoover Middle School

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory November 21, 2025
For your reference, these analyses have been assigned our service request number **R2515830**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | **FAX** +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School
Sample Matrix: Drinking Water

Service Request: R2515830
Date Received: 11/21/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 11/21/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 12/22/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 102.5-100		Lab ID: R2515830-004					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.0			1.0	ug/L	200.8	
CLIENT ID: 102.5-101		Lab ID: R2515830-005					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.1			1.0	ug/L	200.8	
CLIENT ID: 102.5-102		Lab ID: R2515830-006					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.1			1.0	ug/L	200.8	
CLIENT ID: 102.5-109		Lab ID: R2515830-013					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	14.0			1.0	ug/L	200.8	
CLIENT ID: 102.5-110		Lab ID: R2515830-014					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.2			1.0	ug/L	200.8	
CLIENT ID: 102.5-112		Lab ID: R2515830-017					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	9.7			1.0	ug/L	200.8	
CLIENT ID: 102.5-115		Lab ID: R2515830-020					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.6			1.0	ug/L	200.8	
CLIENT ID: 102.5-117		Lab ID: R2515830-023					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.7			1.0	ug/L	200.8	
CLIENT ID: 102.5-118		Lab ID: R2515830-024					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.1			1.0	ug/L	200.8	
CLIENT ID: 102.5-123		Lab ID: R2515830-029					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.7			1.0	ug/L	200.8	
CLIENT ID: 102.5-124		Lab ID: R2515830-030					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.3			1.0	ug/L	200.8	



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request:R2515830

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2515830-001	102.5-98A	11/19/2025	
R2515830-002	102.5-98B	11/19/2025	
R2515830-003	102.5-99	11/19/2025	
R2515830-004	102.5-100	11/19/2025	
R2515830-005	102.5-101	11/19/2025	
R2515830-006	102.5-102	11/19/2025	
R2515830-007	102.5-103	11/19/2025	
R2515830-008	102.5-104	11/19/2025	
R2515830-009	102.5-105	11/19/2025	
R2515830-010	102.5-106	11/19/2025	
R2515830-011	102.5-107	11/19/2025	
R2515830-012	102.5-108	11/19/2025	
R2515830-013	102.5-109	11/19/2025	
R2515830-014	102.5-110	11/19/2025	
R2515830-015	102.5-111A	11/19/2025	
R2515830-016	102.5-111B	11/19/2025	
R2515830-017	102.5-112	11/19/2025	
R2515830-018	102.5-113	11/19/2025	
R2515830-019	102.5-114	11/19/2025	
R2515830-020	102.5-115	11/19/2025	
R2515830-021	102.5-116A	11/19/2025	
R2515830-022	102.5-116B	11/19/2025	
R2515830-023	102.5-117	11/19/2025	
R2515830-024	102.5-118	11/19/2025	
R2515830-025	102.5-119	11/19/2025	
R2515830-026	102.5-120	11/19/2025	
R2515830-027	102.5-121	11/19/2025	
R2515830-028	102.5-122	11/19/2025	
R2515830-029	102.5-123	11/19/2025	
R2515830-030	102.5-124	11/19/2025	
R2515830-031	102.5-125	11/19/2025	
R2515830-032	102.5-126	11/19/2025	
R2515830-033	102.5-127	11/19/2025	
R2515830-034	102.5-128	11/19/2025	
R2515830-035	102.5-129	11/19/2025	
R2515830-036	102.5-130	11/19/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.5

Client: Kenton UFSD

Contact: Georgia Militello

Building: Herbert Hoover Middle School

Location: 249 Thorncliff Rd, Buffalo, NY 14223

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
102.5-98A	DF Near 230	DF	6:52
102.5-98B	DFB Near 230	DFB	6:53
102.5-99	Room 225-1 L Sink	Sink	6:54
102.5-100	Room 225-1 M Sink	Sink	6:55
102.5-101	Room 225-1 R Sink	Sink	6:56
102.5-102	Room 225-2 L Sink	Sink	6:57
102.5-103	Room 225-2 R Sink	Sink	6:58
102.5-104	Room 250-1 L Bay L Sink	Sink	6:59
102.5-105	Room 250-1 L Bay R Sink	Sink	7:00
102.5-106	Room 250-1 R Bay L Sink	Sink	7:01
102.5-107	Room 250-1 R Bay M Sink	Sink	7:02
102.5-108	Room 250-1 R Bay R Sink	Sink	7:03
102.5-109	Room 250 Desk Sink	Sink	7:04
102.5-110	Room 255 Sink	Sink	7:04
102.5-111A	DF by Room 255	DF	7:05
102.5-111B	DFB by Room 255	DFB	7:06
102.5-112	206 Sink	Sink	7:07
102.5-113	L Student Restroom by 206	Sink	7:08

Notes: Please e-mail lab results to labs@stohlenv.com Mscinta@stohlenvironmental.com

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 11/19/2025 + 11/20/2025
 Relinquished By: _____ Print Name _____ Stohl Env: Connor Crilly Date: 11/20/2025
 Received (Name / Lab): [Signature] ALS Date: 11/21/25 Time: 8:25
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____





Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.5

Client: Kenton UFSD

Contact: Georgia Militello

Building: Herbert Hoover Middle School

Location: 249 Thornclyff Rd, Buffalo, NY 14223

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
102.5-114	R Student Restroom by 206	Sink	7:09
102.5-115	Room 207 Sink	Sink	7:10
102.5-116A	DF by Room 207	DF	7:11
102.5-116B	DFB by Room 207	DFB	7:12
102.5-117	2nd Floor Art Room Sink	Sink	7:13
102.5-118	Room 353-1 L Bay L	Sink	7:14
102.5-119	Room 353-1 L Bay M	Sink	7:15
102.5-120	Room 353-1 L Bay R	Sink	7:16
102.5-121	Room 353-1 R Bay L	Sink	7:17
102.5-122	Room 353-1 R Bay M	Sink	7:18
102.5-123	Room 353-1 R Bay R	Sink	7:19
102.5-124	Room 353-3 L Bay L	Sink	7:20
102.5-125	Room 353-3 L Bay M	Sink	7:21
102.5-126	Room 353-3 L Bay R	Sink	7:22
102.5-127	Room 353-3 R Bay L	Sink	7:23
102.5-128	Room 353-3 R Bay M	Sink	7:23
102.5-129	Room 353-3 R Bay R	Sink	7:24
102.5-130	Room 308 L	Sink	7:25

Notes: Please e-mail lab results to labs@stohlenv.com Mscinta@stohlenvironmental.com

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 11/19/2025 + 11/20/2025

Relinquished By: _____ Print Name _____ Stohl Env: Connor Crilly Date: 11/20/2025

Received (Name / Lab): [Signature] ALS Date: 11/21/25 Time: 8:25

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Cooler Receipt and Preservation Check

R2515830 **5**
 Stohl Environmental
 Kenton UFSD - Herbert Hoover Middle School

Project/Client Stohl Folder Number _____

Cooler received on 11/21/25 by: RM

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>(N)</u>
2	Custody papers properly completed (ink, signed)?	<u>(Y)</u> N
3	Did all bottles arrive in good condition (unbroken)?	<u>(Y)</u> N
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>(N)</u>

5a	Did VOA vials have sig* bubbles?	Y N <u>(NA)</u>
5b	Sig* bubbles: Alk? Y N <u>(NA)</u> Sulfide? Y N <u>(NA)</u>	
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set	<u>(NA)</u>

8. Temperature Readings Date: 11/21/25 Time: 8:32 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>10.2</u>						
Within 0-6°C?	<u>Y</u> <u>(N)</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: No ice Ice melted Poorly Packed (described below) Same Day Rule
 & Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMO by RM on 11/21 at 8:32
 5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 11/26 Time: 1545 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO (NA)
- 13. Were dissolved metals filtered in the field? YES NO (NA)
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated (NA)

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>202325</u>	HNO ₃	<u>x</u>		<u>24017606</u>	<u>1/27</u>				
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____
 Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515830

Sample Name: 102.5-98A
Lab Code: R2515830-001
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-98B
Lab Code: R2515830-002
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-99
Lab Code: R2515830-003
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-100
Lab Code: R2515830-004
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-101
Lab Code: R2515830-005
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515830

Sample Name: 102.5-102
Lab Code: R2515830-006
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-103
Lab Code: R2515830-007
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-104
Lab Code: R2515830-008
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-105
Lab Code: R2515830-009
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-106
Lab Code: R2515830-010
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515830

Sample Name: 102.5-107
Lab Code: R2515830-011
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-108
Lab Code: R2515830-012
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-109
Lab Code: R2515830-013
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-110
Lab Code: R2515830-014
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-111A
Lab Code: R2515830-015
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515830

Sample Name: 102.5-111B
Lab Code: R2515830-016
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-112
Lab Code: R2515830-017
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-113
Lab Code: R2515830-018
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-114
Lab Code: R2515830-019
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-115
Lab Code: R2515830-020
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515830

Sample Name: 102.5-116A
Lab Code: R2515830-021
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-116B
Lab Code: R2515830-022
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-117
Lab Code: R2515830-023
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-118
Lab Code: R2515830-024
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-119
Lab Code: R2515830-025
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515830

Sample Name: 102.5-120
Lab Code: R2515830-026
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-121
Lab Code: R2515830-027
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-122
Lab Code: R2515830-028
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-123
Lab Code: R2515830-029
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-124
Lab Code: R2515830-030
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515830

Sample Name: 102.5-125
Lab Code: R2515830-031
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-126
Lab Code: R2515830-032
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-127
Lab Code: R2515830-033
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-128
Lab Code: R2515830-034
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-129
Lab Code: R2515830-035
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515830

Sample Name: 102.5-130
Lab Code: R2515830-036
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-98A
Lab Code: R2515830-001

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 20:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-98B
Lab Code: R2515830-002

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 20:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-99
Lab Code: R2515830-003

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 20:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-100
Lab Code: R2515830-004

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0	ug/L	1.0	1	12/18/25 20:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-101
Lab Code: R2515830-005

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	12/18/25 20:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-102
Lab Code: R2515830-006

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	12/18/25 20:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-103
Lab Code: R2515830-007

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 20:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-104
Lab Code: R2515830-008

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 20:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-105
Lab Code: R2515830-009

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 20:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-106
Lab Code: R2515830-010

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 20:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-107
Lab Code: R2515830-011

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 20:21	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-108
Lab Code: R2515830-012

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 20:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-109
Lab Code: R2515830-013

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	14.0	ug/L	1.0	1	12/18/25 20:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-110
Lab Code: R2515830-014

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	12/18/25 20:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-111A
Lab Code: R2515830-015

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 20:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-111B
Lab Code: R2515830-016

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 20:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-112
Lab Code: R2515830-017

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	9.7	ug/L	1.0	1	12/18/25 20:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-113
Lab Code: R2515830-018

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 20:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-114
Lab Code: R2515830-019

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 20:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-115
Lab Code: R2515830-020

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.6	ug/L	1.0	1	12/18/25 20:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-116A
Lab Code: R2515830-021

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 20:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-116B
Lab Code: R2515830-022

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 20:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-117
Lab Code: R2515830-023

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.7	ug/L	1.0	1	12/18/25 20:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-118
Lab Code: R2515830-024

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	12/18/25 20:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-119
Lab Code: R2515830-025

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 20:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-120
Lab Code: R2515830-026

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 20:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-121
Lab Code: R2515830-027

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 21:00	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-122
Lab Code: R2515830-028

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 21:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-123
Lab Code: R2515830-029

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	12/18/25 21:03	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-124
Lab Code: R2515830-030

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	12/18/25 21:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-125
Lab Code: R2515830-031

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 21:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-126
Lab Code: R2515830-032

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 21:07	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-127
Lab Code: R2515830-033

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 21:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-128
Lab Code: R2515830-034

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 21:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-129
Lab Code: R2515830-035

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 21:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-130
Lab Code: R2515830-036

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 21:21	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515830-MB1

Service Request: R2515830
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 19:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515830-MB2

Service Request: R2515830
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 20:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515830-MB3

Service Request: R2515830
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 21:18	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25
Date Analyzed: 12/18/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.5-111A
Lab Code: R2515830-015
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515830-015MS		Duplicate Matrix Spike R2515830-015DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	21.0	20.0	105	21.0	20.0	105	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25
Date Analyzed: 12/18/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.5-111B
Lab Code: R2515830-016
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515830-016MS		Duplicate Matrix Spike R2515830-016DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	21.1	20.0	105	21.3	20.0	106	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25
Date Analyzed: 12/18/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.5-129
Lab Code: R2515830-035
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515830-035MS		Duplicate Matrix Spike R2515830-035DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	21.5	20.0	107	21.2	20.0	106	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515830
Date Collected: 11/19/25
Date Received: 11/21/25
Date Analyzed: 12/18/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.5-130
Lab Code: R2515830-036
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515830-036MS		Duplicate Matrix Spike R2515830-036DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	21.3	20.0	106	21.9	20.0	110	70-130	3	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515830
Date Analyzed: 12/18/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2515830-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.2	20.0	106	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515830
Date Analyzed: 12/18/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2515830-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.1	20.0	105	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515830

Date Analyzed: 12/18/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample
R2515830-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.1	20.0	105	85-115



December 23, 2025

Service Request No:R2515831

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Kenton UFSD - Herbert Hoover Middle School

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory November 21, 2025
For your reference, these analyses have been assigned our service request number **R2515831**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | **FAX** +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School
Sample Matrix: Drinking Water

Service Request: R2515831
Date Received: 11/21/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Twenty four drinking water samples were received for analysis at ALS Environmental on 11/21/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 12/23/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 102.5-131	Lab ID: R2515831-001
-----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.9			1.0	ug/L	200.8

CLIENT ID: 102.5-133	Lab ID: R2515831-004
-----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.7			1.0	ug/L	200.8

CLIENT ID: 102.5-134	Lab ID: R2515831-005
-----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8

CLIENT ID: 102.5-139	Lab ID: R2515831-011
-----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.3			1.0	ug/L	200.8

CLIENT ID: 102.5-143	Lab ID: R2515831-015
-----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.3			1.0	ug/L	200.8

CLIENT ID: 102.5-145	Lab ID: R2515831-017
-----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.7			1.0	ug/L	200.8

CLIENT ID: 102.5-147	Lab ID: R2515831-019
-----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.0			1.0	ug/L	200.8

CLIENT ID: 102.5-150	Lab ID: R2515831-023
-----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.79			0.50	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request:R2515831

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2515831-001	102.5-131	11/19/2025	
R2515831-002	102.5-132A	11/19/2025	
R2515831-003	102.5-132B	11/19/2025	
R2515831-004	102.5-133	11/19/2025	
R2515831-005	102.5-134	11/19/2025	
R2515831-006	102.5-135	11/19/2025	
R2515831-007	102.5-136	11/19/2025	
R2515831-008	102.5-137A	11/19/2025	
R2515831-009	102.5-137B	11/19/2025	
R2515831-010	102.5-138	11/19/2025	
R2515831-011	102.5-139	11/19/2025	
R2515831-012	102.5-140	11/19/2025	
R2515831-013	102.5-141	11/19/2025	
R2515831-014	102.5-142	11/19/2025	
R2515831-015	102.5-143	11/19/2025	
R2515831-016	102.5-144	11/19/2025	
R2515831-017	102.5-145	11/19/2025	
R2515831-018	102.5-146	11/19/2025	
R2515831-019	102.5-147	11/19/2025	
R2515831-020	102.5-148	11/19/2025	
R2515831-021	102.5-149A	11/19/2025	
R2515831-022	102.5-149B	11/19/2025	
R2515831-023	102.5-150	11/19/2025	
R2515831-024	102.5-151	11/19/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.5

Client: Kenton UFSD

Contact: Georgia Militello

Building: Herbert Hoover Middle School

Location: 249 Thorncliff Rd, Buffalo, NY 14223

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
102.5-131	Room 308 R	Sink	7:26
102.5-132A	DF by 308	DF	7:27
102.5-132B	DFB by 308	DFB	7:28
102.5-133	Room 353 Sink	Sink	5:03
102.5-134	Room 350 Sink	Sink	5:05
102.5-135	Room 344 Sink	Sink	5:06
102.5-136	Room 342 Sink	Sink	5:08
102.5-137A	DF By Room 340	DF	5:10
102.5-137B	DFB By Room 340	DFB	5:12
102.5-138	Room 311 Sink	Sink	5:13
102.5-139	Room 312 FR First Sink	Sink	5:15
102.5-140	Room 312 Second Sink	Sink	5:17
102.5-141	Room 313 Sink	Sink	5:19
102.5-142	Room 315 Sink	Sink	5:20
102.5-143	Room 314 FR First Sink	Sink	5:22
102.5-144	Room 314 Second Sink	Sink	5:24
102.5-145	Room 316 FR First Sink	Sink	5:26
102.5-146	Room 316 Second Sink	Sink	5:27

Notes:

Please e-mail lab results to labs@stohlenv.com

Mscinta@stohlenvironmental.com

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 11/19/2025 + 11/20/2025

Relinquished By: _____ Print Name _____ Stohl Env: Connor Crilly Date: 11/20/2025


Received (Name / Lab): [Signature] ALS Date: 11/21/25 Time: 8:25

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____





Cooler Receipt and Preservation

R2515831 5
 Stohl Environmental
 Kenton UFSD - Herbert Hoover Middle School

Project/Client Stohl Folder Number _____

Cooler received on 11/21/25 by: RM

COURIER: ALS - UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="radio"/> N <input type="radio"/>	5a	Did VOA vials have sig* bubbles?	Y <input type="radio"/> N <input checked="" type="radio"/> NA <input type="radio"/>
2	Custody papers properly completed (ink, signed)?	Y <input checked="" type="radio"/> N <input type="radio"/>	5b	Sig* bubbles: Alk? Y <input type="radio"/> N <input checked="" type="radio"/> NA <input type="radio"/> Sulfide? Y <input type="radio"/> N <input checked="" type="radio"/> NA <input type="radio"/>	
3	Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="radio"/> N <input type="radio"/>	6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="radio"/> N <input type="radio"/>	7	Soil VOA received as:	Bulk Encore 5035set <input checked="" type="radio"/> NA <input type="radio"/>

8. Temperature Readings Date: 11/21/25 Time: 8:32 ID: R#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>10.2</u>						
Within 0-6°C?	Y <input checked="" type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>					
If <0°C, were samples frozen?	Y <input type="radio"/> N <input checked="" type="radio"/>	Y <input type="radio"/> N <input type="radio"/>					

If out of Temperature, note packing/ice condition: No ice Ice melted Poorly Packed (described below) Same Day Rule
 & Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMO by RM on 11/21 at 8:32
 5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 11/26 Time: 1545 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
2	<u>202325</u>	HNO ₃	<input checked="" type="checkbox"/>		<u>24017 f06</u>	<u>7127</u>				
2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____
 Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515831

Sample Name: 102.5-131
Lab Code: R2515831-001
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-132A
Lab Code: R2515831-002
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-132B
Lab Code: R2515831-003
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-133
Lab Code: R2515831-004
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-134
Lab Code: R2515831-005
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515831

Sample Name: 102.5-135
Lab Code: R2515831-006
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-136
Lab Code: R2515831-007
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-137A
Lab Code: R2515831-008
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-137B
Lab Code: R2515831-009
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-138
Lab Code: R2515831-010
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515831

Sample Name: 102.5-139
Lab Code: R2515831-011
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-140
Lab Code: R2515831-012
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-141
Lab Code: R2515831-013
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-142
Lab Code: R2515831-014
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-143
Lab Code: R2515831-015
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515831

Sample Name: 102.5-144
Lab Code: R2515831-016
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-145
Lab Code: R2515831-017
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-146
Lab Code: R2515831-018
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-147
Lab Code: R2515831-019
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.5-148
Lab Code: R2515831-020
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5

Service Request: R2515831

Sample Name: 102.5-149A
Lab Code: R2515831-021
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-149B
Lab Code: R2515831-022
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.5-150
Lab Code: R2515831-023
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By
NMANSEN

Analyzed By
DWINTER

Sample Name: 102.5-151
Lab Code: R2515831-024
Sample Matrix: Drinking Water

Date Collected: 11/19/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-131
Lab Code: R2515831-001

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.9	ug/L	1.0	1	12/18/25 21:25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-132A
Lab Code: R2515831-002

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 21:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-132B
Lab Code: R2515831-003

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 21:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-133
Lab Code: R2515831-004

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.7	ug/L	1.0	1	12/18/25 21:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-134
Lab Code: R2515831-005

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	12/18/25 21:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-135
Lab Code: R2515831-006

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 21:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-136
Lab Code: R2515831-007

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 21:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-137A
Lab Code: R2515831-008

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 21:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-137B
Lab Code: R2515831-009

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 21:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-138
Lab Code: R2515831-010

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 21:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-139
Lab Code: R2515831-011

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.3	ug/L	1.0	1	12/18/25 21:42	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-140
Lab Code: R2515831-012

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 21:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-141
Lab Code: R2515831-013

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 21:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-142
Lab Code: R2515831-014

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 21:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-143
Lab Code: R2515831-015

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	12/18/25 21:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-144
Lab Code: R2515831-016

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 21:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-145
Lab Code: R2515831-017

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	12/18/25 21:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-146
Lab Code: R2515831-018

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 21:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-147
Lab Code: R2515831-019

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0	ug/L	1.0	1	12/18/25 21:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-148
Lab Code: R2515831-020

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 13:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-149A
Lab Code: R2515831-021

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 13:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-149B
Lab Code: R2515831-022

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 13:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-150
Lab Code: R2515831-023

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	4.79	ug/L	0.50	1	12/19/25 14:31	12/18/25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: 102.5-151
Lab Code: R2515831-024

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 13:45	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515831-MB1

Service Request: R2515831
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	ND U	ug/L	0.50	1	12/19/25 14:25	12/18/25	
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 21:18	NA	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515831-MB2

Service Request: R2515831
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 12:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515831-MB3

Service Request: R2515831
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 13:37	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25
Date Analyzed: 12/18/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.5-147
Lab Code: R2515831-019
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515831-019MS		Result	Duplicate Matrix Spike R2515831-019DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.0	21.4	20.0	102	22.2	20.0	106	70-130	4	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25
Date Analyzed: 12/19/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.5-149A
Lab Code: R2515831-021
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515831-021MS		Duplicate Matrix Spike R2515831-021DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	17.6	20.0	88	17.6	20.0	88	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515831
Date Collected: 11/19/25
Date Received: 11/21/25
Date Analyzed: 12/19/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.5-149B
Lab Code: R2515831-022
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515831-022MS		Result	Duplicate Matrix Spike R2515831-022DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	18.1	20.0	90	17.8	20.0	89	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515831
Date Analyzed: 12/18/25 - 12/19/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2515831-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.7	20.0	104	85-115
Lead, Total	200.8	21.1	20.0	105	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515831
Date Analyzed: 12/19/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2515831-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	18.5	20.0	92	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Herbert Hoover Middle School/2023L-102.5
Sample Matrix: Drinking Water

Service Request: R2515831
Date Analyzed: 12/19/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2515831-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	18.4	20.0	92	85-115

1.5 Laboratory Certifications

**NEW YORK STATE DEPARTMENT OF HEALTH
 WADSWORTH CENTER**



Expires 12:01 AM April 01, 2026
 Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE
Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. CHRISTINE KUTZER
ALS ENVIRONMENTAL - ROCHESTER
1565 JEFFERSON ROAD BUILDING 300, SUITE 360
ROCHESTER, NY 14623

NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the
 National Environmental Laboratory Accreditation Conference Standards (2016) for the category
 ENVIRONMENTAL ANALYSES POTABLE WATER
 All approved analytes are listed below:*

Bacteriology	
Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Collert)
Dissolved Gases	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
Fuel Additives	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
Metals I	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Zinc, Total	EPA 200.7 Rev. 4.4

Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elapublicweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.



Page 1 of 5