

January 6, 2026

Ms. Georgia Militello
Ken-Ton UFSD
1500 Colvin Boulevard
Buffalo, New York 14223

Re: Lead Testing in School Drinking Water

Dear Ms. Militello:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Ken-Ton UFSD, including:

- **Kenmore West High School – 33 Highland Parkway, Buffalo, NY**

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: Lead Testing in School Drinking Water, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on November 24, 2025. As detailed in Section 1.2 (Executive Summary) of the accompanying report, based upon the sampling and analysis performed, 0 sources of potable water in Kenmore West High School have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion.

Thank you for the opportunity to be of service to Ken-Ton UFSD.

Sincerely,
Stohl Environmental, LLC.



Michael Scinta
EPA Lead Risk Assessor

Lead Testing in School Drinking Water

Prepared for:

Ken-Ton UFSD

Prepared by:



**3860 California Road
Orchard Park, New York 14127**

Conditions as of November 24, 2025

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports and Chain of Custody Documents
- 1.5. Laboratory Certifications

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Ken-Ton UFSD to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- **Kenmore West High School – 33 Highland Parkway, Buffalo, NY**

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within Kenmore West High School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, **Subpart 67-4: Lead Testing in School Drinking Water**, and the EPA guidance document, **3Ts for Reducing Lead in Drinking Water in Schools**, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at Kenmore West High School:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Kenmore West High School	November 24, 2025	106	106	0

**NYS Action Level is 5 parts per billion*

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

All the locations sampled were analyzed at less than the NYS Action Level of 5 ppb, therefore no further response action is required.

1.4 Laboratory Analytical Reports and Chain of Custody Documents



December 23, 2025

Service Request No:R2516294

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Ken-Ton UFSD - Kenmore West High School

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory December 04, 2025
For your reference, these analyses have been assigned our service request number **R2516294**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | **FAX** +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School
Sample Matrix: Drinking Water

Service Request: R2516294
Date Received: 12/04/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 12/04/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 12/23/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 102.8-01		Lab ID: R2516294-001				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.3			1.0	ug/L	200.8

CLIENT ID: 102.8-05		Lab ID: R2516294-005				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.2			1.0	ug/L	200.8

CLIENT ID: 102.8-06		Lab ID: R2516294-006				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.8			1.0	ug/L	200.8

CLIENT ID: 102.8-09		Lab ID: R2516294-009				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.2			1.0	ug/L	200.8

CLIENT ID: 102.8-11		Lab ID: R2516294-011				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.1			1.0	ug/L	200.8

CLIENT ID: 102.8-25		Lab ID: R2516294-030				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8

CLIENT ID: 102.8-28		Lab ID: R2516294-033				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.5			1.0	ug/L	200.8

CLIENT ID: 102.8-29		Lab ID: R2516294-034				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.8			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request:R2516294

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2516294-001	102.8-01	11/24/2025	
R2516294-002	102.8-02	11/24/2025	
R2516294-003	102.8-03	11/24/2025	
R2516294-004	102.8-04	11/24/2025	
R2516294-005	102.8-05	11/24/2025	
R2516294-006	102.8-06	11/24/2025	
R2516294-007	102.8-07	11/24/2025	
R2516294-008	102.8-08	11/24/2025	
R2516294-009	102.8-09	11/24/2025	
R2516294-010	102.8-10	11/24/2025	
R2516294-011	102.8-11	11/24/2025	
R2516294-012	102.8-12A	11/24/2025	
R2516294-013	102.8-12B	11/24/2025	
R2516294-014	102.8-13	11/24/2025	
R2516294-015	102.8-14A	11/24/2025	
R2516294-016	102.8-14B	11/24/2025	
R2516294-017	102.8-15A	11/24/2025	
R2516294-018	102.8-15B	11/24/2025	
R2516294-019	102.8-16	11/24/2025	
R2516294-020	102.8-17	11/24/2025	
R2516294-021	102.8-18	11/24/2025	
R2516294-022	102.8-19A	11/24/2025	
R2516294-023	102.8-19B	11/24/2025	
R2516294-024	102.8-20	11/24/2025	
R2516294-025	102.8-21	11/24/2025	
R2516294-026	102.8-22	11/24/2025	
R2516294-027	102.8-23A	11/24/2025	
R2516294-028	102.8-23B	11/24/2025	
R2516294-029	102.8-24	11/24/2025	
R2516294-030	102.8-25	11/24/2025	
R2516294-031	102.8-26	11/24/2025	
R2516294-032	102.8-27	11/24/2025	
R2516294-033	102.8-28	11/24/2025	
R2516294-034	102.8-29	11/24/2025	
R2516294-035	102.8-30	11/24/2025	
R2516294-036	102.8-31A	11/24/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.8

Client: Ken-Ton UFSD

Contact: Georgia Militello

Building: Kenmore West High School

Location: 33 Highland Pkwy, Buffalo, NY 14223

LEAD

Water by 200.8 X

Turnaround
10 Days

Sample #	Location	Outlet Type	Time
102.8-01	Dish Line L Sink	Sink	5:05
102.8-02	Dish Line R Sink	Sink	5:06
102.8-03	Kitchen Staff RR Sink	Sink	5:08
102.8-04	First Pillar Sink	Sink	5:09
102.8-05	Dish Cleaner Sink	Sink	5:11
102.8-06	Second Pillar Sink	Sink	5:12
102.8-07	Sink by Mixer	Sink	5:14
102.8-08	Sink by Oven	Sink	5:15
102.8-09	Third Pillar Sink	Sink	5:17
102.8-10	Ice Machine	Ice Machine	5:18
102.8-11	Sink Infront of Exit to Cafe	Sink	5:20
102.08-12A	Cafe DF East Door	DF	5:21
102.08-12B	Cafe DFB east door	DFB	5:23
102.8-13	Cafe DF No DFB East Door	DF	5:24
102.8-14A	Cafe DF West Door	DF	5:26
102.8-14B	Cafe DFB West Door	DFB	5:27
102.8-15A	DF Outside Attendance	DF	5:29
102.8-15B	DFB Outside Attendance	DFB	5:30

Notes:
 Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to: mscinta@stohlenvironmental.com

Sampled By: A. Delinger Print Name A. Delinger Stohl Env: A. Delinger Date: 11/24/2025
 Relinquished By: [Signature] Print Name Connor Crilly Stohl Env: Connor Crilly Date: 12/4/25 5pm
 Received (Name / Lab): [Signature] Date: 12/4/25 Time: 1700
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

R2516294 5
 Stohl Environmental
 Ken-Ton UFSD - Kenmore West High School



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.8

Client: Ken-Ton UFSD

Contact: Georgia Militello

Building: Kenmore West High School

Location: 33 Highland Pkwy, Buffalo, NY 14223

LEAD

Water by 200.8 X

Turnaround
10 Days

Sample #	Location	Outlet Type	Time
102.8-16	Counseling Center Kitchette Sink	Sink	5:32
102.8-17	Girls First Floor Restroom By Main Entrance L Sink	Sink	5:33
102.8-18	Girls First Floor Restroom By Main Entrance R Sink	Sink	5:35
102.8-19A	DF Outside of Auditorium	DF	5:36
102.8-19B	DFB Outside of Auditorium	DFB	5:38
102.8-20	Nurses Office Exam Room Sink L	Sink	5:39
102.8-21	Nurses Office Exam Room Sink R	Sink	5:41
102.8-22	Nurses Restroom Sink	Sink	5:42
102.8-23A	Girls Locker Room DF	DF	5:44
102.8-23B	Girls Locker Room DFB	DFB	5:45
102.8-24	Girls Locker Room Sink Outside Shower L	Sink	5:47
102.8-25	Girls Locker Room Sink Outside Shower R	Sink	5:48
102.8-26	Girls Locker Room DF L	DF	5:50
102.8-27	Girls Locker Room DF R	DF	5:51
102.8-28	Girls Locker Room Restroom Sink L	Sink	5:53
102.8-29	Girls Locker Room Restroom Sink R	Sink	5:54
102.8-30	Girls Locker Room Office Sink	Sink	5:56
102.8-31A	DF Outside Girls Locker Room	DF	5:57

Notes:

Please e-mail lab results to labs@stohlenv.com

mscinta@stohlenvironmental.com

Sampled By: A. Delinger Print Name Stohl Env: A. Delinger Date: 11/24/2025
 Relinquished By: [Signature] Print Name Stohl Env: Connor Crilly Date: 12/4/25 5pm
 Received (Name / Lab): [Signature] Date: 12/4/25 Time: 1700
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Cooler Receipt and Preservation Check Form

Project/Client Stohl Environmental Folder Number _____

Cooler received on 12/4/25 by: RDA COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
2	Custody papers properly completed (ink, signed)?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>
3	Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>

5a	Did VOA vials have sig* bubbles?	Y N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
5b	Sig* bubbles: Alk?	Y N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
	Sulfide?	Y N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as:	Bulk Encore 5035set <u>NA</u>

8. Temperature Readings Date: 12/4/25 Time: 1712 ID: IR#12 IR#12 From: Temp Blank Sample Bottle

Temp (°C)	<u>14.8</u>						
Within 0-6°C?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule & Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMU by RDA on 12/4/25 at 1713
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 12/8/25 Time: 0945 by: CC

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO
- 13. Were dissolved metals filtered in the field? YES NO
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
<u>2</u>	<u>202325</u>	HNO ₃		<input checked="" type="checkbox"/>			<u>All</u>	<u>4ml</u>	<u>245078</u>	<u>All < 2</u>
<u>2</u>		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No-Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 062325-2ADD

Explain all Discrepancies/ Other Comments:

9/10) No bottle Labels

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: CC *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- | | |
|---|--|
| <p>U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.</p> <p>J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).</p> <p>B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.</p> <p>E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.</p> <p>E Organics- Concentration has exceeded the calibration range for that specific analysis.</p> <p>D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.</p> <p>* Indicates that a quality control parameter has exceeded laboratory limits. Under the “Notes” column of the Form I, this qualifier denotes analysis was performed out of Holding Time.</p> <p>H Analysis was performed out of hold time for tests that have an “immediate” hold time criteria.</p> <p># Spike was diluted out.</p> | <p>+ Correlation coefficient for MSA is <0.995.</p> <p>N Inorganics- Matrix spike recovery was outside laboratory limits.</p> <p>N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.</p> <p>S Concentration has been determined using Method of Standard Additions (MSA).</p> <p>W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.</p> <p>P Concentration >40% difference between the two GC columns.</p> <p>C Confirmed by GC/MS</p> <p>Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).</p> <p>X See Case Narrative for discussion.</p> <p>MRL Method Reporting Limit. Also known as:</p> <p>LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.</p> <p>MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).</p> <p>LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.</p> <p>ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.</p> |
|---|--|

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory’s NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request: R2516294

Sample Name: 102.8-01
Lab Code: R2516294-001
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-02
Lab Code: R2516294-002
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-03
Lab Code: R2516294-003
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-04
Lab Code: R2516294-004
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-05
Lab Code: R2516294-005
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request: R2516294

Sample Name: 102.8-06
Lab Code: R2516294-006
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-07
Lab Code: R2516294-007
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-08
Lab Code: R2516294-008
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-09
Lab Code: R2516294-009
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-10
Lab Code: R2516294-010
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request: R2516294

Sample Name: 102.8-11
Lab Code: R2516294-011
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-12A
Lab Code: R2516294-012
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-12B
Lab Code: R2516294-013
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-13
Lab Code: R2516294-014
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-14A
Lab Code: R2516294-015
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request: R2516294

Sample Name: 102.8-14B
Lab Code: R2516294-016
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-15A
Lab Code: R2516294-017
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-15B
Lab Code: R2516294-018
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-16
Lab Code: R2516294-019
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-17
Lab Code: R2516294-020
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request: R2516294

Sample Name: 102.8-18
Lab Code: R2516294-021
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-19A
Lab Code: R2516294-022
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-19B
Lab Code: R2516294-023
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-20
Lab Code: R2516294-024
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-21
Lab Code: R2516294-025
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request: R2516294

Sample Name: 102.8-22
Lab Code: R2516294-026
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-23A
Lab Code: R2516294-027
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-23B
Lab Code: R2516294-028
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-24
Lab Code: R2516294-029
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-25
Lab Code: R2516294-030
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request: R2516294

Sample Name: 102.8-26
Lab Code: R2516294-031
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-27
Lab Code: R2516294-032
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-28
Lab Code: R2516294-033
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-29
Lab Code: R2516294-034
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-30
Lab Code: R2516294-035
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental

Service Request: R2516294

Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Sample Name: 102.8-31A

Date Collected: 11/24/25

Lab Code: R2516294-036

Date Received: 12/4/25

Sample Matrix: Drinking Water

Analysis Method

Extracted/Digested By

Analyzed By

200.8

DWINTER



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-01
Lab Code: R2516294-001

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.3	ug/L	1.0	1	12/19/25 20:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-02
Lab Code: R2516294-002

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 20:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-03
Lab Code: R2516294-003

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 20:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-04
Lab Code: R2516294-004

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 20:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-05
Lab Code: R2516294-005

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.2	ug/L	1.0	1	12/19/25 20:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-06
Lab Code: R2516294-006

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.8	ug/L	1.0	1	12/19/25 20:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-07
Lab Code: R2516294-007

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 20:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-08
Lab Code: R2516294-008

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 20:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-09
Lab Code: R2516294-009

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	12/19/25 20:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-10
Lab Code: R2516294-010

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 20:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-11
Lab Code: R2516294-011

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.1	ug/L	1.0	1	12/19/25 20:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-12A
Lab Code: R2516294-012

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 20:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-12B
Lab Code: R2516294-013

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 20:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-13
Lab Code: R2516294-014

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 20:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-14A
Lab Code: R2516294-015

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 20:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-14B
Lab Code: R2516294-016

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 20:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-15A
Lab Code: R2516294-017

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 20:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-15B
Lab Code: R2516294-018

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 20:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-16
Lab Code: R2516294-019

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 20:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-17
Lab Code: R2516294-020

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 20:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-18
Lab Code: R2516294-021

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:00	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-19A
Lab Code: R2516294-022

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-19B
Lab Code: R2516294-023

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:03	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-20
Lab Code: R2516294-024

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-21
Lab Code: R2516294-025

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-22
Lab Code: R2516294-026

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:07	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-23A
Lab Code: R2516294-027

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-23B
Lab Code: R2516294-028

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-24
Lab Code: R2516294-029

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-25
Lab Code: R2516294-030

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	12/19/25 21:24	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-26
Lab Code: R2516294-031

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-27
Lab Code: R2516294-032

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-28
Lab Code: R2516294-033

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.5	ug/L	1.0	1	12/19/25 21:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-29
Lab Code: R2516294-034

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.8	ug/L	1.0	1	12/19/25 21:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-30
Lab Code: R2516294-035

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-31A
Lab Code: R2516294-036

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:38	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516294-MB1

Service Request: R2516294
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 19:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516294-MB2

Service Request: R2516294
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 20:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516294-MB3

Service Request: R2516294
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:21	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25
Date Analyzed: 12/19/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.8-09
Lab Code: R2516294-009
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516294-009MS		Duplicate Matrix Spike R2516294-009DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	2.2	24.2	20.0	110	24.3	20.0	111	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25
Date Analyzed: 12/19/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.8-10
Lab Code: R2516294-010
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516294-010MS		Duplicate Matrix Spike R2516294-010DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	22.9	20.0	115	22.7	20.0	114	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25
Date Analyzed: 12/19/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.8-24
Lab Code: R2516294-029
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516294-029MS		Duplicate Matrix Spike R2516294-029DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	23.4	20.0	117	22.7	20.0	113	70-130	3	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water

Service Request: R2516294
Date Collected: 11/24/25
Date Received: 12/04/25
Date Analyzed: 12/19/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.8-25
Lab Code: R2516294-030
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516294-030MS		Result	Duplicate Matrix Spike R2516294-030DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.2	23.1	20.0	110	23.4	20.0	111	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water

Service Request: R2516294
Date Analyzed: 12/19/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516294-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.1	20.0	110	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water

Service Request: R2516294
Date Analyzed: 12/19/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516294-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.4	20.0	112	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water

Service Request: R2516294

Date Analyzed: 12/19/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample
R2516294-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.7	20.0	114	85-115



December 23, 2025

Service Request No:R2516297

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Ken-Ton UFSD - Kenmore West High School

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory December 04, 2025
For your reference, these analyses have been assigned our service request number **R2516297**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | **FAX** +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School
Sample Matrix: Drinking Water

Service Request: R2516297
Date Received: 12/04/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 12/04/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 12/23/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 102.8-40		Lab ID: R2516297-011				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.0			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request:R2516297

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2516297-001	102.8-31B	11/24/2025	
R2516297-002	102.8-32A	11/24/2025	
R2516297-003	102.8-32B	11/24/2025	
R2516297-004	102.8-33	11/24/2025	
R2516297-005	102.8-34	11/24/2025	
R2516297-006	102.8-35	11/24/2025	
R2516297-007	102.8-36	11/24/2025	
R2516297-008	102.8-37	11/24/2025	
R2516297-009	102.8-38	11/24/2025	
R2516297-010	102.8-39	11/24/2025	
R2516297-011	102.8-40	11/24/2025	
R2516297-012	102.8-41	11/24/2025	
R2516297-013	102.8-42	11/24/2025	
R2516297-014	102.8-43	11/24/2025	
R2516297-015	102.8-44	11/24/2025	
R2516297-016	102.8-45A	11/24/2025	
R2516297-017	102.8-45B	11/24/2025	
R2516297-018	102.8-46A	11/24/2025	
R2516297-019	102.8-46B	11/24/2025	
R2516297-020	102.8-47	11/24/2025	
R2516297-021	102.8-48	11/24/2025	
R2516297-022	102.8-49	11/24/2025	
R2516297-023	102.8-50	11/24/2025	
R2516297-024	102.8-51A	11/24/2025	
R2516297-025	102.8-51B	11/24/2025	
R2516297-026	102.8-52A	11/24/2025	
R2516297-027	102.8-52B	11/24/2025	
R2516297-028	102.8-53A	11/24/2025	
R2516297-029	102.8-53B	11/24/2025	
R2516297-030	102.8-54	11/24/2025	
R2516297-031	102.8-55	11/24/2025	
R2516297-032	102.8-56	11/24/2025	
R2516297-033	102.8-57	11/24/2025	
R2516297-034	102.8-58A	11/24/2025	
R2516297-035	102.8-58B	11/24/2025	
R2516297-036	102.8-59	11/24/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.8

Client: Ken-Ton UFSD

Contact: Georgia Militello

Building: Kenmore West High School

Location: 33 Highland Pkwy, Buffalo, NY 14223

LEAD		<i>Turnaround</i>
Water by 200.8	<u>X</u>	<u>10 Days</u>

Sample #	Location	Outlet Type	Time
102.8-31B	DFB Outside Girls Locker Room	DFB	5:59
102.8-32A	Gym DF R	DF	6:00
102.8-32B	Gym DFB R	DFB	6:02
102.8-33	Gym DF L	DF	6:03
102.8-34	Boys First Floor Restroom By Gym L Sink	Sink	6:05
102.8-35	Boys First Floor Restroom By Gym R Sink	Sink	6:06
102.8-36	Staff Restroom Sink	Sink	6:08
102.8-37	Boys Locker Room First Restroom Sink	Sink	6:09
102.8-38	Boys Locker Room Second Restroom Sink L	Sink	6:11
102.8-39	Boys Locker Room Second Restroom Sink R	Sink	6:12
102.8-40	Boys Locker Room Coaches Restroom Sink	Sink	6:14
102.8-41	Boys Restroom New Gym Area L Sink	Sink	6:15
102.8-42	Boys Restroom New Gym Area R Sink	Sink	6:17
102.8-43	Girls Restroom New Gym Area L Sink	Sink	6:18
102.8-44	Girls Restroom New Gym Area R Sink	Sink	6:20
102.8-45A	New Gym DF	DF	6:21
102.8-45B	New Gym DFB	DFB	6:23
102.8-46A	DF by Stairwell 9	DF	6:24

Notes: Please e-mail lab results to labs@stohlenv.com mscinta@stohlenvironmental.com

Sampled By: A. Delinger Print Name Stohl Env: A. Delinger Date: 11/24/2025
 Relinquished By: [Signature] Print Name Stohl Env: Connor Crilly Date: 12/4/25 5pm
 Received (Name / Lab): [Signature] Date: 12/4/25 Time: 1700
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

R2516297 **5**
 Stohl Environmental
 Ken-Ton UFSD - Kenmore West High School



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.8

Client: Ken-Ton UFSD

Contact: Georgia Militello

Building: Kenmore West High School

Location: 33 Highland Pkwy, Buffalo, NY 14223

LEAD
 Water by 200.8 X

Turnaround
10 Days

Sample #	Location	Outlet Type	Time
102.8-46B	DFB by Stairwell 9	DFB	6:26
102.8-47	Boys Second Floor Restroom Sink	Sink	6:27
102.8-48	Girls Second Floor Restroom Sink L	Sink	6:29
102.8-49	Girls Second Floor Restroom Sink R	Sink	6:30
102.8-50	Second Floor Staff Restroom Sink	Sink	6:32
102.8-51A	DF by Fitness Center	DF	6:33
102.8-51B	DFB by Fitness Center	DFB	6:35
102.8-52A	DF Second Floor by Stairwell 9	DF	6:36
102.8-52B	DFB Seond Floor by Stairwell 10	DFB	6:38
102.8-53A	DF Second Floor Near Elavator	DF	6:39
102.8-53B	DFB Second Floor Near Elavator	DFB	6:41
102.8-54	Room 244 Front Sink	Sink	6:42
102.8-55	Room 244 Side Sink	Sink	6:44
102.8-56	Room 246 Front Sink	Sink	6:45
102.8-57	Room 246 Back Sink	Sink	6:47
102.8-58A	DF Outside Room 248	DF	6:48
102.8-58B	DFB Outside Room 248	DFB	6:50
102.8-59	Room 250 Sink	Sink	5:02

Notes: Please e-mail lab results to labs@stohlenv.com mscinta@stohlenvironmental.com

Sampled By: A. Delinger Print Name A. Delinger Stohl Env: A. Delinger Date: 11/24/2025
 Relinquished By: [Signature] Print Name Connor Crilly Stohl Env: Connor Crilly Date: 12/4/25 5pm
 Received (Name / Lab): [Signature] Date: 12/4/25 Time: 1700
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Cooler Receipt and Preservation Check Form

R2516297

5

Stohl Environmental
Ken-Ton UFSD - Kenmore West High School



Project/Client Stohl Environmental Folder Number _____

Cooler received on 12/4/25 by: RDA

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
2	Custody papers properly completed (ink, signed)?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>
3	Did all bottles arrive in good condition (unbroken)?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>

5a	Did VOA vials have sig* bubbles?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
5b	Sig* bubbles: Alk?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
	Sulfide?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as:	Bulk Encore 5035set <u>NA</u>

8. Temperature Readings Date: 12/4/25 Time: 1712 ID: IR#12 IR#1 From: Temp Blank Sample Bottle

Temp (°C)	<u>19.8</u>						
Within 0-6°C?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>					
If <0°C, were samples frozen?	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: Shw by RDA on 12/4/25 at 1713
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 12/8/25 Time: 1008 by: CL

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A

14. Air Samples: Cassettes / Tubes Intact Y/N with MS Y/N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
<2	<u>202325</u>	HNO ₃	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<u>24017806</u>	<u>1/27</u>	<u>*</u>	<u>4ml</u>	<u>245078</u>	<u>All <2</u>
<2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 062325-2ADD, 072125-2EKT

Explain all Discrepancies/ Other Comments:

9/10 No bottle Labels

* R2516297-001 through R2516297-024

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: CL

*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request: R2516297

Sample Name: 102.8-31B
Lab Code: R2516297-001
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-32A
Lab Code: R2516297-002
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-32B
Lab Code: R2516297-003
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-33
Lab Code: R2516297-004
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-34
Lab Code: R2516297-005
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request: R2516297

Sample Name: 102.8-35
Lab Code: R2516297-006
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-36
Lab Code: R2516297-007
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-37
Lab Code: R2516297-008
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-38
Lab Code: R2516297-009
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-39
Lab Code: R2516297-010
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request: R2516297

Sample Name: 102.8-40
Lab Code: R2516297-011
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-41
Lab Code: R2516297-012
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-42
Lab Code: R2516297-013
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-43
Lab Code: R2516297-014
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-44
Lab Code: R2516297-015
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request: R2516297

Sample Name: 102.8-45A
Lab Code: R2516297-016
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-45B
Lab Code: R2516297-017
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-46A
Lab Code: R2516297-018
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-46B
Lab Code: R2516297-019
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-47
Lab Code: R2516297-020
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request: R2516297

Sample Name: 102.8-48
Lab Code: R2516297-021
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-49
Lab Code: R2516297-022
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-50
Lab Code: R2516297-023
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-51A
Lab Code: R2516297-024
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-51B
Lab Code: R2516297-025
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request: R2516297

Sample Name: 102.8-52A
Lab Code: R2516297-026
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-52B
Lab Code: R2516297-027
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-53A
Lab Code: R2516297-028
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-53B
Lab Code: R2516297-029
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-54
Lab Code: R2516297-030
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request: R2516297

Sample Name: 102.8-55
Lab Code: R2516297-031
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-56
Lab Code: R2516297-032
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-57
Lab Code: R2516297-033
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-58A
Lab Code: R2516297-034
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-58B
Lab Code: R2516297-035
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental

Service Request: R2516297

Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Sample Name: 102.8-59

Date Collected: 11/24/25

Lab Code: R2516297-036

Date Received: 12/4/25

Sample Matrix: Drinking Water

Analysis Method

Extracted/Digested By

Analyzed By

200.8

DWINTER



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-31B
Lab Code: R2516297-001

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-32A
Lab Code: R2516297-002

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-32B
Lab Code: R2516297-003

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:42	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-33
Lab Code: R2516297-004

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-34
Lab Code: R2516297-005

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-35
Lab Code: R2516297-006

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-36
Lab Code: R2516297-007

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-37
Lab Code: R2516297-008

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-38
Lab Code: R2516297-009

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-39
Lab Code: R2516297-010

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-40
Lab Code: R2516297-011

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.0	ug/L	1.0	1	12/19/25 21:56	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-41
Lab Code: R2516297-012

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-42
Lab Code: R2516297-013

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-43
Lab Code: R2516297-014

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-44
Lab Code: R2516297-015

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-45A
Lab Code: R2516297-016

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:14	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-45B
Lab Code: R2516297-017

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-46A
Lab Code: R2516297-018

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-46B
Lab Code: R2516297-019

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-47
Lab Code: R2516297-020

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-48
Lab Code: R2516297-021

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:21	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-49
Lab Code: R2516297-022

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-50
Lab Code: R2516297-023

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-51A
Lab Code: R2516297-024

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-51B
Lab Code: R2516297-025

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-52A
Lab Code: R2516297-026

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-52B
Lab Code: R2516297-027

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-53A
Lab Code: R2516297-028

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-53B
Lab Code: R2516297-029

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-54
Lab Code: R2516297-030

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-55
Lab Code: R2516297-031

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-56
Lab Code: R2516297-032

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-57
Lab Code: R2516297-033

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-58A
Lab Code: R2516297-034

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-58B
Lab Code: R2516297-035

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-59
Lab Code: R2516297-036

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:58	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516297-MB1

Service Request: R2516297
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 21:21	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516297-MB2

Service Request: R2516297
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:03	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516297-MB3

Service Request: R2516297
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:50	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25
Date Analyzed: 12/19/25

Matrix Spike Summary
Inorganic Parameters

Sample Name: 102.8-43
Lab Code: R2516297-014
Analysis Method: 200.8

Units: ug/L
Basis: NA

Matrix Spike
R2516297-014MS

<u>Analyte Name</u>	<u>Sample Result</u>	<u>Result</u>	<u>Spike Amount</u>	<u>% Rec</u>	<u>% Rec Limits</u>
Lead, Total	ND U	22.2	20.0	111	70-130

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25
Date Analyzed: 12/19/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.8-42
Lab Code: R2516297-013
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516297-013MS		Duplicate Matrix Spike R2516297-013DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	22.3	20.0	112	22.0	20.0	110	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25
Date Analyzed: 12/19/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.8-57
Lab Code: R2516297-033
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516297-033MS		Duplicate Matrix Spike R2516297-033DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	22.6	20.0	113	20.2	20.0	101	70-130	11	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water

Service Request: R2516297
Date Collected: 11/24/25
Date Received: 12/04/25
Date Analyzed: 12/19/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.8-58A
Lab Code: R2516297-034
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516297-034MS		Duplicate Matrix Spike R2516297-034DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	22.2	20.0	111	22.3	20.0	111	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water

Service Request: R2516297
Date Analyzed: 12/19/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516297-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.7	20.0	114	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water

Service Request: R2516297
Date Analyzed: 12/19/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516297-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.8	20.0	114	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water

Service Request: R2516297
Date Analyzed: 12/19/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516297-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.7	20.0	113	85-115



December 23, 2025

Service Request No:R2516299

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Ken-Ton UFSD - Kenmore West High School

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory December 04, 2025
For your reference, these analyses have been assigned our service request number **R2516299**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School
Sample Matrix: Drinking Water

Service Request: R2516299
Date Received: 12/04/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty four drinking water samples were received for analysis at ALS Environmental on 12/04/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 12/23/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 102.8-74	Lab ID: R2516299-022					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8

CLIENT ID: 102.8-75	Lab ID: R2516299-023					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.5			1.0	ug/L	200.8

CLIENT ID: 102.8-82	Lab ID: R2516299-030					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.3			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request:R2516299

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2516299-001	102.8-60A	11/24/2025	
R2516299-002	102.8-60B	11/24/2025	
R2516299-003	102.8-61	11/24/2025	
R2516299-004	102.8-62	11/24/2025	
R2516299-005	102.8-63A	11/24/2025	
R2516299-006	102.8-63B	11/24/2025	
R2516299-007	102.8-64	11/24/2025	
R2516299-008	102.8-65A	11/24/2025	
R2516299-009	102.8-65B	11/24/2025	
R2516299-010	102.8-66	11/24/2025	
R2516299-011	102.8-67	11/24/2025	
R2516299-012	102.8-68	11/24/2025	
R2516299-013	102.8-69	11/24/2025	
R2516299-014	102.8-70A	11/24/2025	
R2516299-015	102.8-70B	11/24/2025	
R2516299-016	102.8-71A	11/24/2025	
R2516299-017	102.8-71B	11/24/2025	
R2516299-018	102.8-72A	11/24/2025	
R2516299-019	102.8-72B	11/24/2025	
R2516299-020	102.8-73A	11/24/2025	
R2516299-021	102.8-73B	11/24/2025	
R2516299-022	102.8-74	11/24/2025	
R2516299-023	102.8-75	11/24/2025	
R2516299-024	102.8-76	11/24/2025	
R2516299-025	102.8-77	11/24/2025	
R2516299-026	102.8-78	11/24/2025	
R2516299-027	102.8-79	11/24/2025	
R2516299-028	102.8-80	11/24/2025	
R2516299-029	102.8-81	11/24/2025	
R2516299-030	102.8-82	11/24/2025	
R2516299-031	102.8-83A	11/24/2025	
R2516299-032	102.8-83B	11/24/2025	
R2516299-033	102.8-84A	11/24/2025	
R2516299-034	102.8-84B	11/24/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.8

Client: Ken-Ton UFSD

Contact: Georgia Militello

Building: Kenmore West High School

Location: 33 Highland Pkwy, Buffalo, NY 14223


LEAD
 Water by 200.8 X

Turnaround
10 Days

Sample #	Location	Outlet Type	Time
102.8-60A	Third Floor DF Near Elevator	DF	5:03
102.8-60B	Third Floor DFB Near Elevator	DFB	5:04
102.8-61	Music Room Restroom Sink L	Sink	5:06
102.8-62	Music Room Restroom Sink L	Sink	5:07
102.8-63A	Band Rom DF	DF	5:08
102.8-63B	Band Room DFB	DFB	5:10
102.8-64	Third Floor Staff Restroom Sink	Sink	5:11
102.8-65A	Third Floor by Room 349 DF	DF	5:12
102.8-65B	Third Floor by Room 349 DFB	DFB	5:14
102.8-66	Boys Restroom Third Floor Sink L	Sink	5:15
102.8-67	Boys Restroom Third Floor Sink R	Sink	5:16
102.8-68	Girls Restroom Third Floor Sink L	Sink	5:18
102.8-69	Girls Restroom Third Floor Sink R	Sink	5:19
102.8-70A	DF Near Room 315	DF	5:20
102.8-70B	DFB Near Room 315	DFB	5:22
102.8-71A	DF Near Room 303	DF	5:23
102.71B	DFB Near Room 303	DFB	5:24
102.72A	DF Near Elevator Fourth Floor	DF	5:26

Notes: Please e-mail lab results to labs@stohlenv.com mscinta@stohlenvironmental.com

Sampled By: A. Delinger Print Name Stohl Env: A. Delinger Date: 11/24/2025
 Relinquished By: [Signature] Print Name Stohl Env: Connor Crilly Date: 12/14/25 5pm
 Received (Name / Lab): [Signature] Date: 12/14/25 Time: 1700
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____





Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.8

Client: Ken-Ton UFSD

Contact: Georgia Militello

Building: Kenmore West High School

Location: 33 Highland Pkwy, Buffalo, NY 14223

LEAD
 Water by 200.8 X

Tumaround
10 Days

Sample #	Location	Outlet Type	Time
102.72B	DFB Near Elevator Fourth Floor	DFB	5:27
102.73A	DF Near Room 450	DF	5:28
102.73B	DFB Near Room 450	DFB	5:30
102.74	Boys Restroom Sink L	Sink	5:31
102.75	Boys Restroom Sink R	Sink	5:32
102.76	Room 424 Sink FL	Sink	5:34
102.77	Room 424 Sink SL	Sink	5:35
102.78	Room 424 Sink TL	Sink	5:36
102.79	Room 424 Sink BL	Sink	5:38
102.8	Room 424 Sink BR	Sink	5:39
102.81	Room 424 Sink R	Sink	5:40
102.82	Girls Restroom Sink	Sink	5:42
102.83A	DF Near Room 417	DF	5:43
102.83B	DFB Near room 417	DFB	5:44
102.84A	DF Near Room	DF	5:46
102.84B	DFB Near room	DFB	5:47

Notes:
 Please e-mail lab results to labs@stohlenv.com mscinta@stohlenvironmental.com

Sampled By: A. Delinger Print Name Stohl Env: A. Delinger Date: 11/24/2025
 Relinquished By: [Signature] Print Name Stohl Env: Connor Crilly Date: 12/1/25 5pm
 Received (Name / Lab): [Signature] Date: 12/1/25 Time: 1700
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Cooler Receipt and Preservation Check Form

R2516299

5

Stohl Environmental
Ken-Ton UFSD - Kenmore West High School



Project/Client Stohl Environmental Folder Number _____

Cooler received on 12/4/25 by: RDA

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
2	Custody papers properly completed (ink, signed)?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>
3	Did all bottles arrive in good condition (unbroken)?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>

5a	Did VOA vials have sig* bubbles?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
5b	Sig* bubbles: Alk?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
	Sulfide?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as:	Bulk Encore 5035set <u>NA</u>

8. Temperature Readings Date: 12/4/25 Time: 1712 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>14.8</u>							
Within 0-6°C?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>						
If <0°C, were samples frozen?	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMW by RDA on 12/4/25 at 1713
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 12/8/25 Time: 1043 by: CC

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels; not leaking)? YES NO
- 13. Were dissolved metals filtered in the field? YES NO

14. Air Samples: Cassettes / Tubes Intact Y/N with MS Y/N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
<u>2</u>	<u>202325</u>	HNO ₃	<input checked="" type="checkbox"/>		<u>24057806</u>	<u>1/27</u>				
<u>2</u>		H ₂ SO ₄								
<u>4</u>		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 080425-2EKJ

Explain all Discrepancies/ Other Comments:

9/10) No bottle label

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: CC *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request: R2516299

Sample Name: 102.8-60A
Lab Code: R2516299-001
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-60B
Lab Code: R2516299-002
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-61
Lab Code: R2516299-003
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-62
Lab Code: R2516299-004
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-63A
Lab Code: R2516299-005
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request: R2516299

Sample Name: 102.8-63B
Lab Code: R2516299-006
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-64
Lab Code: R2516299-007
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-65A
Lab Code: R2516299-008
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-65B
Lab Code: R2516299-009
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-66
Lab Code: R2516299-010
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request: R2516299

Sample Name: 102.8-67
Lab Code: R2516299-011
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-68
Lab Code: R2516299-012
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-69
Lab Code: R2516299-013
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-70A
Lab Code: R2516299-014
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-70B
Lab Code: R2516299-015
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request: R2516299

Sample Name: 102.8-71A
Lab Code: R2516299-016
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-71B
Lab Code: R2516299-017
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-72A
Lab Code: R2516299-018
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-72B
Lab Code: R2516299-019
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-73A
Lab Code: R2516299-020
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request: R2516299

Sample Name: 102.8-73B
Lab Code: R2516299-021
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-74
Lab Code: R2516299-022
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-75
Lab Code: R2516299-023
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-76
Lab Code: R2516299-024
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-77
Lab Code: R2516299-025
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request: R2516299

Sample Name: 102.8-78
Lab Code: R2516299-026
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-79
Lab Code: R2516299-027
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-80
Lab Code: R2516299-028
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-81
Lab Code: R2516299-029
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-82
Lab Code: R2516299-030
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8

Service Request: R2516299

Sample Name: 102.8-83A
Lab Code: R2516299-031
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-83B
Lab Code: R2516299-032
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-84A
Lab Code: R2516299-033
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.8-84B
Lab Code: R2516299-034
Sample Matrix: Drinking Water

Date Collected: 11/24/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-60A
Lab Code: R2516299-001

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:00	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-60B
Lab Code: R2516299-002

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-61
Lab Code: R2516299-003

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-62
Lab Code: R2516299-004

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:07	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-63A
Lab Code: R2516299-005

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-63B
Lab Code: R2516299-006

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-64
Lab Code: R2516299-007

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-65A
Lab Code: R2516299-008

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-65B
Lab Code: R2516299-009

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:14	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-66
Lab Code: R2516299-010

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-67
Lab Code: R2516299-011

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-68
Lab Code: R2516299-012

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-69
Lab Code: R2516299-013

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-70A
Lab Code: R2516299-014

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-70B
Lab Code: R2516299-015

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-71A
Lab Code: R2516299-016

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-71B
Lab Code: R2516299-017

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-72A
Lab Code: R2516299-018

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-72B
Lab Code: R2516299-019

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-73A
Lab Code: R2516299-020

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-73B
Lab Code: R2516299-021

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-74
Lab Code: R2516299-022

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	12/19/25 23:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-75
Lab Code: R2516299-023

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	12/19/25 23:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-76
Lab Code: R2516299-024

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-77
Lab Code: R2516299-025

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-78
Lab Code: R2516299-026

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-79
Lab Code: R2516299-027

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-80
Lab Code: R2516299-028

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-81
Lab Code: R2516299-029

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-82
Lab Code: R2516299-030

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.3	ug/L	1.0	1	12/20/25 00:00	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-83A
Lab Code: R2516299-031

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/20/25 00:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-83B
Lab Code: R2516299-032

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/20/25 00:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-84A
Lab Code: R2516299-033

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/20/25 00:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: 102.8-84B
Lab Code: R2516299-034

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/20/25 00:05	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516299-MB1

Service Request: R2516299
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 22:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516299-MB2

Service Request: R2516299
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 23:32	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25
Date Analyzed: 12/19/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.8-71B
Lab Code: R2516299-017
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516299-017MS		Duplicate Matrix Spike R2516299-017DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	21.6	20.0	108	21.4	20.0	107	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water

Service Request: R2516299
Date Collected: 11/24/25
Date Received: 12/04/25
Date Analyzed: 12/19/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.8-72A
Lab Code: R2516299-018
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516299-018MS		Duplicate Matrix Spike R2516299-018DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	21.7	20.0	109	21.7	20.0	109	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water

Service Request: R2516299
Date Analyzed: 12/19/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516299-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.7	20.0	113	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD - Kenmore West High School/2023L-102.8
Sample Matrix: Drinking Water

Service Request: R2516299
Date Analyzed: 12/19/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516299-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.4	20.0	112	85-115

1.5 Laboratory Certifications

**NEW YORK STATE DEPARTMENT OF HEALTH
 WADSWORTH CENTER**



Expires 12:01 AM April 01, 2026
 Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE
Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. CHRISTINE KUTZER
ALS ENVIRONMENTAL - ROCHESTER
1565 JEFFERSON ROAD BUILDING 300, SUITE 360
ROCHESTER, NY 14623

NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the
 National Environmental Laboratory Accreditation Conference Standards (2016) for the category
 ENVIRONMENTAL ANALYSES POTABLE WATER
 All approved analytes are listed below:*

Bacteriology	
Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Collert)
Dissolved Gases	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
Fuel Additives	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
Metals I	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Zinc, Total	EPA 200.7 Rev. 4.4

Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elapublicweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.



Page 1 of 5