

January 6, 2026

Ms. Georgia Militello  
Ken-Ton UFSD  
1500 Colvin Boulevard  
Buffalo, New York 14223

**Re: Lead Testing in School Drinking Water**

Dear Ms. Militello:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Ken-Ton UFSD, including:

- **Charles A. Lindbergh Elementary School – 184 Irving Terrace, Buffalo, NY**

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: Lead Testing in School Drinking Water, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on November 20, 2025. As detailed in Section 1.2 (Executive Summary) of the accompanying report, based upon the sampling and analysis performed, 3 sources of potable water in Charles A. Lindbergh Elementary School have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion. To comply with NYS regulations, response actions by the district are required. Response actions are outlined in Section 1.3 (Response Actions Required Under NYS Regulations).

Thank you for the opportunity to be of service to Ken-Ton UFSD.

Sincerely,  
Stohl Environmental, LLC.



Michael Scinta  
EPA Lead Risk Assessor

**Lead Testing in School Drinking Water**

**Prepared for:**

**Ken-Ton UFSD**

**Prepared by:**



**3860 California Road  
Orchard Park, New York 14127**

**Conditions as of November 20, 2025**

## Summary Tabulation

### Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports and Chain of Custody Documents
- 1.5. Laboratory Certifications

## 1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Ken-Ton UFSD to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- **Charles A. Lindbergh Elementary School – 184 Irving Terrace, Buffalo, NY**

### Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within Charles A. Lindbergh Elementary School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

### Sampling Protocol:

In accordance with NYS regulations, **Subpart 67-4: Lead Testing in School Drinking Water**, and the EPA guidance document, **3Ts for Reducing Lead in Drinking Water in Schools**, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

**1.2 Executive Summary of Sampling and Analysis:**

**Summary of Samples Collected at Charles A. Lindbergh Elementary School:**

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Charles A. Lindbergh Elementary School	November 20, 2025	76	73	3

*\*NYS Action Level is 5 parts per billion*

**Listing of Outlets Requiring Remediation**

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
102.6-3	Kitchen Prep Sink	Sink	22.5
102.6-6	Kitchen Dish Sprayer	Sprayer	16.6
102.6-64	Boiler Room Sink	Sink	21.4

**1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:**

For outlets analyzed with a lead concentration more than the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
  - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
  - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

## 1.4 Laboratory Analytical Reports and Chain of Custody Documents



December 23, 2025

Service Request No:R2515817

Michael Scinta  
Stohl Environmental  
3860 California Road  
Orchard Park, NY 14219

**Laboratory Results for: Kenton UFSD - Lindbergh Elementary School**

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory November 21, 2025  
For your reference, these analyses have been assigned our service request number **R2515817**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at [Meghan.Pedro@alsglobal.com](mailto:Meghan.Pedro@alsglobal.com).

Respectfully submitted,

**ALS Group USA, Corp. dba ALS Environmental**

Meghan Pedro  
Project Manager

CC: Rebecca  
Franjoine

**ADDRESS** 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
**PHONE** +1 585 288 5380 | **FAX** +1 585 288 8475  
ALS Group USA, Corp.  
dba ALS Environmental



# Narrative Documents

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School  
**Sample Matrix:** Drinking Water

**Service Request:** R2515817  
**Date Received:** 11/21/2025

**CASE NARRATIVE**

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

**Sample Receipt:**

Thirty six drinking water samples were received for analysis at ALS Environmental on 11/21/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

**Metals:**

Method 200.8, 12/18/2025: The upper control limit was exceeded for Lead in the Continuing Calibration Verification (CCV). The field samples analyzed in this sequence did not contain the analyte(s) in question above the Method Reporting Limit (MRL). Since the exceedance equates to a potential high bias, the data quality was not significantly affected and no further corrective action was taken.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by \_\_\_\_\_

Date 12/23/2025



### SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

<b>CLIENT ID: 102.6-1</b>	<b>Lab ID: R2515817-001</b>					
---------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.5			1.0	ug/L	200.8

<b>CLIENT ID: 102.6-3</b>	<b>Lab ID: R2515817-003</b>					
---------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	22.5			1.0	ug/L	200.8

<b>CLIENT ID: 102.6-4</b>	<b>Lab ID: R2515817-004</b>					
---------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.4			1.0	ug/L	200.8

<b>CLIENT ID: 102.6-6</b>	<b>Lab ID: R2515817-006</b>					
---------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	16.6			1.0	ug/L	200.8

<b>CLIENT ID: 102.6-17</b>	<b>Lab ID: R2515817-020</b>					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8



## Sample Receipt Information

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6

**Service Request:**R2515817

**SAMPLE CROSS-REFERENCE**

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2515817-001	102.6-1	11/20/2025	
R2515817-002	102.6-2	11/20/2025	
R2515817-003	102.6-3	11/20/2025	
R2515817-004	102.6-4	11/20/2025	
R2515817-005	102.6-5	11/20/2025	
R2515817-006	102.6-6	11/20/2025	
R2515817-007	102.6-7	11/20/2025	
R2515817-008	102.6-8	11/20/2025	
R2515817-009	102.6-9A	11/20/2025	
R2515817-010	102.6-9B	11/20/2025	
R2515817-011	102.6-10	11/20/2025	
R2515817-012	102.6-11A	11/20/2025	
R2515817-013	102.6-11B	11/20/2025	
R2515817-014	102.6-12	11/20/2025	
R2515817-015	102.6-13	11/20/2025	
R2515817-016	102.6-14	11/20/2025	
R2515817-017	102.6-15	11/20/2025	
R2515817-018	102.6-16A	11/20/2025	
R2515817-019	102.6-16B	11/20/2025	
R2515817-020	102.6-17	11/20/2025	
R2515817-021	102.6-18	11/20/2025	
R2515817-022	102.6-19	11/20/2025	
R2515817-023	102.6-20	11/20/2025	
R2515817-024	102.6-21	11/20/2025	
R2515817-025	102.6-22A	11/20/2025	
R2515817-026	102.6-22B	11/20/2025	
R2515817-027	102.6-23	11/20/2025	
R2515817-028	102.6-24	11/20/2025	
R2515817-029	102.6-25A	11/20/2025	
R2515817-030	102.6-25B	11/20/2025	
R2515817-031	102.6-26	11/20/2025	
R2515817-032	102.6-27	11/20/2025	
R2515817-033	102.6-28	11/20/2025	
R2515817-034	102.6-29	11/20/2025	
R2515817-035	102.6-30	11/20/2025	
R2515817-036	102.6-31	11/20/2025	



# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS  
 STOHL Job # 2023L-102.6

Client: Kenton UFSD Contact: Georgia Militello  
 Building: Lindbergh Elementary School Location: 184 Irving Terrace, Buffalo, NY 14223

**LEAD**  
 Water by 200.8 X Tumaround  
10 Days

Sample #	Location	Outlet Type	Time
102.6-1	Kitchen Hand Wash Next To Kettle	Sink	5:05
102.6-2	Kitchen Pot Filler	Pot Filler	5:06
102.6-3	Kitchen Prep Sink	Sink	5:07
102.6-4	3 Bay L Kitchen	Sink	5:08
102.6-5	3 Bay R Kitchen	Sink	5:10
102.6-6	Kitchen Dish Sprayer	Sprayer	5:11
102.6-7	Kitchen Sink To Right Of Sprayer	Sink	5:12
102.6-8	Kitchen Bathroom Sink	Sink	5:13
102.6-9A	Cafeteria DF	DF	5:15
102.6-9B	Cafeteria DFB	DFB	5:16
102.6-10	Room 114 Sink	Sink	5:17
102.6-11A	DF Outside Gym	DF	5:19
102.6-11B	DFB Outside Gym	DFB	5:20
102.6-12	Womens Staff Bathroom Sink By Gym	Sink	5:21
102.6-13	Room 113 Sink	Sink	5:22
102.6-14	Room 112 Sink	Sink	5:24
102.6-15	Custodial Office Bathroom Sink	Sink	5:25
102.6-16A	DF Outside 111	DF	5:26

Notes:  
 Please e-mail lab results to labs@stohlenv.com  If checked, also e-mail results to: Mscinta@stohlenvironmental.com

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 11/20/2025  
 Relinquished By: \_\_\_\_\_ Print Name Connor Crilly Stohl Env: Connor Crilly Date: 11/20/2025  
 Received (Name / Lab): ALS Date: 11/21/25 Time: 8:25  
 Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_  
 Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_

**R2515817 5**  
 Stohl Environmental  
 Kenton UFSD - Lindbergh Elementary School



# Chain of Custody Document

3860 Callifornia Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS  
 STOHL Job # 2023L-102.6

Client: Kenton UFSD Contact: Georgia Militello  
 Building: Lindbergh Elementary School Location: 184 Irving Terrace, Buffalo, NY 14223

**LEAD**  
 Water by 200.8 X Turnaround 10 Days

Sample #	Location	Outlet Type	Time
102.6-16B	DFB Outside 111	DFB	5:28
102.6-17	111 Sink	Sink	5:29
102.6-18	110 Sink	Sink	5:30
102.6-19	109F Sink	Sink	5:31
102.6-20	109B L Sink	Sink	5:33
102.6-21	109B R Sink	Sink	5:34
102.6-22A	109B DF	DF	5:35
102.6-22B	109B DFB	DFB	5:37
102.6-23	Room 108 Sink	Sink	5:38
102.6-24	Room 107 Sink	Sink	5:39
102.6-25A	DF By 107	DF	5:40
102.6-25B	DFB By 107	DFB	5:42
102.6-26	Room 106 Sink	Sink	5:43
102.6-27	Room 105 Sink	Sink	5:44
102.6-28	Couselors Office Bathroom	Sink	5:46
102.6-29	Couselors Office Sink	Sink	5:47
102.6-30	Room 104 Bathroom	Sink	5:48
102.6-31	Room 104 Kitchenette Sink	Sink	5:49

Notes: Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com) [Mscinta@stohlenvironmental.com](mailto:Mscinta@stohlenvironmental.com)

Sampled By: Jared Rider Print Name Stohl Env: Jared Rider Date: 11/20/2025  
 Relinquished By: \_\_\_\_\_ Print Name Stohl Env: Connor Crilly Date: 11/20/2025  
 Received (Name / Lab): Sam Mammari ALS Date: 11/21/25 Time: 8:25  
 Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Cooler Receipt and Preservation C

R2515817 5

Stahl Environmental  
Kenton UFSD - Lindbergh Elementary School



Project/Client Stahl Folder Number \_\_\_\_\_

Cooler received on 11/21/25 by: RM

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="radio"/> N <input type="radio"/>
2	Custody papers properly completed (ink, signed)?	Y <input checked="" type="radio"/> N <input type="radio"/>
3	Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="radio"/> N <input type="radio"/>
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="radio"/> N <input type="radio"/>

5a	Did VOA vials have sig* bubbles?	Y N <input checked="" type="radio"/> NA
5b	Sig* bubbles: Alk? Y N <input checked="" type="radio"/> NA Sulfide? Y N <input checked="" type="radio"/> NA	
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set	<input checked="" type="radio"/> NA

8. Temperature Readings Date: 11/21/25 Time: 8:32 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>10.2</u>						
Within 0-6°C?	Y <input checked="" type="radio"/> N <input type="radio"/>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: No ice Ice melted Poorly Packed (described below) Same Day Rule  
& Client Approval to Run Samples: \_\_\_\_\_ Standing Approval: Client aware at drop-off Client notified by: \_\_\_\_\_

All samples held in storage location: SMO by RM on 11/21 at 8:32  
5035 samples placed in storage location: \_\_\_\_\_ by \_\_\_\_\_ on \_\_\_\_\_ at \_\_\_\_\_ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check\*\*: Date: 11/26 Time: 1615 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)?  YES  NO
- 10. Did all bottle labels and tags agree with custody papers?  YES  NO
- 11. Were correct containers used for the tests indicated?  YES  NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO  N/A
- 13. Were dissolved metals filtered in the field? YES NO  N/A
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated  N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>202325</u>	HNO <sub>3</sub>	<u>x</u>	<u>κ</u>	<u>24017806</u>	<u>7127</u>	<u>1.2, 27-31</u>	<u>4mL</u>		<u>5.2</u>
≤2		H <sub>2</sub> SO <sub>4</sub>								
<4		NaHSO <sub>4</sub>								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> (625, 608, CN), ascorbic (phenol).					
		Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>								
		ZnAcetate	-	-						
		HCl	**	**						

\*\*VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: \_\_\_\_\_  
Explain all Discrepancies/ Other Comments: \_\_\_\_\_

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG \*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



# Miscellaneous Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



## REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- \* Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ( $\geq 100\%$  Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)  
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

### Rochester Lab ID # for State Accreditations<sup>1</sup>



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

<sup>1</sup> Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

# ALS Laboratory Group

---

## Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6

**Service Request:** R2515817

**Sample Name:** 102.6-1  
**Lab Code:** R2515817-001  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-2  
**Lab Code:** R2515817-002  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-3  
**Lab Code:** R2515817-003  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-4  
**Lab Code:** R2515817-004  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-5  
**Lab Code:** R2515817-005  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6

**Service Request:** R2515817

**Sample Name:** 102.6-6  
**Lab Code:** R2515817-006  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-7  
**Lab Code:** R2515817-007  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-8  
**Lab Code:** R2515817-008  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-9A  
**Lab Code:** R2515817-009  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-9B  
**Lab Code:** R2515817-010  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6

**Service Request:** R2515817

**Sample Name:** 102.6-10  
**Lab Code:** R2515817-011  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-11A  
**Lab Code:** R2515817-012  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-11B  
**Lab Code:** R2515817-013  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-12  
**Lab Code:** R2515817-014  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-13  
**Lab Code:** R2515817-015  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6

**Service Request:** R2515817

**Sample Name:** 102.6-14  
**Lab Code:** R2515817-016  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-15  
**Lab Code:** R2515817-017  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-16A  
**Lab Code:** R2515817-018  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-16B  
**Lab Code:** R2515817-019  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-17  
**Lab Code:** R2515817-020  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6

**Service Request:** R2515817

**Sample Name:** 102.6-18  
**Lab Code:** R2515817-021  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-19  
**Lab Code:** R2515817-022  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-20  
**Lab Code:** R2515817-023  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-21  
**Lab Code:** R2515817-024  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-22A  
**Lab Code:** R2515817-025  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6

**Service Request:** R2515817

**Sample Name:** 102.6-22B  
**Lab Code:** R2515817-026  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-23  
**Lab Code:** R2515817-027  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-24  
**Lab Code:** R2515817-028  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-25A  
**Lab Code:** R2515817-029  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-25B  
**Lab Code:** R2515817-030  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6

**Service Request:** R2515817

**Sample Name:** 102.6-26  
**Lab Code:** R2515817-031  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-27  
**Lab Code:** R2515817-032  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-28  
**Lab Code:** R2515817-033  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-29  
**Lab Code:** R2515817-034  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-30  
**Lab Code:** R2515817-035  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**ALS Group USA, Corp.**  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6

**Service Request:** R2515817

**Sample Name:** 102.6-31  
**Lab Code:** R2515817-036  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN



## PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

### INORGANIC

#### Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

#### Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

### ORGANIC

**Preparation Methods for Organic methods are listed in the header of the Results pages.**

#### Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



# Sample Results

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-1  
**Lab Code:** R2515817-001

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.5	ug/L	1.0	1	12/18/25 11:22	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-2  
**Lab Code:** R2515817-002

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 11:27	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-3  
**Lab Code:** R2515817-003

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	22.5	ug/L	1.0	1	12/19/25 12:51	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-4  
**Lab Code:** R2515817-004

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.4	ug/L	1.0	1	12/19/25 12:56	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-5  
**Lab Code:** R2515817-005

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 11:31	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-6  
**Lab Code:** R2515817-006

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	16.6	ug/L	1.0	1	12/19/25 12:57	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-7  
**Lab Code:** R2515817-007

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 12:59	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-8  
**Lab Code:** R2515817-008

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 11:36	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-9A  
**Lab Code:** R2515817-009

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 11:37	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-9B  
**Lab Code:** R2515817-010

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 11:39	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-10  
**Lab Code:** R2515817-011

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 11:40	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-11A  
**Lab Code:** R2515817-012

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 11:45	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-11B  
**Lab Code:** R2515817-013

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 11:47	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-12  
**Lab Code:** R2515817-014

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 11:48	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-13  
**Lab Code:** R2515817-015

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 11:50	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-14  
**Lab Code:** R2515817-016

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:00	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-15  
**Lab Code:** R2515817-017

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:05	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-16A  
**Lab Code:** R2515817-018

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:06	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-16B  
**Lab Code:** R2515817-019

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:08	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-17  
**Lab Code:** R2515817-020

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	12/18/25 12:09	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-18  
**Lab Code:** R2515817-021

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:11	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-19  
**Lab Code:** R2515817-022

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:16	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-20  
**Lab Code:** R2515817-023

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:17	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-21  
**Lab Code:** R2515817-024

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:19	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-22A  
**Lab Code:** R2515817-025

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:20	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-22B  
**Lab Code:** R2515817-026

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:22	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-23  
**Lab Code:** R2515817-027

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:23	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-24  
**Lab Code:** R2515817-028

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:25	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-25A  
**Lab Code:** R2515817-029

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:26	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-25B  
**Lab Code:** R2515817-030

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:28	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-26  
**Lab Code:** R2515817-031

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:29	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-27  
**Lab Code:** R2515817-032

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:34	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-28  
**Lab Code:** R2515817-033

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:36	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-29  
**Lab Code:** R2515817-034

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:37	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-30  
**Lab Code:** R2515817-035

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:39	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-31  
**Lab Code:** R2515817-036

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:49	



# QC Summary Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2515817-MB1

**Service Request:** R2515817  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 11:08	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2515817-MB2

**Service Request:** R2515817  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 11:57	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2515817-MB3

**Service Request:** R2515817  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:46	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2515817-MB4

**Service Request:** R2515817  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/19/25 12:48	

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25  
**Date Analyzed:** 12/19/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 102.6-3  
**Lab Code:** R2515817-003  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2515817-003MS		Duplicate Matrix Spike R2515817-003DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	22.5	42.1	20.0	98	41.4	20.0	94	70-130	2	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25  
**Date Analyzed:** 12/18/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 102.6-13  
**Lab Code:** R2515817-015  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2515817-015MS		Duplicate Matrix Spike R2515817-015DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	20.1	20.0	100	19.8	20.0	99	70-130	1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25  
**Date Analyzed:** 12/18/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 102.6-14  
**Lab Code:** R2515817-016  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2515817-016MS		Duplicate Matrix Spike R2515817-016DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	20.1	20.0	100	20.2	20.0	101	70-130	<1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25  
**Date Analyzed:** 12/18/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 102.6-30  
**Lab Code:** R2515817-035  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2515817-035MS		Result	Duplicate Matrix Spike R2515817-035DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	19.9	20.0	99	19.7	20.0	98	70-130	<1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water

**Service Request:** R2515817  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25  
**Date Analyzed:** 12/18/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 102.6-31  
**Lab Code:** R2515817-036  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2515817-036MS		Duplicate Matrix Spike R2515817-036DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	20.2	20.0	101	20.3	20.0	101	70-130	<1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water

**Service Request:** R2515817

**Date Analyzed:** 12/18/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L

**Basis:**NA

**Lab Control Sample**  
R2515817-LCS1

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	19.1	20.0	95	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water

**Service Request:** R2515817  
**Date Analyzed:** 12/18/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2515817-LCS2

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	19.9	20.0	100	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water

**Service Request:** R2515817  
**Date Analyzed:** 12/18/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2515817-LCS3

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	19.9	20.0	99	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water

**Service Request:** R2515817  
**Date Analyzed:** 12/19/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2515817-LCS4

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	18.5	20.0	92	85-115



December 23, 2025

Service Request No:R2515818

Michael Scinta  
Stohl Environmental  
3860 California Road  
Orchard Park, NY 14219

**Laboratory Results for: Kenton UFSD - Lindbergh Elementary School**

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory November 21, 2025  
For your reference, these analyses have been assigned our service request number **R2515818**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at [Meghan.Pedro@alsglobal.com](mailto:Meghan.Pedro@alsglobal.com).

Respectfully submitted,

**ALS Group USA, Corp. dba ALS Environmental**

Meghan Pedro  
Project Manager

CC: Rebecca  
Franjoine

**ADDRESS** 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
**PHONE** +1 585 288 5380 | **FAX** +1 585 288 8475  
ALS Group USA, Corp.  
dba ALS Environmental



# Narrative Documents

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School  
**Sample Matrix:** Drinking Water

**Service Request:** R2515818  
**Date Received:** 11/21/2025

**CASE NARRATIVE**

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

**Sample Receipt:**

Forty drinking water samples were received for analysis at ALS Environmental on 11/21/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

**Metals:**

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by \_\_\_\_\_

Date 12/23/2025



### SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

<b>CLIENT ID: 102.6-46</b>	<b>Lab ID: R2515818-018</b>					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.3			1.0	ug/L	200.8

<b>CLIENT ID: 102.6-64</b>	<b>Lab ID: R2515818-040</b>					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	21.4			1.0	ug/L	200.8



## Sample Receipt Information

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6

**Service Request:**R2515818

**SAMPLE CROSS-REFERENCE**

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2515818-001	102.6-32A	11/20/2025	
R2515818-002	102.6-32B	11/20/2025	
R2515818-003	102.6-33	11/20/2025	
R2515818-004	102.6-34	11/20/2025	
R2515818-005	102.6-35A	11/20/2025	
R2515818-006	102.6-35B	11/20/2025	
R2515818-007	102.6-36	11/20/2025	
R2515818-008	102.6-37	11/20/2025	
R2515818-009	102.6-38	11/20/2025	
R2515818-010	102.6-39	11/20/2025	
R2515818-011	102.6-40	11/20/2025	
R2515818-012	102.6-41	11/20/2025	
R2515818-013	102.6-42	11/20/2025	
R2515818-014	102.6-43	11/20/2025	
R2515818-015	102.6-44A	11/20/2025	
R2515818-016	102.6-44B	11/20/2025	
R2515818-017	102.6-45	11/20/2025	
R2515818-018	102.6-46	11/20/2025	
R2515818-019	102.6-47	11/20/2025	
R2515818-020	102.6-48	11/20/2025	
R2515818-021	102.6-49	11/20/2025	
R2515818-022	102.6-50	11/20/2025	
R2515818-023	102.6-51	11/20/2025	
R2515818-024	102.6-52	11/20/2025	
R2515818-025	102.6-53	11/20/2025	
R2515818-026	102.6-54A	11/20/2025	
R2515818-027	102.6-54B	11/20/2025	
R2515818-028	102.6-55	11/20/2025	
R2515818-029	102.6-56	11/20/2025	
R2515818-030	102.6-57	11/20/2025	
R2515818-031	102.6-58	11/20/2025	
R2515818-032	102.6-59A	11/20/2025	
R2515818-033	102.6-59B	11/20/2025	
R2515818-034	102.6-60	11/20/2025	
R2515818-035	102.6-61	11/20/2025	
R2515818-036	102.6-62A	11/20/2025	
R2515818-037	102.6-62B	11/20/2025	
R2515818-038	102.6-63A	11/20/2025	
R2515818-039	102.6-63B	11/20/2025	
R2515818-040	102.6-64	11/20/2025	



# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.6

Client: Kenton UFSD

Contact: Georgia Militello

Building: Lindbergh Elementary School

Location: 184 Irving Terrace, Buffalo, NY 14223

<b>LEAD</b>		<i>Turnaround</i>
Water by 200.8	<u>X</u>	<u>10 Days</u>

Sample #	Location	Outlet Type	Time
102.6-32A	DF Outside Of 104	DF	5:51
106.2-32B	DFB Outside Of 104	DFB	5:52
106.2-33	Room 103 Sink	Sink	5:53
106.2-34	Wellness Room Sink	Sink	5:55
106.2-35A	Girls Gym DF	DF	5:56
106.2-35B	Girls Gym DFB	DFB	5:57
106.2-36	Room 102 Sink	Sink	5:58
106.2-37	Room 101 Sink	Sink	6:00
106.2-38	Girls Slop Sink	Sink	6:01
106.2-39	Girls Bathroom L Single Sink	Sink	6:02
106.2-40	Girls Bathroom BFL	Sink	6:04
106.2-41	Girls Bathroom BBL	Sink	6:05
106.2-42	Girls Bathroom BFR	Sink	6:06
106.2-43	Girls Bathroom BBR	Sink	6:07
106.2-44A	DF By 116	DF	6:09
106.2-44B	DFB By 116	DFB	6:10
106.2-45	Attendance 113 Room Sink	Sink	6:11
102.6-46	Nurse Office 116 Sink On Left	Sink	6:13

Notes: Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com) [Mscinta@stohlenvironmental.com](mailto:Mscinta@stohlenvironmental.com)

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 11/20/2025

Relinquished By: \_\_\_\_\_ Print Name \_\_\_\_\_ Stohl Env: Connor Crilly Date: 11/20/2025


Received (Name / Lab): Connor Crilly ALS Date: 11/21/25 Time: 8:25

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_





# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.6

Client: Kenton UFSD

Contact: Georgia Militello

Building: Lindbergh Elementary School

Location: 184 Irving Terrace, Buffalo, NY 14223

**LEAD**

Water by 200.8 X

*Turnaround*

10 Days

Sample #	Location	Outlet Type	Time
102.6-47	Nurse Office Br Sink	Sink	6:14
102.6-48	Boys Br Sink L	Sink	6:15
102.6-49	Boys Br Sink R	Sink	6:16
102.6-50	Boys Bathroom 2nd Floor Across From Elevator L Sink	Sink	6:18
102.6-51	Boys Bathroom 2nd Floor Across From Elevator R Sink	Sink	6:19
102.6-52	Faculty Lounge L	Sink	6:20
102.6-53	Faculty Lounge R	Sink	6:22
102.6-54A	DF Across From Faculty Lounge	DF	6:23
102.6-54B	DFB Across From Faculty Lounge	DFB	6:24
102.6-55	Girls Bathroom BFL 2nd Floor	Sink	6:25
102.6-56	Girls Bathroom BBL 2nd Floor	Sink	6:27
102.6-57	Girls Bathroom BFR 2nd Floor	Sink	6:28
102.6-58	Girls Bathroom BBR 2nd Floor	Sink	6:29
102.6-59A	DF Next To 206	DF	6:30
102.6-59B	DFB Next To 206	DFB	6:32
102.6-60	Art Room Sink	Sink	6:33
102.6-61	Art Room Bathroom	Sink	6:34
102.6-62A	Room 210 DF	DF	6:36

**Notes:**

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

[Mscinta@stohlenvironmental.com](mailto:Mscinta@stohlenvironmental.com)

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 11/20/2025

Relinquished By: \_\_\_\_\_ Print Name \_\_\_\_\_ Stohl Env: Connor Crilly Date: 11/20/2025

Received (Name / Lab): CONNOR CRILLY ALS Date: 11/21/25 Time: 8:25

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_





# Cooler Receipt and Preservation

**R2515818** **5**  
 Stahl Environmental  
 Kenton UFSO - Lindbergh Elementary School

Project/Client Stohl Folder Number \_\_\_\_\_

Cooler received on 11/21/25 by: RM COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="radio"/> N <input type="radio"/>	5a	Did VOA vials have sig* bubbles?	Y <input type="radio"/> N <input checked="" type="radio"/> NA <input type="radio"/>
2	Custody papers properly completed (ink, signed)?	Y <input checked="" type="radio"/> N <input type="radio"/>	5b	Sig* bubbles: Alk? Y <input type="radio"/> N <input checked="" type="radio"/> NA <input type="radio"/> Sulfide? Y <input type="radio"/> N <input checked="" type="radio"/> NA <input type="radio"/>	
3	Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="radio"/> N <input type="radio"/>	6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="radio"/> N <input type="radio"/>	7	Soil VOA received as: Bulk Encore 5035set	<u>NA</u>

8. Temperature Readings Date: 11/21/25 Time: 8:32 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>10.2</u>						
Within 0-6°C?	Y <input checked="" type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>					
If <0°C, were samples frozen?	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>

If out of Temperature, note packing/ice condition: No ice Ice melted Poorly Packed (described below) Same Day Rule  
 & Client Approval to Run Samples: \_\_\_\_\_ Standing Approval Client aware at drop-off Client notified by: \_\_\_\_\_

All samples held in storage location: SMO by RM on 11/21 at 8:32  
 5035 samples placed in storage location: \_\_\_\_\_ by \_\_\_\_\_ on \_\_\_\_\_ at \_\_\_\_\_ within 48 hours of sampling? Y  N

Cooler Breakdown/Preservation Check\*\*: Date: 11/26 Time: 1809 by: AB

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES  NO
- 10. Did all bottle labels and tags agree with custody papers? YES  NO
- 11. Were correct containers used for the tests indicated? YES  NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES  NO  N/A
- 13. Were dissolved metals filtered in the field? YES  NO  N/A
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized \_\_\_\_\_ Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
>12		NaOH								
<2	<u>202325</u>	HNO <sub>3</sub>	<u>X</u>	<u>X</u>	<u>24017606</u>	<u>7127</u>	<u>32-39</u>	<u>4ml</u>		<u>6.2</u>
<2		H <sub>2</sub> SO <sub>4</sub>								
<4		NaHSO <sub>4</sub>								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> (625, 608, CN), ascorbic (phenol).					
		Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>								
		ZnAcetate	-	-						
		HCl	**	**						

\*\*VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: \_\_\_\_\_  
 Explain all Discrepancies/ Other Comments: \_\_\_\_\_

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AL \*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



## Miscellaneous Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



## REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- \* Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ( $\geq 100\%$  Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)  
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

### Rochester Lab ID # for State Accreditations<sup>1</sup>



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

<sup>1</sup> Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

# ALS Laboratory Group

---

## Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6

**Service Request:** R2515818

**Sample Name:** 102.6-32A  
**Lab Code:** R2515818-001  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-32B  
**Lab Code:** R2515818-002  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-33  
**Lab Code:** R2515818-003  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-34  
**Lab Code:** R2515818-004  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-35A  
**Lab Code:** R2515818-005  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6

**Service Request:** R2515818

**Sample Name:** 102.6-35B  
**Lab Code:** R2515818-006  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-36  
**Lab Code:** R2515818-007  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-37  
**Lab Code:** R2515818-008  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-38  
**Lab Code:** R2515818-009  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-39  
**Lab Code:** R2515818-010  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6

**Service Request:** R2515818

**Sample Name:** 102.6-40  
**Lab Code:** R2515818-011  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-41  
**Lab Code:** R2515818-012  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-42  
**Lab Code:** R2515818-013  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-43  
**Lab Code:** R2515818-014  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-44A  
**Lab Code:** R2515818-015  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6

**Service Request:** R2515818

**Sample Name:** 102.6-44B  
**Lab Code:** R2515818-016  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-45  
**Lab Code:** R2515818-017  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-46  
**Lab Code:** R2515818-018  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-47  
**Lab Code:** R2515818-019  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-48  
**Lab Code:** R2515818-020  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6

**Service Request:** R2515818

**Sample Name:** 102.6-49  
**Lab Code:** R2515818-021  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-50  
**Lab Code:** R2515818-022  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-51  
**Lab Code:** R2515818-023  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-52  
**Lab Code:** R2515818-024  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-53  
**Lab Code:** R2515818-025  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6

**Service Request:** R2515818

**Sample Name:** 102.6-54A  
**Lab Code:** R2515818-026  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-54B  
**Lab Code:** R2515818-027  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-55  
**Lab Code:** R2515818-028  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-56  
**Lab Code:** R2515818-029  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-57  
**Lab Code:** R2515818-030  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6

**Service Request:** R2515818

**Sample Name:** 102.6-58  
**Lab Code:** R2515818-031  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-59A  
**Lab Code:** R2515818-032  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-59B  
**Lab Code:** R2515818-033  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-60  
**Lab Code:** R2515818-034  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-61  
**Lab Code:** R2515818-035  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6

**Service Request:** R2515818

**Sample Name:** 102.6-62A  
**Lab Code:** R2515818-036  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-62B  
**Lab Code:** R2515818-037  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-63A  
**Lab Code:** R2515818-038  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-63B  
**Lab Code:** R2515818-039  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 102.6-64  
**Lab Code:** R2515818-040  
**Sample Matrix:** Drinking Water

**Date Collected:** 11/20/25  
**Date Received:** 11/21/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN



## PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

### INORGANIC

#### Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

#### Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

### ORGANIC

**Preparation Methods for Organic methods are listed in the header of the Results pages.**

#### Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



## Sample Results

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-32A  
**Lab Code:** R2515818-001

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:54	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-32B  
**Lab Code:** R2515818-002

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:55	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-33  
**Lab Code:** R2515818-003

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:57	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-34  
**Lab Code:** R2515818-004

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:59	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-35A  
**Lab Code:** R2515818-005

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:00	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-35B  
**Lab Code:** R2515818-006

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:05	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-36  
**Lab Code:** R2515818-007

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:06	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-37  
**Lab Code:** R2515818-008

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:08	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-38  
**Lab Code:** R2515818-009

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:09	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-39  
**Lab Code:** R2515818-010

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:11	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-40  
**Lab Code:** R2515818-011

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:12	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-41  
**Lab Code:** R2515818-012

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:14	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-42  
**Lab Code:** R2515818-013

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:16	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-43  
**Lab Code:** R2515818-014

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:17	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-44A  
**Lab Code:** R2515818-015

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:19	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-44B  
**Lab Code:** R2515818-016

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:23	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-45  
**Lab Code:** R2515818-017

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:25	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-46  
**Lab Code:** R2515818-018

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.3	ug/L	1.0	1	12/18/25 13:26	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-47  
**Lab Code:** R2515818-019

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:28	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-48  
**Lab Code:** R2515818-020

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:39	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-49  
**Lab Code:** R2515818-021

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:43	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-50  
**Lab Code:** R2515818-022

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:45	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-51  
**Lab Code:** R2515818-023

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:46	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-52  
**Lab Code:** R2515818-024

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:48	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-53  
**Lab Code:** R2515818-025

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:49	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-54A  
**Lab Code:** R2515818-026

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:54	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-54B  
**Lab Code:** R2515818-027

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:56	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-55  
**Lab Code:** R2515818-028

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:57	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-56  
**Lab Code:** R2515818-029

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:59	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-57  
**Lab Code:** R2515818-030

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:00	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-58  
**Lab Code:** R2515818-031

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:02	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-59A  
**Lab Code:** R2515818-032

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:03	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-59B  
**Lab Code:** R2515818-033

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:05	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-60  
**Lab Code:** R2515818-034

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:06	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-61  
**Lab Code:** R2515818-035

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:08	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-62A  
**Lab Code:** R2515818-036

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:13	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-62B  
**Lab Code:** R2515818-037

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:14	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-63A  
**Lab Code:** R2515818-038

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:16	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-63B  
**Lab Code:** R2515818-039

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:17	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.6-64  
**Lab Code:** R2515818-040

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25 08:25

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	21.4	ug/L	1.0	1	12/18/25 14:28	



## QC Summary Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2515818-MB1

**Service Request:** R2515818  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 12:46	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2515818-MB2

**Service Request:** R2515818  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 13:36	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2515818-MB3

**Service Request:** R2515818  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:25	

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25  
**Date Analyzed:** 12/18/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 102.6-47  
**Lab Code:** R2515818-019  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2515818-019MS		Duplicate Matrix Spike R2515818-019DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	18.6	20.0	93	19.1	20.0	95	70-130	2	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25  
**Date Analyzed:** 12/18/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 102.6-48  
**Lab Code:** R2515818-020  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2515818-020MS		Result	Duplicate Matrix Spike R2515818-020DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	19.7	20.0	99	20.3	20.0	101	70-130	3	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25  
**Date Analyzed:** 12/18/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 102.6-63B  
**Lab Code:** R2515818-039  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2515818-039MS		Result	Duplicate Matrix Spike R2515818-039DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	19.3	20.0	96	19.3	20.0	96	70-130	<1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water

**Service Request:** R2515818  
**Date Collected:** 11/20/25  
**Date Received:** 11/21/25  
**Date Analyzed:** 12/18/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 102.6-64  
**Lab Code:** R2515818-040  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2515818-040MS		Duplicate Matrix Spike R2515818-040DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	21.4	42.3	20.0	105	42.8	20.0	107	70-130	1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water

**Service Request:** R2515818  
**Date Analyzed:** 12/18/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2515818-LCS1

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	19.9	20.0	99	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water

**Service Request:** R2515818  
**Date Analyzed:** 12/18/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2515818-LCS2

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	20.6	20.0	103	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Kenton UFSD - Lindbergh Elementary School/2023L-102.6  
**Sample Matrix:** Drinking Water

**Service Request:** R2515818  
**Date Analyzed:** 12/18/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2515818-LCS3

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	19.5	20.0	98	85-115

1.5 Laboratory Certifications

**NEW YORK STATE DEPARTMENT OF HEALTH  
 WADSWORTH CENTER**



Expires 12:01 AM April 01, 2026  
 Issued April 01, 2025

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**  
*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

**MS. CHRISTINE KUTZER**  
**ALS ENVIRONMENTAL - ROCHESTER**  
 1565 JEFFERSON ROAD BUILDING 300, SUITE 360  
 ROCHESTER, NY 14623

NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
 National Environmental Laboratory Accreditation Conference Standards (2016) for the category  
 ENVIRONMENTAL ANALYSES POTABLE WATER  
 All approved analytes are listed below:*

<b>Bacteriology</b>	
Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Collert)
<b>Dissolved Gases</b>	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
<b>Fuel Additives</b>	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
<b>Metals I</b>	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Zinc, Total	EPA 200.7 Rev. 4.4

Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elapublicweb/>, by phone (518) 485-5570 or by email to [elap@health.ny.gov](mailto:elap@health.ny.gov).



Page 1 of 5