

January 6, 2026

Ms. Georgia Militello
Ken-Ton UFSD
1500 Colvin Boulevard
Buffalo, New York 14223

Re: Lead Testing in School Drinking Water

Dear Ms. Militello:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Ken-Ton UFSD, including:

- **Benjamin Franklin Middle School – 540 Parkhurst Blvd, Buffalo, NY**

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: Lead Testing in School Drinking Water, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on November 14, 2025 and November 15, 2025. As detailed in Section 1.2 (Executive Summary) of the accompanying report, based upon the sampling and analysis performed, 0 sources of potable water in Benjamin Franklin Middle School have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion.

Thank you for the opportunity to be of service to Ken-Ton UFSD.

Sincerely,
Stohl Environmental, LLC.



Michael Scinta
EPA Lead Risk Assessor

Lead Testing in School Drinking Water

Prepared for:

Ken-Ton UFSD

Prepared by:



Conditions as of November 14, 2025 and November 15, 2025

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports and Chain of Custody Documents
- 1.5. Laboratory Certifications

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Ken-Ton UFSD to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- **Benjamin Franklin Middle School – 540 Parkhurst Blvd, Buffalo, NY**

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within Benjamin Franklin Middle School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, **Subpart 67-4: Lead Testing in School Drinking Water**, and the EPA guidance document, **3Ts for Reducing Lead in Drinking Water in Schools**, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at Benjamin Franklin Middle School:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Benjamin Franklin Middle School	November 14, 2025 & November 15, 2025	64	64	0

**NYS Action Level is 5 parts per billion*

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

All the locations sampled were analyzed at less than the NYS Action Level of 5 ppb, therefore no further response action is required.

1.4 Laboratory Analytical Reports and Chain of Custody Documents



December 23, 2025

Service Request No:R2515820

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Kenton UFSD - Benjamin Franklin Middle School

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory November 21, 2025
For your reference, these analyses have been assigned our service request number **R2515820**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | **FAX** +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School
Sample Matrix: Drinking Water

Service Request: R2515820
Date Received: 11/21/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 11/21/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 12/23/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 102.3-16		Lab ID: R2515820-021				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3

Service Request:R2515820

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2515820-001	102.3-1A	11/14/2025	
R2515820-002	102.3-1B	11/14/2025	
R2515820-003	102.3-2	11/14/2025	
R2515820-004	102.3-3	11/14/2025	
R2515820-005	102.3-4A	11/14/2025	
R2515820-006	102.3-4B	11/14/2025	
R2515820-007	102.3-5A	11/14/2025	
R2515820-008	102.3-5B	11/14/2025	
R2515820-009	102.3-6	11/14/2025	
R2515820-010	102.3-7	11/14/2025	
R2515820-011	102.3-8	11/14/2025	
R2515820-012	102.3-9	11/14/2025	
R2515820-013	102.3-10A	11/14/2025	
R2515820-014	102.3-10B	11/14/2025	
R2515820-015	102.3-11	11/14/2025	
R2515820-016	102.3-12	11/14/2025	
R2515820-017	102.3-13	11/14/2025	
R2515820-018	102.3-14A	11/14/2025	
R2515820-019	102.3-14B	11/14/2025	
R2515820-020	102.3-15	11/14/2025	
R2515820-021	102.3-16	11/14/2025	
R2515820-022	102.3-17	11/14/2025	
R2515820-023	102.3-18	11/14/2025	
R2515820-024	102.3-19	11/14/2025	
R2515820-025	102.3-20	11/14/2025	
R2515820-026	102.3-21	11/14/2025	
R2515820-027	102.3-22A	11/14/2025	
R2515820-028	102.3-22B	11/14/2025	
R2515820-029	102.3-23	11/14/2025	
R2515820-030	102.3-24A	11/14/2025	
R2515820-031	102.3-24B	11/14/2025	
R2515820-032	102.3-25	11/14/2025	
R2515820-033	102.3-26A	11/14/2025	
R2515820-034	102.3-26B	11/14/2025	
R2515820-035	102.3-27A	11/14/2025	
R2515820-036	102.3-27B	11/14/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.3

Client: Kenton UFSD

Contact: Georgia Militello

Building: Benjamin Franklin Middle School

Location: 540 Parkhurst Blvd, Buffalo, NY 14223

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
102.3-1A	Cafeteria drinking fountain	Fountain	6:45
102.3-1B	Cafeteria drinking fountain BF	Bottle fill	6:46
102.3-2	Cafeteria Faculty Room Sink	Sink	6:48
102.3-3	Cafeteria Faculty Room Ice Machine	Ice Machine	6:49
102.3-4A	Hall near M175 - drinking fountain	DF	6:51
102.3-4B	Hall near M175 - Bottle Fill	DFB	6:52
102.3-5A	Boys locker room water fountain	DF	6:54
102.3-5B	Boys locker room water fountain - BF	DFB	6:56
102.3-6	Boys Locker Room Sink L	Sink	6:57
102.3-7	Boys Locker Room Sink R	Sink	6:59
102.3-8	Boy's Locker Room Coach Office	Sink	7:00
102.3-9	Single Restroom Across From Girls Locker	Sink	7:02
102.3-10A	Girls locker room water fountain	DF	7:04
102.3-10B	Girls Locker Room Water Fountain - BF	DFB	7:05
102.3-11	Girls Locker Room Sink L	Sink	7:07
102.3-12	Girls Locker Room Sink R	Sink	7:08
102.3-13	Girls Locker Room Coaches Office	Sink	7:10
102.3-14A	Drinking Fountain Across From rm183	DF	7:11

Notes:

Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to: Mscinta@stohlenvironmental.com

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 11/14/2025 + 11/15/2025

Relinquished By: _____ Print Name _____ Stohl Env: Connor Crilly Date: 11/19/2025


Received (Name / Lab): Tom M... ALS Date: 11/21/25 Time: 8:25

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____

QA/QC Review (Name / Lab): _____ Date: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____





Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.3

Client: Kenton UFSD

Contact: Georgia Militello

Building: Benjamin Franklin Middle School

Location: 540 Parkhurst Blvd, Buffalo, NY 14223

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
102.3-14B	Drinking Fountain Across From rm183 BF	DFB	7:13
102.3-15	Boy's Restroom Across from 183 L	Sink	7:15
102.3-16	Boy's Restroom Across from 183 R	Sink	7:16
102.3-17	Staff Only Restroom by Door 6 L	Sink	7:18
102.3-18	Staff Only Restroom by Door 6 R	Sink	7:19
102.3-19	Women's Staff Only Restroom L by Door 6	Sink	7:21
102.3-20	Women's Staff Only Restroom R b Door 6	Sink	7:23
102.3-21	Rm 191	Sink	7:24
102.3-22A	Drinking Fountain by 195	DF	7:26
102.3-22B	Drinking Fountain by 195 BF	DFB	7:27
102.3-23	Rm 193	Sink	7:29
102.3-24A	Hallway Near 194	DFB	7:05
102.3-24B	Hallway Near 292	DF	7:07
102.3-25	Office Kitchen	Sink	7:09
102.3-26A	Across From Assistant Prinicipal's Office	DFB	7:12
102.3-26B	Across From Assistant Principals Office	DF	7:14
102.3-27A	Water Fountain Across From 253	DFB	7:16
102.3-27B	Water Fountain Across From 253	DF	7:19

Notes:

Please e-mail lab results to labs@stohlenv.com

Mscinta@stohlenvironmental.com

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 11/14/2025 + 11/15/2025

Relinquished By: _____ Print Name _____ Stohl Env: Connor Crilly Date: 11/19/2025

Received (Name / Lab): Sam Reilly ALS Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Cooler Receipt and Preservation

R2515820 **5**
 Stohl Environmental
 Kenton UFSD - Benjamin Franklin Middle School

Project/Client Stohl Folder Number _____

Cooler received on 11/21/25 by: RM COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="radio"/> N <input type="radio"/>	5a	Did VOA vials have sig* bubbles?	Y N <input checked="" type="radio"/> NA
2	Custody papers properly completed (ink, signed)?	Y <input checked="" type="radio"/> N <input type="radio"/>	5b	Sig* bubbles: Alk? Y N <input checked="" type="radio"/> NA Sulfide? Y N <input checked="" type="radio"/> NA	
3	Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="radio"/> N <input type="radio"/>	6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="radio"/> N <input type="radio"/>	7	Soil VOA received as: Bulk Encore 5035set	<input checked="" type="radio"/> NA

8. Temperature Readings Date: 11/21/25 Time: 8:32 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>10.2</u>						
Within 0-6°C?	Y <input checked="" type="radio"/> N <input type="radio"/>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: No ice Ice melted Poorly Packed (described below) Same Day Rule
 & Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMO by RM on 11/21 at 8:32
 5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 11/26 Time: 1813 by: AG

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12	<u>252320</u>	NaOH								
≤2	<u>2407</u>	HNO ₃	<u>X</u>	<u>X</u>	<u>24017806</u>	<u>7/27</u>	<u>1-23</u>	<u>4mL</u>		<u>6.2</u>
≤2	<u>AG 11/26</u>	H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____
 Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AG *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3

Service Request: R2515820

Sample Name: 102.3-1A
Lab Code: R2515820-001
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-1B
Lab Code: R2515820-002
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-2
Lab Code: R2515820-003
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-3
Lab Code: R2515820-004
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-4A
Lab Code: R2515820-005
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3

Service Request: R2515820

Sample Name: 102.3-4B
Lab Code: R2515820-006
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-5A
Lab Code: R2515820-007
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-5B
Lab Code: R2515820-008
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-6
Lab Code: R2515820-009
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-7
Lab Code: R2515820-010
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3

Service Request: R2515820

Sample Name: 102.3-8
Lab Code: R2515820-011
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-9
Lab Code: R2515820-012
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-10A
Lab Code: R2515820-013
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-10B
Lab Code: R2515820-014
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-11
Lab Code: R2515820-015
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3

Service Request: R2515820

Sample Name: 102.3-12
Lab Code: R2515820-016
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-13
Lab Code: R2515820-017
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-14A
Lab Code: R2515820-018
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-14B
Lab Code: R2515820-019
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-15
Lab Code: R2515820-020
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3

Service Request: R2515820

Sample Name: 102.3-16
Lab Code: R2515820-021
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-17
Lab Code: R2515820-022
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-18
Lab Code: R2515820-023
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-19
Lab Code: R2515820-024
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-20
Lab Code: R2515820-025
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3

Service Request: R2515820

Sample Name: 102.3-21
Lab Code: R2515820-026
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-22A
Lab Code: R2515820-027
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-22B
Lab Code: R2515820-028
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-23
Lab Code: R2515820-029
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-24A
Lab Code: R2515820-030
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3

Service Request: R2515820

Sample Name: 102.3-24B
Lab Code: R2515820-031
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-25
Lab Code: R2515820-032
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-26A
Lab Code: R2515820-033
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-26B
Lab Code: R2515820-034
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.3-27A
Lab Code: R2515820-035
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/21/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental

Service Request: R2515820

Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3

Sample Name: 102.3-27B

Date Collected: 11/14/25

Lab Code: R2515820-036

Date Received: 11/21/25

Sample Matrix: Drinking Water

Analysis Method

Extracted/Digested By

Analyzed By

200.8

MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-1A
Lab Code: R2515820-001

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-1B
Lab Code: R2515820-002

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-2
Lab Code: R2515820-003

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-3
Lab Code: R2515820-004

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-4A
Lab Code: R2515820-005

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-4B
Lab Code: R2515820-006

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-5A
Lab Code: R2515820-007

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-5B
Lab Code: R2515820-008

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-6
Lab Code: R2515820-009

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-7
Lab Code: R2515820-010

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-8
Lab Code: R2515820-011

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-9
Lab Code: R2515820-012

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-10A
Lab Code: R2515820-013

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-10B
Lab Code: R2515820-014

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:56	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-11
Lab Code: R2515820-015

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-12
Lab Code: R2515820-016

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-13
Lab Code: R2515820-017

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:03	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-14A
Lab Code: R2515820-018

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-14B
Lab Code: R2515820-019

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:07	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-15
Lab Code: R2515820-020

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-16
Lab Code: R2515820-021

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	12/18/25 15:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-17
Lab Code: R2515820-022

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:24	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-18
Lab Code: R2515820-023

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-19
Lab Code: R2515820-024

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-20
Lab Code: R2515820-025

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-21
Lab Code: R2515820-026

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-22A
Lab Code: R2515820-027

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-22B
Lab Code: R2515820-028

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-23
Lab Code: R2515820-029

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-24A
Lab Code: R2515820-030

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-24B
Lab Code: R2515820-031

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-25
Lab Code: R2515820-032

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:42	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-26A
Lab Code: R2515820-033

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-26B
Lab Code: R2515820-034

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-27A
Lab Code: R2515820-035

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-27B
Lab Code: R2515820-036

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25 08:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:51	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515820-MB1

Service Request: R2515820
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 14:25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515820-MB2

Service Request: R2515820
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/18/25 15:14	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25
Date Analyzed: 12/18/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.3-14B
Lab Code: R2515820-019
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515820-019MS		Duplicate Matrix Spike R2515820-019DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	19.2	20.0	96	19.2	20.0	96	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water

Service Request: R2515820
Date Collected: 11/14/25
Date Received: 11/21/25
Date Analyzed: 12/18/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.3-15
Lab Code: R2515820-020
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515820-020MS		Duplicate Matrix Spike R2515820-020DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	20.1	20.0	101	20.4	20.0	102	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water

Service Request: R2515820

Date Analyzed: 12/18/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample
R2515820-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.5	20.0	98	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water

Service Request: R2515820
Date Analyzed: 12/18/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2515820-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.7	20.0	99	85-115



December 16, 2025

Service Request No:R2515821

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Kenton UFSD - Benjamin Franklin Middle School

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory November 26, 2025
For your reference, these analyses have been assigned our service request number **R2515821**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | **FAX** +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School
Sample Matrix: Drinking Water

Service Request: R2515821
Date Received: 11/26/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Twenty eight drinking water samples were received for analysis at ALS Environmental on 11/26/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 12/16/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 102.3-38	Lab ID: R2515821-020					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.0			1.0	ug/L	200.8

CLIENT ID: 102.3-39	Lab ID: R2515821-021					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.8			1.0	ug/L	200.8

CLIENT ID: 102.3-40	Lab ID: R2515821-022					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.0			1.0	ug/L	200.8

CLIENT ID: 102.3-41	Lab ID: R2515821-023					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.6			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3

Service Request:R2515821

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2515821-001	102.3-28A	11/14/2025	
R2515821-002	102.3-28B	11/14/2025	
R2515821-003	102.3-29A	11/14/2025	
R2515821-004	102.3-29B	11/14/2025	
R2515821-005	102.3-30A	11/14/2025	
R2515821-006	102.3-30B	11/14/2025	
R2515821-007	102.3-31A	11/14/2025	
R2515821-008	102.3-31B	11/14/2025	
R2515821-009	102.3-32A	11/14/2025	
R2515821-010	102.3-32B	11/14/2025	
R2515821-011	102.3-33A	11/14/2025	
R2515821-012	102.3-33B	11/14/2025	
R2515821-013	102.3-34A	11/14/2025	
R2515821-014	102.3-34B	11/14/2025	
R2515821-015	102.3-35A	11/14/2025	
R2515821-016	102.3-35B	11/14/2025	
R2515821-017	102.3-36A	11/14/2025	
R2515821-018	102.3-36B	11/14/2025	
R2515821-019	102.3-37	11/14/2025	
R2515821-020	102.3-38	11/14/2025	
R2515821-021	102.3-39	11/14/2025	
R2515821-022	102.3-40	11/14/2025	
R2515821-023	102.3-41	11/14/2025	
R2515821-024	102.3-42	11/14/2025	
R2515821-025	102.3-43	11/14/2025	
R2515821-026	102.3-44	11/14/2025	
R2515821-027	102.3-45	11/14/2025	
R2515821-028	102.3-46	11/14/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.3

Client: Kenton UFSD

Contact: Georgia Militello

Building: Benjamin Franklin Middle School

Location: 540 Parkhurst Blvd, Buffalo, NY 14223

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
102.3-28A	Hallway Near 258	DFB	7:21
102.3-28B	Water Fountain Near 258	DF	7:24
102.3-29A	Water Fountain Near 265	DF	7:26
102.3-29B	Water Fountain Near 265	DFB	7:29
102.3-30A	Hallway Near 276	DFB	7:31
102.3-30B	Water Fountain Near 276	DF	7:33
102.3-31A	Water Fountain Across From 283	DFB	7:36
102.3-31B	Water Fountain Across From 283	DF	7:38
102.3-32A	Across From 353	DFB	7:41
102.3-32B	Across From 353	DF	7:43
102.3-33A	Across From 358	DFB	7:45
102.3-33B	Across From 358	DF	7:48
102.3-34A	Next to 365	DFB	7:50
102.3-34B	Next to 365	DF	7:53
102.3-35A	Next to 375	DFB	7:55
102.3-35B	Next to 375	DF	7:58
102.3-36A	Across From 383	DFB	8:00
102.3-36B	Across From 383	DF	8:02

Notes: Please e-mail lab results to labs@stohlenv.com Mscinta@stohlenvironmental.com

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 11/14/2025 + 11/15/2025

Relinquished By: _____ Print Name _____ Stohl Env: Connor Crilly Date: 11/19/2025

Received (Name / Lab): Emma Nanni ALS Date: 11/21/25 Time: 8:25

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____

QA/QC Review (Name / Lab): _____ Date: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____

R2515821 5

Stohl Environmental
Kenton UFSD - Benjamin Franklin Middle School





Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.3

Client: Kenton UFSD

Contact: Georgia Militello

Building: Benjamin Franklin Middle School

Location: 540 Parkhurst Blvd, Buffalo, NY 14223

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
102.3-37	Rm 384 - North Wall	Sink	8:05
102.3-38	Rm 381 - West Wall, Left Sink	Sink	8:07
102.3-39	Rm 381 - West Wall, Right Sink	Sink	8:10
102.3-40	Rm 381 - Center of Room, East Wall	Sink	8:12
102.3-41	Rm 381 - Center of Room, West Wall	Sink	8:14
102.3-42	Rm 375 - West Wall, Left Sink	Sink	8:17
102.3-43	Rm 375 - West Wall, Right Sink	Sink	8:19
102.3-44	Rm 375 - Center of Room, West Wall	Sink	8:22
102.3-45	Rm 375 Next to Entrance	Sink	8:24
102.3-46	Teachers Lounge	Sink	8:27

Notes: Please e-mail lab results to labs@stohlenvironmental.com Mscinta@stohlenvironmental.com

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 11/14/2025 + 11/15/2025

Relinquished By: _____ Print Name _____ Stohl Env: Connor Crilly Date: 11/19/2025

Received (Name / Lab): SMC ALS Date: 11/21/25 Time: 8:25

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



R2515821 **5**
 Stohl Environmental
 Kenton UFSD - Benjamin Franklin Middle School

Cooler Receipt and Preservation Check

Project/Client Stohl Folder Number _____

Cooler received on 11/21/25 by: RM COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>(N)</u>	5a	Did VOA vials have sig* bubbles?	Y N <u>(NA)</u>
2	Custody papers properly completed (ink, signed)?	<u>(Y)</u> N	5b	Sig* bubbles: Alk? Y N <u>(NA)</u> Sulfide? Y N <u>(NA)</u>	
3	Did all bottles arrive in good condition (unbroken)?	<u>(Y)</u> N	6	Where did the bottles originate?	<u>(ALS/ROC)</u> CLIENT
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>(N)</u>	7	Soil VOA received as: Bulk Encore 5035set	<u>(NA)</u>

8. Temperature Readings Date: 11/21/25 Time: 8:32 ID: (IR#12) IR#11 From: Temp Blank (Sample Bottle)

Temp (°C)	<u>10.2</u>						
Within 0-6°C?	<u>(Y)</u> N	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: No ice Ice melted Poorly Packed (described below) Same Day Rule
 & Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMO by RM on 11/21 at 8:32
 5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 11/26 Time: 1800 by: AG

- Were all bottle labels complete (i.e. analysis, preservation, etc.)? (YES) NO
- Did all bottle labels and tags agree with custody papers? (YES) NO
- Were correct containers used for the tests indicated? (YES) NO
- Were 5035 vials acceptable (no extra labels, not leaking)? YES NO (N/A)
- Were dissolved metals filtered in the field? YES NO (N/A)
- Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated (N/A)

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>202225</u>	HNO ₃	<u>(X)</u>		<u>24017806</u>	<u>7127</u>				
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____
 Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: (X) *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3

Service Request: R2515821

Sample Name: 102.3-28A
Lab Code: R2515821-001
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.3-28B
Lab Code: R2515821-002
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.3-29A
Lab Code: R2515821-003
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.3-29B
Lab Code: R2515821-004
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.3-30A
Lab Code: R2515821-005
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3

Service Request: R2515821

Sample Name: 102.3-30B
Lab Code: R2515821-006
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.3-31A
Lab Code: R2515821-007
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.3-31B
Lab Code: R2515821-008
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.3-32A
Lab Code: R2515821-009
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.3-32B
Lab Code: R2515821-010
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3

Service Request: R2515821

Sample Name: 102.3-33A
Lab Code: R2515821-011
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.3-33B
Lab Code: R2515821-012
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.3-34A
Lab Code: R2515821-013
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.3-34B
Lab Code: R2515821-014
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.3-35A
Lab Code: R2515821-015
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3

Service Request: R2515821

Sample Name: 102.3-35B
Lab Code: R2515821-016
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.3-36A
Lab Code: R2515821-017
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.3-36B
Lab Code: R2515821-018
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.3-37
Lab Code: R2515821-019
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.3-38
Lab Code: R2515821-020
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3

Service Request: R2515821

Sample Name: 102.3-39
Lab Code: R2515821-021
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.3-40
Lab Code: R2515821-022
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.3-41
Lab Code: R2515821-023
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.3-42
Lab Code: R2515821-024
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.3-43
Lab Code: R2515821-025
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3

Service Request: R2515821

Sample Name: 102.3-44
Lab Code: R2515821-026
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By
GCONSTANTINO

Analyzed By
DWINTER

Sample Name: 102.3-45
Lab Code: R2515821-027
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.3-46
Lab Code: R2515821-028
Sample Matrix: Drinking Water

Date Collected: 11/14/25
Date Received: 11/26/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-28A
Lab Code: R2515821-001

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 14:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-28B
Lab Code: R2515821-002

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 15:03	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-29A
Lab Code: R2515821-003

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 15:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-29B
Lab Code: R2515821-004

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 15:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-30A
Lab Code: R2515821-005

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 15:07	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-30B
Lab Code: R2515821-006

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 15:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-31A
Lab Code: R2515821-007

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 15:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-31B
Lab Code: R2515821-008

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 15:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-32A
Lab Code: R2515821-009

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 15:25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-32B
Lab Code: R2515821-010

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 15:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-33A
Lab Code: R2515821-011

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 15:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-33B
Lab Code: R2515821-012

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 15:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-34A
Lab Code: R2515821-013

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 15:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-34B
Lab Code: R2515821-014

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 15:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-35A
Lab Code: R2515821-015

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 15:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-35B
Lab Code: R2515821-016

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 15:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-36A
Lab Code: R2515821-017

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 15:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-36B
Lab Code: R2515821-018

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 15:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-37
Lab Code: R2515821-019

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 15:42	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-38
Lab Code: R2515821-020

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0	ug/L	1.0	1	12/12/25 15:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-39
Lab Code: R2515821-021

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.8	ug/L	1.0	1	12/12/25 15:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-40
Lab Code: R2515821-022

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.0	ug/L	1.0	1	12/12/25 15:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-41
Lab Code: R2515821-023

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.6	ug/L	1.0	1	12/12/25 15:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-42
Lab Code: R2515821-024

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 15:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-43
Lab Code: R2515821-025

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 15:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-44
Lab Code: R2515821-026

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	ND U	ug/L	0.50	1	12/10/25 14:22	12/09/25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-45
Lab Code: R2515821-027

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 16:03	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: 102.3-46
Lab Code: R2515821-028

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25 10:11
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 16:07	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515821-MB1

Service Request: R2515821
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	ND U	ug/L	0.50	1	12/10/25 14:18	12/09/25	
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 14:29	NA	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515821-MB2

Service Request: R2515821
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 15:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2515821-MB3

Service Request: R2515821
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/12/25 16:00	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25
Date Analyzed: 12/12/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.3-30A
Lab Code: R2515821-005
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515821-005MS		Duplicate Matrix Spike R2515821-005DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	20.5	20.0	102	21.2	20.0	106	70-130	3	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25
Date Analyzed: 12/12/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.3-30B
Lab Code: R2515821-006
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515821-006MS		Result	Duplicate Matrix Spike R2515821-006DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	21.0	20.0	105	18.9	20.0	95	70-130	10	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25
Date Analyzed: 12/12/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.3-43
Lab Code: R2515821-025
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515821-025MS		Duplicate Matrix Spike R2515821-025DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	21.8	20.0	109	20.6	20.0	103	70-130	6	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water

Service Request: R2515821
Date Collected: 11/14/25
Date Received: 11/26/25
Date Analyzed: 12/12/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.3-45
Lab Code: R2515821-027
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2515821-027MS		Duplicate Matrix Spike R2515821-027DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	20.2	20.0	101	21.5	20.0	107	70-130	6	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water

Service Request: R2515821
Date Analyzed: 12/10/25 - 12/12/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2515821-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.5	20.0	107	85-115
Lead, Total	200.8	22.1	20.0	110	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water

Service Request: R2515821
Date Analyzed: 12/12/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2515821-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.5	20.0	108	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Kenton UFSD - Benjamin Franklin Middle School/2023L-102.3
Sample Matrix: Drinking Water

Service Request: R2515821

Date Analyzed: 12/12/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample
R2515821-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.8	20.0	104	85-115

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
 WADSWORTH CENTER



Expires 12:01 AM April 01, 2026
 Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE
Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. CHRISTINE KUTZER
ALS ENVIRONMENTAL - ROCHESTER
 1565 JEFFERSON ROAD BUILDING 300, SUITE 360
 ROCHESTER, NY 14623

NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the
 National Environmental Laboratory Accreditation Conference Standards (2016) for the category
 ENVIRONMENTAL ANALYSES POTABLE WATER
 All approved analytes are listed below:*

Bacteriology	
Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Collert)
Dissolved Gases	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
Fuel Additives	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
Metals I	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Zinc, Total	EPA 200.7 Rev. 4.4

Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elapublicweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.

Page 1 of 5

