

January 6, 2026

Ms. Georgia Militello
Ken-Ton UFSD
1500 Colvin Boulevard
Buffalo, New York 14223

Re: Lead Testing in School Drinking Water

Dear Ms. Militello:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Ken-Ton UFSD, including:

- **Kenmore Junior/Senior High School – 155 Delaware Road, Kenmore, NY**

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: Lead Testing in School Drinking Water, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on December 3, 2025. As detailed in Section 1.2 (Executive Summary) of the accompanying report, based upon the sampling and analysis performed, 24 sources of potable water in Kenmore Junior/Senior High School have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion. To comply with NYS regulations, response actions by the district are required. Response actions are outlined in Section 1.3 (Response Actions Required Under NYS Regulations).

Thank you for the opportunity to be of service to Ken-Ton UFSD.

Sincerely,
Stohl Environmental, LLC.



Michael Scinta
EPA Lead Risk Assessor

Lead Testing in School Drinking Water

Prepared for:

Ken-Ton UFSD

Prepared by:



**3860 California Road
Orchard Park, New York 14127**

Conditions as of December 3, 2025

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports and Chain of Custody Documents
- 1.5. Laboratory Certifications

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Ken-Ton UFSD to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- **Kenmore Junior/Senior High School – 155 Delaware Road, Kenmore, NY**

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within Kenmore Junior/Senior High School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, **Subpart 67-4: Lead Testing in School Drinking Water**, and the EPA guidance document, **3Ts for Reducing Lead in Drinking Water in Schools**, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at Kenmore Junior/Senior High School:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Kenmore Jr./Sr. High School	December 3, 2025	62	38	24

*NYS Action Level is 5 parts per billion

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
102.11-01	Hand Wash Sink	Sink	34.7
102.11-04	Dish Line Sink 1	Sink	9.3
102.11-05	Dish Line Sink 2	Sink	7.5
102.11-07	Dish Room Sink 2	Sink	8.3
102.11-11	Room 317 Sink	Sink	14.4
102.11-13	Room 315 Sink	Sink	5.4
102.11-15	Room 301 Sink	Sink	37.1
102.11-17	Room 335 Sink	Sink	36.6
102.11-19	Room 333 Sink	Sink	8.5
102.11-20	Room 332 Sink	Sink	5.5
102.11-22	Room 330 Sink	Sink	373
102.11-23	Room 329 Sink	Sink	115
102.11-26	Room 216 Sink	Sink	9.3
102.11-27	Room 213 Sink	Sink	31.1
102.11-28	Room 212 Sink	Sink	8.5
102.11-30	Fitness Center Sink	Sink	26.7
102.11-32	Room 207 Bathroom Sink	Sink	28.6
102.11-34	Room 233 Library Media Center Sink	Sink	9.0
102.11-36	Room 224 Bathroom Sink	Sink	9.1
102.11-39	Room 111A Sink	Sink	34.8
102.11-40	Room 110 Sink	Sink	9.5

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
102.11-42	Room 108 Sink	Sink	7.9
102.11-45	Room 123 Sink	Sink	31.8
102.11-48B	DFB Next to Room 113R	DFB	11.8

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration more than the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports and Chain of Custody Documents



December 30, 2025

Service Request No:R2516332

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Ken-Ton UFSD Jr/Sr HS

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory December 04, 2025
For your reference, these analyses have been assigned our service request number **R2516332**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | **FAX** +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS
Sample Matrix: Drinking Water

Service Request: R2516332
Date Received: 12/04/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 12/04/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

Method 200.8, 12/23/2025: The upper control criterion was exceeded for one or more analytes in the Laboratory Control Sample (LCS). There were no detections of the analyte(s) above the MRL in the associated field samples. The error associated with elevated recovery equates to a high bias. The sample data is not significantly affected. No further corrective action was appropriate.

Approved by _____

Date 12/30/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 102.11-01		Lab ID: R2516332-001					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	34.7			1.0	ug/L	200.8	
CLIENT ID: 102.11-02		Lab ID: R2516332-002					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.3			1.0	ug/L	200.8	
CLIENT ID: 102.11-03		Lab ID: R2516332-003					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.4			1.0	ug/L	200.8	
CLIENT ID: 102.11-04		Lab ID: R2516332-004					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	9.3			1.0	ug/L	200.8	
CLIENT ID: 102.11-05		Lab ID: R2516332-005					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	7.5			1.0	ug/L	200.8	
CLIENT ID: 102.11-06		Lab ID: R2516332-006					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.7			1.0	ug/L	200.8	
CLIENT ID: 102.11-07		Lab ID: R2516332-007					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	8.3			1.0	ug/L	200.8	
CLIENT ID: 102.11-08		Lab ID: R2516332-008					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.5			1.0	ug/L	200.8	
CLIENT ID: 102.11-09		Lab ID: R2516332-009					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.3			1.0	ug/L	200.8	
CLIENT ID: 102.11-10		Lab ID: R2516332-010					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.8			1.0	ug/L	200.8	
CLIENT ID: 102.11-11		Lab ID: R2516332-011					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	14.4			1.0	ug/L	200.8	
CLIENT ID: 102.11-12		Lab ID: R2516332-012					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.3			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 102.11-13		Lab ID: R2516332-013					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.4			1.0	ug/L	200.8	
CLIENT ID: 102.11-15		Lab ID: R2516332-016					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	37.1			1.0	ug/L	200.8	
CLIENT ID: 102.11-17		Lab ID: R2516332-019					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	36.6			1.0	ug/L	200.8	
CLIENT ID: 102.11-18		Lab ID: R2516332-020					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.0			1.0	ug/L	200.8	
CLIENT ID: 102.11-19		Lab ID: R2516332-021					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	8.5			1.0	ug/L	200.8	
CLIENT ID: 102.11-20		Lab ID: R2516332-022					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.5			1.0	ug/L	200.8	
CLIENT ID: 102.11-22		Lab ID: R2516332-025					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	373			20	ug/L	200.8	
CLIENT ID: 102.11-23		Lab ID: R2516332-026					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	115			1.0	ug/L	200.8	
CLIENT ID: 102.11-24		Lab ID: R2516332-027					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.6			1.0	ug/L	200.8	
CLIENT ID: 102.11-26		Lab ID: R2516332-030					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	9.3			1.0	ug/L	200.8	
CLIENT ID: 102.11-27		Lab ID: R2516332-031					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	31.1			1.0	ug/L	200.8	
CLIENT ID: 102.11-28		Lab ID: R2516332-032					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	8.5			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 102.11-30		Lab ID: R2516332-035				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	26.7			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211

Service Request:R2516332

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2516332-001	102.11-01	12/3/2025	
R2516332-002	102.11-02	12/3/2025	
R2516332-003	102.11-03	12/3/2025	
R2516332-004	102.11-04	12/3/2025	
R2516332-005	102.11-05	12/3/2025	
R2516332-006	102.11-06	12/3/2025	
R2516332-007	102.11-07	12/3/2025	
R2516332-008	102.11-08	12/3/2025	
R2516332-009	102.11-09	12/3/2025	
R2516332-010	102.11-10	12/3/2025	
R2516332-011	102.11-11	12/3/2025	
R2516332-012	102.11-12	12/3/2025	
R2516332-013	102.11-13	12/3/2025	
R2516332-014	102.11-14A	12/3/2025	
R2516332-015	102.11-14B	12/3/2025	
R2516332-016	102.11-15	12/3/2025	
R2516332-017	102.11-16A	12/3/2025	
R2516332-018	102.11-16B	12/3/2025	
R2516332-019	102.11-17	12/3/2025	
R2516332-020	102.11-18	12/3/2025	
R2516332-021	102.11-19	12/3/2025	
R2516332-022	102.11-20	12/3/2025	
R2516332-023	102.11-21A	12/3/2025	
R2516332-024	102.11-21B	12/3/2025	
R2516332-025	102.11-22	12/3/2025	
R2516332-026	102.11-23	12/3/2025	
R2516332-027	102.11-24	12/3/2025	
R2516332-028	102.11-25A	12/3/2025	
R2516332-029	102.11-25B	12/3/2025	
R2516332-030	102.11-26	12/3/2025	
R2516332-031	102.11-27	12/3/2025	
R2516332-032	102.11-28	12/3/2025	
R2516332-033	102.11-29A	12/3/2025	
R2516332-034	102.11-29B	12/3/2025	
R2516332-035	102.11-30	12/3/2025	
R2516332-036	102.11-31A	12/3/2025	

Stohl ENVIRONMENTAL

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.11

Client: Ken-Ton UFSD

Contact: Georgia Militello

Building: Kenmore Jr/Sr HS

Location: 155 Delaware Rd., Kenmore, NY

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
102.11-01	Hand Wash Sink	Sink	5:10
102.11-02	Island Sink	Sink	5:11
102.11-03	Back Left Corner Sink	Sink	5:12
102.11-04	Dish Line Sink 1	Sink	5:13
102.11-05	Dish Line Sink 2	Sink	5:15
102.11-06	Dish Room Sink 1	Sink	5:16
102.11-07	Dish Room Sink 2	Sink	5:17
102.11-08	Dish Room Sprayer	Sprayer	5:19
102.11-09	Custodial Office Sink	Sink	5:20
102.11-10	Custodial Office Bathroom Sink	Sink	5:21
102.11-11	Room 317 Sink	Sink	5:23
102.11-12	Room 316 Sink	Sink	5:24
102.11-13	Room 315 Sink	Sink	5:25
102.11-14A	Next to Room 311 DF	DF	5:27
102.11-14B	Next to Room 311 DFB	DFB	5:28
102.11-15	Room 301 Sink	Sink	5:29
102.11-16A	Next to Room 336 DF	DF	5:31
102.11-16B	Next to Room 336 DFB	DFB	5:32

Notes: Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to: mscinta@stohlenvironmental.com

Sampled By: A. Dellinger Print Name A. Dellinger Stohl Env: A. Dellinger Date: 12/3/2025
 Relinquished By: [Signature] Print Name Connor Crilly Stohl Env: Connor Crilly Date: 12/14/25
 Received (Name / Lab): [Signature] Date: 12/14/25 Time: 1700
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

R2516332 **5**
 Stohl Environmental
 Ken-Ton UFSD Jr/Sr HS




Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.11

Client: Ken-Ton UFSD

Contact: Georgia Militello

Building: Kenmore Jr/Sr HS

Location: 155 Delaware Rd., Kenmore, NY

LEAD

Water by 200.8 X

Turnaround

10 Days


Sample #	Location	Outlet Type	Time
102.11-17	Room 335 Sink	Sink	5:33
102.11-18	Room 334 Sink	Sink	5:35
102.11-19	Room 333 Sink	Sink	5:36
102.11-20	Room 332 Sink	Sink	5:37
102.11-21A	Next to Room 332 DF	DF	5:38
102.11-21B	Next to Room 332 DFB	DFB	5:40
102.11-22	Room 330 Sink	Sink	5:41
102.11-23	Room 329 Sink	Sink	5:42
102.11-24	Room 327 Sink	Sink	5:44
102.11-25A	Next to Door 5 DF	DF	5:45
102.11-25B	Next to Door 5 DFB	DFB	5:46
102.11-26	Room 216 Sink	Sink	5:48
102.11-27	Room 213 Sink	Sink	5:49
102.11-28	Room 212 Sink	Sink	5:50
102.11-29A	Next to Door 8 DF	DF	5:52
102.11-29B	Next to Door 8 DFB	DFB	5:53
102.11-30	Fitness Center Sink	Sink	5:54
102.11-31A	Fitness Center DF	DF	5:56


Notes:

Please e-mail lab results to labs@stohlenv.com

mscinta@stohlenvironmental.com

Sampled By: A. Dellinger Print Name Stohl Env: A. Dellinger Date: 12/3/2025

Relinquished By:  Print Name Stohl Env: Connor Crilly Date: 12/4/25 *5 pm*

Received (Name / Lab):  Date: 12/4/25 Time: 1700

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



R2516332 5

Stahl Environmental
Ken-Ton UFSD Jr/Sr HS



Cooler Receipt and Preservation

Project/Client Stohl

Folder Number _____

Cooler received on 12/4/25 by: RDA

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
2	Custody papers properly completed (ink, signed)?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
3	Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>

5a	Did VOA vials have sig* bubbles?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
5b	Sig* bubbles: Alk?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
	Sulfide?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as:	Bulk Encore 5035set <u>NA</u>

8. Temperature Readings Date: 12/4/25 Time: 1712 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>14.5</u>						
Within 0-6°C?	Y <input checked="" type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>
If <0°C, were samples frozen?	Y <input type="checkbox"/> N <input type="checkbox"/>						

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMU by RDA on 12/4/25 at 1713
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 12/9/25 Time: 8:49 by: RM

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A
- 14. Air Samples: Cassettes / Tubes Intact Y/N with MS Y/N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>202325</u>	HNO ₃	<input checked="" type="checkbox"/>		<u>24017806</u>	<u>1/27</u>				
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 072125-2EKJ

Explain all Discrepancies/ Other Comments:

10) only sample ID on bottles

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: RM

*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- | | |
|---|--|
| <p>U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.</p> <p>J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).</p> <p>B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.</p> <p>E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.</p> <p>E Organics- Concentration has exceeded the calibration range for that specific analysis.</p> <p>D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.</p> <p>* Indicates that a quality control parameter has exceeded laboratory limits. Under the “Notes” column of the Form I, this qualifier denotes analysis was performed out of Holding Time.</p> <p>H Analysis was performed out of hold time for tests that have an “immediate” hold time criteria.</p> <p># Spike was diluted out.</p> | <p>+ Correlation coefficient for MSA is <0.995.</p> <p>N Inorganics- Matrix spike recovery was outside laboratory limits.</p> <p>N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.</p> <p>S Concentration has been determined using Method of Standard Additions (MSA).</p> <p>W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.</p> <p>P Concentration >40% difference between the two GC columns.</p> <p>C Confirmed by GC/MS</p> <p>Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).</p> <p>X See Case Narrative for discussion.</p> <p>MRL Method Reporting Limit. Also known as:</p> <p>LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.</p> <p>MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).</p> <p>LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.</p> <p>ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.</p> |
|---|--|

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory’s NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211

Service Request: R2516332

Sample Name: 102.11-01
Lab Code: R2516332-001
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 102.11-02
Lab Code: R2516332-002
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 102.11-03
Lab Code: R2516332-003
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 102.11-04
Lab Code: R2516332-004
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 102.11-05
Lab Code: R2516332-005
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211

Service Request: R2516332

Sample Name: 102.11-06
Lab Code: R2516332-006
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 102.11-07
Lab Code: R2516332-007
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 102.11-08
Lab Code: R2516332-008
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 102.11-09
Lab Code: R2516332-009
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 102.11-10
Lab Code: R2516332-010
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211

Service Request: R2516332

Sample Name: 102.11-11
Lab Code: R2516332-011
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 102.11-12
Lab Code: R2516332-012
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 102.11-13
Lab Code: R2516332-013
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 102.11-14A
Lab Code: R2516332-014
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-14B
Lab Code: R2516332-015
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211

Service Request: R2516332

Sample Name: 102.11-15
Lab Code: R2516332-016
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 102.11-16A
Lab Code: R2516332-017
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-16B
Lab Code: R2516332-018
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-17
Lab Code: R2516332-019
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-18
Lab Code: R2516332-020
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211

Service Request: R2516332

Sample Name: 102.11-19
Lab Code: R2516332-021
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-20
Lab Code: R2516332-022
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-21A
Lab Code: R2516332-023
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-21B
Lab Code: R2516332-024
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-22
Lab Code: R2516332-025
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211

Service Request: R2516332

Sample Name: 102.11-23
Lab Code: R2516332-026
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-24
Lab Code: R2516332-027
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-25A
Lab Code: R2516332-028
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-25B
Lab Code: R2516332-029
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-26
Lab Code: R2516332-030
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211

Service Request: R2516332

Sample Name: 102.11-27
Lab Code: R2516332-031
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-28
Lab Code: R2516332-032
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-29A
Lab Code: R2516332-033
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-29B
Lab Code: R2516332-034
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-30
Lab Code: R2516332-035
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211

Service Request: R2516332

Sample Name: 102.11-31A
Lab Code: R2516332-036
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-01
Lab Code: R2516332-001

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	34.7	ug/L	1.0	1	12/24/25 13:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-02
Lab Code: R2516332-002

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	12/24/25 13:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-03
Lab Code: R2516332-003

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.4	ug/L	1.0	1	12/24/25 13:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-04
Lab Code: R2516332-004

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	9.3	ug/L	1.0	1	12/24/25 13:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-05
Lab Code: R2516332-005

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.5	ug/L	1.0	1	12/24/25 13:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-06
Lab Code: R2516332-006

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.7	ug/L	1.0	1	12/24/25 13:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-07
Lab Code: R2516332-007

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.3	ug/L	1.0	1	12/24/25 13:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-08
Lab Code: R2516332-008

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.5	ug/L	1.0	1	12/24/25 13:38	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-09
Lab Code: R2516332-009

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.3	ug/L	1.0	1	12/24/25 13:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-10
Lab Code: R2516332-010

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.8	ug/L	1.0	1	12/24/25 13:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-11
Lab Code: R2516332-011

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	14.4	ug/L	1.0	1	12/24/25 13:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-12
Lab Code: R2516332-012

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.3	ug/L	1.0	1	12/24/25 13:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-13
Lab Code: R2516332-013

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.4	ug/L	1.0	1	12/24/25 13:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-14A
Lab Code: R2516332-014

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/23/25 19:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-14B
Lab Code: R2516332-015

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/23/25 19:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-15
Lab Code: R2516332-016

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	37.1	ug/L	1.0	1	12/24/25 13:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-16A
Lab Code: R2516332-017

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/23/25 19:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-16B
Lab Code: R2516332-018

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/23/25 19:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-17
Lab Code: R2516332-019

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	36.6	ug/L	1.0	1	12/23/25 19:24	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-18
Lab Code: R2516332-020

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.0	ug/L	1.0	1	12/23/25 19:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-19
Lab Code: R2516332-021

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.5	ug/L	1.0	1	12/23/25 19:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-20
Lab Code: R2516332-022

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.5	ug/L	1.0	1	12/23/25 19:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-21A
Lab Code: R2516332-023

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/23/25 19:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-21B
Lab Code: R2516332-024

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/23/25 19:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-22
Lab Code: R2516332-025

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	373	ug/L	20	20	12/24/25 13:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-23
Lab Code: R2516332-026

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	115	ug/L	1.0	1	12/23/25 19:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-24
Lab Code: R2516332-027

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	12/23/25 19:42	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-25A
Lab Code: R2516332-028

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/23/25 19:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-25B
Lab Code: R2516332-029

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/23/25 19:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-26
Lab Code: R2516332-030

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	9.3	ug/L	1.0	1	12/23/25 19:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-27
Lab Code: R2516332-031

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	31.1	ug/L	1.0	1	12/23/25 19:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-28
Lab Code: R2516332-032

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.5	ug/L	1.0	1	12/23/25 19:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-29A
Lab Code: R2516332-033

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/23/25 19:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-29B
Lab Code: R2516332-034

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/23/25 19:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-30
Lab Code: R2516332-035

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	26.7	ug/L	1.0	1	12/23/25 19:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: 102.11-31A
Lab Code: R2516332-036

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/23/25 19:59	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516332-MB1

Service Request: R2516332
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/23/25 18:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516332-MB2

Service Request: R2516332
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/23/25 19:21	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516332-MB3

Service Request: R2516332
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/24/25 12:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516332-MB4

Service Request: R2516332
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/24/25 13:26	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25
Date Analyzed: 12/24/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.11-02
Lab Code: R2516332-002
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516332-002MS		Duplicate Matrix Spike R2516332-002DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	1.3	23.1	20.0	109	22.0	20.0	104	70-130	5	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25
Date Analyzed: 12/24/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.11-03
Lab Code: R2516332-003
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516332-003MS		Duplicate Matrix Spike R2516332-003DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	2.4	23.8	20.0	107	24.5	20.0	111	70-130	3	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25
Date Analyzed: 12/23/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.11-16B
Lab Code: R2516332-018
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516332-018MS		Duplicate Matrix Spike R2516332-018DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	22.2	20.0	111	22.2	20.0	111	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water

Service Request: R2516332
Date Collected: 12/03/25
Date Received: 12/04/25
Date Analyzed: 12/23/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.11-17
Lab Code: R2516332-019
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516332-019MS		Result	Duplicate Matrix Spike R2516332-019DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	36.6	60.9	20.0	121	60.1	20.0	117	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water

Service Request: R2516332
Date Analyzed: 12/23/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516332-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	23.2	20.0	116 *	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water

Service Request: R2516332
Date Analyzed: 12/23/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516332-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.5	20.0	112	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water

Service Request: R2516332
Date Analyzed: 12/24/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516332-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.9	20.0	110	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-10211
Sample Matrix: Drinking Water

Service Request: R2516332
Date Analyzed: 12/24/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516332-LCS4

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.4	20.0	112	85-115



January 05, 2026

Service Request No:R2516333

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Ken-Ton UFSD Jr/Sr HS

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory December 04, 2025
For your reference, these analyses have been assigned our service request number **R2516333**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | **FAX** +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 102.11-32		Lab ID: R2516333-002				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	28.6			1.0	ug/L	200.8

CLIENT ID: 102.11-34		Lab ID: R2516333-005				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	9.0			1.0	ug/L	200.8

CLIENT ID: 102.11-36		Lab ID: R2516333-008				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	9.1			1.0	ug/L	200.8

CLIENT ID: 102.11-37		Lab ID: R2516333-009				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.8			1.0	ug/L	200.8

CLIENT ID: 102.11-39		Lab ID: R2516333-012				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	34.8			1.0	ug/L	200.8

CLIENT ID: 102.11-40		Lab ID: R2516333-013				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	9.5			1.0	ug/L	200.8

CLIENT ID: 102.11-42		Lab ID: R2516333-016				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	7.9			1.0	ug/L	200.8

CLIENT ID: 102.11-45		Lab ID: R2516333-021				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	31.8			1.0	ug/L	200.8

CLIENT ID: 102.11-48B		Lab ID: R2516333-025				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	11.8			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11

Service Request:R2516333

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2516333-001	102.11-31B	12/3/2025	
R2516333-002	102.11-32	12/3/2025	
R2516333-003	102.11-33A	12/3/2025	
R2516333-004	102.11-33B	12/3/2025	
R2516333-005	102.11-34	12/3/2025	
R2516333-006	102.11-35A	12/3/2025	
R2516333-007	102.11-35B	12/3/2025	
R2516333-008	102.11-36	12/3/2025	
R2516333-009	102.11-37	12/3/2025	
R2516333-010	102.11-38A	12/3/2025	
R2516333-011	102.11-38B	12/3/2025	
R2516333-012	102.11-39	12/3/2025	
R2516333-013	102.11-40	12/3/2025	
R2516333-014	102.11-41A	12/3/2025	
R2516333-015	102.11-41B	12/3/2025	
R2516333-016	102.11-42	12/3/2025	
R2516333-017	102.11-43A	12/3/2025	
R2516333-018	102.11-43B	12/3/2025	
R2516333-019	102.11-44A	12/3/2025	
R2516333-020	102.11-44B	12/3/2025	
R2516333-021	102.11-45	12/3/2025	
R2516333-022	102.11-46	12/3/2025	
R2516333-023	102.11-47	12/3/2025	
R2516333-024	102.11-48A	12/3/2025	
R2516333-025	102.11-48B	12/3/2025	
R2516333-026	102.11-49	12/3/2025	

Stohl ENVIRONMENTAL

Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.11

Client: Ken-Ton UFSD

Contact: Georgia Militello

Building: Kenmore Jr/Sr HS

Location: 155 Delaware Rd., Kenmore, NY

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
102.11-31B	Fitness Center DFB	DFB	5:57
102.11-32	Room 207 Bathroom Sink	Sink	5:58
102.11-33A	DF Near Door 10	DF	6:00
102.11-33B	DFB Near Door 10	DFB	6:01
102.11-34	Room 233 Library Media Center Sink	Sink	6:02
102.11-35A	DF Across from Room 232	DF	6:03
102.11-35B	DFB Across from Room 232	DFB	6:05
102.11-36	Room 224 Bathroom Sink	Sink	6:06
102.11-37	Room 219 Sink	Sink	6:07
102.11-38A	DF Near Door 5 Second Floor	DF	6:09
102.11-38B	DFB Near Door 5 Second floor	DFB	6:10
102.11-39	Room 111A Sink	Sink	6:11
102.11-40	Room 110 Sink	Sink	6:13
102.11-41A	DF Near Room 109	DF	6:14
102.11-41B	DFB Near Room 109	DFB	6:15
102.11-42	Room 108 Sink	Sink	6:17
102.11-43A	DF Across From Room 127B	DF	6:18
102.11-43B	DFB Across From Room 127B	DFB	6:19

Notes:

Please e-mail lab results to labs@stohlenv.com

msscinta@stohlenvironmental.com

Sampled By: A. Dellinger Print Name Stohl Env: A. Dellinger Date: 12/3/2025
 Relinquished By: [Signature] Print Name Stohl Env: Connor Crilly Date: 12/4/25 5pm
 Received (Name / Lab): [Signature] Date: 12/4/25 Time: 1700
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____





R2516333

5

Stohl Environmental
Ken-Ton UFSD Jr/Sr HS

Cooler Receipt and Preservation



Project/Client Stohl

Folder Number _____

Cooler received on 12/4/25 by: RDA

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
2	Custody papers properly completed (ink, signed)?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>
3	Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>

5a	Did VOA vials have sig* bubbles?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
5b	Sig* bubbles: Alk?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
	Sulfide?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as:	Bulk Encore 5035set <u>NA</u>

8. Temperature Readings Date: 12/4/25 Time: 1712 ID: IR#12 IR#12 From: Temp Blank Sample Bottle

Temp (°C)	<u>14.5</u>						
Within 0-6°C?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>					
If <0°C, were samples frozen?	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMU by RDA on 12/4/25 at 1713
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 12/9/25 Time: 9:08 by: RM

- Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- Did all bottle labels and tags agree with custody papers? YES NO
- Were correct containers used for the tests indicated? YES NO
- Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- Were dissolved metals filtered in the field? YES NO N/A
- Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
<2	<u>202325</u>	HNO ₃	✓		<u>24017806</u>	<u>1/27</u>				
<2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 080425-2EKT, 072125-2EKT
Explain all Discrepancies/ Other Comments:

10) Only date time sample ID on bottles
RM

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: RM

*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11

Service Request: R2516333

Sample Name: 102.11-31B
Lab Code: R2516333-001
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-32
Lab Code: R2516333-002
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 102.11-33A
Lab Code: R2516333-003
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-33B
Lab Code: R2516333-004
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-34
Lab Code: R2516333-005
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11

Service Request: R2516333

Sample Name: 102.11-35A
Lab Code: R2516333-006
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-35B
Lab Code: R2516333-007
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-36
Lab Code: R2516333-008
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-37
Lab Code: R2516333-009
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.11-38A
Lab Code: R2516333-010
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11

Service Request: R2516333

Sample Name: 102.11-38B
Lab Code: R2516333-011
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-39
Lab Code: R2516333-012
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-40
Lab Code: R2516333-013
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-41A
Lab Code: R2516333-014
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.11-41B
Lab Code: R2516333-015
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11

Service Request: R2516333

Sample Name: 102.11-42
Lab Code: R2516333-016
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.11-43A
Lab Code: R2516333-017
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.11-43B
Lab Code: R2516333-018
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-44A
Lab Code: R2516333-019
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-44B
Lab Code: R2516333-020
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11

Service Request: R2516333

Sample Name: 102.11-45
Lab Code: R2516333-021
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-46
Lab Code: R2516333-022
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-47
Lab Code: R2516333-023
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 102.11-48A
Lab Code: R2516333-024
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 102.11-48B
Lab Code: R2516333-025
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11

Service Request: R2516333

Sample Name: 102.11-49
Lab Code: R2516333-026
Sample Matrix: Drinking Water

Date Collected: 12/3/25
Date Received: 12/4/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-31B
Lab Code: R2516333-001

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/23/25 20:00	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-32
Lab Code: R2516333-002

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	28.6	ug/L	1.0	1	12/24/25 13:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-33A
Lab Code: R2516333-003

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/26/25 14:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-33B
Lab Code: R2516333-004

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/26/25 14:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-34
Lab Code: R2516333-005

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	9.0	ug/L	1.0	1	12/26/25 14:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-35A
Lab Code: R2516333-006

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/26/25 14:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-35B
Lab Code: R2516333-007

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/26/25 14:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-36
Lab Code: R2516333-008

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	9.1	ug/L	1.0	1	12/26/25 14:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-37
Lab Code: R2516333-009

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.8	ug/L	1.0	1	12/31/25 19:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-38A
Lab Code: R2516333-010

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/26/25 14:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-38B
Lab Code: R2516333-011

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/26/25 14:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-39
Lab Code: R2516333-012

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	34.8	ug/L	1.0	1	12/26/25 14:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-40
Lab Code: R2516333-013

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	9.5	ug/L	1.0	1	12/26/25 14:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-41A
Lab Code: R2516333-014

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 18:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-41B
Lab Code: R2516333-015

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 18:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-42
Lab Code: R2516333-016

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.9	ug/L	1.0	1	12/29/25 18:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-43A
Lab Code: R2516333-017

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 18:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-43B
Lab Code: R2516333-018

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/26/25 16:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-44A
Lab Code: R2516333-019

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/26/25 16:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-44B
Lab Code: R2516333-020

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/26/25 16:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-45
Lab Code: R2516333-021

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	31.8	ug/L	1.0	1	12/26/25 16:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-46
Lab Code: R2516333-022

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/26/25 16:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-47
Lab Code: R2516333-023

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/26/25 16:42	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-48A
Lab Code: R2516333-024

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 18:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-48B
Lab Code: R2516333-025

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	11.8	ug/L	1.0	1	12/29/25 18:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: 102.11-49
Lab Code: R2516333-026

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25 17:00
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 19:07	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516333-MB1

Service Request: R2516333
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/23/25 19:21	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516333-MB2

Service Request: R2516333
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/24/25 13:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516333-MB3

Service Request: R2516333
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/26/25 14:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516333-MB4

Service Request: R2516333
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/26/25 16:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516333-MB5

Service Request: R2516333
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 18:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516333-MB6

Service Request: R2516333
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 19:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2516333-MB7

Service Request: R2516333
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/31/25 18:36	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25
Date Analyzed: 12/26/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.11-43B
Lab Code: R2516333-018
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516333-018MS		Result	Duplicate Matrix Spike R2516333-018DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	21.1	20.0	105	20.8	20.0	104	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25
Date Analyzed: 12/29/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.11-48B
Lab Code: R2516333-025
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516333-025MS		Duplicate Matrix Spike R2516333-025DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	11.8	33.7	20.0	110	33.8	20.0	110	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water

Service Request: R2516333
Date Collected: 12/03/25
Date Received: 12/04/25
Date Analyzed: 12/29/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 102.11-49
Lab Code: R2516333-026
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2516333-026MS		Duplicate Matrix Spike R2516333-026DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	21.7	20.0	109	21.7	20.0	109	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water

Service Request: R2516333
Date Analyzed: 12/23/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516333-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.5	20.0	112	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water

Service Request: R2516333
Date Analyzed: 12/24/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516333-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.4	20.0	112	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water

Service Request: R2516333
Date Analyzed: 12/26/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516333-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.4	20.0	97	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water

Service Request: R2516333
Date Analyzed: 12/26/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516333-LCS4

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.8	20.0	109	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water

Service Request: R2516333
Date Analyzed: 12/29/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516333-LCS5

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.6	20.0	113	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water

Service Request: R2516333
Date Analyzed: 12/29/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516333-LCS6

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	23.4	20.0	117 *	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Ken-Ton UFSD Jr/Sr HS/2023L-102.11
Sample Matrix: Drinking Water

Service Request: R2516333
Date Analyzed: 12/31/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516333-LCS7

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.2	20.0	101	85-115

1.5 Laboratory Certifications

**NEW YORK STATE DEPARTMENT OF HEALTH
 WADSWORTH CENTER**



Expires 12:01 AM April 01, 2026
 Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE
Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. CHRISTINE KUTZER
ALS ENVIRONMENTAL - ROCHESTER
1565 JEFFERSON ROAD BUILDING 300, SUITE 360
ROCHESTER, NY 14623

NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the
 National Environmental Laboratory Accreditation Conference Standards (2016) for the category
 ENVIRONMENTAL ANALYSES POTABLE WATER
 All approved analytes are listed below:*

Bacteriology	
Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Collert)
Dissolved Gases	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
Fuel Additives	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
Metals I	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Zinc, Total	EPA 200.7 Rev. 4.4

Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elapublicweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.



Page 1 of 5