

January 6, 2026

Ms. Georgia Militello  
Ken-Ton UFSD  
1500 Colvin Boulevard  
Buffalo, New York 14223

**Re: Lead Testing in School Drinking Water**

Dear Ms. Militello:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Ken-Ton UFSD, including:

- **Hamilton Elementary School – 44 Westfall Drive, Tonawanda, NY**

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: Lead Testing in School Drinking Water, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on December 2, 2025. As detailed in Section 1.2 (Executive Summary) of the accompanying report, based upon the sampling and analysis performed, 15 sources of potable water in Hamilton Elementary School have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion. To comply with NYS regulations, response actions by the district are required. Response actions are outlined in Section 1.3 (Response Actions Required Under NYS Regulations).

Thank you for the opportunity to be of service to Ken-Ton UFSD.

Sincerely,  
Stohl Environmental, LLC.



Michael Scinta  
EPA Lead Risk Assessor

**Lead Testing in School Drinking Water**

**Prepared for:**

**Ken-Ton UFSD**

**Prepared by:**



**3860 California Road  
Orchard Park, New York 14127**

**Conditions as of December 2, 2025**

## Summary Tabulation

### Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports and Chain of Custody Documents
- 1.5. Laboratory Certifications

## 1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Ken-Ton UFSD to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- **Hamilton Elementary School – 44 Westfall Drive, Tonawanda, NY**

### Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within Hamilton Elementary School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

### Sampling Protocol:

In accordance with NYS regulations, **Subpart 67-4: Lead Testing in School Drinking Water**, and the EPA guidance document, **3Ts for Reducing Lead in Drinking Water in Schools**, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

**1.2 Executive Summary of Sampling and Analysis:**

**Summary of Samples Collected at Hamilton Elementary School:**

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Hamilton Elementary	December 2, 2025	47	32	15

*\*NYS Action Level is 5 parts per billion*

**Listing of Outlets Requiring Remediation**

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
102.10-01	Hand Wash Station	Sink	23.3
102.10-02	Line Sink	Sink	10.2
102.10-09	Room 115 Sink	Sink	25.3
102.10-11	Room 113 Sink	Sink	34.8
102.10-12	Room 112 Sink	Sink	16.0
102.10-13	Room 111 Sink	Sink	9.8
102.10-14	Room 110 Sink	Sink	8.7
102.10-15	Room 109 Sink	Sink	10.1
102.10-16	Room 108 Sink	Sink	5.4
102.10-20	Room 106 Sink	Sink	6.3
102.10-22	Room 105 Sink	Sink	10.0
102.10-27	Room 103 Sink	Sink	11.0
102.10-28	Room 103 Bathroom Sink	Sink	6.7
102.10-32	Nurses Office Sink	Sink	8.5
102.10-37	Room 131 Sink	Sink	55.8

**1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:**

For outlets analyzed with a lead concentration more than the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
  - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
  - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

**1.4 Laboratory Analytical Reports and Chain of Custody Documents**



January 05, 2026

Service Request No:R2516334

Michael Scinta  
Stohl Environmental  
3860 California Road  
Orchard Park, NY 14219

**Laboratory Results for: Ken-Ton UFSD Aledander Hamilton Elementary School**

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory December 04, 2025  
For your reference, these analyses have been assigned our service request number **R2516334**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at [Meghan.Pedro@alsglobal.com](mailto:Meghan.Pedro@alsglobal.com).

Respectfully submitted,

**ALS Group USA, Corp. dba ALS Environmental**

Meghan Pedro  
Project Manager

CC: Rebecca  
Franjoine

**ADDRESS**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

**PHONE** +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.  
dba ALS Environmental



# Narrative Documents

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School  
**Sample Matrix:** Drinking Water

**Service Request:** R2516334  
**Date Received:** 12/04/2025

**CASE NARRATIVE**

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

**Sample Receipt:**

Forty seven drinking water samples were received for analysis at ALS Environmental on 12/04/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

**Metals:**

Method 200.8, 12/29/2025: The upper control criterion was exceeded for Lead in the Laboratory Control Sample (LCS). There were no detections of the analyte(s) above the MRL in the associated field samples. The error associated with elevated recovery equates to a high bias. The sample data is not significantly affected. No further corrective action was appropriate.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by \_\_\_\_\_

Date 01/05/2026



### SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 102.10-01		Lab ID: R2516334-001					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	23.3			1.0	ug/L	200.8	
CLIENT ID: 102.10-02		Lab ID: R2516334-002					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	10.2			1.0	ug/L	200.8	
CLIENT ID: 102.10-03		Lab ID: R2516334-003					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.8			1.0	ug/L	200.8	
CLIENT ID: 102.10-04		Lab ID: R2516334-004					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.8			1.0	ug/L	200.8	
CLIENT ID: 102.10-05		Lab ID: R2516334-005					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.8			1.0	ug/L	200.8	
CLIENT ID: 102.10-7		Lab ID: R2516334-008					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.1			1.0	ug/L	200.8	
CLIENT ID: 102.10-9		Lab ID: R2516334-011					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	25.3			1.0	ug/L	200.8	
CLIENT ID: 102.10-11		Lab ID: R2516334-014					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	34.8			1.0	ug/L	200.8	
CLIENT ID: 102.10-12		Lab ID: R2516334-015					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	16.0			1.0	ug/L	200.8	
CLIENT ID: 102.10-13		Lab ID: R2516334-016					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	9.8			1.0	ug/L	200.8	
CLIENT ID: 102.10-14		Lab ID: R2516334-017					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	8.7			1.0	ug/L	200.8	
CLIENT ID: 102.10-15		Lab ID: R2516334-018					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	10.1			1.0	ug/L	200.8	



### SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 102.10-16		Lab ID: R2516334-019					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.4			1.0	ug/L	200.8	
CLIENT ID: 102.10-17		Lab ID: R2516334-020					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.4			1.0	ug/L	200.8	
CLIENT ID: 102.10-18		Lab ID: R2516334-021					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.8			1.0	ug/L	200.8	
CLIENT ID: 102.10-19		Lab ID: R2516334-022					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.99			0.50	ug/L	200.8	
CLIENT ID: 102.10-20		Lab ID: R2516334-023					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	6.3			1.0	ug/L	200.8	
CLIENT ID: 102.10-21		Lab ID: R2516334-024					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.8			1.0	ug/L	200.8	
CLIENT ID: 102.10-22		Lab ID: R2516334-025					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	10.0			1.0	ug/L	200.8	
CLIENT ID: 102.10-23		Lab ID: R2516334-026					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.7			1.0	ug/L	200.8	
CLIENT ID: 102.10-25		Lab ID: R2516334-029					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.8			1.0	ug/L	200.8	
CLIENT ID: 102.10-26		Lab ID: R2516334-030					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.3			1.0	ug/L	200.8	
CLIENT ID: 102.10-27		Lab ID: R2516334-031					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	11.0			1.0	ug/L	200.8	
CLIENT ID: 102.10-28		Lab ID: R2516334-032					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	6.7			1.0	ug/L	200.8	



### SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 102.10-30		Lab ID: R2516334-034					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.6			1.0	ug/L	200.8	
CLIENT ID: 102.10-31		Lab ID: R2516334-035					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.0			1.0	ug/L	200.8	
CLIENT ID: 102.10-32		Lab ID: R2516334-036					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	8.5			1.0	ug/L	200.8	
CLIENT ID: 102.10-33		Lab ID: R2516334-037					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.2			1.0	ug/L	200.8	
CLIENT ID: 102.10-35		Lab ID: R2516334-040					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.1			1.0	ug/L	200.8	
CLIENT ID: 102.10-36		Lab ID: R2516334-041					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.1			1.0	ug/L	200.8	
CLIENT ID: 102.10-37		Lab ID: R2516334-042					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	55.8			1.0	ug/L	200.8	
CLIENT ID: 102.10-39		Lab ID: R2516334-044					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.7			1.0	ug/L	200.8	
CLIENT ID: 102.10-40		Lab ID: R2516334-045					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.9			1.0	ug/L	200.8	
CLIENT ID: 102.10-41		Lab ID: R2516334-046					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.3			1.0	ug/L	200.8	



## Sample Receipt Information

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10

**Service Request:**R2516334

**SAMPLE CROSS-REFERENCE**

R2516334-001	102.10-01	12/2/2025
R2516334-002	102.10-02	12/2/2025
R2516334-003	102.10-03	12/2/2025
R2516334-004	102.10-04	12/2/2025
R2516334-005	102.10-05	12/2/2025
R2516334-006	102.10-06A	12/2/2025
R2516334-007	102.10-06B	12/2/2025
R2516334-008	102.10-7	12/2/2025
R2516334-009	102.10-8A	12/2/2025
R2516334-010	102.10-8B	12/2/2025
R2516334-011	102.10-9	12/2/2025
R2516334-012	102.10-10A	12/2/2025
R2516334-013	102.10-10B	12/2/2025
R2516334-014	102.10-11	12/2/2025
R2516334-015	102.10-12	12/2/2025
R2516334-016	102.10-13	12/2/2025
R2516334-017	102.10-14	12/2/2025
R2516334-018	102.10-15	12/2/2025
R2516334-019	102.10-16	12/2/2025
R2516334-020	102.10-17	12/2/2025
R2516334-021	102.10-18	12/2/2025
R2516334-022	102.10-19	12/2/2025
R2516334-023	102.10-20	12/2/2025
R2516334-024	102.10-21	12/2/2025
R2516334-025	102.10-22	12/2/2025
R2516334-026	102.10-23	12/2/2025
R2516334-027	102.10-24A	12/2/2025
R2516334-028	102.10-24B	12/2/2025
R2516334-029	102.10-25	12/2/2025
R2516334-030	102.10-26	12/2/2025
R2516334-031	102.10-27	12/2/2025
R2516334-032	102.10-28	12/2/2025
R2516334-033	102.10-29	12/2/2025
R2516334-034	102.10-30	12/2/2025
R2516334-035	102.10-31	12/2/2025
R2516334-036	102.10-32	12/2/2025
R2516334-037	102.10-33	12/2/2025
R2516334-038	102.10-34A	12/2/2025
R2516334-039	102.10-34B	12/2/2025
R2516334-040	102.10-35	12/2/2025
R2516334-041	102.10-36	12/2/2025
R2516334-042	102.10-37	12/2/2025

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10

**Service Request:**R2516334

**SAMPLE CROSS-REFERENCE**

R2516334-043	102.10-38	12/2/2025
R2516334-044	102.10-39	12/2/2025
R2516334-045	102.10-40	12/2/2025
R2516334-046	102.10-41	12/2/2025
R2516334-047	102.10-42	12/2/2025

# Stohl ENVIRONMENTAL

3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

## Chain of Custody Document

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.10

Client: Ken-Ton UFSD

Contact: Georgia Militello

Building: Alexander Hamilton Elementary School

Location: 44 Westfall Dr, Tonawanda, NY 14150

**LEAD**

Water by 200.8 X

*Turnaround*

10 Days

Sample #	Location	Outlet Type	Time
102.10-01	Hand Wash Station	Sink	5:10
102.10-02	Line Sink	Sink	5:11
102.10-03	Dishes Sink 01	Sink	5:12
102.10-04	Dishes Sink 02	Sink	5:14
102.10-05	Dishes Sink 03	Sink	5:15
102.10-06A	Cafeteria DF	DF	5:17
102.10-06B	Cafeteria BF	BF	5:18
102.10-07	Faculty Dining Room Sink	Sink	5:19
102.10-08A	Outside Faculty Restroom DF	DF	5:21
102.10-08B	Outside Faculty Restroom BF	BF	5:22
102.10-09	Room 115 Sink	Sink	5:24
102.10-10A	Across From Room 113 DF	DF	5:25
102.10-10B	Across From Room 113 BF	BF	5:27
102.10-11	Room 113 Sink	Sink	5:28
102.10-12	Room 112 Sink	Sink	5:29
102.10-13	Room 111 Sink	Sink	5:31
102.10-14	Room 110 Sink	Sink	5:32
102.10-15	Room 109 Sink	Sink	5:34

Notes: Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)  If checked, also e-mail results to: [msscinta@stohlenvironmental.com](mailto:msscinta@stohlenvironmental.com)

Sampled By: A. Dellinger Print Name A. Dellinger Stohl Env: A. Dellinger Date: 12/2/2025  
 Relinquished By: [Signature] Print Name Connor Crilly Stohl Env: Connor Crilly Date: 12/4/25 6pm  
 Received (Name / Lab): [Signature] Date: 12/4/25 Time: 1700  
 Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_





# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-102.10

Client: Ken-Ton UFSD

Contact: Georgia Militello

Building: Alexander Hamilton Elementary School

Location: 44 Westfall Dr, Tonawanda, NY 14150

**LEAD**  
 Water by 200.8 X

*Turnaround*  
10 Days

Sample #	Location	Outlet Type	Time
102.10-16	Room 108 Sink	Sink	5:35
102.10-17	Room 108 Bathroom Sink	Sink	5:36
102.10-18	Room 107 Sink	Sink	5:38
102.10-19	Room 107 Bathroom Sink	Sink	5:39
102.10-20	Room 106 Sink	Sink	5:41
102.10-21	Room 106 Bathroom Sink	Sink	5:42
102.10-22	Room 105 Sink	Sink	5:44
102.10-23	Room 105 Bathroom Sink	Sink	5:45
102.10-24A	Outside Room 105 DF	DF	5:46
102.10-24B	Outside Room 105 BF	BF	5:48
102.10-25	Room 104 Sink	Sink	5:49
102.10-26	Room 104 Bathroom Sink	Sink	5:51
102.10-27	Room 103 Sink	Sink	5:52
102.10-28	Room 103 Bathroom Sink	Sink	5:53
102.10-29	Room 100 Kitchenette Sink	Sink	5:55
102.10-30	Room 100 Bathroom Sink	Sink	5:56
102.10-31	Nurses office Bathroom Sink	Sink	5:58
102.10-32	Nurses Office Sink	Sink	5:59

Notes: Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com) [mscinta@stohlenvironmental.com](mailto:mscinta@stohlenvironmental.com)

Sampled By: A. Dellinger Print Name A. Dellinger Stohl Env: A. Dellinger Date: 12/2/2025

Relinquished By: [Signature] Print Name Connor Crilly Stohl Env: Connor Crilly Date: 12/14/25 5PM

Received (Name / Lab): [Signature] Date: 12/14/25 Time: 1700

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS  
 STOHL Job # 2023L-102.10

Client: Ken-Ton UFSD Contact: Georgia Militello  
 Building: Alexander Hamilton Elementary School Location: 44 Westfall Dr, Tonawanda, NY 14150

**LEAD**  
 Water by 200.8 X Turnaround 10 Days

Sample #	Location	Outlet Type	Time
102.10-33	OTPT Room- Room 127 Sink	Sink	6:01
102.10-34A	Across From Door 2 DF	DF	6:02
102.10-34B	Across From Door 2 BF	BF	6:03
102.10-35	Room 129 Sink	Sink	6:05
102.10-36	Room 130 Sink	Sink	6:06
102.10-37	Room 131 Sink	Sink	6:08
102.10-38	Room 132 Sink	Sink	6:09
102.10-39	Room 133 Sink	Sink	6:10
102.10-40	Room 134 Sink	Sink	6:12
102.10-41	Room 135 Sink	Sink	6:13
102.10-42	Room 136 Sink	Sink	6:15

Notes:  
 Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com) [mscinta@stohlenvironmental.com](mailto:mscinta@stohlenvironmental.com)

Sampled By: A. Dellinger Print Name A. Dellinger Stohl Env: A. Dellinger Date: 12/2/2025  
 Relinquished By: [Signature] Print Name Connor Crilly Stohl Env: Connor Crilly Date: 12/4/25 5pm  
 Received (Name / Lab): [Signature] Date: 12/4/25 Time: 1700  
 Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



R2516334

5

Stohl Environmental  
Ken-Ton UFSD Alexander Hamilton Elementary Sc

### Cooler Receipt and Preservation

Project/Client Stohl Folder Number \_\_\_\_\_



Cooler received on 12/4/25 by: RDA

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
2	Custody papers properly completed (ink, signed)?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>
3	Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>

5a	Did VOA vials have sig* bubbles?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
5b	Sig* bubbles: Alk?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
	Sulfide?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/>
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as:	Bulk Encore 5035set <u>NA</u>

8. Temperature Readings Date: 12/4/25 Time: 1712 ID: IR#12 IR#12 From: Temp Blank Sample Bottle

Temp (°C)	<u>19.8</u>						
Within 0-6°C?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>					
If <0°C, were samples frozen?	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>

If out of Temperature, note packing/ice condition: \_\_\_\_\_ Ice melted Poorly Packed (described below) Same Day Rule  
& Client Approval to Run Samples: \_\_\_\_\_ Standing Approval Client aware at drop-off Client notified by: \_\_\_\_\_

All samples held in storage location: SMU by RDA on 12/4/25 at 1713  
5035 samples placed in storage location: \_\_\_\_\_ by \_\_\_\_\_ on \_\_\_\_\_ at \_\_\_\_\_ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check\*\*: Date: 12/4/25 Time: 10:05 by: RM

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES  NO
- 10. Did all bottle labels and tags agree with custody papers? YES  NO
- 11. Were correct containers used for the tests indicated?  YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO  NA
- 13. Were dissolved metals filtered in the field? YES NO  NA
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated  NA

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>202325</u>	HNO <sub>3</sub>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<u>24017806</u>	<u>1/27</u>	<u>102.10-03</u>	<u>4mL</u>	<u>245078</u>	<u>≤2</u>
≤2		H <sub>2</sub> SO <sub>4</sub>								
<4		NaHSO <sub>4</sub>								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> (625, 608, CN), ascorbic (phenol).					
		Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>								
		ZnAcetate	-	-						
		HCl	**	**						

\*\*VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 072125-2EKT  
Explain all Discrepancies/ Other Comments:  
10) Only sample ID on bottles

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: RM \*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



## Miscellaneous Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



## REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- \* Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ( $\geq 100\%$  Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)  
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

### Rochester Lab ID # for State Accreditations<sup>1</sup>



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

<sup>1</sup> Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

# ALS Laboratory Group

---

## Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10

**Service Request:** R2516334

**Sample Name:** 102.10-01  
**Lab Code:** R2516334-001  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-02  
**Lab Code:** R2516334-002  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-03  
**Lab Code:** R2516334-003  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-04  
**Lab Code:** R2516334-004  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-05  
**Lab Code:** R2516334-005  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10

**Service Request:** R2516334

**Sample Name:** 102.10-06A  
**Lab Code:** R2516334-006  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-06B  
**Lab Code:** R2516334-007  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-7  
**Lab Code:** R2516334-008  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-8A  
**Lab Code:** R2516334-009  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-8B  
**Lab Code:** R2516334-010  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10

**Service Request:** R2516334

**Sample Name:** 102.10-9  
**Lab Code:** R2516334-011  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-10A  
**Lab Code:** R2516334-012  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-10B  
**Lab Code:** R2516334-013  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-11  
**Lab Code:** R2516334-014  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-12  
**Lab Code:** R2516334-015  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10

**Service Request:** R2516334

**Sample Name:** 102.10-13  
**Lab Code:** R2516334-016  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-14  
**Lab Code:** R2516334-017  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-15  
**Lab Code:** R2516334-018  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-16  
**Lab Code:** R2516334-019  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-17  
**Lab Code:** R2516334-020  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10

**Service Request:** R2516334

**Sample Name:** 102.10-18  
**Lab Code:** R2516334-021  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-19  
**Lab Code:** R2516334-022  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**  
NMANSEN

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-20  
**Lab Code:** R2516334-023  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-21  
**Lab Code:** R2516334-024  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-22  
**Lab Code:** R2516334-025  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10

**Service Request:** R2516334

**Sample Name:** 102.10-23  
**Lab Code:** R2516334-026  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-24A  
**Lab Code:** R2516334-027  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-24B  
**Lab Code:** R2516334-028  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-25  
**Lab Code:** R2516334-029  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-26  
**Lab Code:** R2516334-030  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10

**Service Request:** R2516334

**Sample Name:** 102.10-27  
**Lab Code:** R2516334-031  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-28  
**Lab Code:** R2516334-032  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-29  
**Lab Code:** R2516334-033  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-30  
**Lab Code:** R2516334-034  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-31  
**Lab Code:** R2516334-035  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10

**Service Request:** R2516334

**Sample Name:** 102.10-32  
**Lab Code:** R2516334-036  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-33  
**Lab Code:** R2516334-037  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-34A  
**Lab Code:** R2516334-038  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-34B  
**Lab Code:** R2516334-039  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-35  
**Lab Code:** R2516334-040  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10

**Service Request:** R2516334

**Sample Name:** 102.10-36  
**Lab Code:** R2516334-041  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-37  
**Lab Code:** R2516334-042  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-38  
**Lab Code:** R2516334-043  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-39  
**Lab Code:** R2516334-044  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-40  
**Lab Code:** R2516334-045  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**ALS Group USA, Corp.**  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10

**Service Request:** R2516334

**Sample Name:** 102.10-41  
**Lab Code:** R2516334-046  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 102.10-42  
**Lab Code:** R2516334-047  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/2/25  
**Date Received:** 12/4/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER



## PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

### INORGANIC

#### Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

#### Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

### ORGANIC

**Preparation Methods for Organic methods are listed in the header of the Results pages.**

#### Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



# Sample Results

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-01  
**Lab Code:** R2516334-001

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	23.3	ug/L	1.0	1	12/30/25 19:04	

**ALS Group USA, Corp.**  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-02  
**Lab Code:** R2516334-002

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

**Inorganic Parameters**

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	10.2	ug/L	1.0	1	12/30/25 19:05	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-03  
**Lab Code:** R2516334-003

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	3.8	ug/L	1.0	1	12/30/25 19:07	

**ALS Group USA, Corp.**  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-04  
**Lab Code:** R2516334-004

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

**Inorganic Parameters**

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	4.8	ug/L	1.0	1	12/30/25 19:08	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-05  
**Lab Code:** R2516334-005

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.8	ug/L	1.0	1	12/30/25 19:09	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-06A  
**Lab Code:** R2516334-006

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 19:21	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-06B  
**Lab Code:** R2516334-007

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 19:22	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-7  
**Lab Code:** R2516334-008

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	2.1	ug/L	1.0	1	12/30/25 19:16	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-8A  
**Lab Code:** R2516334-009

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 19:25	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-8B  
**Lab Code:** R2516334-010

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 19:26	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-9  
**Lab Code:** R2516334-011

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	25.3	ug/L	1.0	1	12/30/25 19:21	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-10A  
**Lab Code:** R2516334-012

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<u>Analyte Name</u>	<u>Analysis Method</u>	<u>Result</u>	<u>Units</u>	<u>MRL</u>	<u>Dil.</u>	<u>Date Analyzed</u>	<u>Q</u>
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 19:29	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-10B  
**Lab Code:** R2516334-013

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 19:30	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-11  
**Lab Code:** R2516334-014

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	34.8	ug/L	1.0	1	12/30/25 19:25	

**ALS Group USA, Corp.**  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-12  
**Lab Code:** R2516334-015

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

**Inorganic Parameters**

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	<b>16.0</b>	ug/L	1.0	1	12/30/25 19:26	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-13  
**Lab Code:** R2516334-016

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	9.8	ug/L	1.0	1	12/30/25 19:30	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-14  
**Lab Code:** R2516334-017

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	8.7	ug/L	1.0	1	12/30/25 19:32	

**ALS Group USA, Corp.**  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-15  
**Lab Code:** R2516334-018

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

**Inorganic Parameters**

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	10.1	ug/L	1.0	1	12/30/25 19:33	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-16  
**Lab Code:** R2516334-019

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	5.4	ug/L	1.0	1	12/30/25 19:35	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-17  
**Lab Code:** R2516334-020

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.4	ug/L	1.0	1	12/29/25 19:51	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-18  
**Lab Code:** R2516334-021

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	4.8	ug/L	1.0	1	12/29/25 19:55	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-19  
**Lab Code:** R2516334-022

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Date Extracted</b>	<b>Q</b>
Lead, Total	200.8	3.99	ug/L	0.50	1	12/19/25 15:06	12/18/25	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-20  
**Lab Code:** R2516334-023

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.3	ug/L	1.0	1	12/29/25 19:57	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-21  
**Lab Code:** R2516334-024

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	2.8	ug/L	1.0	1	12/29/25 19:58	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-22  
**Lab Code:** R2516334-025

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	10.0	ug/L	1.0	1	12/29/25 19:59	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-23  
**Lab Code:** R2516334-026

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	3.7	ug/L	1.0	1	12/29/25 20:01	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-24A  
**Lab Code:** R2516334-027

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<u>Analyte Name</u>	<u>Analysis Method</u>	<u>Result</u>	<u>Units</u>	<u>MRL</u>	<u>Dil.</u>	<u>Date Analyzed</u>	<u>Q</u>
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 20:05	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-24B  
**Lab Code:** R2516334-028

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 20:06	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-25  
**Lab Code:** R2516334-029

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	4.8	ug/L	1.0	1	12/29/25 20:08	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-26  
**Lab Code:** R2516334-030

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	3.3	ug/L	1.0	1	12/29/25 20:09	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-27  
**Lab Code:** R2516334-031

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	11.0	ug/L	1.0	1	12/29/25 20:11	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-28  
**Lab Code:** R2516334-032

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

**Inorganic Parameters**

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	6.7	ug/L	1.0	1	12/29/25 20:12	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-29  
**Lab Code:** R2516334-033

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 20:13	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-30  
**Lab Code:** R2516334-034

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	1.6	ug/L	1.0	1	12/29/25 20:15	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-31  
**Lab Code:** R2516334-035

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	5.0	ug/L	1.0	1	12/29/25 20:16	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-32  
**Lab Code:** R2516334-036

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	8.5	ug/L	1.0	1	12/29/25 20:17	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-33  
**Lab Code:** R2516334-037

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	2.2	ug/L	1.0	1	12/29/25 20:22	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-34A  
**Lab Code:** R2516334-038

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 20:23	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-34B  
**Lab Code:** R2516334-039

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 20:24	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-35  
**Lab Code:** R2516334-040

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	1.1	ug/L	1.0	1	12/29/25 20:26	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-36  
**Lab Code:** R2516334-041

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	1.1	ug/L	1.0	1	12/29/25 20:33	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-37  
**Lab Code:** R2516334-042

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	55.8	ug/L	1.0	1	12/29/25 20:40	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-38  
**Lab Code:** R2516334-043

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 20:41	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-39  
**Lab Code:** R2516334-044

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	4.7	ug/L	1.0	1	12/29/25 20:42	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-40  
**Lab Code:** R2516334-045

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	2.9	ug/L	1.0	1	12/29/25 20:44	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-41  
**Lab Code:** R2516334-046

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	3.3	ug/L	1.0	1	12/29/25 20:45	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** 102.10-42  
**Lab Code:** R2516334-047

**Service Request:** R2516334  
**Date Collected:** 12/02/25  
**Date Received:** 12/04/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 20:46	



# QC Summary Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2516334-MB1

**Service Request:** R2516334  
**Date Collected:** NA  
**Date Received:** NA

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	ND U	ug/L	0.50	1	12/19/25 14:25	12/18/25	
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 19:04	NA	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2516334-MB2

**Service Request:** R2516334  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 19:48	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2516334-MB3

**Service Request:** R2516334  
**Date Collected:** NA  
**Date Received:** NA

**Basis:** NA

Inorganic Parameters

<u>Analyte Name</u>	<u>Analysis Method</u>	<u>Result</u>	<u>Units</u>	<u>MRL</u>	<u>Dil.</u>	<u>Date Analyzed</u>	<u>Q</u>
Lead, Total	200.8	ND U	ug/L	1.0	1	12/29/25 20:30	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2516334-MB4

**Service Request:** R2516334  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

<u>Analyte Name</u>	<u>Analysis Method</u>	<u>Result</u>	<u>Units</u>	<u>MRL</u>	<u>Dil.</u>	<u>Date Analyzed</u>	<u>Q</u>
Lead, Total	200.8	ND U	ug/L	1.0	1	12/30/25 18:57	

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

<b>Client:</b>	Stohl Environmental	<b>Service Request:</b>	R2516334
<b>Project:</b>	Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10	<b>Date Collected:</b>	12/02/25
<b>Sample Matrix:</b>	Drinking Water	<b>Date Received:</b>	12/04/25
		<b>Date Analyzed:</b>	12/30/25

**Duplicate Matrix Spike Summary**  
**Inorganic Parameters**

<b>Sample Name:</b>	102.10-16	<b>Units:</b>	ug/L
<b>Lab Code:</b>	R2516334-019	<b>Basis:</b>	NA
<b>Analysis Method:</b>	200.8		

Analyte Name	Sample Result	Result	Matrix Spike R2516334-019MS		Result	Duplicate Matrix Spike R2516334-019DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	5.4	26.4	20.0	105	27.3	20.0	109	70-130	3	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

<b>Client:</b>	Stohl Environmental	<b>Service Request:</b>	R2516334
<b>Project:</b>	Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10	<b>Date Collected:</b>	12/02/25
<b>Sample Matrix:</b>	Drinking Water	<b>Date Received:</b>	12/04/25
		<b>Date Analyzed:</b>	12/29/25

**Duplicate Matrix Spike Summary**  
**Inorganic Parameters**

<b>Sample Name:</b>	102.10-17	<b>Units:</b>	ug/L
<b>Lab Code:</b>	R2516334-020	<b>Basis:</b>	NA
<b>Analysis Method:</b>	200.8		

Analyte Name	Sample Result	Result	Matrix Spike R2516334-020MS		Duplicate Matrix Spike R2516334-020DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	2.4	24.5	20.0	111	25.0	20.0	113	70-130	2	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

<b>Client:</b>	Stohl Environmental	<b>Service Request:</b>	R2516334
<b>Project:</b>	Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10	<b>Date Collected:</b>	12/02/25
<b>Sample Matrix:</b>	Drinking Water	<b>Date Received:</b>	12/04/25
		<b>Date Analyzed:</b>	12/29/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

<b>Sample Name:</b>	102.10-35	<b>Units:</b>	ug/L
<b>Lab Code:</b>	R2516334-040	<b>Basis:</b>	NA
<b>Analysis Method:</b>	200.8		

Analyte Name	Sample Result	Result	Matrix Spike R2516334-040MS		Duplicate Matrix Spike R2516334-040DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	1.1	24.0	20.0	115	23.8	20.0	114	70-130	<1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

<b>Client:</b>	Stohl Environmental	<b>Service Request:</b>	R2516334
<b>Project:</b>	Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10	<b>Date Collected:</b>	12/02/25
<b>Sample Matrix:</b>	Drinking Water	<b>Date Received:</b>	12/04/25
		<b>Date Analyzed:</b>	12/29/25

**Duplicate Matrix Spike Summary**  
**Inorganic Parameters**

<b>Sample Name:</b>	102.10-36	<b>Units:</b>	ug/L
<b>Lab Code:</b>	R2516334-041	<b>Basis:</b>	NA
<b>Analysis Method:</b>	200.8		

Analyte Name	Sample Result	Result	Matrix Spike R2516334-041MS		Duplicate Matrix Spike R2516334-041DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	1.1	23.3	20.0	111	23.6	20.0	113	70-130	1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water

**Service Request:** R2516334  
**Date Analyzed:** 12/19/25 - 12/29/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2516334-LCS1

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	20.7	20.0	104	85-115
Lead, Total	200.8	23.4	20.0	117 *	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water

**Service Request:** R2516334  
**Date Analyzed:** 12/29/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2516334-LCS2

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	23.1	20.0	115	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water

**Service Request:** R2516334  
**Date Analyzed:** 12/29/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2516334-LCS3

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	22.7	20.0	114	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Ken-Ton UFSD Aledander Hamilton Elementary School/2023L-102.10  
**Sample Matrix:** Drinking Water

**Service Request:** R2516334

**Date Analyzed:** 12/30/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L

**Basis:**NA

**Lab Control Sample**  
R2516334-LCS4

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	20.9	20.0	104	85-115

1.5 Laboratory Certifications

**NEW YORK STATE DEPARTMENT OF HEALTH  
 WADSWORTH CENTER**



Expires 12:01 AM April 01, 2026  
 Issued April 01, 2025

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**  
*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

**MS. CHRISTINE KUTZER**  
**ALS ENVIRONMENTAL - ROCHESTER**  
 1565 JEFFERSON ROAD BUILDING 300, SUITE 360  
 ROCHESTER, NY 14623

NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
 National Environmental Laboratory Accreditation Conference Standards (2016) for the category  
 ENVIRONMENTAL ANALYSES POTABLE WATER  
 All approved analytes are listed below:*

<b>Bacteriology</b>	
Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Collert)
<b>Dissolved Gases</b>	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
<b>Fuel Additives</b>	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
<b>Metals I</b>	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Zinc, Total	EPA 200.7 Rev. 4.4

Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elapublicweb/>, by phone (518) 485-5570 or by email to [elap@health.ny.gov](mailto:elap@health.ny.gov).

