Lead in School Drinking Water Report

Lakeridge Middle School

EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per RCW 28A.210.410 sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

RCW 28A.210.410 does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing Location	Room/space where fixture is located (i.e. room number, gym, playground)
Fixture Housing Type	Structure that contains the individual fixtures where water samples were collected from. Fixture housing may contain one or more individual fixture for sampling.
Fixture Location Details	Location within a room or space where fixture housing is located, starting to the left of the entrance and rotating clockwise, of the total number of fixture housings in a room or space (e.g. 1/5, 2/5)
Fixture Type	Tap, Sprayer, Water Fountain, Water Bottle Filler, Icemaker
Fixture Position	Left, Center, Right

Date(s) collected: 2025-11-22
Date(s) analyzed: 2025-12-01, 2025-12-08

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	414517	Main Building	Pot Filler	Kitchen	7 of 7. Bread maker pot filler	Tap	center	533
2	414467	Main Building	Pot Filler	Kitchen	2 of 7	Tap	center	127
3	414498	Main Building	Sink	2nd Floor Work Room	1 of 1	Tap	center	62
4	414472	Main Building	Sink	Kitchen	6 of 7 Furthest sink on west side.	Tap	center	31
5	414504	Main Building	Fountain/Tap Combo	Room 605	1 of 1	Water Fountain	right	13
6	414471	Main Building	Sink	Kitchen	5 of 7 Prep sink in middle near buffet	Tap	center	8
7	414477	Main Building	Fountain/Tap Combo	Room 408	1 of 1	Tap	center	7

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
8	414496	Main Building	Fountain/Tap Combo	Library Office	1 of 1	Tap	center	7
9	414502	Main Building	Fountain/Tap Combo	Room 608	1 of 1	Water Fountain	right	7
10	414448	Main Building	Fountain/Tap Combo	Room 208	1 of 1	Water Fountain	right	6
11	414451	Main Building	Fountain/Tap Combo	Room 204	1 of 1	Tap	center	6
12	414487	Main Building	Fountain/Tap Combo	Room 402	1 of 1	Tap	center	6
13	414497	Main Building	Fountain/Tap Combo	Library Office	1 of 1	Water Fountain	right	6
14	414444	Main Building	Sink	Work Room	1 of 1	Tap	center	5
15	414449	Main Building	Fountain/Tap Combo	Room 205	1 of 1	Tap	center	5
16	414468	Main Building	Sink	Kitchen	3 of 7 Prep sink with sprayer	Tap	center	5
17	414481	Main Building	Fountain/Tap Combo	Room. 407	1 of 1	Tap	center	5
18	414486	Main Building	Fountain/Tap Combo	Room 401	1 of 1	Water Fountain	right	5

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
19	414495	Main Building	Fountain/Tap Combo	Room 403	1 of 1	Water Fountain	right	5
20	414447	Main Building	Sink	Room 208	1 of 1	Tap	center	4
21	414461	Main Building	Fountain/Tap Combo	Room 310	1 of 2	Tap	center	4
22	414462	Main Building	Sink	Room 310	2 of 2	Tap	left	4
23	414475	Main Building	Fountain/Tap Combo	Band Room	1 of 1	Tap	center	4
24	414476	Main Building	Fountain/Tap Combo	Band Room	1 of 1	Water Fountain	right	4
25	414485	Main Building	Fountain/Tap Combo	Room 401	1 of 1	Tap	center	4
26	414488	Main Building	Fountain/Tap Combo	Room 402	1 of 1	Water Fountain	right	4
27	414489	Main Building	Fountain/Tap Combo	Room 405	1 of 1	Tap	center	4
28	414501	Main Building	Fountain/Tap Combo	Room 608	1 of 1	Tap	center	4
29	414507	Main Building	Fountain/Tap Combo	Room 601	1 of 1	Tap	center	4
30	414509	Main Building	Fountain/Tap Combo	Room 602	1 of 1	Tap	center	4

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
31	414442	Main Building	Sink	Staff Lounge	2 of 3. West wall	Tap	center	3
32	414443	Main Building	Sink - Multi-Compartment	Staff Lounge	3 of 3	Tap	center	3
33	414450	Main Building	Fountain/Tap Combo	Room 205	1 of 1	Water Fountain	left	3
34	414452	Main Building	Fountain/Tap Combo	Room 204	1 of 1	Water Fountain	right	3
35	414453	Main Building	Fountain/Tap Combo	Room 201	1 of 1	Tap	center	3
36	414454	Main Building	Fountain/Tap Combo	Room 201	1 of 1	Water Fountain	right	3
37	414455	Main Building	Fountain/Tap Combo	Room 202	1 of 1	Tap	center	3
38	414457	Main Building	Fountain/Tap Combo	Room 203	1 of 1	Tap	center	3
39	414458	Main Building	Fountain/Tap Combo	Room 203	1 of 1	Water Fountain	right	3
40	414460	Main Building	Fountain/Tap Combo	Room 315	1 of 1	Water Fountain	right	3
41	414463	Main Building	Sink	Room 310	2 of 2	Tap	center	3

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
42	414464	Main Building	Sink	Room 310	2 of 2	Tap	right	3
43	414466	Main Building	Sink	Kitchen	1 of 7 Prep sink closest to dish washing station. East corner	Tap	center	3
44	414469	Main Building	Sink	Kitchen	3 of 7 Sink with sprayer	Sprayer	center	3
45	414478	Main Building	Fountain/Tap Combo	Room 408	1 of 1	Water Fountain	right	3
46	414482	Main Building	Fountain/Tap Combo	Room 407	1 of 1	Water Fountain	right	3
47	414483	Main Building	Fountain/Tap Combo	Room 406	1 of 1	Tap	center	3
48	414484	Main Building	Fountain/Tap Combo	Room 406	1 of 1	Water Fountain	left	3
49	414490	Main Building	Fountain/Tap Combo	Room 405	1 of 1	Water Fountain	right	3

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
50	414492	Main Building	Fountain/Tap Combo	Room 404	1 of 1	Water Fountain	right	3
51	414503	Main Building	Fountain/Tap Combo	Room 605	1 of 1	Tap	center	3
52	414505	Main Building	Fountain/Tap Combo	Room 604	1 of 1	Tap	center	3
53	414506	Main Building	Fountain/Tap Combo	Room 604	1 of 1	Water Fountain	right	3
54	414510	Main Building	Fountain/Tap Combo	Room 602	1 of 1	Water Fountain	right	3
55	414512	Main Building	Fountain/Tap Combo	Room 603	1 of 1	Water Fountain	right	3
56	414440	Main Building	Sink	Nurses Office	1 of 1	Tap	center	2
57	414441	Main Building	Sink	Staff Lounge	1 of 3. Island sink	Tap	center	2
58	414456	Main Building	Fountain/Tap Combo	Room 202	1 of 1	Water Fountain	right	2
59	414459	Main Building	Fountain/Tap Combo	Room 315	1 of 1	Tap	center	2
60	414465	Main Building	Sink - Multi-Compartment	Room 311	1 of 1	Tap	center	2

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
61	414491	Main Building	Fountain/Tap Combo	Room 404	1 of 1	Tap	center	2
62	414508	Main Building	Fountain/Tap Combo	Room 601	1 of 1	Water Fountain	right	2
63	414511	Main Building	Fountain/Tap Combo	Room 603	1 of 1	Tap	center	2
64	414516	Main Building	Fountain	Main Gym	1 of 1	Water Fountain	right	2
65	414493	Main Building	Sink - Multi-Compartment	Pod Sink Outside Of Room 404	1 of 1	Tap	center	1
66	414494	Main Building	Fountain/Tap Combo	Room 403	1 of 1	Tap	center	1
67	414500	Main Building	Fountain - Multi-Level	Hallway Next To Room 608	1 of 1	Water Fountain	right	1
68	414445	Main Building	Fountain - Multi-Level	Hallway Across From Room 206	1 of 1	Water Fountain	left	<1
69	414446	Main Building	Fountain - Multi-Level	Hallway Across From Room 206	1 of 1	Water Fountain	right	<1
70	414470	Main Building	Ice Machine	Kitchen	4 of 7	Ice Machine	center	<1
71	414473	Main Building	Fountain with Bottle Filler	Cafeteria	1 of 1	Water Bottle Filler	center	<1
72	414474	Main Building	Fountain with Bottle Filler	Cafeteria	1 of 1	Water Fountain	right	<1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
73	414479	Main Building	Fountain - Multi-Level	Hallway Next To Room 408	1 of 1	Water Fountain	left	<1
74	414480	Main Building	Fountain - Multi-Level	Hallway Next To Room 408	1 of 1	Water Fountain	right	<1
75	414499	Main Building	Fountain - Multi-Level	Hallway Next To Room 608	1 of 1	Water Fountain	left	<1
76	414513	Main Building	Fountain with Bottle Filler	Gym Foyer	1 of 1	Water Bottle Filler	center	<1
77	414514	Main Building	Fountain with Bottle Filler	Gym Foyer	1 of 1	Water Fountain	right	<1
78	414515	Main Building	Fountain	Aux Gym	1 of 1	Water Fountain	right	<1