

Lead in School Drinking Water Report

Bonney Lake Elementary School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-11-19

Date(s) analyzed: 2025-11-25

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	414827	Building 2	Fountain/Tap Combo	Room 205	1 of 1	Tap	center	18
2	414815	Building 5	Sink	Kitchen	1 of 1	Tap	center	13
3	414824	Building 1	Fountain/Tap Combo	Room 102	1 of 1	Tap	center	12
4	414818	Building 4	Fountain/Tap Combo	Nurses Office	1 of 1	Tap	center	11
5	414822	Building 1	Fountain/Tap Combo	Room 101	1 of 1	Tap	center	11
6	415642	Building 3	Fountain/Tap Combo	Room 313	1 of 1	Tap	center	11
7	415648	Building 3	Fountain/Tap Combo	Room 315	1 of 1	Tap	center	11
8	414820	Building 4	Fountain/Tap Combo	Work Room	1 of 1	Tap	left	10
9	414834	Building 2	Fountain/Tap Combo	Room 209	1 of 1	Tap	center	10
10	415650	Building 3	Fountain/Tap Combo	Room 316	1 of 1	Tap	center	10

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	415652	Building 3	Fountain/Tap Combo	Room 317	1 of 1	Tap	center	10
12	414836	Building 2	Fountain/Tap Combo	Room 210	1 of 1	Tap	center	9
13	415640	Building 2	Fountain/Tap Combo	Room 212	1 of 1	Tap	center	9
14	415644	Building 3	Fountain/Tap Combo	Room 314	1 of 1	Tap	center	9
15	414816	Building 5	Sink	Kitchen	1 of 1	Sprayer	center	8
16	414817	Building 4	Sink	Staff Lounge	1 of 1	Tap	center	8
17	414828	Building 2	Fountain/Tap Combo	Room 206	1 of 1	Tap	center	8
18	414830	Building 2	Fountain/Tap Combo	Room 207	1 of 1	Tap	center	8
19	415656	Building 3	Fountain/Tap Combo	Room 318	1 of 1	Tap	center	8
20	414838	Building 2	Fountain/Tap Combo	Room 211	1 of 1	Tap	center	7
21	414826	Building 1	Fountain/Tap Combo	Room 104	1 of 1	Tap	center	5
22	414832	Building 2	Fountain/Tap Combo	Room 208	1 of 1	Tap	center	5

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
23	414819	Building 4	Fountain/Tap Combo	Nurses Office	1 of 1	Water Fountain	right	3
24	414829	Building 2	Fountain/Tap Combo	Room 206	1 of 1	Water Fountain	right	3
25	415645	Building 3	Fountain/Tap Combo	Room 314	1 of 1	Water Fountain	right	3
26	415647	Building 4	Fountain - Multi-Level	Gym	1 of 1	Water Fountain	right	3
27	414821	Building 4	Fountain/Tap Combo	Work Room	1 of 1	Water Fountain	right	2
28	414823	Building 1	Fountain/Tap Combo	Room 101	1 of 1	Water Fountain	right	2
29	414825	Building 1	Fountain/Tap Combo	Room 102	1 of 1	Water Fountain	right	2
30	414831	Building 2	Fountain/Tap Combo	Room 207	1 of 1	Water Fountain	right	2
31	414833	Building 2	Fountain/Tap Combo	Room 208	1 of 1	Water Fountain	right	2
32	414837	Building 2	Fountain/Tap Combo	Room 210	1 of 1	Water Fountain	right	2
33	415641	Building 2	Fountain/Tap Combo	Room 212	1 of 1	Water Fountain	right	2

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
34	415643	Building 3	Fountain/Tap Combo	Room 313	1 of 1	Water Fountain	right	2
35	415646	Building 4	Fountain - Multi-Level	Gym	1 of 1	Water Fountain	left	2
36	415649	Building 3	Fountain/Tap Combo	Room 315	1 of 1	Water Fountain	right	2
37	415651	Building 3	Fountain/Tap Combo	Room 316	1 of 1	Water Fountain	right	2
38	415654	Building 3	Fountain/Tap Combo	Room 317	1 of 1	Water Fountain	right	2
39	414835	Building 2	Fountain/Tap Combo	Room 209	1 of 1	Water Fountain	right	1
40	414839	Building 2	Fountain/Tap Combo	Room 211	1 of 1	Water Fountain	right	1
41	415658	Building 3	Fountain/Tap Combo	Room 318	1 of 1	Water Fountain	right	1