

March 5, 2025

Mr. Bill Bosinski
Orchard Park CSD
2240 Southwestern Boulevard
West Seneca, New York 14224

Re: Lead Testing in School Drinking Water

Dear Mr. Bosinski:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Orchard Park Central School District, including:

- Ellicott Elementary – 5180 Ellicott Road, Orchard Park, New York

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: *Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on February 8, 2025. As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 24 sources of potable water in Ellicott Elementary have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion. To comply with NYS regulations, response actions by the district are required. Response actions are outlined in Section 1.3 (*Response Actions Required Under NYS Regulations*).

Thank you for the opportunity to be of service to Orchard Park Central School District.

Sincerely,
Stohl Environmental, LLC.



Michael Scinta
EPA Lead Risk Assessor

Lead Testing in School Drinking Water

Prepared for:

Orchard Park Central School District

Prepared by:



3860 California Road
Orchard Park, New York 14127

Conditions as of February 8, 2025

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports and Chain of Custody Documents
- 1.5. Laboratory Certifications

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Orchard Park Central School District to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- Ellicott Elementary – 5180 Ellicott Road, Orchard Park, New York

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within Ellicott Elementary. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, *Subpart 67-4: Lead Testing in School Drinking Water*, and the EPA guidance document, *3Ts for Reducing Lead in Drinking Water in Schools*, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at Ellicott Elementary:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Ellicott Elementary	February 8, 2025	83	59	24

*NYS Action Level is 5 parts per billion

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
103.3-03	Kitchen Triple Right	Sink	5.6
103.3-09	A5 Fountain	Drinking Fountain	34.8
103.3-16	A Wing Fountain	Drinking Fountain	7.9
103.3-23	B12 Main	Sink	7.5
103.3-33	M03 Main	Sink	7.2
103.3-35	M08 Nurse Back	Sink	5.9
103.3-43	C Wing Bubbler	Drinking Fountain	9.2
103.3-45	C16	Sink	23.0
103.3-46	C15	Sink	96.8
103.3-49	C9	Sink	6.4
103.3-52	M17g	Drinking Fountain	21.8
103.3-56	M21 Fountain	Drinking Fountain	28.9
103.3-58	M23 Fountain	Drinking Fountain	53.3
103.3-61	M31 Fountain	Drinking Fountain	35.0
103.3-66	D10 Fountain	Drinking Fountain	53.6
103.3-67	D12	Sink	8.5
103.3-68	D12 Fountain	Drinking Fountain	47.8
103.3-70	D13 Fountain	Drinking Fountain	41.2
103.3-71	D11	Sink	5.7
103.3-72	D11 Fountain	Drinking Fountain	38.6
103.3-73	D9	Sink	14.1
103.3-74	D9 Fountain	Drinking Fountain	52.6
103.3-76	D7 Fountain	Drinking Fountain	45.5
103.3-77	Instrumental Music Storage	Drinking Fountain	7.1

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration more than the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports and Chain of Custody Documents



February 25, 2025

Service Request No:R2501631

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Orchard Park CSD Ellicott Elementary

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory February 14, 2025
For your reference, these analyses have been assigned our service request number **R2501631**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | **FAX** +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary
Sample Matrix: Drinking Water

Service Request: R2501631
Date Received: 02/14/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 02/14/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 02/25/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 103.3-01		Lab ID: R2501631-001					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.1			1.0	ug/L	200.8	
CLIENT ID: 103.3-02		Lab ID: R2501631-002					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.9			1.0	ug/L	200.8	
CLIENT ID: 103.3-03		Lab ID: R2501631-003					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.6			1.0	ug/L	200.8	
CLIENT ID: 103.3-05		Lab ID: R2501631-005					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.3			1.0	ug/L	200.8	
CLIENT ID: 103.3-07		Lab ID: R2501631-007					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.6			1.0	ug/L	200.8	
CLIENT ID: 103.3-09		Lab ID: R2501631-009					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	34.8			1.0	ug/L	200.8	
CLIENT ID: 103.3-10		Lab ID: R2501631-010					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.9			1.0	ug/L	200.8	
CLIENT ID: 103.3-11		Lab ID: R2501631-011					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.5			1.0	ug/L	200.8	
CLIENT ID: 103.3-13		Lab ID: R2501631-013					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.4			1.0	ug/L	200.8	
CLIENT ID: 103.3-14		Lab ID: R2501631-014					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.8			1.0	ug/L	200.8	
CLIENT ID: 103.3-15		Lab ID: R2501631-015					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.6			1.0	ug/L	200.8	
CLIENT ID: 103.3-16		Lab ID: R2501631-016					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	7.9			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 103.3-17		Lab ID: R2501631-017					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.6			1.0	ug/L	200.8	
CLIENT ID: 103.3-19		Lab ID: R2501631-020					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.5			1.0	ug/L	200.8	
CLIENT ID: 103.3-20		Lab ID: R2501631-021					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.1			1.0	ug/L	200.8	
CLIENT ID: 103.3-21		Lab ID: R2501631-022					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.3			1.0	ug/L	200.8	
CLIENT ID: 103.3-22		Lab ID: R2501631-023					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.8			1.0	ug/L	200.8	
CLIENT ID: 103.3-23		Lab ID: R2501631-024					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	7.5			1.0	ug/L	200.8	
CLIENT ID: 103.3-24		Lab ID: R2501631-025					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.7			1.0	ug/L	200.8	
CLIENT ID: 103.3-25		Lab ID: R2501631-026					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.9			1.0	ug/L	200.8	
CLIENT ID: 103.3-26		Lab ID: R2501631-027					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.8			1.0	ug/L	200.8	
CLIENT ID: 103.3-27		Lab ID: R2501631-028					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.6			1.0	ug/L	200.8	
CLIENT ID: 103.3-28		Lab ID: R2501631-029					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.6			1.0	ug/L	200.8	
CLIENT ID: 103.3-29		Lab ID: R2501631-030					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.4			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 103.3-30	Lab ID: R2501631-031					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.9			1.0	ug/L	200.8

CLIENT ID: 103.3-33	Lab ID: R2501631-034					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	7.2			1.0	ug/L	200.8

CLIENT ID: 103.3-35	Lab ID: R2501631-036					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.9			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3

Service Request:R2501631

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2501631-001	103.3-01	2/8/2025	0730
R2501631-002	103.3-02	2/8/2025	0731
R2501631-003	103.3-03	2/8/2025	0732
R2501631-004	103.3-04	2/8/2025	0733
R2501631-005	103.3-05	2/8/2025	0734
R2501631-006	103.3-06	2/8/2025	0735
R2501631-007	103.3-07	2/8/2025	0736
R2501631-008	103.3-08	2/8/2025	0737
R2501631-009	103.3-09	2/8/2025	0738
R2501631-010	103.3-10	2/8/2025	0739
R2501631-011	103.3-11	2/8/2025	0740
R2501631-012	103.3-12	2/8/2025	0741
R2501631-013	103.3-13	2/8/2025	0742
R2501631-014	103.3-14	2/8/2025	0743
R2501631-015	103.3-15	2/8/2025	0744
R2501631-016	103.3-16	2/8/2025	0745
R2501631-017	103.3-17	2/8/2025	0746
R2501631-018	103.3-18A	2/8/2025	0747
R2501631-019	103.3-18b	2/8/2025	0748
R2501631-020	103.3-19	2/8/2025	0749
R2501631-021	103.3-20	2/8/2025	0750
R2501631-022	103.3-21	2/8/2025	0751
R2501631-023	103.3-22	2/8/2025	0752
R2501631-024	103.3-23	2/8/2025	0753
R2501631-025	103.3-24	2/8/2025	0754
R2501631-026	103.3-25	2/8/2025	0755
R2501631-027	103.3-26	2/8/2025	0756
R2501631-028	103.3-27	2/8/2025	0757
R2501631-029	103.3-28	2/8/2025	0758
R2501631-030	103.3-29	2/8/2025	0759
R2501631-031	103.3-30	2/8/2025	0800
R2501631-032	103.3-31	2/8/2025	0801
R2501631-033	103.3-32	2/8/2025	0802
R2501631-034	103.3-33	2/8/2025	0803
R2501631-035	103.3-34	2/8/2025	0804
R2501631-036	103.3-35	2/8/2025	0805



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-103.3

Client: Orchard Park CSD Contact: Bill Bosinski

Building: Ellicott Elementary Location: 5180 Ellicott Rd, Orchard Park, NY 14127

LEAD		<i>Turnaround</i>
Water by 200.8	<u>X</u>	<u>10 Days</u>

Sample #	Location	Outlet Type	Time
103.3-01	double basin	Sink	7:30
103.3-02	triple left	Sink	7:31
103.3-03	triple right	Sink	7:32
103.3-04	prep sink	Sink	7:33
103.3-05	service window sink	Sink	7:34
103.3-06	small cafe	Drinking Fountain	7:35
103.3-07	A5 Left	Sink	7:36
103.3-08	A5 Right	Sink	7:37
103.3-09	A5 fountain	Drinking Fountain	7:38
103.3-10	A4 Left	Sink	7:39
103.3-11	A4 Right	Sink	7:40
103.3-12	A4 Fountain	Drinking Fountain	7:41
103.3-13	A3 Main	Sink	7:42
103.3-14	A2 Main	Sink	7:43
103.3-15	A1 Main	Sink	7:44
103.3-16	A Wing Fountain	Drinking Fountain	7:45
103.3-17	B2 Main	Sink	7:46
103.3-18A	B Wing Fountain	Drinking Fountain	7:47

Notes:
 Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to: Rfranoine@stohlenvironmental.com

Sampled By: Rebecca Franjoine Print Name Stohl Env: Rebecca Franjoine Date: 2/8/2025

Relinquished By: Rebecca Franjoine Print Name Stohl Env: Rebecca Franjoine Date: _____

Received (Name / Lab): Albi Austin ALS Date: 2/14/25 Time: 1330

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

R2501631 **5**
 Stohl Environmental
 Orchard Park CSD Ellicott Elementary



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-103.3

Client: Orchard Park CSD

Contact: Bill Bosinski

Building: Ellicott Elementary

Location: 5180 Ellicott Rd, Orchard Park, NY 14127

LEAD
 Water by 200.8 X

Turnaround
10 Days

Sample #	Location	Outlet Type	Time
103.3-18B	B wing Fountain	Bottle Fill	7:48
103.3-19	B4 Main	Sink	7:49
103.3-20	B6 Main	Sink	7:50
103.3-21	B8 Main	Sink	7:51
103.3-22	B10 Main	Sink	7:52
103.3-23	B12 Main	Sink	7:53
103.3-24	B14 Main	Sink	7:54
103.3-25	B13 Main	Sink	7:55
103.3-26	B11 Main	Sink	7:56
103.3-27	B9 Main	Sink	7:57
103.3-28	B7 Main	Sink	7:58
103.3-29	B5 Main	Sink	7:59
103.3-30	B3 Main	Sink	8:00
103.3-31	B1 Staff Room Kit	Sink	8:01
103.3-32	M1 Music	Sink	8:02
103.3-33	M03 Main	Sink	8:03
103.3-34	M08 Nurse Main	Sink	8:04
103.3-35	M08 Nurse Back	Sink	8:05

Notes: Please e-mail lab results to labs@stohlenvironmental.com Rfranjoine@stohlenvironmental.com

Sampled By: Rebecca Franjoine Print Name Stohl Env: Rebecca Franjoine Date: 2/8/2025
 Relinquished By: Rebecca Franjoine Print Name Stohl Env: Rebecca Franjoine Date: 1/0/1900
 Received (Name / Lab): [Signature] Date: 2/14/23 Time: 1330
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



R2501631 5

Stohl Environmental
Orchard Park CSD Ellcott Elementary



Cooler Receipt and Preservation Check Form

Project/Client _____ Folder Number _____

Cooler received on 2/14/25 by: AA

COURIER: (ALS) UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>(N)</u>	5a	Did VOA vials have sig* bubbles?	Y N <u>(NA)</u>
2	Custody papers properly completed (ink, signed)?	<u>(Y)</u> N	5b	Sig* bubbles: Alk? Y N <u>(NA)</u> Sulfide? Y N <u>(NA)</u>	
3	Did all bottles arrive in good condition (unbroken)?	<u>(Y)</u> N	6	Where did the bottles originate?	<u>(ALS/ROC)</u> CLIENT
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>(N)</u>	7	Soil VOA received as: Bulk Encore 5035set	<u>(NA)</u>

8. Temperature Readings Date: 2/14/25 Time: 1346 ID: IR#12 (R#11) From: Temp Blank (Sample Bottle)

Temp (°C)	<u>15.9</u>						
Within 0-6°C?	Y <u>(N)</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMO by AA on 2/14 at 1349
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 2/14/25 Time: 1529 by: AA

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES (NO) no date or time
- 10. Did all bottle labels and tags agree with custody papers? YES (NO)
- 11. Were correct containers used for the tests indicated? (YES) NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO (N/A)
- 13. Were dissolved metals filtered in the field? YES NO (N/A)
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated (N/A)

Limits	Lot of test paper	Reagent	In Limits?		Lot Received	Exp.	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
pH ≥12		NaOH								
pH ≤		HNO ₃		✓			<u>all</u>	<u>4mL</u>	<u>239258</u>	<u>4.2</u>
pH ≤		H ₂ SO ₄								
pH <4		522 NaHSO ₄								
pH 5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃	-	-						
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 110424-2ADD

Explain all Discrepancies/ Other Comments: _____

HPROD.	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AA

*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3

Service Request: R2501631

Sample Name: 103.3-01
Lab Code: R2501631-001
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-02
Lab Code: R2501631-002
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-03
Lab Code: R2501631-003
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-04
Lab Code: R2501631-004
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-05
Lab Code: R2501631-005
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3

Service Request: R2501631

Sample Name: 103.3-06
Lab Code: R2501631-006
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-07
Lab Code: R2501631-007
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-08
Lab Code: R2501631-008
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-09
Lab Code: R2501631-009
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-10
Lab Code: R2501631-010
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3

Service Request: R2501631

Sample Name: 103.3-11
Lab Code: R2501631-011
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-12
Lab Code: R2501631-012
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-13
Lab Code: R2501631-013
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-14
Lab Code: R2501631-014
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-15
Lab Code: R2501631-015
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3

Service Request: R2501631

Sample Name: 103.3-16
Lab Code: R2501631-016
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-17
Lab Code: R2501631-017
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-18A
Lab Code: R2501631-018
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-18b
Lab Code: R2501631-019
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-19
Lab Code: R2501631-020
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3

Service Request: R2501631

Sample Name: 103.3-20
Lab Code: R2501631-021
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-21
Lab Code: R2501631-022
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-22
Lab Code: R2501631-023
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-23
Lab Code: R2501631-024
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-24
Lab Code: R2501631-025
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3

Service Request: R2501631

Sample Name: 103.3-25
Lab Code: R2501631-026
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-26
Lab Code: R2501631-027
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-27
Lab Code: R2501631-028
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-28
Lab Code: R2501631-029
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-29
Lab Code: R2501631-030
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3

Service Request: R2501631

Sample Name: 103.3-30
Lab Code: R2501631-031
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-31
Lab Code: R2501631-032
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-32
Lab Code: R2501631-033
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-33
Lab Code: R2501631-034
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-34
Lab Code: R2501631-035
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3

Service Request: R2501631

Sample Name: 103.3-35
Lab Code: R2501631-036
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7	200.2
200.8	200.2
6010C or 6010D	3005A/3010A
6020A or 6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010C or 6010D	3050B
6020A or 6020B	3050B
6010C or 6010D TCLP (1311) extract	3005A/3010A
6010C or 6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-01
Lab Code: R2501631-001

Service Request: R2501631
Date Collected: 02/08/25 07:30
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.1	ug/L	1.0	1	02/21/25 13:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-02
Lab Code: R2501631-002

Service Request: R2501631
Date Collected: 02/08/25 07:31
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.9	ug/L	1.0	1	02/21/25 13:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-03
Lab Code: R2501631-003

Service Request: R2501631
Date Collected: 02/08/25 07:32
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.6	ug/L	1.0	1	02/21/25 13:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-04
Lab Code: R2501631-004

Service Request: R2501631
Date Collected: 02/08/25 07:33
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 13:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-05
Lab Code: R2501631-005

Service Request: R2501631
Date Collected: 02/08/25 07:34
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	02/21/25 13:14	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-06
Lab Code: R2501631-006

Service Request: R2501631
Date Collected: 02/08/25 07:35
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 13:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-07
Lab Code: R2501631-007

Service Request: R2501631
Date Collected: 02/08/25 07:36
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.6	ug/L	1.0	1	02/21/25 13:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-08
Lab Code: R2501631-008

Service Request: R2501631
Date Collected: 02/08/25 07:37
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 13:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-09
Lab Code: R2501631-009

Service Request: R2501631
Date Collected: 02/08/25 07:38
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	34.8	ug/L	1.0	1	02/21/25 13:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-10
Lab Code: R2501631-010

Service Request: R2501631
Date Collected: 02/08/25 07:39
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.9	ug/L	1.0	1	02/21/25 13:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-11
Lab Code: R2501631-011

Service Request: R2501631
Date Collected: 02/08/25 07:40
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	02/21/25 13:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-12
Lab Code: R2501631-012

Service Request: R2501631
Date Collected: 02/08/25 07:41
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 13:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-13
Lab Code: R2501631-013

Service Request: R2501631
Date Collected: 02/08/25 07:42
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.4	ug/L	1.0	1	02/21/25 13:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-14
Lab Code: R2501631-014

Service Request: R2501631
Date Collected: 02/08/25 07:43
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.8	ug/L	1.0	1	02/21/25 13:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-15
Lab Code: R2501631-015

Service Request: R2501631
Date Collected: 02/08/25 07:44
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.6	ug/L	1.0	1	02/21/25 13:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-16
Lab Code: R2501631-016

Service Request: R2501631
Date Collected: 02/08/25 07:45
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.9	ug/L	1.0	1	02/21/25 13:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-17
Lab Code: R2501631-017

Service Request: R2501631
Date Collected: 02/08/25 07:46
Date Received: 02/14/25 13:30

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.6	ug/L	1.0	1	02/21/25 13:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-18A
Lab Code: R2501631-018

Service Request: R2501631
Date Collected: 02/08/25 07:47
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 13:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-18b
Lab Code: R2501631-019

Service Request: R2501631
Date Collected: 02/08/25 07:48
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 13:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-19
Lab Code: R2501631-020

Service Request: R2501631
Date Collected: 02/08/25 07:49
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	02/21/25 13:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-20
Lab Code: R2501631-021

Service Request: R2501631
Date Collected: 02/08/25 07:50
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.1	ug/L	1.0	1	02/21/25 13:56	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-21
Lab Code: R2501631-022

Service Request: R2501631
Date Collected: 02/08/25 07:51
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.3	ug/L	1.0	1	02/21/25 13:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-22
Lab Code: R2501631-023

Service Request: R2501631
Date Collected: 02/08/25 07:52
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.8	ug/L	1.0	1	02/21/25 13:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-23
Lab Code: R2501631-024

Service Request: R2501631
Date Collected: 02/08/25 07:53
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.5	ug/L	1.0	1	02/21/25 14:00	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-24
Lab Code: R2501631-025

Service Request: R2501631
Date Collected: 02/08/25 07:54
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.7	ug/L	1.0	1	02/21/25 14:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-25
Lab Code: R2501631-026

Service Request: R2501631
Date Collected: 02/08/25 07:55
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.9	ug/L	1.0	1	02/21/25 14:03	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-26
Lab Code: R2501631-027

Service Request: R2501631
Date Collected: 02/08/25 07:56
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.8	ug/L	1.0	1	02/21/25 14:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-27
Lab Code: R2501631-028

Service Request: R2501631
Date Collected: 02/08/25 07:57
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.6	ug/L	1.0	1	02/21/25 14:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-28
Lab Code: R2501631-029

Service Request: R2501631
Date Collected: 02/08/25 07:58
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.6	ug/L	1.0	1	02/21/25 14:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-29
Lab Code: R2501631-030

Service Request: R2501631
Date Collected: 02/08/25 07:59
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.4	ug/L	1.0	1	02/21/25 14:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-30
Lab Code: R2501631-031

Service Request: R2501631
Date Collected: 02/08/25 08:00
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.9	ug/L	1.0	1	02/21/25 14:14	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-31
Lab Code: R2501631-032

Service Request: R2501631
Date Collected: 02/08/25 08:01
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 14:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-32
Lab Code: R2501631-033

Service Request: R2501631
Date Collected: 02/08/25 08:02
Date Received: 02/14/25 13:30

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 14:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-33
Lab Code: R2501631-034

Service Request: R2501631
Date Collected: 02/08/25 08:03
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.2	ug/L	1.0	1	02/21/25 14:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-34
Lab Code: R2501631-035

Service Request: R2501631
Date Collected: 02/08/25 08:04
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 14:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-35
Lab Code: R2501631-036

Service Request: R2501631
Date Collected: 02/08/25 08:05
Date Received: 02/14/25 13:30

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.9	ug/L	1.0	1	02/21/25 14:33	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2501631-MB1

Service Request: R2501631
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 12:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2501631-MB2

Service Request: R2501631
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 13:38	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2501631-MB3

Service Request: R2501631
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 14:26	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water

Service Request: R2501631
Date Collected: 02/08/25
Date Received: 02/14/25
Date Analyzed: 02/21/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 103.3-14
Lab Code: R2501631-014
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2501631-014MS		Duplicate Matrix Spike R2501631-014DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	1.8	22.0	20.0	101	22.0	20.0	101	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water

Service Request: R2501631
Date Collected: 02/08/25
Date Received: 02/14/25
Date Analyzed: 02/21/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 103.3-15
Lab Code: R2501631-015
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2501631-015MS		Duplicate Matrix Spike R2501631-015DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	3.6	24.0	20.0	102	25.1	20.0	108	70-130	4	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water

Service Request: R2501631
Date Collected: 02/08/25
Date Received: 02/14/25
Date Analyzed: 02/21/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 103.3-33
Lab Code: R2501631-034
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2501631-034MS		Duplicate Matrix Spike R2501631-034DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	7.2	28.2	20.0	105	28.3	20.0	105	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water

Service Request: R2501631
Date Collected: 02/08/25
Date Received: 02/14/25
Date Analyzed: 02/21/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 103.3-34
Lab Code: R2501631-035
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2501631-035MS		Duplicate Matrix Spike R2501631-035DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	21.5	20.0	108	21.7	20.0	108	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water

Service Request: R2501631

Date Analyzed: 02/21/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample
R2501631-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.9	20.0	104	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water

Service Request: R2501631
Date Analyzed: 02/21/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2501631-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.3	20.0	107	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water

Service Request: R2501631
Date Analyzed: 02/21/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2501631-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.6	20.0	108	85-115



February 25, 2025

Service Request No:R2501635

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Orchard Park CSD Ellicott Elementary

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory February 14, 2025
For your reference, these analyses have been assigned our service request number **R2501635**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary
Sample Matrix: Drinking Water

Service Request: R2501635
Date Received: 02/14/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Forty seven drinking water samples were received for analysis at ALS Environmental on 02/14/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 02/25/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 103.3-36		Lab ID: R2501635-001					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.5			1.0	ug/L	200.8	
CLIENT ID: 103.3-38		Lab ID: R2501635-003					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.6			1.0	ug/L	200.8	
CLIENT ID: 103.3-41		Lab ID: R2501635-007					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.2			1.0	ug/L	200.8	
CLIENT ID: 103.3-42		Lab ID: R2501635-008					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.4			1.0	ug/L	200.8	
CLIENT ID: 103.3-43		Lab ID: R2501635-009					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	9.2			1.0	ug/L	200.8	
CLIENT ID: 103.3-44		Lab ID: R2501635-010					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.0			1.0	ug/L	200.8	
CLIENT ID: 103.3-45		Lab ID: R2501635-011					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	23.0			1.0	ug/L	200.8	
CLIENT ID: 103.3-46		Lab ID: R2501635-012					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	96.8			1.0	ug/L	200.8	
CLIENT ID: 103.3-49		Lab ID: R2501635-015					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	6.4			1.0	ug/L	200.8	
CLIENT ID: 103.3-50		Lab ID: R2501635-016					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.5			1.0	ug/L	200.8	
CLIENT ID: 103.3-51		Lab ID: R2501635-017					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.1			1.0	ug/L	200.8	
CLIENT ID: 103.3-52		Lab ID: R2501635-018					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	21.8			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 103.3-54		Lab ID: R2501635-020					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.0			1.0	ug/L	200.8	
CLIENT ID: 103.3-55		Lab ID: R2501635-021					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.6			1.0	ug/L	200.8	
CLIENT ID: 103.3-56		Lab ID: R2501635-022					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	28.9			1.0	ug/L	200.8	
CLIENT ID: 103.3-58		Lab ID: R2501635-024					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	53.3			1.0	ug/L	200.8	
CLIENT ID: 103.3-59		Lab ID: R2501635-025					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.0			1.0	ug/L	200.8	
CLIENT ID: 103.3-60		Lab ID: R2501635-026					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.7			1.0	ug/L	200.8	
CLIENT ID: 103.3-61		Lab ID: R2501635-027					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	35.0			1.0	ug/L	200.8	
CLIENT ID: 103.3-62		Lab ID: R2501635-028					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.1			1.0	ug/L	200.8	
CLIENT ID: 103.3-64		Lab ID: R2501635-031					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.5			1.0	ug/L	200.8	
CLIENT ID: 103.3-65		Lab ID: R2501635-032					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.0			1.0	ug/L	200.8	
CLIENT ID: 103.3-66		Lab ID: R2501635-033					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	53.6			1.0	ug/L	200.8	
CLIENT ID: 103.3-67		Lab ID: R2501635-034					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	8.5			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 103.3-68		Lab ID: R2501635-035				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	47.8			1.0	ug/L	200.8
CLIENT ID: 103.3-69		Lab ID: R2501635-036				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.3			1.0	ug/L	200.8
CLIENT ID: 103.3-70		Lab ID: R2501635-037				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	41.2			1.0	ug/L	200.8
CLIENT ID: 103.3-71		Lab ID: R2501635-038				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.7			1.0	ug/L	200.8
CLIENT ID: 103.3-72		Lab ID: R2501635-039				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	38.6			1.0	ug/L	200.8
CLIENT ID: 103.3-73		Lab ID: R2501635-040				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	14.1			1.0	ug/L	200.8
CLIENT ID: 103.3-74		Lab ID: R2501635-041				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	52.6			1.0	ug/L	200.8
CLIENT ID: 103.3-76		Lab ID: R2501635-043				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	45.5			1.0	ug/L	200.8
CLIENT ID: 103.3-77		Lab ID: R2501635-044				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	7.1			1.0	ug/L	200.8
CLIENT ID: 103.3-78		Lab ID: R2501635-045				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.7			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3

Service Request:R2501635

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2501635-001	103.3-36	2/8/2025	0806
R2501635-002	103.3-37	2/8/2025	0807
R2501635-003	103.3-38	2/8/2025	0808
R2501635-004	103.3-39A	2/8/2025	0809
R2501635-005	103.3-39B	2/8/2025	0810
R2501635-006	103.3-40	2/8/2025	0811
R2501635-007	103.3-41	2/8/2025	0812
R2501635-008	103.3-42	2/8/2025	0813
R2501635-009	103.3-43	2/8/2025	0814
R2501635-010	103.3-44	2/8/2025	0815
R2501635-011	103.3-45	2/8/2025	0816
R2501635-012	103.3-46	2/8/2025	0817
R2501635-013	103.3-47	2/8/2025	0818
R2501635-014	103.3-48	2/8/2025	0819
R2501635-015	103.3-49	2/8/2025	0820
R2501635-016	103.3-50	2/8/2025	0821
R2501635-017	103.3-51	2/8/2025	0822
R2501635-018	103.3-52	2/8/2025	0823
R2501635-019	103.3-53	2/8/2025	0824
R2501635-020	103.3-54	2/8/2025	0825
R2501635-021	103.3-55	2/8/2025	0826
R2501635-022	103.3-56	2/8/2025	0827
R2501635-023	103.3-57	2/8/2025	0828
R2501635-024	103.3-58	2/8/2025	0829
R2501635-025	103.3-59	2/8/2025	0830
R2501635-026	103.3-60	2/8/2025	0831
R2501635-027	103.3-61	2/8/2025	0832
R2501635-028	103.3-62	2/8/2025	0833
R2501635-029	103.3-63A	2/8/2025	0834
R2501635-030	103.3-63B	2/8/2025	0835
R2501635-031	103.3-64	2/8/2025	0836
R2501635-032	103.3-65	2/8/2025	0837
R2501635-033	103.3-66	2/8/2025	0838
R2501635-034	103.3-67	2/8/2025	0839
R2501635-035	103.3-68	2/8/2025	0840
R2501635-036	103.3-69	2/8/2025	0841
R2501635-037	103.3-70	2/8/2025	0842
R2501635-038	103.3-71	2/8/2025	0843
R2501635-039	103.3-72	2/8/2025	0844
R2501635-040	103.3-73	2/8/2025	0845
R2501635-041	103.3-74	2/8/2025	0846
R2501635-042	103.3-75	2/8/2025	0847

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3

Service Request:R2501635

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2501635-043	103.3-76	2/8/2025	0848
R2501635-044	103.3-77	2/8/2025	0849
R2501635-045	103.3-78	2/8/2025	0850
R2501635-046	103.3-79A	2/8/2025	0851
R2501635-047	103.3-79B	2/8/2025	0852



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-103.3

Client: Orchard Park CSD

Contact: Bill Bosinski

Building: Ellicott Elementary

Location: 5180 Ellicott Rd, Orchard Park, NY 14127

LEAD
 Water by 200.8 X


Turnaround
10 Days

Sample #	Location
103.3-36	M10
103.3-37	M14
103.3-38	C2
103.3-39A	C Wing Fountain
103.3-39B	C Wing Fountain
103.3-40	C8
103.3-41	C10
103.3-42	C12
103.3-43	C Wing Bubblers
103.3-44	C14
103.3-45	C16
103.3-46	C15
103.3-47	C13
103.3-48	C11
103.3-49	C9
103.3-50	C7
103.3-51	C5
103.3-52	M17G

Outlet Type	Time
Sink	8:06
Sink	8:07
Sink	8:08
Drinking Fountain	8:09
Bottle Fill	8:10
Sink	8:11
Sink	8:12
Sink	8:13
Drinking Fountain	8:14
Sink	8:15
Sink	8:16
Sink	8:17
Sink	8:18
Sink	8:19
Sink	8:20
Sink	8:21
Sink	8:22
Drinking Fountain	8:23

Notes:
 Please e-mail lab results to labs@stohlenv.com Rfranjoine@stohlenvironmental.com

Sampled By: Rebecca Franjoine Print Name Rebecca Franjoine Stohl Env: Rebecca Franjoine Date: 2/8/2025
 Relinquished By: Rebecca Franjoine Print Name Rebecca Franjoine Stohl Env: Rebecca Franjoine Date: 1/0/1900
 Received (Name / Lab): Abbi Austin ALS Date: 2/14/23 Time: 1330
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____





Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-103.3

Client: Orchard Park CSD Contact: Bill Bosinski

Building: Ellicott Elementary Location: 5180 Ellicott Rd, Orchard Park, NY 14127

LEAD		Turnaround
Water by 200.8	<u>X</u>	<u>10 Days</u>

Sample #	Location	Outlet Type	Time
103.3-53	Boys Locker Room Next to M17G	Drinking Fountain	8:24
103.3-54	M19	Sink	8:25
103.3-55	M21	Sink	8:26
103.3-56	M21 Fountain	Drinking Fountain	8:27
103.3-57	M23	Sink	8:28
103.3-58	M23 Fountain	Drinking Fountain	8:29
103.3-59	M25	Sink	8:30
103.3-60	M31	Sink	8:31
103.3-61	M31 Fountain	Drinking Fountain	8:32
103.3-62	M24	Sink	8:33
103.3-63A	D Wing Fountain	Drinking Fountain	8:34
103.3-63B	D Wing Fountain	Bottle Fill	8:35
103.3-64	D8	Sink	8:36
103.3-65	D10	Sink	8:37
103.3-66	D10 Fountain	Drinking Fountain	8:38
103.3-67	D12	Sink	8:39
103.3-68	D12 fountain	Drinking Fountain	8:40
103.3-69	D13	Sink	8:41

Notes: Please e-mail lab results to labs@stohlenvironmental.com Rfranjoine@stohlenvironmental.com

Sampled By: Rebecca Franjoine Print Name Stohl Env: Rebecca Franjoine Date: 2/8/2025

Relinquished By: Rebecca Franjoine Print Name Stohl Env: Rebecca Franjoine Date: 1/0/1900

Received (Name / Lab): Chli Austin ALS Date: 2/14/25 Time: 1330

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-103.3

Client: Orchard Park CSD Contact: Bill Bosinski

Building: Ellicott Elementary Location: 5180 Ellicott Rd, Orchard Park, NY 14127

LEAD		<i>Turnaround</i>
Water by 200.8	<u>X</u>	<u>10 Days</u>

Sample #	Location	Outlet Type	Time
103.3-70	D13 Fountain	Drinking Fountain	8:42
103.3-71	D11	Sink	8:43
103.3-72	D11 Fountain	Drinking Fountain	8:44
103.3-73	D9	Sink	8:45
103.3-74	D9 Fountain	Drinking Fountain	8:46
103.3-75	D7	Sink	8:47
103.3-76	D7 Fountain	Drinking Fountain	8:48
103.3-77	Instrumental Music storage	Drinking Fountain	8:49
103.3-78	Boys locker room across from cafe	Drinking Fountain	8:50
103.3-79A	Cafeteria Fountain	Drinking Fountain	8:51
103.3-79B	Cafeteria Fountain	Bottle Fill	8:52

Notes:
 Please e-mail lab results to labs@stohlenv.com Rfranjoine@stohlenvironmental.com

Sampled By: Rebecca Franjoine Print Name Stohl Env: Rebecca Franjoine Date: 2/8/2025
 Relinquished By: Rebecca Franjoine Print Name Stohl Env: Rebecca Franjoine Date: 1/0/1900
 Received (Name / Lab): Albi Austin ALS Date: 2/14/23 Time: 1330
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Cooler Receipt and Preservation Check Form

Project/Client _____ Folder Number _____

Cooler received on 2/14/25 by: AA

COURIER: (ALS) UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>(N)</u>
2	Custody papers properly completed (ink, signed)?	Y <u>(N)</u>
3	Did all bottles arrive in good condition (unbroken)?	Y <u>(N)</u>
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>(N)</u>

5a	Did VOA vials have sig* bubbles?	Y N <u>(NA)</u>
5b	Sig* bubbles: Alk? Y N <u>(NA)</u> Sulfide? Y N <u>(NA)</u>	
6	Where did the bottles originate?	<u>(ALS/ROC)</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set	<u>(NA)</u>

8. Temperature Readings Date: 2/14/25 Time: 1346 ID: IR#12 (IR#11) From: Temp Blank (Sample Bottle)

Temp (°C)	<u>15.9</u>						
Within 0-6°C?	Y <u>(N)</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule
 & Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMO by AA on 2/14 at 1349
 5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 2/14/25 Time: 1522 by: AA

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES (NO) no date or time
- 10. Did all bottle labels and tags agree with custody papers? YES (NO)
- 11. Were correct containers used for the tests indicated? (YES) NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO (N/A)
- 13. Were dissolved metals filtered in the field? YES NO (N/A)
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated (N/A)

Limits	Lot of test paper	Reagent	In Limits?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
pH ≥12		NaOH								
pH ≤		HNO ₃		✓			<u>all</u>	<u>4ml</u>	<u>239258</u>	<u>≤2</u>
pH ≤		H ₂ SO ₄								
pH <4		522 NaHSO ₄								
pH 5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃	-	-						
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____
 Explain all Discrepancies/ Other Comments: _____

HPROD.	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: AA

*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3

Service Request: R2501635

Sample Name: 103.3-36
Lab Code: R2501635-001
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-37
Lab Code: R2501635-002
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-38
Lab Code: R2501635-003
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-39A
Lab Code: R2501635-004
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-39B
Lab Code: R2501635-005
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3

Service Request: R2501635

Sample Name: 103.3-40
Lab Code: R2501635-006
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-41
Lab Code: R2501635-007
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-42
Lab Code: R2501635-008
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-43
Lab Code: R2501635-009
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-44
Lab Code: R2501635-010
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3

Service Request: R2501635

Sample Name: 103.3-45
Lab Code: R2501635-011
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-46
Lab Code: R2501635-012
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-47
Lab Code: R2501635-013
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-48
Lab Code: R2501635-014
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-49
Lab Code: R2501635-015
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3

Service Request: R2501635

Sample Name: 103.3-50
Lab Code: R2501635-016
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-51
Lab Code: R2501635-017
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-52
Lab Code: R2501635-018
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-53
Lab Code: R2501635-019
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-54
Lab Code: R2501635-020
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3

Service Request: R2501635

Sample Name: 103.3-55
Lab Code: R2501635-021
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-56
Lab Code: R2501635-022
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-57
Lab Code: R2501635-023
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-58
Lab Code: R2501635-024
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-59
Lab Code: R2501635-025
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3

Service Request: R2501635

Sample Name: 103.3-60
Lab Code: R2501635-026
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-61
Lab Code: R2501635-027
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-62
Lab Code: R2501635-028
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-63A
Lab Code: R2501635-029
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-63B
Lab Code: R2501635-030
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3

Service Request: R2501635

Sample Name: 103.3-64
Lab Code: R2501635-031
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-65
Lab Code: R2501635-032
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-66
Lab Code: R2501635-033
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-67
Lab Code: R2501635-034
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-68
Lab Code: R2501635-035
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3

Service Request: R2501635

Sample Name: 103.3-69
Lab Code: R2501635-036
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-70
Lab Code: R2501635-037
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-71
Lab Code: R2501635-038
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-72
Lab Code: R2501635-039
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-73
Lab Code: R2501635-040
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3

Service Request: R2501635

Sample Name: 103.3-74
Lab Code: R2501635-041
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-75
Lab Code: R2501635-042
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-76
Lab Code: R2501635-043
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-77
Lab Code: R2501635-044
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-78
Lab Code: R2501635-045
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3

Service Request: R2501635

Sample Name: 103.3-79A
Lab Code: R2501635-046
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 103.3-79B
Lab Code: R2501635-047
Sample Matrix: Drinking Water

Date Collected: 02/8/25
Date Received: 02/14/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7	200.2
200.8	200.2
6010C or 6010D	3005A/3010A
6020A or 6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010C or 6010D	3050B
6020A or 6020B	3050B
6010C or 6010D TCLP (1311) extract	3005A/3010A
6010C or 6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-36
Lab Code: R2501635-001

Service Request: R2501635
Date Collected: 02/08/25 08:06
Date Received: 02/14/25 13:30

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	02/21/25 14:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-37
Lab Code: R2501635-002

Service Request: R2501635
Date Collected: 02/08/25 08:07
Date Received: 02/14/25 13:30

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 14:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-38
Lab Code: R2501635-003

Service Request: R2501635
Date Collected: 02/08/25 08:08
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.6	ug/L	1.0	1	02/21/25 14:38	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-39A
Lab Code: R2501635-004

Service Request: R2501635
Date Collected: 02/08/25 08:09
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 14:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-39B
Lab Code: R2501635-005

Service Request: R2501635
Date Collected: 02/08/25 08:10
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 14:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-40
Lab Code: R2501635-006

Service Request: R2501635
Date Collected: 02/08/25 08:11
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 14:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-41
Lab Code: R2501635-007

Service Request: R2501635
Date Collected: 02/08/25 08:12
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	02/21/25 14:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-42
Lab Code: R2501635-008

Service Request: R2501635
Date Collected: 02/08/25 08:13
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.4	ug/L	1.0	1	02/21/25 14:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-43
Lab Code: R2501635-009

Service Request: R2501635
Date Collected: 02/08/25 08:14
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	9.2	ug/L	1.0	1	02/21/25 14:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-44
Lab Code: R2501635-010

Service Request: R2501635
Date Collected: 02/08/25 08:15
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.0	ug/L	1.0	1	02/21/25 14:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-45
Lab Code: R2501635-011

Service Request: R2501635
Date Collected: 02/08/25 08:16
Date Received: 02/14/25 13:30

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	23.0	ug/L	1.0	1	02/21/25 14:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-46
Lab Code: R2501635-012

Service Request: R2501635
Date Collected: 02/08/25 08:17
Date Received: 02/14/25 13:30

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	96.8	ug/L	1.0	1	02/21/25 14:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-47
Lab Code: R2501635-013

Service Request: R2501635
Date Collected: 02/08/25 08:18
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 14:56	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-48
Lab Code: R2501635-014

Service Request: R2501635
Date Collected: 02/08/25 08:19
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 14:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-49
Lab Code: R2501635-015

Service Request: R2501635
Date Collected: 02/08/25 08:20
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.4	ug/L	1.0	1	02/21/25 15:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-50
Lab Code: R2501635-016

Service Request: R2501635
Date Collected: 02/08/25 08:21
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.5	ug/L	1.0	1	02/21/25 15:03	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-51
Lab Code: R2501635-017

Service Request: R2501635
Date Collected: 02/08/25 08:22
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.1	ug/L	1.0	1	02/21/25 15:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-52
Lab Code: R2501635-018

Service Request: R2501635
Date Collected: 02/08/25 08:23
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	21.8	ug/L	1.0	1	02/21/25 15:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-53
Lab Code: R2501635-019

Service Request: R2501635
Date Collected: 02/08/25 08:24
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 15:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-54
Lab Code: R2501635-020

Service Request: R2501635
Date Collected: 02/08/25 08:25
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.0	ug/L	1.0	1	02/21/25 15:21	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-55
Lab Code: R2501635-021

Service Request: R2501635
Date Collected: 02/08/25 08:26
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.6	ug/L	1.0	1	02/21/25 15:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-56
Lab Code: R2501635-022

Service Request: R2501635
Date Collected: 02/08/25 08:27
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	28.9	ug/L	1.0	1	02/21/25 15:24	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-57
Lab Code: R2501635-023

Service Request: R2501635
Date Collected: 02/08/25 08:28
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 15:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-58
Lab Code: R2501635-024

Service Request: R2501635
Date Collected: 02/08/25 08:29
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	53.3	ug/L	1.0	1	02/21/25 15:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-59
Lab Code: R2501635-025

Service Request: R2501635
Date Collected: 02/08/25 08:30
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0	ug/L	1.0	1	02/21/25 15:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-60
Lab Code: R2501635-026

Service Request: R2501635
Date Collected: 02/08/25 08:31
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.7	ug/L	1.0	1	02/21/25 15:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-61
Lab Code: R2501635-027

Service Request: R2501635
Date Collected: 02/08/25 08:32
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	35.0	ug/L	1.0	1	02/21/25 15:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-62
Lab Code: R2501635-028

Service Request: R2501635
Date Collected: 02/08/25 08:33
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	02/21/25 15:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-63A
Lab Code: R2501635-029

Service Request: R2501635
Date Collected: 02/08/25 08:34
Date Received: 02/14/25 13:30

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 15:38	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-63B
Lab Code: R2501635-030

Service Request: R2501635
Date Collected: 02/08/25 08:35
Date Received: 02/14/25 13:30

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 15:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-64
Lab Code: R2501635-031

Service Request: R2501635
Date Collected: 02/08/25 08:36
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	02/21/25 15:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-65
Lab Code: R2501635-032

Service Request: R2501635
Date Collected: 02/08/25 08:37
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.0	ug/L	1.0	1	02/21/25 15:42	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-66
Lab Code: R2501635-033

Service Request: R2501635
Date Collected: 02/08/25 08:38
Date Received: 02/14/25 13:30

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	53.6	ug/L	1.0	1	02/21/25 15:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-67
Lab Code: R2501635-034

Service Request: R2501635
Date Collected: 02/08/25 08:39
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.5	ug/L	1.0	1	02/21/25 15:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-68
Lab Code: R2501635-035

Service Request: R2501635
Date Collected: 02/08/25 08:40
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	47.8	ug/L	1.0	1	02/21/25 15:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-69
Lab Code: R2501635-036

Service Request: R2501635
Date Collected: 02/08/25 08:41
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	02/21/25 15:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-70
Lab Code: R2501635-037

Service Request: R2501635
Date Collected: 02/08/25 08:42
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	41.2	ug/L	1.0	1	02/21/25 15:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-71
Lab Code: R2501635-038

Service Request: R2501635
Date Collected: 02/08/25 08:43
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.7	ug/L	1.0	1	02/21/25 15:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-72
Lab Code: R2501635-039

Service Request: R2501635
Date Collected: 02/08/25 08:44
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	38.6	ug/L	1.0	1	02/21/25 16:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-73
Lab Code: R2501635-040

Service Request: R2501635
Date Collected: 02/08/25 08:45
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	14.1	ug/L	1.0	1	02/21/25 16:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-74
Lab Code: R2501635-041

Service Request: R2501635
Date Collected: 02/08/25 08:46
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	52.6	ug/L	1.0	1	02/21/25 16:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-75
Lab Code: R2501635-042

Service Request: R2501635
Date Collected: 02/08/25 08:47
Date Received: 02/14/25 13:30

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 16:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-76
Lab Code: R2501635-043

Service Request: R2501635
Date Collected: 02/08/25 08:48
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	45.5	ug/L	1.0	1	02/21/25 16:14	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-77
Lab Code: R2501635-044

Service Request: R2501635
Date Collected: 02/08/25 08:49
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.1	ug/L	1.0	1	02/21/25 16:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-78
Lab Code: R2501635-045

Service Request: R2501635
Date Collected: 02/08/25 08:50
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.7	ug/L	1.0	1	02/21/25 16:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-79A
Lab Code: R2501635-046

Service Request: R2501635
Date Collected: 02/08/25 08:51
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 16:21	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: 103.3-79B
Lab Code: R2501635-047

Service Request: R2501635
Date Collected: 02/08/25 08:52
Date Received: 02/14/25 13:30
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 16:23	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2501635-MB1

Service Request: R2501635
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 14:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2501635-MB2

Service Request: R2501635
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 15:14	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2501635-MB3

Service Request: R2501635
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	02/21/25 16:02	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water

Service Request: R2501635
Date Collected: 02/08/25
Date Received: 02/14/25
Date Analyzed: 02/21/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 103.3-52
Lab Code: R2501635-018
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2501635-018MS		Duplicate Matrix Spike R2501635-018DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	21.8	43.4	20.0	108	44.1	20.0	111	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water

Service Request: R2501635
Date Collected: 02/08/25
Date Received: 02/14/25
Date Analyzed: 02/21/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 103.3-53
Lab Code: R2501635-019
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2501635-019MS		Duplicate Matrix Spike R2501635-019DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	21.8	20.0	109	22.3	20.0	112	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water

Service Request: R2501635
Date Collected: 02/08/25
Date Received: 02/14/25
Date Analyzed: 02/21/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 103.3-71
Lab Code: R2501635-038
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2501635-038MS		Duplicate Matrix Spike R2501635-038DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	5.7	26.6	20.0	104	25.8	20.0	100	70-130	3	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water

Service Request: R2501635
Date Collected: 02/08/25
Date Received: 02/14/25
Date Analyzed: 02/21/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 103.3-72
Lab Code: R2501635-039
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2501635-039MS		Duplicate Matrix Spike R2501635-039DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	38.6	60.7	20.0	110	58.0	20.0	97	70-130	4	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water

Service Request: R2501635
Date Analyzed: 02/21/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2501635-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.6	20.0	108	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water

Service Request: R2501635
Date Analyzed: 02/21/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2501635-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.6	20.0	108	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Orchard Park CSD Ellicott Elementary/2023L-103.3
Sample Matrix: Drinking Water

Service Request: R2501635
Date Analyzed: 02/21/25

Lab Control Sample Summary
Inorganic Parameters


Units:ug/L
Basis:NA

Lab Control Sample
R2501635-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.3	20.0	107	85-115

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2025
Issued April 01, 2024

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE
Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. CHRISTINE KUTZER
ALS ENVIRONMENTAL - ROCHESTER
1565 JEFFERSON ROAD BUILDING 300, SUITE 360
ROCHESTER, NY 14623


NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Bacteriology	
Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Colilert)
Disinfection By-products	
Bromide	EPA 300.0 Rev. 2.1
Dissolved Gases	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
Fuel Additives	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
Metals I	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4

Serial No.: 68402

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdotn/applinks/wc/elapublicweb/>, by phone (518) 485-5570 or by email to etap@health.ny.gov.



Page 1 of 5