

PO Box 733  
Marlboro, NY 12542  
Phone 845-236-7823  
Fax 845-236-3911  
NYSDOH #10824

**ENVIRONMENTAL LABWORKS, INC.**

---

January 29, 2026

Ulster BOCES  
175 Route 32 N  
New Paltz, NY 12561

Dear James,


The following are results of the analyses performed on water samples from **iPark** received at the laboratory on 01/22/26.

Date/Time Collected: 01/22/26 7:12-7:13am First Draw  
Collected By: UC BOCES  
Project ID: 01222602  
Secondary ID: UB260400-01

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
Kitchen Storage Sink 1 01222602-1	EPA 200.8 Lead	0.000678 mg/L	0.005 mg/L	01/23/26
Kitchen Storage Sink 2 01222602-2	EPA 200.8 Lead	0.000607 mg/L	0.005 mg/L	01/23/26

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #12150. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi  
Technical Director

**ENVIRONMENTAL LABWORKS, INC.**

---

January 29, 2026

Ulster BOCES  
175 Route 32 N  
New Paltz, NY 12561

Dear James,

The following are results of the analyses performed on water samples from **iPark** received at the laboratory on 01/21/26.

Date/Time Collected: 01/21/26 5:57-6:38am First Draw  
Collected By: UC BOCES  
Project ID: 01212601  
Secondary ID: UB260314-60

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
Veg Sink 1 01212601-1	EPA 200.8 Lead	0.00147 mg/L	0.005 mg/L	01/28/26
Veg Sink 2 01212601-2	EPA 200.8 Lead	0.00178 mg/L	0.005 mg/L	01/28/26
Veg Sink 3 01212601-3	EPA 200.8 Lead	0.000784 mg/L	0.005 mg/L	01/28/26
Veg Sink 4 01212601-4	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/28/26
Veg Sink 5 01212601-5	EPA 200.8 Lead	0.00285 mg/L	0.005 mg/L	01/28/26
Pot Filler 01212601-6	EPA 200.8 Lead	0.00161 mg/L	0.005 mg/L	01/28/26
Veg Sink 6 01212601-7	EPA 200.8 Lead	0.00269 mg/L	0.005 mg/L	01/28/26
Veg Sink 7 01212601-8	EPA 200.8 Lead	0.00311 mg/L	0.005 mg/L	01/28/26
Veg Sink 8 01212601-9	EPA 200.8 Lead	0.000478 mg/L	0.005 mg/L	01/28/26
Veg Sink 9 01212601-10	EPA 200.8 Lead	0.00103 mg/L	0.005 mg/L	01/28/26

**ENVIRONMENTAL LABWORKS, INC.**

Ulster BOCES - iPark - 01212601

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
Ice Machine 01212601-11	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/28/26
Veg Sink 10 01212601-12	EPA 200.8 Lead	0.000952 mg/L	0.005 mg/L	01/28/26
Veg Sink 11 01212601-13	EPA 200.8 Lead	0.00130 mg/L	0.005 mg/L	01/28/26
Veg Sink 12 01212601-14	EPA 200.8 Lead	0.000870 mg/L	0.005 mg/L	01/28/26
Veg Sink 13 01212601-15	EPA 200.8 Lead	0.000749 mg/L	0.005 mg/L	01/28/26
Bottle Fill O/S Kitchen 01212601-16	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/28/26
Left WC O/S Kitchen 01212601-17	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/28/26
Right WC O/S Kitchen 01212601-18	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/28/26
Left WC O/S 226 01212601-19	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/28/26
Bottle Fill O/S 226 01212601-20	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/28/26
Right WC O/S 226 01212601-21	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
Left WC O/S 207 01212601-22	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
Bottle Fill O/S 207 01212601-23	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
Right WC O/S 207 01212601-24	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
2 <sup>nd</sup> Fl Break Room Sink 01212601-25	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26

**ENVIRONMENTAL LABWORKS, INC.**

Ulster BOCES - iPark - 01212601

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
Left WC O/S 203 01212601-26	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
Bottle Fill O/S 203 01212601-27	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
Right WC O/S 203 01212601-28	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
Left WC O/S 230 01212601-29	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
Bottle Fill O/S 230 01212601-30	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
Right WC O/S 230 01212601-31	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
1 <sup>st</sup> Fl Break Room Sink 01212601-32	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
Left WC O/S 104 01212601-33	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
Bottle Fill O/S 104 01212601-34	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
Right WC O/S 104 01212601-35	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
Left WC O/S 121 01212601-36	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
Bottle Fill O/S 121 01212601-37	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
Right WC O/S 121 01212601-38	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
Left WC O/S 120 01212601-39	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
Bottle Fill O/S 120 01212601-40	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26


**ENVIRONMENTAL LABWORKS, INC.**

Ulster BOCES - iPark - 01212601

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
Right WC O/S 120 01212601-41	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
Left WC in HVAC 01212601-42	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
Bottle Fill in HVAC 01212601-43	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
Right WC in HVAC 01212601-44	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
Left WC O/S Nurse 01212601-45	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
Bottle Fill O/S Nurse 01212601-46	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26
Right WC O/S Nurse 01212601-47	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	01/23/26

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #12150. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi  
Technical Director