

**NORTH SALEM CENTRAL SCHOOL DISTRICT**  
**PEQUENAKONCK ELEMENTARY LEAD RESULTS**  
*Samples Drawn: 12/06/2025*

Action Level: 0.005 mg/L  
 Exceedances are coded in *red*.

Site ID	Type	Location	Result
PQES 007	Classroom Sink	C-31 Art room, double bay sink left of kiln	0.0032
PQES 019	Classroom Sink	Back of C-34 Multi-Purpose room	0.0128
PQES 021	Kitchen Sink	C-34A Service room inside of Multi-purpose room deep bay sink	0.0393
PQES 029	Kitchen Sink	W-13 Faculty Lounge	0.0032
PQES 031	Nurse's Office	W-21 Nurse's Office back room	0.0043
PQES 032	Restroom Sink	B-9 Spec Ed. Bathroom on left at the beginning of south wing hall	0.0500
PQES 033	Restroom Sink	B-8 Boys Bathroom on right at the beginning of south wing hall	0.0058
PQES 039	Classroom Sink	S-17 E (Burdette)	0.0022
PQES 041	Classroom Sink	S-17-A (Donofrio)	0.0015
PQES 043	Classroom Sink	S-17-B (Ulrich)	0.0015
PQES 045	Classroom Sink	S-17-D (Lodewick)	0.0014
PQES 047	Classroom Sink	S-17-C (DeLuca)	0.0014
PQES 049	Classroom Sink	S-18 (Farrell)	0.0017
PQES 053	Classroom Sink	S-19 (Fox)	0.0041
PQES 054	Classroom Sink	S-23 (Carl)	< 0.0010
PQES 055	Classroom Sink	S-24 (Hussey)	0.0025
PQES 056	Classroom Sink	S-26 (Burch)	0.0052
PQES 057	Classroom Sink	S-25 (Farney)	0.0054
PQES 059	Kitchen Sink	C-21 Double bay sink inside service area	0.0054
PQES 061	Kitchen Sink	C-21 Handwashing sink inside service area	0.0019
PQES 062	Kitchen Sink	C-21B Dishwashing sink in back room (left sink)	0.0036
PQES 063	Kitchen Sink	C-21B Dishwashing sink in back room (right sink)	< 0.0010
PQES 067	Restroom Sink	Gym Lobby boys bathroom (left sink)	0.0074
PQES 068	Restroom Sink	Gym Lobby boys bathroom (right sink)	0.0042
PQES 071	Restroom Sink	Gym lobby girls bathroom (left sink)	0.0212
PQES 072	Restroom Sink	Gym lobby girls bathroom (right sink)	0.0259
PQES 086	Ice Machine	C-21 Kitchen	< 0.0010



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:35  
 16:35

Laboratory Data

SDG ID: GCU89926  
 Phoenix ID: CU89926

Project ID: PQ ELEMENTARY LEAD ZONE 2  
 Client ID: PQ-007

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0032	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:34  
 16:35

Laboratory Data

SDG ID: GCU89926  
 Phoenix ID: CU89927

Project ID: PQ ELEMENTARY LEAD ZONE 2  
 Client ID: PQ-019

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0128	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 15, 2025**

**Reviewed and Released by: Rashmi Makol, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:15  
 16:35

Laboratory Data

SDG ID: GCU89926  
 Phoenix ID: CU89928

Project ID: PQ ELEMENTARY LEAD ZONE 2  
 Client ID: PQ-021

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0393	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							12/10/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:13  
 16:35

Laboratory Data

SDG ID: GCU89926  
 Phoenix ID: CU89929

Project ID: PQ ELEMENTARY LEAD ZONE 2  
 Client ID: PQ-029

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0032	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:32  
 16:35

Laboratory Data

SDG ID: GCU89926  
 Phoenix ID: CU89930

Project ID: PQ ELEMENTARY LEAD ZONE 2  
 Client ID: PQ-031

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0043	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:18  
 16:35

Laboratory Data

SDG ID: GCU89926  
 Phoenix ID: CU89931

Project ID: PQ ELEMENTARY LEAD ZONE 2  
 Client ID: PQ-032

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0500	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							12/10/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director  
 December 15, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:18  
 16:35

Laboratory Data

SDG ID: GCU89926  
 Phoenix ID: CU89932

Project ID: PQ ELEMENTARY LEAD ZONE 2  
 Client ID: PQ-033

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0058	0.0010	1	mg/L	0.015			12/12/25	TH	E200.5
Total Metal Digestion	Completed							12/10/25	BF/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Rashmi Makol, Project Manager



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:21  
 16:35

Laboratory Data

SDG ID: GCU89915  
 Phoenix ID: CU89915

Project ID: PQ ELEMENTARY LEAD ZONE 3  
 Client ID: PQ-039

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0022	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**  
 December 15, 2025

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:21  
 16:35

Laboratory Data

SDG ID: GCU89915  
 Phoenix ID: CU89916

Project ID: PQ ELEMENTARY LEAD ZONE 3  
 Client ID: PQ-041

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0015	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:22  
 16:35

Laboratory Data

SDG ID: GCU89915  
 Phoenix ID: CU89917

Project ID: PQ ELEMENTARY LEAD ZONE 3  
 Client ID: PQ-043

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0015	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**  
 December 15, 2025

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:23  
 16:35

Laboratory Data

SDG ID: GCU89915  
 Phoenix ID: CU89918

Project ID: PQ ELEMENTARY LEAD ZONE 3  
 Client ID: PQ-045

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0014	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**  
 December 15, 2025

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:25  
 16:35

Laboratory Data

SDG ID: GCU89915  
 Phoenix ID: CU89919

Project ID: PQ ELEMENTARY LEAD ZONE 3  
 Client ID: PQ-047

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0014	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:24  
 16:35

Laboratory Data

SDG ID: GCU89915  
 Phoenix ID: CU89920

Project ID: PQ ELEMENTARY LEAD ZONE 3  
 Client ID: PQ-049

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0017	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**  
 December 15, 2025

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:26  
 16:35

Laboratory Data

SDG ID: GCU89915  
 Phoenix ID: CU89921

Project ID: PQ ELEMENTARY LEAD ZONE 3  
 Client ID: PQ-053

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0041	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**  
 December 15, 2025

**Reviewed and Released by: Alejandro Paredes, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:26  
 16:35

Laboratory Data

SDG ID: GCU89915  
 Phoenix ID: CU89922

Project ID: PQ ELEMENTARY LEAD ZONE 3  
 Client ID: PQ-054

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 15, 2025**

**Reviewed and Released by: Alejandro Paredes, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:27  
 16:35

Laboratory Data

SDG ID: GCU89915  
 Phoenix ID: CU89923

Project ID: PQ ELEMENTARY LEAD ZONE 3  
 Client ID: PQ-055

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0025	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**  
 December 15, 2025

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:28  
 16:35

Laboratory Data

SDG ID: GCU89915  
 Phoenix ID: CU89924

Project ID: PQ ELEMENTARY LEAD ZONE 3  
 Client ID: PQ-056

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0052	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**  
 December 15, 2025

**Reviewed and Released by: Alejandro Paredes, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:29  
 16:35

Laboratory Data

SDG ID: GCU89915  
 Phoenix ID: CU89925

Project ID: PQ ELEMENTARY LEAD ZONE 3  
 Client ID: PQ-057

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0054	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25		E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**

**December 15, 2025**

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:08  
 16:35

Laboratory Data

SDG ID: GCU89906  
 Phoenix ID: CU89906

Project ID: PQ ELEMENTARY LEAD ZONE 1  
 Client ID: PQ-059

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0054	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**  
 December 15, 2025

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:10  
 16:35

Laboratory Data

SDG ID: GCU89906  
 Phoenix ID: CU89907

Project ID: PQ ELEMENTARY LEAD ZONE 1  
 Client ID: PQ-061

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0019	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**  
 December 15, 2025

**Reviewed and Released by: Alejandro Paredes, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:12  
 16:35

Laboratory Data

SDG ID: GCU89906  
 Phoenix ID: CU89908

Project ID: PQ ELEMENTARY LEAD ZONE 1  
 Client ID: PQ-062

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0036	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**  
 December 15, 2025

**Reviewed and Released by: Alejandro Paredes, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:10  
 16:35

Laboratory Data

SDG ID: GCU89906  
 Phoenix ID: CU89909

Project ID: PQ ELEMENTARY LEAD ZONE 1  
 Client ID: PQ-063

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**  
 December 15, 2025

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:36  
 16:35

Laboratory Data

SDG ID: GCU89906  
 Phoenix ID: CU89910

Project ID: PQ ELEMENTARY LEAD ZONE 1  
 Client ID: PQ-067

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0074	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**  
 December 15, 2025

**Reviewed and Released by: Alejandro Paredes, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:39  
 16:35

Laboratory Data

SDG ID: GCU89906  
 Phoenix ID: CU89911

Project ID: PQ ELEMENTARY LEAD ZONE 1  
 Client ID: PQ-068

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0042	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:36  
 16:35

## Laboratory Data

SDG ID: GCU89906  
 Phoenix ID: CU89912

Project ID: PQ ELEMENTARY LEAD ZONE 1  
 Client ID: PQ-071

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0212	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							12/10/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director  
 December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



# Analysis Report

December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:37  
 16:35

## Laboratory Data

SDG ID: GCU89906  
 Phoenix ID: CU89913

Project ID: PQ ELEMENTARY LEAD ZONE 1  
 Client ID: PQ-072

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0259	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
*** Lead exceeds Action Level of 0.015 ***										
Total Metal Digestion	Completed							12/10/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director  
 December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102



**Analysis Report**  
 December 15, 2025

FOR: Attn: Roy Barticcio  
 CEMCO Water & Wastewater Specialists Inc  
 122 Grapehollow Rd  
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER  
 Location Code: CEMCO  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by:  
 Received by: CP  
 Analyzed by: see "By" below

Date

12/06/25  
 12/08/25

Time

7:12  
 16:35

Laboratory Data

SDG ID: GCU89906  
 Phoenix ID: CU89914

Project ID: PQ ELEMENTARY LEAD ZONE 1  
 Client ID: PQ-086

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.  
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.  
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

**Phyllis Shiller, Laboratory Director**  
 December 15, 2025

**Reviewed and Released by: Alejandro Paredes, Project Manager**