

NORTH SALEM CENTRAL SCHOOL DISTRICT
HIGH SCHOOL/MIDDLE SCHOOL LEAD RESULTS
Samples Drawn: 12/06/2025

Action Level: 0.005 mg/L
Exceedances are coded in *red*.

Site ID	Type	Location	Result (mg/L)
HSMS 026	Office sink	C-67 Main office (Kitchenette)	0.0063
HSMS 028	Nurse's office	C-64 Nurse's main room	0.0025
HSMS 029	Nurse's office	C-64 Nurse's back exam room	0.0139
HSMS 054	Water fountain	2nd floor hall at the top of main staircase between bathrooms Bottle fill	< 0.0010
HSMS 100	Water fountain	Left of B-36 girls bathroom 2nd floor MS 200 quad Bottle fill Only	< 0.0010
HSMS 115	Water fountain	Between bathrooms B-1 & B-2 1st floor (bottle fill)	< 0.0010
HSMS 147	Water fountain	right of custodial closet 1st floor MS 100 quad bottle fill	< 0.0010
HSMS 154	Water fountain	Hall - Left of girls bathroom 1st floor MS 100 quad Bottle fill	< 0.0010
HSMS 164	Water fountain	Hall - Across from room W-34 (Bottle fill)	< 0.0010
HSMS 170	Classroom Sink	W-21 Science Lab Prep room/Green house room (Non Supervised)	0.0148
HSMS 237	Water fountain	Hall by C-52 (Bottle fill)	< 0.0010
HSMS 241	Classroom sink	C-52 STEP Kitchenette	0.0020
HSMS 246	Kitchen sink	C-54 Kitchen MS cafe side (from kitchen) 1st on Right (handwashing sink)	0.0119
HSMS 247	Water fountain	Middle School cafeteria (Bottle fill)	< 0.0010
HSMS 252	Kitchen sink	C-54 Kitchen (small sink in island) Handwashing	0.0097
HSMS 253	Kitchen sink	C-54 Kitchen Big bay sinks (Left) Dishwashing	0.0118
HSMS 254	Kitchen sink	C-54 Kitchen Big bay sinks (Middle) Dishwashing	0.0088
HSMS 255	Kitchen sink	C-54 Kitchen Big bay sinks (Right) Food washing and cooking	0.0048
HSMS 259	Ice Machine	C-56 Apartment refrigerator ice machine	< 0.0010
HSMS 262	Classroom Sink	C-56 Apartment Sink	< 0.0010
HSMS 265	Kitchen sink	C-54 Kitchen MS cafe side (Handwashing sink) From kitchen 1st on the Left	0.0070
HSMS 272	Kitchen sink	C-54 Kitchen MS cafe side (Steam table)	0.0036
HSMS 275	Ice Machine	By HS gymnasium for sports Cold Line	0.0011
HSMS 276	Ice Machine	C-54 In Kitchen - Off Filter to Ice Machine and Sink	< 0.0010
HSMS 290	Water Fountain	In lobby of Turf restroom area - Bottle Fill Only	< 0.0010
HSMS 292	Spigot	Turf Field - Left Entrance	0.0016
HSMS 293	Spigot	Turf Field - Behind Bleachers by Defibrillator	0.0041
HSMS 317	Kitchen Sink	Kitchen - 3 Tub Sink Sprayer - Left (dishwashing)	0.0030
HSMS 318	Kitchen Sink	Kitchen - 2 Tub Sink Sprayer - Right (dishwashing)	< 0.0010



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:48
 16:35

Laboratory Data

SDG ID: GCU89885
 Phoenix ID: CU89885

Project ID: NORTH SALEM HS/MS LEAD ZONE 3
 Client ID: HSMS-026

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0063	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:41
 16:35

Laboratory Data

SDG ID: GCU89885
 Phoenix ID: CU89886

Project ID: NORTH SALEM HS/MS LEAD ZONE 3
 Client ID: HSMS-028

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0025	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:44
 16:35

Laboratory Data

SDG ID: GCU89885
 Phoenix ID: CU89887

Project ID: NORTH SALEM HS/MS LEAD ZONE 3
 Client ID: HSMS-029

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0139	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:57
 16:35

Laboratory Data

SDG ID: GCU89902
 Phoenix ID: CU89902

Project ID: NORTH SALEM HS/MS LEAD ZONE 4
 Client ID: HSMS-054

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:56
 16:35

Laboratory Data

SDG ID: GCU89902
 Phoenix ID: CU89903

Project ID: NORTH SALEM HS/MS LEAD ZONE 4
 Client ID: HSMS-100

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:50
 16:35

Laboratory Data

SDG ID: GCU89885
 Phoenix ID: CU89888

Project ID: NORTH SALEM HS/MS LEAD ZONE 3
 Client ID: HSMS-115

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:55
 16:35

Laboratory Data

SDG ID: GCU89885
 Phoenix ID: CU89889

Project ID: NORTH SALEM HS/MS LEAD ZONE 3
 Client ID: HSMS-147

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:39
 16:35

Laboratory Data

SDG ID: GCU89885
 Phoenix ID: CU89890

Project ID: NORTH SALEM HS/MS LEAD ZONE 3
 Client ID: HSMS-154

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			12/11/25	TH	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director
 December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:06
 16:35

Laboratory Data

SDG ID: GCU89877
 Phoenix ID: CU89877

Project ID: NORTH SALEM HS/MS LEAD ZONE 1
 Client ID: HSMS-164

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:07
 16:35

Laboratory Data

SDG ID: GCU89877
 Phoenix ID: CU89878

Project ID: NORTH SALEM HS/MS LEAD ZONE 1
 Client ID: HSMS-170

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0148	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:17
 16:35

Laboratory Data

SDG ID: GCU89877
 Phoenix ID: CU89879

Project ID: NORTH SALEM HS/MS LEAD ZONE 1
 Client ID: HSMS-237

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:19
 16:35

Laboratory Data

SDG ID: GCU89877
 Phoenix ID: CU89880

Project ID: NORTH SALEM HS/MS LEAD ZONE 1
 Client ID: HSMS-241

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0020	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:28
 16:35

Laboratory Data

SDG ID: GCU89891
 Phoenix ID: CU89891

Project ID: NORTH SALEM HS/MS LEAD ZONE 2
 Client ID: HSMS-246

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0119	0.0010	1	mg/L	0.015			12/11/25	TH	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director
 December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:29
 16:35

Laboratory Data

SDG ID: GCU89891
 Phoenix ID: CU89892

Project ID: NORTH SALEM HS/MS LEAD ZONE 2
 Client ID: HSMS-247

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			12/11/25	TH	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:18
 16:35

Laboratory Data

SDG ID: GCU89891
 Phoenix ID: CU89893

Project ID: NORTH SALEM HS/MS LEAD ZONE 2
 Client ID: HSMS-252

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0097	0.0010	1	mg/L	0.015			12/11/25	TH	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:19
 16:35

Laboratory Data

SDG ID: GCU89891
 Phoenix ID: CU89894

Project ID: NORTH SALEM HS/MS LEAD ZONE 2
 Client ID: HSMS-253

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0118	0.0010	1	mg/L	0.015			12/11/25	TH	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director
 December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:18
 16:35

Laboratory Data

SDG ID: GCU89891
 Phoenix ID: CU89895

Project ID: NORTH SALEM HS/MS LEAD ZONE 2
 Client ID: HSMS-254

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0088	0.0010	1	mg/L	0.015			12/11/25	TH	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director
 December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:21
 16:35

Laboratory Data

SDG ID: GCU89891
 Phoenix ID: CU89896

Project ID: NORTH SALEM HS/MS LEAD ZONE 2
 Client ID: HSMS-255

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0048	0.0010	1	mg/L	0.015			12/11/25	TH	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:15
 16:35

Laboratory Data

SDG ID: GCU89877
 Phoenix ID: CU89881

Project ID: NORTH SALEM HS/MS LEAD ZONE 1
 Client ID: HSMS-259

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:11
 16:35

Laboratory Data

SDG ID: GCU89877
 Phoenix ID: CU89882

Project ID: NORTH SALEM HS/MS LEAD ZONE 1
 Client ID: HSMS-262

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:40
 16:35

Laboratory Data

SDG ID: GCU89891
 Phoenix ID: CU89897

Project ID: NORTH SALEM HS/MS LEAD ZONE 2
 Client ID: HSMS-265

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0070	0.0010	1	mg/L	0.015			12/11/25	TH	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:25
 16:35

Laboratory Data

SDG ID: GCU89891
 Phoenix ID: CU89898

Project ID: NORTH SALEM HS/MS LEAD ZONE 2
 Client ID: HSMS-272

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0036	0.0010	1	mg/L	0.015			12/11/25	TH	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director
 December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:18
 16:35

Laboratory Data

SDG ID: GCU89877
 Phoenix ID: CU89883

Project ID: NORTH SALEM HS/MS LEAD ZONE 1
 Client ID: HSMS-275

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0011	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:53
 16:35

Laboratory Data

SDG ID: GCU89891
 Phoenix ID: CU89899

Project ID: NORTH SALEM HS/MS LEAD ZONE 2
 Client ID: HSMS-276

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			12/11/25	TH	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:09
 16:35

Laboratory Data

SDG ID: GCU89877
 Phoenix ID: CU89884

Project ID: NORTH SALEM HS/MS LEAD ZONE 1
 Client ID: HSMS-290

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/09/25	P/AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

8:45
 16:35

Laboratory Data

SDG ID: GCU89902
 Phoenix ID: CU89904

Project ID: NORTH SALEM HS/MS LEAD ZONE 4
 Client ID: HSMS-292

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0016	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

8:45
 16:35

Laboratory Data

SDG ID: GCU89902
 Phoenix ID: CU89905

Project ID: NORTH SALEM HS/MS LEAD ZONE 4
 Client ID: HSMS-293

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0041	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:20
 16:35

Laboratory Data

SDG ID: GCU89891
 Phoenix ID: CU89900

Project ID: NORTH SALEM HS/MS LEAD ZONE 2
 Client ID: HSMS-317

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0030	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102



Analysis Report
 December 15, 2025

FOR: Attn: Roy Barticcio
 CEMCO Water & Wastewater Specialists Inc
 122 Grapehollow Rd
 Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
 Location Code: CEMCO
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

12/06/25
 12/08/25

Time

6:22
 16:35

Laboratory Data

SDG ID: GCU89891
 Phoenix ID: CU89901

Project ID: NORTH SALEM HS/MS LEAD ZONE 2
 Client ID: HSMS-318

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0010	0.0010	1	mg/L	0.015			12/11/25	CPP	E200.5
Total Metal Digestion	Completed							12/10/25	AG	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.
 If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
 The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director
 December 15, 2025

Reviewed and Released by: Alejandro Paredes, Project Manager