

		Outlets Not Tested					
ID #	Outlet Type	Outlet Location	Remedial Actions				Notes/Comments
			Engineering controls	Supervision	Education	Signage	
PQ elementary School							
PQ ES-001	Restroom Sink	B-16 & B-17 North wing handwashing station (left faucet)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Tempered
PQ ES-002	Restroom Sink	B-16 & B-17 North wing handwashing station (middle faucet)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Tempered
PQ ES-003	Restroom Sink	B-16 & B-17 North wing handwashing station (right faucet)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Tempered
PQ ES-004	Restroom Sink	North wing handwashing station (right faucet)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	no longer exists
PQ ES-005	Slop Sink	Custodial closet in B-17 4th & 5th grade Bathroom	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
PQ ES-006	Classroom Sink	C-31B Storage room inside room C-31	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off
PQ ES-008	Water Fountain	Beginning of north wing to the left - Hall to O/S	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ Will be tested when cleared for PFOAs
PQ ES-009	Water Fountain	Beginning of east wing (bottle fill) by C-33	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ Will be tested when cleared for PFOAs
PQ ES-010	Water Fountain	Beginning of east wing (mouth spigot) by C-33	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ Will be tested when cleared for PFOAs
PQ ES-011	Restroom Sink	B-14 & B-15 East wing handwashing station (left faucet)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Tempered
PQ ES-012	Restroom Sink	B-14 & B-15 East wing handwashing station (middle faucet)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Tempered
PQ ES-013	Restroom Sink	B-14 & B-15 East wing handwashing station (right faucet)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Tempered
PQ ES-014	Restroom Sink	East wing handwashing station (right faucet)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	no longer exists
PQ ES-015	Slop Sink	B-15 Custodial closet in 3rd grade Boys Bathroom	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
PQ ES-016	Classroom Sink	E-17	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
PQ ES-017	Classroom Sink	E-18	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
PQ ES-018	Water Fountain	E-18	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
PQ ES-020	Kitchen Sink	C-34A Service room inside of Multi-purpose hand washing sink	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	behind locked door
PQ ES-021-A	Bucket fill	C-34A Service room inside of Multi-purpose room filtered bucket fill (Hot water line No	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
PQ ES-022	Restroom Sink	B-13 Bathroom inside C-34A service room of Multi-purpose room Faculty Only)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
PQ ES-023	Restroom Sink	C-38,B-11 Men's faculty Bathroom Front of school (left sink)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
PQ ES-024	Restroom Sink	C-38, B-11 Men's Faculty Bathroom Front of school (right sink)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
PQ ES-025	Restroom Sink	C-39,B-10 Women's Faculty Bathroom Front of school (left sink)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
PQ ES-026	Restroom Sink	C-39,B-10 Women's Faculty Bathroom Front of school (right sink)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
PQ ES-027	Slop Sink	Custodial Closet across from C-11	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
PQ ES-028	Slop Sink	Custodial Closet on the right at the beginning of South wing	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
PQ ES-030	Restroom Sink	W-21 Nurse's Office bathroom	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	tempered
PQ ES-031-A	Nurse's Office	W-21 Nurse's Office back room bottle fill	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	does not function
PQ ES-034	Restroom Sink	B-6 & B-7 South wing Handwashing station (left faucet)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Tempered
PQ ES-035	Restroom Sink	B-6 & B-7 South wing Handwashing station (middle faucet)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Tempered
PQ ES-036	Restroom Sink	B-6 & B-7 South wing Handwashing station (right faucet)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Tempered
PQ ES-037	Restroom Sink	South wing Handwashing station (right faucet)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	no longer exists
PQ ES-038	Slop Sink	B-6 Custodial closet in 1st & 2nd grade boys bathroom	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-040	Water Fountain	S-17 E	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
PQ ES-042	Water Fountain	S-17-A	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
PQ ES-044	Water Fountain	S-17-B	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
PQ ES-046	Water Fountain	S-17-D	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
PQ ES-048	Water Fountain	S-17-C	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
PQ ES-050	Water Fountain	South wing water fountain (Bottle fill)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ Will be tested when cleared for PFOAs
PQ ES-051	Water Fountain	South wing water fountain (Mouth spigot)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ Will be tested when cleared for PFOAs
PQ ES-052	Slop Sink	M-1 Custodial closet to the right of water fountain in the middle of the south wing	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
PQ ES-058	Office Sink	C-24 Library office (Koehler)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
PQ ES-060	Kitchen Sink	C-21 Steam table (Hot water line No need to test)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-064	Water Fountain	outside kitchen/cafeteria (bottle fill) in hallway	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ Will be tested when cleared for PFOAs
PQ ES-065	Water Fountain	outside kitchen/cafeteria (Mouth Spigot) in hallway	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ Will be tested when cleared for PFOAs
PQ ES-066	Restroom Sink	B-18 Women's faculty bathroom across from kitchen	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
PQ ES-069	Water Fountain	Gym Lobby (bottle fill)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ Will be tested when cleared for PFOAs
PQ ES-070	Water Fountain	Gym Lobby (mouth spigot)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ Will be tested when cleared for PFOAs
PQ ES-073	Restroom Sink	West Gym office bathroom sink - Gilchrist	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
PQ ES-074	Restroom Sink	East Gym office bathroom sink - MacKenzie	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
PQ ES-075	Outside Spigot	Outside Music room (right of exterior door) No need to test/need key	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-076	Outside Spigot	On Loading dock	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-077	Outside Spigot	Outside room N-15 (right of exterior door) No need to test/need key	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-078	Outside Spigot	By pump house O/S N-11 on the Left of the exit door. No need to test/need key	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-079	Outside Spigot	Garden spigot Hand Pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ Will be tested when cleared for PFOAs
PQ ES-080	Outside Spigot	end of east wing (outside classroom side) O/S E-18 Wall, Corner of Bldg. No need to test/need key	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-081	Outside Spigot	by generator (exterior wall of east wing bathroom) No need to test/need key	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-082	Outside Spigot	outside S-16 No need to test/need key	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-083	Outside Spigot	outside S-17-C No need to test/need key	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-084	Outside Spigot	outside S-13 (in front of building in the chicken coop area) No need to test/need key	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-085	Outside Spigot	outside nurse's room (by flagpole) South Wall No need to test/need key	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-087	Eye Wash	B-6 Custodial closet in 1st & 2nd grade boys bathroom	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
PQ ES-088	Eye Wash	B-17 Custodial closet in 4th & 5th grade boys bathroom	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
PQ ES-089	Eye Wash	B-15 Custodial closet in 3rd grade Boys Bathroom	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
PQ ES-090	Restroom Sink	West Locker Room - Left	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	does not function
PQ ES-091	Restroom Sink	West Locker Room - Right	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	does not function

PQ ES-092	Shower	G-3A Coaches Office (Gilchrist)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
PQ ES-093	Shower	G-2A Coaches Office (MacKenzie)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
PQ ES-094	Restroom Sink	East Locker Room - Left	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	does not function
PQ ES-095	Restroom Sink	East Locker Room - Right	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	does not function
PQ ES-096	Shower	East Locker Room Right Shower - Left Head	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	does not function
PQ ES-097	Shower	East Locker Room Right Shower - Right Head	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	does not function
PQ ES-098	Shower	East Locker Room Left Shower - Left Head	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	does not function
PQ ES-099	Shower	East Locker Room Left Shower - Right Head	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	does not function
PQ ES-100	Spigot	Water Filtration Room - West Wall - Middle	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
PQ ES-101	Spigot	Water Filtration Room - East Wall	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
PQ ES-102	Spigot	Water Filtration Room - North Wall	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
PQ ES-103	Spigot	Water Filtration Room - West Wall	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
PQ ES-104	Spigot	Water Filtration Room - West Wall	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
PQ ES-105	Spigot	Geo Thermal Shed - East Side above pipes	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
PQ ES-106	Spigot	Geo Thermal Shed - West Side above pipes	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
PQ ES-107	Outside Spigot	O/S N-14	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-108	Outside Spigot	O/S E-17 Wall - Corner of Bldg	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-109	Outside Spigot	Garden - Next to Hand Pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-110	Outside Spigot	Garden 1st on the Left	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-111	Outside Spigot	Garden 2nd on Left	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-112	Outside Spigot	Garden - Center Row 1st in	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-113	Outside Spigot	Garden - Center Row 2nd in	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-114	Outside Spigot	Garden - Center Row 3rd in	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-115	Outside Spigot	Garden - Center Row 4th in	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-116	Outside Spigot	Garden - Center Row 5th in	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-117	Outside Spigot	Garden - Center Row 6th in	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-118	Outside Spigot	Garden - Right Row 1st in	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PQ ES-119	Outside Spigot	O/S Gym - West Wall by South door (Gilchrist)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
North Salem High school/ Middle school							
HS/MS-001	Outside Spigot	Garden outside of building on the wall in corner by MS Girls Locker Room	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
HS/MS-002	Outside Spigot	Garden Standing spigot	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	no longer exists
HS/MS-003	Outside Spigot	Garden standing spigot	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	no longer exists
HS/MS-004	Outside Spigot	Outside Maintenance shop on side of building	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Need key
HS/MS-005	Outside Spigot	Outside boys bathroom 1st floor quad	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Need key
HS/MS-006	Outside Spigot	Outside by student drop off (Bus Entrance)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Need key
HS/MS-007	Outside Spigot	Outside MS cafeteria	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Need key
HS/MS-008	Outside Spigot	Outside C entrance	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Need key
HS/MS-009	Outside Spigot	Outside HS Science room W-19	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Need key
HS/MS-010	Outside Spigot	Outside HS boys team room	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Need key
HS/MS-011	Outside Spigot	Outside HS girls team room	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Need key
HS/MS-012	Outside Spigot	In courtyard with mound	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Need key
HS/MS-013	Outside Spigot	In courtyard with pond (West Wall - South Side)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Need key
HS/MS-014	Outside Spigot	In courtyard with pond (West Wall - North Side)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Need key
HS/MS-015	Floor Spigot	Pump room - Inside door 1st on Right	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Need key
HS/MS-016	Floor Spigot	Pump room - Inside door 2nd on Right	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
HS/MS-017	Floor Spigot	Pump room - inside door 3rd on Right	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
HS/MS-018	Floor Spigot	Pump room	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
HS/MS-019	N/A	N/A	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
HS/MS-020	Floor Spigot	Pump room - at the north end of the east wall	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
HS/MS-021	Floor Spigot	Pump room	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
HS/MS-022	Floor Spigot	Pump room	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
HS/MS-023	Floor Spigot	Pump room - inside door on the left	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
HS/MS-024	Floor Spigot	Maintenance	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
HS/MS-025	Floor Spigot	Maintenance	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
HS/MS-027	Restroom Sink	C-64 Nurse's bathroom	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-030	Restroom Sink	B-6 STEP restroom outside MS girls locker room	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-031	Floor Spigot	Pump room	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
HS/MS-032	Restroom Sink	B-7 Unisex restroom outside MS girls locker room	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-033	Water fountain	C-59b Middle school girls locker room	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	no longer exists
HS/MS-034	Restroom Sink	C-59b Middle school girls locker room	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-035	Restroom Sink	B-8 Middle school girls locker room bathroom	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-036	Floor spigot	B-8 Middle school girls locker room bathroom	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	no longer exists
HS/MS-037	Restroom Sink	C-59b Middle school girls locker room office	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-038	Water fountain	C-59 Middle School Gymnasium	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-039	Water fountain	C-59a Middle school boys locker room	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-040	Restroom Sink	C-59a Middle school boys locker room	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-040-A	Restroom Sink	B-16 Middle school boys locker room Bathroom sink	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-041	Restroom sink	C-58 Middle school boys locker room office	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-042	Slop Sink	Custodial closet Outside HS boys locker room	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
HS/MS-043	Restroom Sink	B-14 High school boys locker room bathroom (Left)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-044	Restroom Sink	B-14 High school boys locker room bathroom (Right)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-045	Water fountain	C-62a High school boys locker room	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	no longer exists
HS/MS-046	Restroom Sink	B-13 High school boys locker room office bathroom	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-047	Water fountain	C-62d High school girls locker room	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-048	Restroom Sink	B-11 High school girls locker room bathroom (Left)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-049	Restroom Sink	B-11 High school girls locker room bathroom (Right)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-050	N/A	N/A	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	no longer exists
HS/MS-051	Restroom Sink	B-31 2nd floor girls bathroom at top of main staircase (Left)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-052	Restroom Sink	B-31 2nd floor girls bathroom at top of main staircase (Middle)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	

HS/MS-053	Restroom Sink	B-31 2nd floor girls bathroom at top of main staircase (Right)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-054-A	Water fountain	2nd floor hall at the top of main staircase between bathrooms Mouth	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	no longer exists
HS/MS-055	Slop Sink	Custodial closet at the top of main staircase between bathrooms	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
HS/MS-056	Restroom Sink	B-32 2nd floor men's bathroom at top of main staircase (Right)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-057	Restroom Sink	B-32 2nd floor men's bathroom at top of main staircase (Middle)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-058	Restroom Sink	B-32 2nd floor men's bathroom at top of main staircase (Left)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-059	Floor spigot	B-32 2nd floor men's bathroom at top of main staircase (Right)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	no longer exists
HS/MS-060	Floor spigot	B-32 2nd floor men's bathroom at top of main staircase (Left)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	no longer exists
HS/MS-061	Floor spigot	B-31 2nd floor girls bathroom at top of main staircase (Left)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
HS/MS-062	Floor spigot	B-31 2nd floor girls bathroom at top of main staircase (Right)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
HS/MS-063	Water fountain	2nd floor hall across from room E-209	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-064	Classroom Sink	E-209 Art room (Left)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-065	Classroom Sink	E-209 Art room (Middle)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-066	Classroom Sink	E-209 Art room (Right)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-067	Prep sink	Klin room between E-209 & E-210 (Left) (may be hot supply)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-068	Prep sink	Klin room between E-209 & E-210 (Right)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-069	Classroom Sink	E-211 Art room 1st sink - Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-070	Classroom Sink	E-211 Art room 1st sink - Middle	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-071	Classroom Sink	E-211 Art room 1st sink - Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-072	Classroom Sink	E-211 Art room 2nd sink - Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-073	Classroom Sink	E-211 Art room 2nd Sink - Middle	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-074	Restroom Sink	B-34 Women's faculty bathroom by E-211	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-075	Restroom Sink	B-33 Men's faculty bathroom by E-211	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-076	Faculty room sink	E-212 MS faculty room	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-077	Classroom Sink	E-214 MS science room 1st sink on left - Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-078	Classroom Sink	E-214 MS science room 1st sink on left - Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-079	Classroom Sink	E-214 MS science room 2nd sink on left - Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-080	Classroom Sink	E-214 MS science room 2nd sink on left - Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-081	Classroom Sink	E-214 MS science room 3rd sink on left - Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-082	Classroom Sink	E-214 MS science room 3rd sink on left - Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-083	Classroom Sink	E-214 MS science room Sink in middle of room - Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-084	Classroom Sink	E-214 MS science room Sink in middle of room - Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-085	Classroom Sink	E-214 MS science room 1st sink on right side of room - Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-086	Classroom Sink	E-214 MS science room 1st sink on right side of room - Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-087	Classroom Sink	E-214 MS science room 2nd sink on right side of room - Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-088	Classroom Sink	E-214 MS science room 2nd sink on right side of room - Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-089	Classroom Sink	E-214 MS science room 3rd sink on right side of room - Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-090	Classroom Sink	E-214 MS science room 3rd sink on right side of room - Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-091	Eye wash station	E-214 MS science room	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-092	Prep sink	E-214 MS science room office	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-093	Slop Sink	Custodial closet outside of room E-214	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Behind locked door
HS/MS-094	Water fountain	Left of B-35 boys bathroom 2nd floor MS 200 quad Mouth Spigot	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shut off/ not used
HS/MS-095	Restroom Sink	B-35 Boys bathroom 2nd floor MS 200 quad (Left)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-096	Restroom Sink	B-35 Boys bathroom 2nd floor MS 200 quad (Middle)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-097	Restroom Sink	B-35 Boys bathroom 2nd floor MS 200 quad (Right)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-098	Floor spigot	B-35 Boys bathroom 2nd floor MS 200 quad (Left)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-099	Floor spigot	B-35 Boys bathroom 2nd floor MS 200 quad (Right)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-100	Water fountain	Left of B-36 girls bathroom 2nd floor MS 200 quad Bottle fill Only	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-100-A	Water fountain	Left of B-36 girls bathroom 2nd floor MS 200 quad Mouth spigot	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	no longer exists
HS/MS-101	Classroom Sink	E-218	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	no longer exists
HS/MS-102	Restroom Sink	B-36 girls bathroom 2nd floor MS quad (Left)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-103	Restroom Sink	B-36 girls bathroom 2nd floor MS quad (Middle)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-104	Restroom Sink	B-36 girls bathroom 2nd floor MS quad (Right)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-105	Floor spigot	B-36 girls bathroom 2nd floor MS quad (Left)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-106	Floor spigot	B-36 girls bathroom 2nd floor MS quad (Right)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-107	Restroom Sink	B-37 Men's staff bathroom right of elevator 2nd floor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-108	Restroom Sink	B-38 Women's staff bathroom right of elevator 2nd floor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-109	Office sink	E-222 District office (Kitchenette) 2nd floor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-110	Restroom Sink	B-1 Women's faculty bathroom 1st floor (Left)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-111	Restroom Sink	B-1 Women's faculty bathroom 1st floor (Middle)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-112	Restroom Sink	B-1 Women's faculty bathroom 1st floor (Right)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-113	Floor spigot	B-1 Women's faculty bathroom 1st floor (Left)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
HS/MS-114	Floor spigot	B-1 Women's faculty bathroom 1st floor (Right)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
HS/MS-115	Water fountain	Between bathrooms B-1 & B-2 1st floor (bottle fill)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-116	Water fountain	Between bathrooms B-1 & B-2 1st floor (mouth spigot)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	no longer exists
HS/MS-117	Slop Sink	Custodial closet left of B-2 men's faculty bathroom	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
HS/MS-118	Restroom Sink	B-2 Men's faculty bathroom 1st floor (Right)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-119	Restroom Sink	B-2 Men's faculty bathroom 1st floor (middle)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-120	Restroom Sink	B-2 Men's faculty bathroom 1st floor (left)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-121	Floor spigot	B-2 Men's faculty bathroom 1st floor (left)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	no longer exists
HS/MS-122	Floor spigot	B-2 Men's faculty bathroom 1st floor (Right)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	no longer exists
HS/MS-123	Water fountain	Hall - Across from room E-101 (Mouth Spigot)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shut off/ not used
HS/MS-124	Classroom Sink	E-101 MS Science room (1st Sink on the Left)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-125	Classroom Sink	E-101 MS Science room (2nd Sink from the Left)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-126	Classroom Sink	E-101 MS Science room (3rd Sink from the Left - South Spigot)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-127	Classroom Sink	E-101 MS Science room (3rd Sink from the Left - North Spigot)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-128	Classroom Sink	E-101 MS Science room (4th Sink from the Left - South Spigot)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-129	Classroom Sink	E-101 MS Science room (4th Sink from the Left - North Spigot)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-130	Classroom Sink	E-101 MS Science room (5th Sink from the Left - South Spigot)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	

HS/MS-131	Classroom Sink	E-101 MS Science room (5th Sink from the Left - North Spigot)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-132	Classroom Sink	E-101 MS Science room (6th Sink from the left - South Spigot)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-133	Classroom Sink	E-101 MS Science room (6th Sink from the left - North Spigot)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-134	Classroom Sink	E-101 MS Science room Teachers Desk - South Spigot)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-135	Class Sink/Eye Wash	E-101 MS Science room (Eye wash and sink) - North Spigot)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-136	Prep sink	E-102 Prep/office between E-101 & E-103 - North Sink	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-137	Prep sink	E-102 Prep/office between E-101 & E-103 - South Sink	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-138	Classroom Sink	E-103 MS Science room - Teachers Desk - North Spigot)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-139	Classroom Sink	E-103 MS Science room - Teachers Desk - South Spigot)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-140	Classroom Sink	E-103 MS Science room - 1st Sink on the Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-141	Classroom Sink	E-103 MS Science room - 2nd Sink from the Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-142	Classroom Sink	E-103 MS Science room - 3rd Sink from the Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-143	Classroom Sink	E-103 MS Science room - 4th Sink from the Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-144	Classroom Sink	E-103 MS Science room - 5th Sink from the Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-145	Classroom Sink	E-103 MS Science room - 6th Sink from the Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-146	Shop sink	Maintenance shop	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-147	Water fountain	right of custodial closet 1st floor MS 100 quad bottle fill	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
HS/MS-147-A	Water fountain	right of custodial closet 1st floor MS 100 quad mouth spigot	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-148	Slop Sink	Custodial closet 1st floor MS 100 quad	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Behind locked door
HS/MS-149	Restroom Sink	B-3 Boys bathroom 1st floor MS 100 quad (Left)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-150	Restroom Sink	B-3 Boys bathroom 1st floor MS 100 quad (Middle)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	no longer exists
HS/MS-151	Restroom Sink	B-3 Boys bathroom 1st floor MS 100 quad (Right)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-152	Floor spigot	B-3 Boys bathroom 1st floor MS 100 quad (Left)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	no longer exists
HS/MS-153	Floor spigot	B-3 Boys bathroom 1st floor MS 100 quad (Right)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	no longer exists
HS/MS-154	Water fountain	Hall - Left of girls bathroom 1st floor MS 100 quad Bottle fill	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
HS/MS-154-A	Water fountain	Hall - Left of girls bathroom 1st floor MS 100 quad Mouth spigot	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	no longer exists
HS/MS-155	Restroom Sink	B-4 girls bathroom 1st floor MS 100 quad (Left)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-156	Restroom Sink	B-4 girls bathroom 1st floor MS 100 quad (Middle)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	no longer exists
HS/MS-157	Restroom Sink	B-4 girls bathroom 1st floor MS 100 quad (Right)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-158	Floor spigot	B-4 girls bathroom 1st floor MS 100 quad (Left)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	no longer exists
HS/MS-159	Floor spigot	B-4 girls bathroom 1st floor MS 100 quad (Right)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	no longer exists
HS/MS-160	Restroom Sink	B-12 High school girls locker room office bathroom	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-161	Water fountain	Hall Outside High school girls locker room (Left)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-162	Water fountain	Hall Outside High school girls locker room (Right)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-163	Slop Sink	Custodial closet to the right of room C-56	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	behind locked door
HS/MS-164	Water fountain	Hall - Across from room W-34 (Bottle fill)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
HS/MS-165	Water fountain	Hall - Across from room W-34 Mouth spigot	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-166	Restroom Sink	B-18 Girls bathroom across from W-33 (Left)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-167	Restroom Sink	B-18 Girls bathroom across from W-33 (Right)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-168	Restroom Sink	B-19 Faculty bathroom by W-22	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-169	Restroom Sink	B-20 Faculty bathroom by W-23	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-170	Classroom Sink	W-21 Science Lab Prep room/Green house room (Non Supervised)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
HS/MS-171	Classroom Sink	W-19 HS Science room 1st sink on right - Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-172	Classroom Sink	W-19 HS Science room 1st sink on right - Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-173	Classroom Sink	W-19 HS Science room 2nd sink on right - Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-174	Classroom Sink	W-19 HS Science room 2nd sink on right - Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-175	Classroom Sink	W-19 HS Science room 3rd sink on right - Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-176	Classroom Sink	W-19 HS Science room 3rd sink on right - Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-177	Classroom Sink	W-19 HS Science room 4th sink on right - Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-178	Classroom Sink	W-19 HS Science room 4th sink on right - Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-179	Classroom Sink	W-19 HS Science room 5th sink on right - Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-180	Classroom Sink	W-19 HS Science room 5th sink on right - Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-181	Classroom Sink	W-19 HS Science room 6th sink on right - Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-182	Classroom Sink	W-19 HS Science room 6th sink on right - Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-183	Classroom Sink	W-19 HS Science room - Teacher Desk - Left - cold	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-184	Classroom Sink	W-19 HS Science room - Teachers Desk - Right - Hot water	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-185	Eye wash station	W-19 HS Science room 1st on Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-186	Office Sink	W-20 Science office/Prep room (Left)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-187	Classroom Sink	W-19 HS Science room 1 sink on Left - Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-188	Classroom Sink	W-18 HS Science room Teachers Desk Not replaced yet	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	no longer exists
HS/MS-189	Spigot	W-18 HS Science room Fume Hood in on Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-190	Classroom Sink	W-18 HS Science room 6th Sink on Left - Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-191	Eye wash station	W-18 HS Science room	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-192	Classroom Sink	W-18 HS Science room 5th sink on the Left - Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-193	Classroom Sink	W-18 HS Science room 5th sink on the Left - Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-194	Classroom Sink	W-18 HS Science room 4th sink on the Left - Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-195	Classroom Sink	W-18 HS Science room 4th sink on the Left - Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-196	Classroom Sink	W-18 HS Science room 3rd sink on Left - Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-197	Classroom Sink	W-18 HS Science room 3rd sink on Right - Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-198	Classroom Sink	W-18 HS Science room 2nd sink on the Left - Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-199	Classroom Sink	W-18 HS Science room 2nd sink on the Left - Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-200	Classroom Sink	W-18 HS Science room 1st sink on the Left - Left	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-201	Classroom Sink	W-18 HS Science room 6th sink on Left - Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-202	Classroom Sink	W-18 HS Science room Cold faucet -1st sink on Left - Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-203	Classroom Sink	W-18 HS Science room 1st sink on the Right	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-204	Eye wash station	W-18 HS Science room	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-205	Prep sink	W-17 Science prep room	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-206	Prep sink	W-17 Science prep room	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HS/MS-207	Restroom Sink	B-21 faculty bathroom	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	

HS/MS-302	Shower	MS Girls Locker Room 2nd on the Right	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-303	Shower	MS Girls Locker Room 3rd on the Right	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-304	Shower	MS Girls Locker Room 4th on the Right	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-305	Shower	MS Boys Locker Room - Coaches Office Shower	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-306	Shower	HS Boys Locker Room - Coaches Office Shower	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-307	Shower	HS Boys Locker Room - Coaches Office Shower Hand Sprayer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-308	Shower	HS Boys Locker Room - 1st Shower on the Left	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-309	Shower	HS Boys Locker Room - 2nd Shower on the Left	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-310	Shower	HS Boys Locker Room - 3rd Shower on the Left	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-311	Shower	HS Girls Locker Room Coaches Office Shower	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-312	Shower	HS Girls Locker Room Coaches Office Shower Hand Sprayer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-313	Shower	HS Girls Locker Room - 1st Shower on Right	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-314	Shower	HS Girls Locker Room - 1st Shower on Right Hand Sprayer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-315	Shower	HS Girls Locker Room - 2nd Shower on Right	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-316	Shower	HS Girls Locker Room - 3rd Shower on Right	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shut off/ not used
HS/MS-319	Classroom Sink	C-56 - 1st sink on Right - Spigot - Right	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	no longer exists
HS/MS-320	Shower	E-214 Emergency Shower	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
HS/MS-321	Shower	E-101 Emergency Shower	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
HS/MS-322	Shower	E-103 Emergency Shower	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
HS/MS-323	Shower	W-25 Emergency Shower	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
HS/MS-324	Shower	W-27 Emergency Shower	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
HS/MS-325	Shower	W-18 Emergency Shower	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
HS/MS-326	Shower	W-19 Emergency Shower	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	