RIALTO UNIFIED SCHOOL DISTRICT
Child Nutrition
151 S. Cactus Ave.
Rialto, CA 92376

Kitchen Equipment
RFP No. RIANS-2025-2026-006

ADDENDUM #2

Question: For line item# 4, DDA-3 Direct Steam Oven, for complete install, unit will be required utilities connection (steam, gas & electric), does installer need to be a licensed contractor? Does prevailing wage install required to comply with DIR requirement?

Answer: We have steam generators on site. Utilities connection will be steam and electric. Yes, we need a licensed contractor and prevailing wage is required per DIR requirement.

Question: For line item# 4, DDA-3 Direct Steam Oven, the unit comes with flanged feet. Does it required to be bolt down to floor?

Answer: It needs to be bolt down to floor and strap to the wall.

This addendum must be signed & returned with your proposal.

Signature _____ Date _____

Print Name _____ Title _____

Name of Company _____

~ END OF ADDENDUM #2 ~