

location	sample ID	date collected	results initial test	results 2nd test	comments
RMS	RMS-25-1B	11/4/2025	<1.0		
RMS	RMS-25-1F	11/4/2025	<1.0		
RMS	RMS-25-2	11/4/2025	<1.0		
RMS	RMS-25-3	11/4/2025	<1.0		
RMS	RMS-25-4B	11/4/2025	<1.0		
RMS	RMS-25-4F	11/4/2025	<1.0		
RMS	RMS-25-5	11/4/2025	<1.0		
RMS	RMS-25-6	11/6/2025	<1.0		
RMS	RMS-25-7	11/4/2025	<1.0		
RMS	RMS-25-8	11/4/2025	2.6		
RMS	RMS-25-9	11/4/2025	<1.0		
RMS	RMS-25-10	11/4/2025	<1.0		
RMS	RMS-25-11	11/4/2025	<1.0		
RMS	RMS-25-12	11/6/2025	<1.0		
RMS	RMS-25-13	11/6/2025	<1.0		
RMS	RMS-25-14	11/6/2025	<1.0		
RMS	RMS-25-15	11/6/2025	<1.0		
RMS	RMS-25-16	11/6/2025	1.2		
RMS	RMS-25-17	11/6/2025	<1.0		
JVF	JVF-25-1	11/4/2025	<1.0		
JVF	JVF-25-2	11/4/2025	1.4		
JVF	JVF-25-3	11/4/2025	<1.0		
JVF	JVF-25-4	11/4/2025	<1.0		
JVF	JVF-25-5	11/4/2025	<1.0		
JVF	JVF-25-6	11/4/2025	<1.0		
JVF	JVF-25-7	11/4/2025	<1.0		
JVF	JVF-25-8	11/4/2025	<1.0		
JVF	JVF-25-9	11/4/2025	<1.0		
JVF	JVF-25-10	11/4/2025	<1.0		
JVF	JVF-25-11	11/4/2025	<1.0		
JVF	JVF-25-12	11/4/2025	<1.0		
JVF	JVF-25-13	11/4/2025	<1.0		
JVF	JVF-25-14	11/4/2025	<1.0		
JVF	JVF-25-15	11/4/2025	<1.0		
JVF	JVF-25-16	11/4/2025	<1.0		
JVF	JVF-25-17	11/4/2025	<1.0		
SOUTH AVE.	SA-25-1	11/20/2025	<1.0		
SOUTH AVE.	SA-25-2	11/20/2025	1.5		
SOUTH AVE.	SA-25-3	11/20/2025	<1.0		
SOUTH AVE.	SA-25-4	11/20/2025	<1.0		
SOUTH AVE.	SA-25-5	11/20/2025	<1.0		
SOUTH AVE.	SA-25-6	11/20/2025	<1.0		

SOUTH AVE.	SA-25-7	11/20/2025	<1.0		
SARGENT	SG-25-1	11/14/2025	<1.0		
SARGENT	SG-25-2	11/14/2025	2		
SARGENT	SG-25-3	10/17/2025	1.3		
SARGENT	SG-25-4	10/17/2025	<1.0		
SARGENT	SG-25-5	10/17/2025	<1.0		
SARGENT	SG-25-6	10/17/2025	<1.0		
GLENHAM	GE-25-1	11/21/2025	<1.0		
GLENHAM	GE-25-2	11/21/2025	1.5		
GLENHAM	GE-25-3	11/21/2025	<1.0		
GLENHAM	GE-25-4	11/21/2025	<1.0		
GLENHAM	GE-25-5	11/21/2025	<1.0		
GLENHAM	GE-25-6	11/21/2025	<1.0		
BHS	HS-25-1	11/26/2025	14.1	<1.0	fixture replaced
BHS	HS-25-2	11/26/2025	<1.0		
BHS	HS-25-3	11/26/2025	<1.0		
BHS	HS-25-4	11/26/2025	<1.0		
BHS	HS-25-5	11/26/2025	<1.0		
BHS	HS-25-6	11/26/2025	<1.0		
BHS	HS-25-7	11/26/2025	<1.0		
BHS	HS-25-8	11/26/2025	<1.0		
BHS	HS-25-9	11/26/2025	<1.0		
BHS	HS-25-10	11/26/2025	<1.0		
BHS	HS-25-11	11/26/2025	<1.0		
BHS	HS-25-12	11/26/2025	<1.0		
BHS	HS-25-13	11/26/2025	<1.0		
BHS	HS-25-14	11/26/2025	<1.0		
BHS	HS-25-15	11/26/2025	<1.0		
BHS	HS-25-16	11/26/2025	<1.0		
BHS	HS-25-17	11/26/2025	<1.0		
BHS	HS-25-18	11/26/2025	<1.0		
BHS	HS-25-19	11/26/2025	<1.0		
BHS	HS-25-20	11/26/2025	<1.0		
BHS	HS-25-21	11/26/2025	<1.0		
BHS	HS-25-22	11/26/2025	<1.0		
BHS	HS-25-23	11/26/2025	<1.0		
BHS	HS-25-24	11/26/2025	<1.0		
BHS	HS-25-25	11/26/2025	<1.0		
BHS	HS-25-26	11/26/2025	<1.0		



ANALYTICAL RESULTS

Project: RMS
Pace Project No.: 70392910

Sample: GE-25-1		Lab ID: 70392910001		Collected: 11/21/25 06:30		Received: 11/21/25 14:50		Matrix: Drinking Water									
Parameters		Results		Units		Report Limit		DF		Prepared		Analyzed		CAS No.		Qual	

NB 200.8 ICPMS DW No Prep
Analytical Method: EPA 200.8, Rev. 5.4
Pace Analytical Services - Newburgh

Lead	<1.0	ug/L	1.0	1		12/01/25 21:25	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

Sample: GE-25-2		Lab ID: 70392910002		Collected: 11/21/25 06:30	Received: 11/21/25 14:50	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

NB 200.8 ICPMS DW No Prep
Analytical Method: EPA 200.8, Rev. 5.4
Pace Analytical Services - Newburgh

Lead	1.5	ug/L	1.0	1		12/01/25 21:28	7439-92-1	
------	-----	------	-----	---	--	----------------	-----------	--

Sample: GE-25-3		Lab ID: 70392910003		Collected: 11/21/25 06:30		Received: 11/21/25 14:50		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

NB 200.8 ICPMS DW No Prep
Analytical Method: EPA 200.8, Rev. 5.4
Pace Analytical Services - Newburgh

Lead	<1.0	ug/L	1.0	1		12/01/25 21:30	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

Sample: GE-25-4		Lab ID: 70392910004		Collected: 11/21/25 06:30		Received: 11/21/25 14:50		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

NB 200.8 ICPMS DW No Prep
Analytical Method: EPA 200.8, Rev. 5.4
Pace Analytical Services - Newburgh

Lead	<1.0	ug/L	1.0	1		12/01/25 21:33	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

Sample: GE-25-5		Lab ID: 70392910005		Collected: 11/21/25 06:30		Received: 11/21/25 14:50		Matrix: Drinking Water									
Parameters		Results		Units		Report Limit		DF		Prepared		Analyzed		CAS No.		Qual	

NB 200.8 ICPMS DW No Prep
Analytical Method: EPA 200.8, Rev. 5.4
Pace Analytical Services - Newburgh

Lead	<1.0	ug/L	1.0	1		12/01/25 21:36	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**ANALYTICAL RESULTS**

Project: RMS
Pace Project No.: 70392910

Sample: GE-25-6		Lab ID: 70392910006	Collected: 11/21/25 06:30		Received: 11/21/25 14:50		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		12/01/25 21:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: Beacon High School

Pace Project No.: 70393958

Sample: HS-25-1		Lab ID: 70393958001		Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

NB 200.8 ICPMS DW No Prep
Analytical Method: EPA 200.8, Rev. 5.4
Pace Analytical Services - Newburgh

Lead	14.1	ug/L	1.0	1		12/17/25 15:17	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

Sample: HS-25-2		Lab ID: 70393958002		Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

NB 200.8 ICPMS DW No Prep
Analytical Method: EPA 200.8, Rev. 5.4
Pace Analytical Services - Newburgh

Lead	<1.0	ug/L	1.0	1		12/17/25 15:21	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

Sample: HS-25-3		Lab ID: 70393958003		Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

NB 200.8 ICPMS DW No Prep
Analytical Method: EPA 200.8, Rev. 5.4
Pace Analytical Services - Newburgh

Lead	<1.0	ug/L	1.0	1		12/17/25 15:25	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

Sample: HS-25-4		Lab ID: 70393958004		Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

NB 200.8 ICPMS DW No Prep
Analytical Method: EPA 200.8, Rev. 5.4
Pace Analytical Services - Newburgh

Lead	<1.0	ug/L	1.0	1		12/17/25 15:29	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

Sample: HS-25-5		Lab ID: 70393958005	Collected: 11/26/25 06:30	Received: 11/26/25 14:33	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

NB 200.8 ICPMS DW No Prep
Analytical Method: EPA 200.8, Rev. 5.4
Pace Analytical Services - Newburgh

Lead	<1.0	ug/L	1.0	1		12/17/25 15:33	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**ANALYTICAL RESULTS**

Project: Beacon High School

Pace Project No.: 70393958

Sample: HS-25-6		Lab ID: 70393958006		Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	1		12/17/25 15:49	7439-92-1		

Sample: HS-25-7		Lab ID: 70393958007		Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	1		12/17/25 15:53	7439-92-1		

Sample: HS-25-8		Lab ID: 70393958008		Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	1		12/17/25 15:56	7439-92-1		

Sample: HS-25-9		Lab ID: 70393958009		Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	1		12/17/25 17:23	7439-92-1		

Sample: HS-25-10		Lab ID: 70393958010		Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	1		12/17/25 17:27	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**ANALYTICAL RESULTS**

Project: Beacon High School

Pace Project No.: 70393958

Sample: HS-25-12		Lab ID: 70393958011	Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		12/17/25 17:31	7439-92-1	
Sample: HS-25-13		Lab ID: 70393958012	Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		12/17/25 17:34	7439-92-1	
Sample: HS-25-14		Lab ID: 70393958013	Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		12/17/25 17:38	7439-92-1	
Sample: HS-25-15		Lab ID: 70393958014	Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		12/17/25 17:42	7439-92-1	
Sample: HS-25-16		Lab ID: 70393958015	Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		12/17/25 16:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**ANALYTICAL RESULTS**

Project: Beacon High School

Pace Project No.: 70393958

Sample: HS-25-17		Lab ID: 70393958016		Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:32	7439-92-1		

Sample: HS-25-18		Lab ID: 70393958017		Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:36	7439-92-1		

Sample: HS-25-19		Lab ID: 70393958018		Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:40	7439-92-1		

Sample: HS-25-20		Lab ID: 70393958019		Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:43	7439-92-1		

Sample: HS-25-21		Lab ID: 70393958020		Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:47	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: Beacon High School

Pace Project No.: 70393958

Sample: HS-25-22		Lab ID: 70393958021		Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:51	7439-92-1		

Sample: HS-25-23		Lab ID: 70393958022		Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:55	7439-92-1		

Sample: HS-25-24		Lab ID: 70393958023		Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:59	7439-92-1		

Sample: HS-25-25		Lab ID: 70393958024		Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	1		12/17/25 17:03	7439-92-1		

Sample: HS-25-26		Lab ID: 70393958025		Collected: 11/26/25 06:30		Received: 11/26/25 14:33		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	1		12/17/25 17:07	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: JVF / RMS

Pace Project No.: 70389402

Sample: JVF-25-1		Lab ID: 70389402001	Collected: 11/04/25 06:30	Received: 11/04/25 15:13	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/12/25 21:56	7439-92-1	
Sample: JVF-25-2		Lab ID: 70389402002	Collected: 11/04/25 06:30	Received: 11/04/25 15:13	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	1.4	ug/L	1.0	1		11/12/25 22:13	7439-92-1	
Sample: JVF-25-3		Lab ID: 70389402003	Collected: 11/04/25 06:30	Received: 11/04/25 15:13	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/12/25 22:15	7439-92-1	
Sample: JVF-25-4		Lab ID: 70389402004	Collected: 11/04/25 06:30	Received: 11/04/25 15:13	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/12/25 22:18	7439-92-1	
Sample: JVF-25-5		Lab ID: 70389402005	Collected: 11/04/25 06:30	Received: 11/04/25 15:13	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/12/25 22:21	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: JVF / RMS

Pace Project No.: 70389402

Sample: JVF-25-6		Lab ID: 70389402006	Collected: 11/04/25 06:30		Received: 11/04/25 15:13		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/12/25 22:23	7439-92-1	
Sample: JVF-25-7		Lab ID: 70389402007	Collected: 11/04/25 06:30		Received: 11/04/25 15:13		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/12/25 22:26	7439-92-1	
Sample: JVF-25-8		Lab ID: 70389402008	Collected: 11/04/25 06:30		Received: 11/04/25 15:13		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/12/25 22:29	7439-92-1	
Sample: JVF-25-9		Lab ID: 70389402009	Collected: 11/04/25 06:30		Received: 11/04/25 15:13		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/12/25 22:37	7439-92-1	
Sample: JVF-25-10		Lab ID: 70389402010	Collected: 11/04/25 06:30		Received: 11/04/25 15:13		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/12/25 22:40	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: JVF / RMS

Pace Project No.: 70389402

Sample: JVF-25-11		Lab ID: 70389402011	Collected: 11/04/25 06:30		Received: 11/04/25 15:13		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/12/25 22:42	7439-92-1	
Sample: JVF-25-12		Lab ID: 70389402012	Collected: 11/04/25 06:30		Received: 11/04/25 15:13		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/12/25 22:48	7439-92-1	
Sample: JVF-25-13		Lab ID: 70389402013	Collected: 11/04/25 06:30		Received: 11/04/25 15:13		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/12/25 22:50	7439-92-1	
Sample: JVF-25-14		Lab ID: 70389402014	Collected: 11/04/25 06:30		Received: 11/04/25 15:13		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/12/25 22:53	7439-92-1	
Sample: JVF-25-15		Lab ID: 70389402015	Collected: 11/04/25 06:30		Received: 11/04/25 15:13		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/12/25 22:56	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: JVF / RMS

Pace Project No.: 70389402

Sample: JVF-25-16		Lab ID: 70389402016	Collected: 11/04/25 06:30		Received: 11/04/25 15:13		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/12/25 22:58	7439-92-1	
Sample: JVF-25-17		Lab ID: 70389402017	Collected: 11/04/25 06:30		Received: 11/04/25 15:13		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/12/25 23:01	7439-92-1	
Sample: RMS -25-1B		Lab ID: 70389402018	Collected: 11/04/25 06:30		Received: 11/04/25 15:13		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/12/25 23:09	7439-92-1	
Sample: RMS -25-1F		Lab ID: 70389402019	Collected: 11/04/25 06:30		Received: 11/04/25 15:13		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/12/25 23:12	7439-92-1	
Sample: RMS -25-2		Lab ID: 70389402020	Collected: 11/04/25 07:00		Received: 11/04/25 15:13		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/12/25 23:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: JVF / RMS

Pace Project No.: 70389402

Sample: RMS -25-3		Lab ID: 70389402021	Collected: 11/04/25 07:00		Received: 11/04/25 15:13		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/12/25 23:23	7439-92-1	
Sample: RMS -25-4F		Lab ID: 70389402022	Collected: 11/04/25 07:00		Received: 11/04/25 15:13		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/12/25 23:34	7439-92-1	
Sample: RMS -25-4B		Lab ID: 70389402023	Collected: 11/04/25 07:00		Received: 11/04/25 15:13		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/13/25 17:01	7439-92-1	
Sample: RMS -25-5		Lab ID: 70389402024	Collected: 11/04/25 07:00		Received: 11/04/25 15:13		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/13/25 17:04	7439-92-1	
Sample: RMS -25-7		Lab ID: 70389402025	Collected: 11/04/25 07:00		Received: 11/04/25 15:13		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/13/25 17:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: JVF / RMS

Pace Project No.: 70389402

Sample: RMS -25-8		Lab ID: 70389402026	Collected: 11/04/25 07:00	Received: 11/04/25 15:13	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

NB 200.8 ICPMS DW No Prep
Analytical Method: EPA 200.8, Rev. 5.4
Pace Analytical Services - Newburgh

Lead	2.6	ug/L	1.0	1		11/13/25 17:10	7439-92-1	
------	-----	------	-----	---	--	----------------	-----------	--

Sample: RMS -25-9		Lab ID: 70389402027	Collected: 11/04/25 07:00	Received: 11/04/25 15:13	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

NB 200.8 ICPMS DW No Prep
Analytical Method: EPA 200.8, Rev. 5.4
Pace Analytical Services - Newburgh

Lead	<1.0	ug/L	1.0	1		11/13/25 17:12	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

Sample: RMS -25-10		Lab ID: 70389402028	Collected: 11/04/25 07:00	Received: 11/04/25 15:13	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

NB 200.8 ICPMS DW No Prep
Analytical Method: EPA 200.8, Rev. 5.4
Pace Analytical Services - Newburgh

Lead	<1.0	ug/L	1.0	1		11/13/25 17:15	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

Sample: RMS -25-11		Lab ID: 70389402029	Collected: 11/04/25 07:00	Received: 11/04/25 15:13	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

NB 200.8 ICPMS DW No Prep
Analytical Method: EPA 200.8, Rev. 5.4
Pace Analytical Services - Newburgh

Lead	<1.0	ug/L	1.0	1		11/13/25 17:18	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RMS
Pace Project No.: 70389968

Sample: RMS-25-6		Lab ID: 70389968001	Collected: 11/06/25 06:30	Received: 11/06/25 14:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/14/25 15:09	7439-92-1	
Sample: RMS-25-12		Lab ID: 70389968002	Collected: 11/06/25 06:30	Received: 11/06/25 14:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/14/25 15:12	7439-92-1	
Sample: RMS-25-13		Lab ID: 70389968003	Collected: 11/06/25 06:30	Received: 11/06/25 14:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/14/25 15:14	7439-92-1	
Sample: RMS-25-14		Lab ID: 70389968004	Collected: 11/06/25 06:30	Received: 11/06/25 14:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/14/25 15:17	7439-92-1	
Sample: RMS-25-15		Lab ID: 70389968005	Collected: 11/06/25 06:30	Received: 11/06/25 14:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/14/25 15:20	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RMS
Pace Project No.: 70389968

Sample: RMS-25-16		Lab ID: 70389968006		Collected: 11/06/25 06:30		Received: 11/06/25 14:50		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.2	ug/L	1.0	1		11/14/25 15:23	7439-92-1		

Sample: RMS-25-17		Lab ID: 70389968007	Collected: 11/06/25 06:30	Received: 11/06/25 14:50	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/14/25 15:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RMS
Pace Project No.: 70392628

Sample: SA-25-1		Lab ID: 70392628001	Collected: 11/20/25 06:30		Received: 11/20/25 14:50		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/26/25 18:28	7439-92-1	
Sample: SA-25-2		Lab ID: 70392628002	Collected: 11/20/25 06:30		Received: 11/20/25 14:50		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	1.5	ug/L	1.0	1		11/26/25 18:30	7439-92-1	
Sample: SA-25-3		Lab ID: 70392628003	Collected: 11/20/25 06:30		Received: 11/20/25 14:50		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/26/25 18:39	7439-92-1	
Sample: SA-25-4		Lab ID: 70392628004	Collected: 11/20/25 06:30		Received: 11/20/25 14:50		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/26/25 18:41	7439-92-1	
Sample: SA-25-5		Lab ID: 70392628005	Collected: 11/20/25 06:30		Received: 11/20/25 14:50		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/26/25 18:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RMS
Pace Project No.: 70392628

Sample: SA-25-6		Lab ID: 70392628006		Collected: 11/20/25 06:30		Received: 11/20/25 14:50		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	1		11/26/25 18:47	7439-92-1		

Sample: SA-25-7		Lab ID: 70392628007		Collected: 11/20/25 06:30		Received: 11/20/25 14:50		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	1		11/26/25 18:49	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: Sargent ES

Pace Project No.: 70386414

Sample: SG-25-3		Lab ID: 70386414001	Collected: 10/17/25 07:00	Received: 10/17/25 14:48	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

NB 200.8 ICPMS DW No Prep
Analytical Method: EPA 200.8, Rev. 5.4
Pace Analytical Services - Newburgh

Lead	1.3	ug/L	1.0	1		10/24/25 16:02	7439-92-1	
------	-----	------	-----	---	--	----------------	-----------	--

Sample: SG-25-4		Lab ID: 70386414002	Collected: 10/17/25 07:05	Received: 10/17/25 14:48	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

NB 200.8 ICPMS DW No Prep
Analytical Method: EPA 200.8, Rev. 5.4
Pace Analytical Services - Newburgh

Lead	<1.0	ug/L	1.0	1		10/24/25 16:05	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

Sample: SG-25-5		Lab ID: 70386414003	Collected: 10/17/25 07:10	Received: 10/17/25 14:48	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

NB 200.8 ICPMS DW No Prep
Analytical Method: EPA 200.8, Rev. 5.4
Pace Analytical Services - Newburgh

Lead	<1.0	ug/L	1.0	1		10/24/25 16:07	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

Sample: SG-25-6		Lab ID: 70386414004	Collected: 10/17/25 07:15	Received: 10/17/25 14:48	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

NB 200.8 ICPMS DW No Prep
Analytical Method: EPA 200.8, Rev. 5.4
Pace Analytical Services - Newburgh

Lead	<1.0	ug/L	1.0	1		10/24/25 16:09	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**ANALYTICAL RESULTS**

Project: Sargent ES

Pace Project No.: 70391569

Sample: SG-25-1		Lab ID: 70391569001		Collected: 11/14/25 06:30		Received: 11/14/25 14:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	1		11/18/25 21:24	7439-92-1		

Sample: SG-25-2		Lab ID: 70391569002		Collected: 11/14/25 06:30		Received: 11/14/25 14:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.0	ug/L	1.0	1		11/18/25 21:27	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**ANALYTICAL RESULTS**

Project: RMS
Pace Project No.: 70389968

Sample: RMS-25-6		Lab ID: 70389968001	Collected: 11/06/25 06:30		Received: 11/06/25 14:50		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/14/25 15:09	7439-92-1	
Sample: RMS-25-12		Lab ID: 70389968002	Collected: 11/06/25 06:30		Received: 11/06/25 14:50		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/14/25 15:12	7439-92-1	
Sample: RMS-25-13		Lab ID: 70389968003	Collected: 11/06/25 06:30		Received: 11/06/25 14:50		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/14/25 15:14	7439-92-1	
Sample: RMS-25-14		Lab ID: 70389968004	Collected: 11/06/25 06:30		Received: 11/06/25 14:50		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/14/25 15:17	7439-92-1	
Sample: RMS-25-15		Lab ID: 70389968005	Collected: 11/06/25 06:30		Received: 11/06/25 14:50		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh						
Lead	<1.0	ug/L	1.0	1		11/14/25 15:20	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RMS
Pace Project No.: 70389968

Sample: RMS-25-16		Lab ID: 70389968006		Collected: 11/06/25 06:30		Received: 11/06/25 14:50		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.2	ug/L	1.0	1		11/14/25 15:23	7439-92-1		

Sample: RMS-25-17		Lab ID: 70389968007		Collected: 11/06/25 06:30		Received: 11/06/25 14:50		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	1		11/14/25 15:25	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.