

Westport Public Schools – Painting, Caulking, Sill and Lintel Repairs at (5) Selected School Exteriors

26-009-RFP-Addendum No. 1

Original Issue Date: 1/13/2026

Changes to Request for Proposal

1.	MODIFY	None
1.	ADD	None
1.	DELETE	None

Pre-bid Observations

During the pre-bid walkthrough, the following items were referenced and added to the scope of work for the Saugatuck Elementary School exterior:

1. The metal staircase, landings and railings leading to Door #21 (both topside and underside) are to be cleaned, primed and painted.



Westport Public Schools – Painting, Caulking, Sill and Lintel Repairs at (5) Selected School Exteriors

26-009-RFP-Addendum No. 1

2. The painted wood frieze above the entry and the fascia components at the front half-round extension at the northeast end of the school front (photo below) are to be cleaned, prepped, primed and painted.



3. The metal fascia section located on the back side of the school is to be repaired.




Westport Public Schools – Painting, Caulking, Sill and Lintel Repairs at (5) Selected School Exteriors

26-009-RFP-Addendum No. 1

During the pre-bid walkthrough, the following items were referenced and added to the scope of work for the Kings Highway Elementary School exterior:

1. Exterior building Doors #8 and #9 are to be added to the scope for required prep and repainting of these doors and frames.



Westport Public Schools – Painting, Caulking, Sill and Lintel Repairs at (5) Selected School Exteriors

26-009-RFP-Addendum No. 1

2. The EIFS fascia on the west façade of the school is to be repaired as necessary and repainted.



3. The number of rain leaders to be prepped, prime and repainted was changed from (5) to (8) total.

A question was posed regarding the presence of lead paint at any of the school exteriors.

Response

The Facilities Department could not confirm if lead paint was present at any of the building exteriors so the request was made to perform testing on both Saugatuck and Kings Highway Elementary Schools as these would be the two schools out of the five in question from the list for any necessary painting work scope.

Attachments

**Westport Facilities Department Sign-in Sheet
Colliers Project Leaders Sign-in Sheet**

WESTPORT PUBLIC SCHOOLS
MANDATORY WALK THRU SIGN IN SHEET

BID/RFP NO: 26-009 RFP (5) Schools, Painting, Caulking, Sill and Lintels Repairs Exterior Facades

DATE: Friday, January 23, 2026, 11:00 am Saugatuck Elementary



PLEASE PRINT LEGIBLY

PLEASE INCLUDE BUSINESS CARD


NAME	COMPANY/FIRM	E-MAIL	PHONE #
Frank Butler	Ferraro's Painting	fbutter@ferrarospainting.com	203-906-3007
Alx Almeida	Almeida Dry Wall	info@almeidadrywall.com	120315567299
Rosario Tine	General Builders LLC	generalbuilders@snet.net	860-214-9521
QUINN DUFFY	SPITALE CONSTRUCTION	QUINN@SPITALETECH.COM	631-759-0412
Jonathan O'Coin	A1 Home Improvement LLC	zak@a1roofproct.com	860-218-8362 836
John Koplas	LOWERS	JOHN.KOPLAS@LOWERSBK.COM	203-504-7878
Vanya Butler	Scholar Painting	scholospainting@gmail.com	203-906-8650



ALMEIDA
DRYWALL

SCAN ME



 (203) 556-7299

 info@almeidadrywall.com

 www.almeidadrywall.com



Jonathan O'Coin

W | 917.970.0822 ext. 1003
M | 860.218.8362
442 5th Ave #1087
New York, NY 10018
jocoin@freehillcapital.com

**SPITALE CONSTRUCTION
RESOURCES, INC.**

JACK CONNER

Cell: (516) 429-4716
Office: 914-352-6366

jack@scrinc.co



MEETING SIGN-IN SHEET



Westport Public Schools

District Wide-Painting, Caulking, Sill and Lintel Repairs at (5) Selected School Locations

Contractor Pre-Bid Site Visit

Friday, January 23, 2026

11:00 a.m. meeting

NAME	REPRESENTING	PHONE NO.	EMAIL ADDRESS
John Kopras	COLLIERS	203-504-7877	john.kopras@collierseng.com
Rosario Vire	General Builders, LLC	860-214-9521	generalbuilders@snet.net
QUINN DUFFY	SPITALE CONSTRUCTION	631-757-0412	QUINN@SPITALETECH.COM
JACK CONNER	SPITALE CONSTRUCTION	516-429-4716	JACK@SCRINC.CO
Jonathan O'Coin	A1 Home Improvement LLC	860-218-8362	zack@a1roofproct.com
Alex Almeida	Almeida Drywall Inc.	203-5567299	imp@a1meida.drywall.com
Frank Butler	Ferraros Painting	203-906-3007	frank@ferrarospainting.com
Vaughn Butler	WPS BLS Scholar Painting	203-341-1230 203-906-8650	THUNYADLO@WESTPORTPS.ORG scholarpainting@gmail.com