



Hendry County School District

ADDENDUM # 6

IMPORTANT DOCUMENT – Central Elementary School & Country Oaks Re-Cabling Project for Hendry County School District

ADDENDUM DATE: 2/10/2026

**Information Technology RELATED DOCUMENTS – Q&A Additional Questions 49
– 59**

49. Please advise if drawings to scale are available

A: All floor plans that are on the RFP is the only documentation that's available. There are NO prints that are to scale.

50. Q: Please confirm the attached (2)two excel files included in the RFP are not required to be included in RFP response. If they are required to be included, please provide direction on how to complete.

A: Please refer to Addendum number 3

51. Q: The RFP directs bidders to submit proposals with fiber and ethernet broken out. Addendum #1, response #2 directs bidders to submit proposals with breakouts per school. Please confirm RFP responses shall only be broken out per school.

A: The RFP requires fiber, ethernet, and all materials to be proposed as 1 proposal with a breakdown of each school. Not as two different proposals. Addendum #4 states that all materials are to be itemized. Please see addendum #4.

52. Q: Addendum #1 Response #6 states that wiremold will be used for block/brick walls inside classrooms. However, during the walk-through it was stated that conduit would be required instead. Please confirm that conduit shall be installed on the outboard side of all block/brick walls.

A: During the walkthrough, responses were not provided for questions outside of the information contained in the RFP or issued addendums. All attendees were instructed to submit a Request for Information (RFI) for any project-specific questions to ensure accurate,

consistent, and formally documented responses. Please refer to Addendum #4 for additional guidance.

53. Q: Please confirm that all cables above the ceilings shall be plenum rated.

A: Plenum rated cables will be required.

54. Q: Please confirm that the demolition and removal of the existing system—including, but not limited to, fiber cabling, Ethernet cabling, ports, racks, enclosures, and access points—is excluded from the RFP response.

A: We will not be requiring, or requesting, the demolition or removal of our existing system infrastructure including, but not limited to fiber cabling, ethernet cabling, ports, racks, enclosures, or access points.

55. Q: Please confirm that cabinets can be utilized in lieu of the specified racks in the IDF closets.

A: Although not required, cabinets can be used in lieu of racks in the IDF closets.

56. Q: Please specify the required depth for installation of all below-grade conduit.

A: Addendum #4 states the client has no preference in depth but does list requirements. Please see Addendum #4.

57. Q: Please confirm the connection to the gate at Central Elementary Scholl can be a point to point connection.

A: Hendry County confirms that the single cable run that's on the identified plans located outside of room 1-002B is for a point-to-point connection.

58. Q: It was stated at the walk-through that the turnover date of the MDF & IDF closets shall be August 1, 2026. Addendum #2, Response #13 states that the "the work may not exceed past December 31,2026". Please clarify.

A: During the walkthrough, attendees were instructed to refer to the RFP for all schedule-related information. No specific dates, including August 1, 2026, were provided during the walkthrough. As noted in Addendum #2, Response #13, the work may not extend beyond December 31, 2026. Please review the RFP and associated addendums for the applicable turnover dates of the MDF and IDF closets. Any further requests for clarification should be submitted through the RFI process.

59. Q: It was stated at the walk-through that HCSB required 12 strand at each IDF closet. Please confirm that (a) a larger Fiber cable can be introduced that can be split to each individual IDF closet IDF and (b) pathways for both Fiber and Ethernet cables are to be determined by the installing contractor.

A: The requirement for a 12-strand fiber connection at each IDF closet is specified in the RFP. During the walkthrough, responses were not provided for questions beyond the information contained in the RFP or issued addendums. All attendees were instructed to submit a Request for Information (RFI) for any project-specific questions to ensure accurate, consistent, and formally documented responses. As stated in the RFP, we will be requiring a 12 strand fiber cable to each portable.

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM AND RETURN IT WITH YOUR SUBMITTAL. FAILURE TO SIGN AND RETURN WITH YOUR SUBMITTAL COULD RESULT IN REJECTION OF YOUR PROPOSAL.

SIGNATURE

PRINT OR TYPE NAME

COMPANY NAME

EMAIL ADDRESS