



ADDENDUM NO. 3

TENNIS COURT REPLACEMENT

KFHS, NRHS, LHS - SUFFOLK PUBLIC SCHOOLS

IFB #1845-B

RRMM Project No.21222-24,25 & 27

February 11, 2026

This Addendum forms a part of the Construction Documents and modifies the original bidding documents dated January 20, 2026.

The information in this Addendum supersedes any contradictory information or omission set forth in previous addendums and the Contract Documents.

Where any component of the Contract Documents is modified or deleted by this Addendum, the unaltered components of that Section, Article, or Drawing shall remain in effect.

Acknowledge receipt of this Addendum by inserting its number and date in the Proposal Form. Failure to do so may subject Bidder to disqualification.

This Addendum consists of two (2) pages.

PERTAINING TO THE ITB:

3.1 Invitation To Bid #1845-B:

REVISE the Bid Date to Wednesday, February 18, 2026 @ 1:00 PM (same location).

3.2 Addendum #1 and SECTION 000300 – BID FORM:

OPTIONAL BID ALTERNATE: REVISE PER BELOW:

The Optional Bid Alternate to provide Post-Tension Concrete courts as an alternate to the Asphalt Court Pavement Repairs must be a minimum depth of **5-inches** post-tensioned concrete and must be installed by an ASBA certified professional tennis court builder. The base stone removal and replacement may be performed by **Full Depth Reclamation to within 1-inch above the existing subgrade**. The Geogrid Fabric is not required for the concrete alternate. **The contractor is responsible for providing any additional design and testing associated with post tension concrete construction.** Finish Grade shall be as shown on the plans. The tennis court acrylic surface coating, court markings, posts, nets, fences, and all other equipment required for the courts shall remain the same for both options.

CLARIFICATIONS (ALL SITES):

- 3.3 The existing asphalt that will be removed can be recycled, pulverized and mixed with the underlying base stone for court reconstruction. Full Depth Reclamation can be performed to within 1-inch above subgrade for the base course ONLY below the 4-inches of new asphalt or below Optional Alternate Bid of 5-inch minimum post tensioned concrete course. The Geogrid Fabric is not required for Full Depth Reclamation option for the base layer. A tack coat is required if Full Depth Reclamation method is used for the asphalt court construction. The contractor is responsible for providing a stable base and final product that meets the requirements of tennis court construction industry standards.

END OF ADDENDUM NO. 3