

Lead in School Drinking Water Report

Sumner High School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2026-01-10

Date(s) analyzed: 2026-01-16

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	411451	Main Building	Sink	Student Store	1 of 1	Tap	center	27
2	411445	Main Building	Fountain Tap Combo	Concessions	1 of 1	Water Fountain	right	16
3	411453	Main Building	Sink	Old Kitchen	1 of 2	Tap	center	15
4	411469	Athletics Office/Health	Sink	Athletic Office	1 of 1	Tap	center	14
5	411473	Pool	Fountain	Pool	1 of 1	Water Fountain	left	13
6	411465	Main Building	Fountain Tap Combo	Room 8a	1 of 1	Water Fountain	right	12
7	411455	Main Building	Sink	Spart Mart	1 of 1	Tap	center	11
8	411454	Main Building	Sink	Old Kitchen	2 of 2	Sprayer	center	6
9	411456	Main Building	Sink	Nurses Office	1 of 1	Tap	center	5
10	411474	Main Building	Sink - Multi-compartment	Room 52c	1 of 1	Tap	center	5
11	411446	Main Building	Fountain	Hallway Outside Of Room 44c	1 of 1	Water Fountain	right	4
12	411450	Main Building	Fountain	Fountain Outside Of Student Store	1 of 1	Water Fountain	right	4

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
13	411452	Main Building	Sink - Multi-compartment	Staff Lounge	1 of 1	Tap	center	3
14	411475	Main Building	Sink - Multi-compartment	Room 53c	1 of 1	Tap	center	3
15	411466	Stadium	Sink	Concessions	1 of 1	Tap	center	2
16	411467	Stadium	Fountain With Bottle Filler	Weight Room	1 of 1	Water Bottle Filler	center	2
17	411468	Stadium	Fountain With Bottle Filler	Weight Room	1 of 1	Water Fountain	right	2
18	411470	Main Building	Fountain	Hallway Next To Room 29b	1 of 1	Water Fountain	left	2
19	411442	Main Building	Fountain	Gym	1 of 2	Water Fountain	right	1
20	411457	Main Building	Fountain With Bottle Filler	Hallway Next To Room 11a	1 of 1	Water Bottle Filler	center	1
21	411458	Main Building	Fountain With Bottle Filler	Hallway Next To Room 11a	1 of 1	Water Fountain	right	1
22	411443	Main Building	Water Bottle Filling Station	Gym	2 of 2	Water Bottle Filler	center	<1
23	411444	Main Building	Water Bottle Filling Station	Auxiliary Gym	1 of 1	Water Bottle Filler	center	<1
24	411447	Main Building	Fountain With Bottle Filler	Room 44c	1 of 1	Water Bottle Filler	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
25	411448	Main Building	Fountain With Bottle Filler	Room 44c	1 of 1	Water Fountain	right	<1
26	411449	Main Building	Fountain With Bottle Filler	C Hall Fountain	1 of 1	Water Bottle Filler	center	<1
27	411459	Main Building	Sink - Multi-compartment	Room 7a	1 of 6	Tap	center	<1
28	411460	Main Building	Sink - Multi-compartment	Room 7a	2 of 6	Tap	center	<1
29	411461	Main Building	Sink - Multi-compartment	Room 7a	3 of 6	Tap	center	<1
30	411462	Main Building	Sink - Multi-compartment	Room 7a	4 of 6	Tap	center	<1
31	411463	Main Building	Sink - Multi-compartment	Room 7a	5 of 6	Tap	center	<1
32	411464	Main Building	Sink - Multi-compartment	Room 7a	6 of 6	Tap	center	<1
33	411471	Main Building	Fountain With Bottle Filler	Automotive Hallway	1 of 1	Water Bottle Filler	center	<1
34	411472	Main Building	Fountain With Bottle Filler	Automotive Hallway	1 of 1	Water Fountain	right	<1