

Lead in School Drinking Water Report

Victor Falls Elementary School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2026-01-08

Date(s) analyzed: 2026-01-14

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	411294	Main Building	Sink - Multi-Compartment	Kitchen	1 of 1	Tap	center	6
2	411295	Main Building	Sink - Multi-Compartment	Kitchen	1 of 1	Sprayer	center	4
3	411321	Main Building	Fountain/Tap Combo	Room 223	1 of 1	Water Fountain	right	4
4	411296	Main Building	Fountain	Gym	1 of 1	Water Fountain	right	2
5	411326	Main Building	Fountain/Tap Combo	Room 24	1 of 1	Water Fountain	right	2
6	411341	Main Building	Fountain/Tap Combo	Room 36	1 of 1	Water Fountain	right	2
7	411345	Main Building	Fountain/Tap Combo	Nurses Office	1 of 1	Water Fountain	right	2
8	411297	Main Building	Fountain - Multi-Level	Gym Hall	1 of 1	Water Fountain	left	1
9	411322	Main Building	Fountain/Tap Combo	Room 26	1 of 1	Water Fountain	right	1
10	411327	Main Building	Fountain/Tap Combo	Room 22	1 of 1	Water Fountain	right	1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	411333	Main Building	Fountain/Tap Combo	Room 16	1 of 1	Water Fountain	right	1
12	411334	Main Building	Fountain/Tap Combo	Room 15	1 of 1	Water Fountain	right	1
13	411335	Main Building	Fountain/Tap Combo	Room 13	1 of 1	Water Fountain	right	1
14	411336	Main Building	Fountain/Tap Combo	Room 11	1 of 1	Water Fountain	right	1
15	411337	Main Building	Fountain/Tap Combo	Room 10	1 of 1	Water Fountain	right	1
16	411340	Main Building	Fountain/Tap Combo	Room 3	1 of 1	Water Fountain	right	1
17	411342	Main Building	Fountain/Tap Combo	Room 2	1 of 1	Water Fountain	right	1
18	411343	Main Building	Fountain/Tap Combo	Room 1	1 of 1	Water Fountain	right	1
19	411344	Main Building	Sink - Multi-Compartment	Staff Lounge	1 of 1	Tap	center	1
20	411320	Main Building	Fountain - Multi-Level	Gym Hall	1 of 1	Water Fountain	right	<1
21	411323	Main Building	Fountain/Tap Combo	Room 27	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
22	411324	Main Building	Fountain/Tap Combo	Room 28	1 of 1	Water Fountain	right	<1
23	411325	Main Building	Fountain/Tap Combo	Room 29	1 of 1	Water Fountain	right	<1
24	411328	Main Building	Fountain/Tap Combo	Room 21	1 of 1	Water Fountain	right	<1
25	411329	Main Building	Fountain/Tap Combo	Room 20	1 of 1	Water Fountain	right	<1
26	411330	Main Building	Fountain/Tap Combo	Room 19	1 of 1	Water Fountain	right	<1
27	411331	Main Building	Fountain/Tap Combo	Room 18	1 of 1	Water Fountain	right	<1
28	411332	Main Building	Fountain/Tap Combo	Room 17	1 of 1	Water Fountain	right	<1
29	411338	Main Building	Fountain/Tap Combo	Room 9	1 of 1	Water Fountain	right	<1
30	411339	Main Building	Fountain/Tap Combo	Room 8	1 of 1	Water Fountain	right	<1