

CEDAR MILL ELEMENTARY_LOCATION	SAMPLE ID	DATE	LEAD RESULT (ppb)
Main Office, Work Room, Staff Faucet	22430600-001SF	10/22/2025	2.85
Main Office, Health, Staff Faucet	22430600-002SF	10/22/2025	1.37
Main Hall outside Main Office, Left Drinking Fountain	22430600-003DW	10/22/2025	0.24
Main Hall outside Main Office, Right Drinking Fountain	22430600-004DW	10/22/2025	ND
Main Hall outside Main Office, Water Bottler Filler	22430600-005WB	10/22/2025	ND
A100, Classroom Faucet	22430600-006CF	10/22/2025	6.13
A100, Drinking Fountain	22430600-007DW	10/22/2025	0.618
A102, Classroom Faucet	22430600-008CF	10/22/2025	3.61
A102, Drinking Fountain	22430600-009DW	10/22/2025	0.341
A104, Classroom Faucet	22430600-010CF	10/22/2025	2.88
A104, Drinking Fountain	22430600-011DW	10/22/2025	0.244
A106, Classroom Faucet	22430600-012CF	10/22/2025	3.59
A106, Drinking Fountain	22430600-013DW	10/22/2025	0.456
A108, Classroom Faucet	22430600-014CF	10/22/2025	3.24
A108, Drinking Fountain	22430600-015DW	10/22/2025	0.35
A110, Classroom Faucet	22430600-016CF	10/22/2025	2.16
A110, Drinking Fountain	22430600-017DW	10/22/2025	ND
A112, Classroom Faucet	22430600-018CF	10/22/2025	4.05
A112, Drinking Fountain	22430600-019DW	10/22/2025	0.897
Main Hallway, Outside A104, Left Drinking Fountain	22430600-020DW	10/22/2025	3.32
Main Hallway, Outside A104, Right Drinking Fountain	22430600-021DW	10/22/2025	1.63
Resource Room, Drinking Fountain	22430600-022DW	10/22/2025	4.47
Resource Room, Staff Faucet	22430600-023SF	10/22/2025	5.14
A114, Classroom Faucet	22430600-024CF	10/22/2025	2.91
A114, Drinking Fountain	22430600-025DW	10/22/2025	2.61
A116, Classroom Faucet	22430600-026CF	10/22/2025	2.58
A116, Drinking Fountain	22430600-027DW	10/22/2025	ND
A118, Classroom Faucet	22430600-028CF	10/22/2025	4
A118, Drinking Fountain	22430600-029DW	10/22/2025	ND
A120, Classroom Faucet	22430600-030CF	10/22/2025	1.39
A120, Drinking Fountain	22430600-031DW	10/22/2025	ND
A122, Classroom Faucet	22430600-032CF	10/22/2025	2.27
A122, Drinking Fountain	22430600-033DW	10/22/2025	ND
Staff Lounge, Staff Faucet	22430600-034SF	10/22/2025	0.57
Cafeteria, Left Drinking Fountain	22430600-035DW	10/22/2025	0.225
Cafeteria, Right Drinking Fountain	22430600-036DW	10/22/2025	ND
Cafeteria, Water Bottle Filler	22430600-037WB	10/22/2025	ND
Kitchen, Kitchen Faucet, Food Prep	22430600-038KF	10/22/2025	0.932
B100, Classroom Faucet	22430600-039CF	10/22/2025	6.4
B100, Drinking Fountain	22430600-040DW	10/22/2025	0.901
B102, Classroom Faucet	22430600-041CF	10/22/2025	1.89
B102, Drinking Fountain	22430600-042DW	10/22/2025	0.636
B104, Classroom Faucet	22430600-043CF	10/22/2025	0.304
B104, Drinking Fountain	22430600-044DW	10/22/2025	0.33
B106, Classroom Faucet	22430600-045CF	10/22/2025	3.63
B106, Drinking Fountain	22430600-046DW	10/22/2025	1.27

B108, Classroom Faucet	22430600-047CF	10/22/2025	2.12
B108, Drinking Fountain	22430600-048DW	10/22/2025	0.976
B110, Classroom Faucet	22430600-049CF	10/22/2025	6.01
B110, Drinking Fountain	22430600-050DW	10/22/2025	2.84
Exterior, Outside Gym, Drinking Fountain	22430600-051DW	10/22/2025	ND
M100, Classroom Faucet	22430601-001CF	10/22/2025	9.8
M100, Left Drinking Fountain	22430601-002DW	10/22/2025	3.28
M102, Right Drinking Fountain	22430601-003DW	10/22/2025	5.5
M102, Classroom Faucet <i>(restricted from use)</i>	22430601-004CF	10/22/2025	15.4
M102, Classroom Faucet <i>(postmitigation)</i>	22430601-004CF26A	1/16/2026	5.4
M104, Drinking Fountain	22430601-005DW	10/22/2025	2.66
M104, Classroom Faucet <i>(restricted from use)</i>	22430601-006CF	10/22/2025	15
M104, Classroom Faucet <i>(postmitigation)</i>	22430601-006CF26A	1/16/2026	3.29